



THE CLEVELAND ELECTRIC ILLUMINATING COMPANY

P.O. BOX 5000 - CLEVELAND, OHIO 44101 - TELEPHONE (216) 622-9800 - ILLUMINATING BLDG. - 55 PUBLIC SQUARE

Serving The Best Location in the Nation

MURRAY R. EDELMAN
VICE PRESIDENT
NUCLEAR

July 10, 1984
PY-CEI/OIE-008 L

Mr. James G. Keppler
Director, Region III
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Glen Ellyn, 60137

Perry Nuclear Power Plant
Docket Nos. 50-440; 50-441
I. E. Bulletin 84-02

Dear Mr. Keppler:

In accordance with your request, the following information is provided in response to I. E. Bulletin 84-02 on HFA Relays in use in Class IE safety systems.

We have evaluated the HFA relays used in class IE systems at PNPP and have completed replacement of all but two of the Unit 1 HFA relay coil spools with the Tefzel coil spools. Replacement of all of the Unit 1 coil spools will be completed by September 1, 1984. Replacement of the Unit 2 relays will be completed consistent with the Unit 2 construction schedule prior to turnover of affected safety systems.

Please call if there are additional questions.

Very truly yours,

Murray R. Edelman
Vice President
Nuclear Group

B407200036 B40710
PDR ADOCK 05000440
Q PDR

MRE:njc

cc: Jay Silberg, Esq.
John Stefano
J. Grobe

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Washington, DC 20555

U. S. Nuclear Regulatory Commission
c/o Document Management Branch
Washington, DC 20555

JUL 16 1984

1/0
IEH