

RECEIVED
NRC

Washington Public Power Supply System

Box 1223 Elma, Washington 98541 (206) 482-4428 -2 PN 12: 38

June 28, 1984
G03-84-412

REGION V I&E

Mr. J. Martin
Regional Administrator
U.S. Nuclear Regulatory Commission
Region V
1450 Maria Lane, Suite 260
Walnut Creek, California 94596

Subject: **NUCLEAR PROJECTS 3 AND 5
DOCKET NOS. 50-508 AND 50-509
IE BULLETIN 83-06**

Reference: a) IE Bulletin 83-06: "Nonconforming Materials Supplied by Tube-Line Corporation Facilities at Long Island City, New York; Houston, Texas; and Carol Stream, Illinois"

b) Letter (G03-83-887), A.D. Kohler to J.B. Martin, same subject, dated November 17, 1983.

The subject IE Bulletin requested that holders of construction permits submit a report describing the actions taken or planned regarding materials used in safety-related systems which were supplied by Tube-Line Corporation.

The Supply System has conducted a thorough search of its own purchases and requested all suppliers and contractors to review their subcontractors' procurement documents and respond in writing to the Supply System.

Combustion Engineering (CE), WNP-3 NSSS Supplier, responded that all but one vendor (CTI-Nuclear) supplying material for application on WNP-3 have replied.

The Supply System has confirmed that Tube-Line products were supplied and utilized in fabrication of the Emergency Diesel Generators. The suspect material was used to fabricate the channel nozzle flanges in the Lube Oil, Jacket Water, and Inter-Cooler Heat Exchangers. The subject material has been identified on a site nonconformance report and a material evaluation is currently in progress.

8407230135 840628
PDR ADOCK 05000508
G PDR

IE-11
84-24 11

The Supply System will continue efforts to obtain confirmation from the remaining CE subvendor and forward results of the material evaluation and any subsequent actions/schedules regarding the Emergency Diesel Generator nozzle flanges.

As requested by the subject Bulletin, time expended during research, evaluation and preparation of a written response has amounted to approximately three hundred and fifty (350) manhours of Supply System effort. We did not request the suppliers keep track of time spent performing their reviews. However, based on the number of WNP-3 suppliers involved (58), we estimate that response to the bulletin required several hundred manhours of suppliers' time.



A.D. Kohler
Program Director, WNP-3

JAV/mam
Attachment

cc: U.S. Nuclear Regulatory Commission
Document Control Desk, Washington, D.C.
Mr. J.A. Adams - NESCO
Mr. D. Smithpeter - BPA
Ebasco, Elma
Mr. M.K. Yates, Ebasco, New York
Director, NRC Office of I&E, Washington, D.C.
Mr. N.S. Reynolds, (Bishop, Liberman, Cook, Purcell and Reynolds)
Mr. A.A. Tuzes, Combustion Engineering

STATE OF WASHINGTON)
) ss
COUNTY OF GRAYS HARBOR)

Subject: IE BULLETIN 83-06

I, A.D. KOHLER, being duly sworn, subscribe to and say that I am the WNP-3 Program Director for the WASHINGTON PUBLIC POWER SUPPLY SYSTEM, the applicant herein; that I have full authority to execute this oath; that I have reviewed the foregoing and to the best of my knowledge, information, and belief, the statements made in it are true.

DATED June 28, 1984

A.D. Kohler
A.D. KOHLER
PROGRAM DIRECTOR, WNP-3

On this day personally appeared before me A.D. KOHLER to me known to be the individual who executed the foregoing instrument and acknowledged that he signed the same as his free act and deed for the uses and purposes therein mentioned.

GIVEN under my hand and seal this 28th day of June 1984.

Linda McGeachy
Notary Public in and for the
State of Washington

Residing at MONTE SANO
WASHINGTON