

Bd. 78

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-84-41-A Date: 7/19/84

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by IE staff on this date.

FACILITY: Southern California Edison Co.  
San Onofre Nuclear Generating Station  
Unit 3  
San Clemente, CA  
Docket No. 50-362


Licensee Emergency Classification  
\_\_\_ Notification of Unusual Event  
\_\_\_ Alert  
\_\_\_ Site Area Emergency  
\_\_\_ General Emergency  
XX Not Applicable

SUBJECT: PLANT SHUTDOWN TO REPAIR STEAM GENERATOR TUBE LEAK

As of 8:00 a.m. PDT on 7/19/84, San Onofre Unit 3 was at approximately 10% power and in the process of shutting down to locate and repair a tube leak in steam generator E-089. The highest leakage observed was 150 gallons per day (approximately 0.1 GPM) on 7/18/84. An outage of approximately three weeks is anticipated.

The licensee is planning a press release concerning the shutdown. Pertinent information has been made available on the Region V plant status recording.

This information was received from the NRC Resident Inspector at 8:00 a.m. PDT on 7/19/84 and was current as of that time.

CONTACT:  P. H. Johnson  
FTS 463-3745

A. Chaffee  
FTS 796-4015

DISTRIBUTION

H St. <u>12:26</u>	MNBB <u>12:38</u>	Phillips <u>12:29</u>	E/W <u>12:34</u>	Willste <u>12:36</u>	Air Rights <u>12:37</u>	Mail:
Chairman Pallidino	EDO	NRR	IE	NMSS		ADM:DMB
Comm. Zech	PA		OIA	RES		DOT:Trans
Comm. Bernthal	MPA		AEOD			Only
Comm. Roberts	ELD					
Comm. Asseistine						
SECY		Regions: <u>I-2:44, II-2:45, III-12:42, IV-12:48</u>				
ACRS		INPO <u>2:49</u> NSAC <u>2:45</u>				
CA		Licensee: <u>2:43</u>				
PDR		(Reactor Licensees)				
		Resident Inspector <u>12:27</u>				
					REGION V: FORM 211	
					(Revised 3/14/83)	

8407240092 840719  
PDR I&E  
PNO-V-84-041A PDR

0/1  
IE-34