



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

DUKE POWER COMPANY

NORTH CAROLINA ELECTRIC MEMBERSHIP CORPORATION

SALUDA RIVER ELECTRIC COOPERATIVE, INC.

DOCKET NO. 50-413

CATAWBA NUCLEAR STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 94
License No. NPF-35

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 1 (the facility) Facility Operating License No. NPF-35 filed by the Duke Power Company, acting for itself, North Carolina Electric Membership Corporation and Saluda River Electric Cooperative, Inc. (licensees) dated August 6, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-35 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 94, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: March 3, 1992



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

DUKE POWER COMPANY

NORTH CAROLINA MUNICIPAL POWER AGENCY NO. 1

PIEDMONT MUNICIPAL POWER AGENCY

DOCKET NO. 50-414

CATAWBA NUCLEAR STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 88
License No. NPF-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment to the Catawba Nuclear Station, Unit 2 (the facility) Facility Operating License No. NPF-52 filed by the Duke Power Company, acting for itself, North Carolina Municipal Power Agency No. 1 and Piedmont Municipal Power Agency (licensees) dated August 6, 1991, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations as set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is hereby amended by page changes to the Technical Specifications as indicated in the attachment to this license amendment, and Paragraph 2.C.(2) of Facility Operating License No. NPF-52 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 88, and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. Duke Power Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects-I/II
Office of Nuclear Reactor Regulation

Attachment:
Technical Specification
Changes

Date of Issuance: March 3, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 94

FACILITY OPERATING LICENSE NO. NPF-35

DOCKET NO. 50-413

AND

TO LICENSE AMENDMENT NO. 88

FACILITY OPERATING LICENSE NO. NPF-52

DOCKET NO. 50-414

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove Pages

3/4 3-92a

3/4 3-92b

3/4 9-1a

3/4 9-1b

Insert Pages

3/4 3-92a

3/4 3-92b

3/4 9-1a

3/4 9-1b

INSTRUMENTATION

BORON DILUTION MITIGATION SYSTEM

LIMITING CONDITION FOR OPERATION

3.3.3.12 As a minimum, two trains of the Boron Dilution Mitigation System shall be OPERABLE and operating with Shutdown Margin Alarm ratios set at less than or equal to 4 times the steady-state count rate.

APPLICABILITY: MODES 3, 4, AND 5

ACTION:

- (a) With one train of the Boron Dilution Mitigation System inoperable or not operating, restore the inoperable train to OPERABLE status within 48 hours, or
 - (1) suspend all operations involving positive reactivity changes and verify that valve NV-230 is closed and secured within the next hour, or
 - (2) verify two Source Range Neutron Flux Monitors are OPERABLE with Alarm Setpoints less than or equal to one-half decade (square root of 10) above the steady-state count rate and verify that the combined flowrate from both Reactor Makeup Water Pumps is less than or equal to 150 gpm (Mode 3 or 4) or 75 gpm (Mode 5) within the next hour.
- (b) With both trains of the Boron Dilution Mitigation System inoperable or not operating, restore the inoperable trains to OPERABLE status within 12 hours, or
 - (1) suspend all operations involving positive reactivity changes and verify that valve NV-230 is closed and secured within the next hour, or
 - (2) verify two Source Range Neutron Flux Monitors are OPERABLE with Alarm Setpoints less than or equal to one-half decade (square root of 10) above the steady-state count rate and verify that the combined flow rate from both Reactor Makeup Water Pumps is less than or equal to 150 gpm (Mode 3 or 4) or 75 gpm (Mode 5) within the next hour.

SURVEILLANCE REQUIREMENTS

4.3.3.12.1 Each train of the Boron Dilution Mitigation System shall be demonstrated OPERABLE by performance of:

- (a) A CHANNEL CHECK at least once per 12 hours,

INSTRUMENTATION

SURVEILLANCE REQUIREMENTS (Continued)

- (b) An ANALOG CHANNEL OPERATIONAL TEST at least once per 31 days, and
- (c) At least once per 18 months the BDMS shall be demonstrated OPERABLE by:
 - (1) Verifying that each automatic valve actuated by the BDMS moves to its correct position upon receipt of a trip signal, and
 - (2) Verifying each reactor makeup water pump stops, as designed, upon receipt of a trip signal.

4.3.3.12.2 If using the Source Range Neutron Flux Monitors to meet the requirements of Technical Specification 3.3.3.12,

- (a) The monthly surveillance requirements of Table 4.3-1 for the Source Range Neutron Flux Monitors shall include verification that the Alarm Setpoint is less than or equal to one-half decade (square root of 10) above the steady-state count rate.
- (b) The combined flow rate from both Reactor Makeup Water Pumps shall be verified as less than or equal to 150 gpm (Mode 3 or 4) or 75 gpm (Mode 5) at least once per 31 days.

REFUELING OPERATIONS

3/4.9.2 INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.9.2.1 As a minimum, two trains of the Boron Dilution Mitigation System shall be OPERABLE and operating with Shutdown Margin Alarm Ratios set at less than or equal to 4 times the steady-state count rate, each with continuous indication in the control room.

APPLICABILITY: MODE 6

ACTION:

- (a) With one or both trains of the Boron Dilution Mitigation System inoperable or not operating,
 - (1) immediately suspend all operations involving CORE ALTERATIONS or positive reactivity changes, and verify that valve NV-230 is closed and secured within the next hour or
 - (2) verify that two Source Range Neutron Flux Monitors are OPERABLE and operating with Alarm Setpoints less than or equal to one-half decade (square root of 10) above the steady-state count rate, each with continuous visual indication in the control room and one with audible indication in the control room and one with audible indication in the containment and verify that the combined flowrate from both Reactor Makeup Water Pumps is less than or equal to 70 gpm within the next hour.
- (b) With both trains of the Boron Dilution Mitigation System inoperable or not operating and one of the Source Range Neutron Flux Monitors inoperable or not operating immediately suspend all operations involving core ALTERATIONS or positive reactivity changes and verify that valve NV-230 is closed and secured within the next hour.
- (c) With both trains of the Boron Dilution Mitigation System inoperable or not operating and both of the Source Range Neutron Flux Monitors inoperable or not operating, determine the boron concentration of the Reactor Coolant System at least once per 12 hours and verify that valve NV-230 is closed and secured within the next hour.

SURVEILLANCE REQUIREMENT

4.9.2.1.1 Each train of the Boron Dilution Mitigation System shall be demonstrated OPERABLE by performance of:

- (a) A CHANNEL CHECK at least once per 12 hours,
- (b) An ANALOG CHANNEL OPERATIONAL TEST within 8 hours prior to the initial start of CORE ALTERATIONS and
- (c) An ANALOG CHANNEL OPERATIONAL TEST at least once per 31 days.

REFUELING OPERATIONS

SURVEILLANCE REQUIREMENTS (CONTINUED)

- (d) At least once per 18 months the BDMS shall be demonstrated OPERABLE by:
 - (1) Verifying that each automatic valve actuated by the BDMS moves to its correct position upon receipt of a trip signal, and
 - (2) Verifying each reactor makeup water pump stops, as designed, upon receipt of a trip signal.

4.9.2.1.2 If using the Source Range Neutron Flux Monitors to meet the requirements of Technical Specification 3.9.2, each Source Range Neutron Flux Monitor shall be demonstrated OPERABLE by performance of:

- (a) A CHANNEL CHECK at least once per 12 hours,
- (b) An ANALOG CHANNEL OPERATIONAL TEST within 8 hours prior to the initial start of CORE ALTERATIONS or within 1 hour after declaring the BORON DILUTION MITIGATION SYSTEM inoperable, and
- (c) An ANALOG CHANNEL OPERATIONAL TEST at least once per 7 days.
- (d) The combined flowrate from both Reactor Makeup Water Pumps shall be verified as less than or equal to 70 gpm at least once per 7 days.