



**GPU Nuclear Corporation**  
100 Interpace Parkway  
Parsippany, New Jersey 07054-1149  
(201) 263-6500  
TELEX 136-482  
Writer's Direct Dial Number:

July 19, 1984

Director, Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Technical Specification Change Request No. 112

In accordance with 10CFR50.59, 10CFR50.90 and 10CFR50.91, GPU Nuclear Corporation, operator of the Oyster Creek Nuclear Generating Station, Provisional Operating License No. DPR-16, requests changes to Appendix A of that license.

The subject Technical Specification Change Request involves Section 3.5, 3.5 Bases and Section 4.5 Bases. This change will reduce the primary containment atmosphere from 5% O<sub>2</sub> to 4% O<sub>2</sub>.

This Technical Specification Change Request has been reviewed in accordance with Section 6.5 of the Oyster Creek Technical Specifications.

Pursuant to 10CFR50.91(b)(1), a copy of this Technical Specification Change Request has been sent to the State of New Jersey Department of Environmental Protection.

8407260162 840719  
PDR ADOCK 05000219  
P PDR

*Acc'd w/ check \$150  
# 0011913A*

- 2 -

In accordance with 10 CFR 170.21, Revision of License Fee Schedule effective on June 18, 1984, we have enclosed a check for \$150.00 pursuant to the new Schedule of Facility Fees.

Very truly yours,



P. B. Fiedler  
Vice President and Director  
Oyster Creek

1r/0258e

cc: Administrator  
Region I  
U.S. Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pa. 19406

NRC Resident Inspector  
Oyster Creek Nuclear Generating Station  
Forked River, N. J. 08731