

March 30, 2020

Title: Pre-Submittal Teleconference Regarding Approximately Six Regulatory Actions for the Spring 2020 Outage at Beaver Valley Power Station, Unit 2

Date(s) and Time(s): March 31, 2020, 01:00 PM to 03:00 PM

Location: Teleconference

Category: This is a Category 2 meeting. The public is invited to participate in this meeting by discussing regulatory issues with the Nuclear Regulatory Commission (NRC) at designated points identified on the agenda.

Purpose: The purpose of this teleconference is for NRC staff and Energy Harbor Nuclear Corp. (Energy Harbor) to discuss approximately six regulatory actions for the spring 2020 outage at Beaver Valley Power Station, Unit 2.

Contact: Jennifer Tobin  
301-415-2328  
[jennifer.tobin@nrc.gov](mailto:jennifer.tobin@nrc.gov)

Participants: NRC Jennifer Tobin, Office of Nuclear Reactor Regulation  
External Energy Harbor Nuclear Corp.

Teleconference: Bridge Number (888) 659-9574  
Pass Code 9845474

Docket No: 05000412

# PUBLIC MEETING AGENDA

Pre-Submittal Teleconference Regarding Approximately Six Regulatory Actions for the Spring 2020 Outage at Beaver Valley Power Station, Unit 2

March 31, 2020, 01:00 PM to 03:00 PM

## Teleconference

<i>Time</i>	<i>Topic</i>	<i>Speaker</i>
1:00 P.M.	Introductions and Opening Remarks	NRC/Energy Harbor
1:15 P.M.	Discussion of Potential Regulatory Actions for the Spring 2020 Outage	Energy Harbor
1:45 P.M.	Questions and Answers	NRC/Energy Harbor
2:30 P.M.	Public Comments and Questions	Public/NRC

### Potential Regulatory Actions for Beaver Valley, Unit 2:

1. Hot Leg Nozzle Inspection, Request to extend the frequency of ASME Code Case N-770-2, Table 1, Item A-2, that the weld surface must be visually examined each refueling outage.
2. Bottom Mounted Instrumentation, Request to extend the examination frequency specified in ASME Code Case N-722-1, Table 1 for Item B15.80, to examine all penetrations every other refueling outage.
3. Relief Valve Testing, Request to extend the 10-year interval required by Mandatory Appendix I, 171350, and Mandatory Appendix I, 1-1390.
4. Motor Operated Valve Testing, Request to extend the testing frequency required by ASME Code Case OMN-1, including the 6-month allowance allowed by OMN-20.
5. Containment Isolation Valve Water Testing, Request to extend the 2-year testing frequency specified in ISTC-3630(a).
6. Safety Significant Dynamic Restraint (Snubber) Testing, Request to extend the testing requirement specified in ISTD-5200 to inspect snubbers each fuel cycle.

