

NUREG-0020  
Vol. 8, No. 3  
March 1984

---

---

# LICENSED OPERATING REACTORS

STATUS SUMMARY REPORT  
DATA AS OF 02-29-84

---

---

UNITED STATES NUCLEAR REGULATORY COMMISSION



8405220049 840430  
PDR NUREG  
0020 R PDR

Available from

NRC/GPO Sales Program

Superintendent of Documents  
Government Printing Office  
Washington, D. C. 20402

A year's subscription consists of 12 issues for  
this publication.

Single copies of this publication  
are available from National Technical  
Information Service, Springfield, VA 22161

Microfiche of single copies are  
available from NRC/GPO Sales Program  
Washington, D. C. 20555

**NUREG-0020  
Vol. 8, No. 3  
March 1984**

---

---

# **LICENSED OPERATING REACTORS**

## **STATUS SUMMARY REPORT**

**DATA AS OF 02-29-84**

---

---

Manuscript Completed: April 1984  
Date Published: April 1984

**OFFICE OF RESOURCE MANAGEMENT  
U.S. NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555**

#### AUTHORIZATION AND CLEARANCE\*

The U.S. Nuclear Regulatory Commission's Office of Management and Program Analysis publishes this monthly status report "as part of the reporting requirements in Section 50.36 of 10 CFR Part 50 under GAO Clearance Number B-180225, with an expiration date of September 30, 1981," as stated in the October 3, 1978 letter from John M. Lovelady, Assistant Director, General Government Division, U.S. General Accounting Office, to J.M. Felton, Director, Division of Rules and Records, U.S. Nuclear Regulatory Commission.

\*Extended to April 30, 1985 by OMB Directive 3150-0011.

#### STATEMENT OF PURPOSE

The U.S. Nuclear Regulatory Commission's monthly LICENSED OPERATING REACTORS Status Summary Report provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management, from the Headquarters Staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. Since all of the data concerning operation of the units is provided by the utility operators less than two weeks after the end of the month, necessary corrections to published information are shown on the ERRATA page.

This report is divided into three sections: the first contains monthly highlights and statistics for commercial operating units, and errata from previously reported data; the second is a compilation of detailed information on each unit, provided by NRC Regional Offices, IE Headquarters and the Utilities; and the third section is an appendix for miscellaneous information such as spent fuel storage capability, reactor years of experience and non-power reactors in the United States.

The percentage computations, Items 20 through 24 in Section 2, the vendor capacity factors on page 1-7, and actual vs. potential energy production on Page 1-2 are computed using actual data for the period of consideration. The percentages listed in power generation on Page 1-2 are computed as an arithmetic average. The factors for the life-span of each unit (the "Cumulative" column) are reported by the utility and are not entirely re-computed by NRC. Utility power production data is checked for consistency with previously submitted statistics.

It is hoped this status report proves informative and helpful to all agencies and individuals interested in analyzing trends in the nuclear industry which might have safety implications, or in maintaining an awareness of the U.S. energy situation as a whole.

# T A B L E O F C O N T E N T S

	PAGE
GLOSSARY	ii
INDEX TO LICENSED UNITS	vii
<u>SECTION 1 - CURRENT DATA SUMMARIES</u>	
MONTHLY HIGHLIGHTS OF COMMERCIAL NUCLEAR POWER UNITS	1-2
Licensed Power Reactors	1-2
Power Generation	1-2
Actual vs. Potential Energy Production	1-2
Outage Data	1-2
Reasons for Shutdown	1-3
Derated Units	1-3
Shutdowns Greater Than 72 Hours Each	1-3
UNIT AVAILABILITY, CAPACITY, AND FORCED OUTAGE RATE PLOT	1-4
AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIAL OPERATING UNITS	1-5
AVERAGE CAPACITY FACTORS BY VENDOR	
Vendor Plot	1-6
Statistics	1-7
MEMORANDA - SPECIAL INFORMATION	1-8
ERRATA - CORRECTIONS TO PREVIOUSLY REPORTED DATA	1-9
<u>SECTION 2 - OPERATING POWER REACTORS</u>	
ARKANSAS 1 THROUGH ZION 2	2-002 through 2-358
For each reactor:	
Operating Status	
Average Daily Power Level (MWe) Plot	
Unit Shutdowns/Reductions Summary	
Facility Data	
Inspection Status	
Licensee Reports	
<u>SECTION 3 - APPENDIX</u>	
STATUS OF SPENT FUEL STORAGE CAPABILITY	3-2
REACTOR-YEARS OF OPERATION	3-4
NON-POWER REACTORS IN THE U.S.	3-5

## G L O S S A R Y

AVERAGE DAILY POWER LEVEL (MWe)	The net electrical energy generated during the day (measured from 0001 to 2400 hours inclusive) in megawatts hours, divided by 24 hours.
LICENSED THERMAL POWER (MWt)	The maximum thermal power of the reactor authorized by the NRC, expressed in megawatts.
DATE OF COMMERCIAL OPERATION	Date unit was declared by utility owner to be available for the regular production of electricity; usually related to satisfactory completion of qualification tests as specified in the purchase contract and to accounting policies and practices of utility.
DESIGN ELECTRICAL RATING (DER) (NET MWe)	The nominal net electrical output of the unit specified by the utility and used for the purpose of plant design.
FORCED OUTAGE	An outage required to be initiated no later than the weekend following discovery of an offnormal condition.
FORCED OUTAGE HOURS	The clock hours during the report period that a unit is unavailable due to forced outages.
GROSS ELECTRICAL ENERGY GENERATED (MWH)	Electrical output of the unit during the report period as measured at the output terminals of the turbine generator, in megawatts hours.
GROSS HOURS	The clock hours from the beginning of a specified situation until its end. For outage durations, the clock hours during which the unit is not in power production.
GROSS THERMAL ENERGY GENERATED (MWH)	The thermal energy produced by the unit during the report period as measured or computed by the licensee in megawatt hours.
HOURS GENERATOR ON-LINE	Also, "Unit Service Hours." The total clock hours in the report period during which the unit operated with breakers closed to the station bus. These hours added to the total outage hours experienced by the unit during the report period, shall equal the hours in the report period.
HOURS IN REPORTING PERIOD	<p>For units in power ascension at the end of the period, the gross hours from the beginning of the period or the first electrical production, whichever comes last, to the end of the period.</p> <p>For units in commercial operation at the end of the period, the gross hours from the beginning of the period or of commercial operation, whichever comes last, to the end of the period or decommissioning, whichever comes first.</p>

G L O S S A R Y (continued)

HOURS REACTOR CRITICAL	The total clock hours in the report period during which the reactor sustained a controlled chain reaction.
MAXIMUM DEPENDABLE CAPACITY (GROSS) (MDC Gross) (Gross MWe)	Dependable main-unit gross capacity, winter or summer, whichever is smaller. The dependable capacity varies because the unit efficiency varies during the year due to cooling water temperature variations. It is the gross electrical output as measured at the output terminals of the turbine generator during the most restrictive seasonal conditions (usually summer).
MAXIMUM DEPENDABLE CAPACITY (NET) (MDC Net) (Net MWe)	Maximum Dependable Capacity (Gross) less the normal station service loads.
NAMEPLATE RATING (Gross MWe)	The nameplate power designation of the generator in megavolt amperes (MVA) times the nameplate power factor of the generator. NOTE: The nameplate rating of the generator may not be indicative of the maximum or dependable capacity, since some other item of equipment of a lesser rating (e.g., turbine) may limit unit output.
NET ELECTRICAL ENERGY GENERATED	Gross electrical output of the unit measured at the output terminals of the turbine generator during the reporting period, minus the normal station service electrical energy utilization. If this quantity is less than zero, a negative number should be recorded.
OUTAGE	A situation in which no electrical production takes place.
OUTAGE DATE	As reported on Appendix D of Reg. Guide 1.16, the date of the start of the outage. If continued from a previous month, report the same outage date but change "Method of Shutting Down Reactor" to "4 (continuations)" and add a note: "Continued from previous month."
OUTAGE DURATION	The Total clock hours of the outage measured from the beginning of the report period or the outage, whichever comes last, to the end of the report period or the outage, whichever comes first.
OUTAGE NUMBER	A number unique to the outage assigned by the licensee. The same number is reported each month in which the outage is in progress. One format is "76-05" for the fifth outage to occur in 1976.
PERIOD HOURS	See "Hours in Reporting Period."
POWER REDUCTION	A reduction in the Average Daily Power Level of more than 20% from the previous day. All power reductions are defined as outage of zero hours durations for the purpose of computing unit service and availability factors, and forced outage rate.



G L O S S A R Y (continued)

REACTOR AVAILABLE HOURS	The Total clock hours in the report period during which the reactor was critical or was capable of being made critical. (Reactor Reserve Shutdown Hours + Hours Reactor Critical.)
REACTOR AVAILABILITY FACTOR	$\frac{\text{Reactor Available Hours} \times 100}{\text{Period Hours}}$
REACTOR RESERVE SHUTDOWN	The cessation of criticality in the reactor for administrative or other similar reasons when operation could have been continued.
REACTOR RESERVE SHUTDOWN HOURS	The total clock hours in the report period that the reactor is in reserve shutdown mode. NOTE: No credit is given for NRC imposed shutdowns.
REACTOR SERVICE FACTOR	$\frac{\text{Hours Reactor Critical} \times 100}{\text{Period Hours}}$
REPORT PERIOD	Usually, the preceding calendar month. Can also be the preceding calendar year, (Year-to-Date), or the life-span of a unit (cumulative).
RESTRICTED POWER LEVEL	Maximum net electrical generation to which the unit is restricted during the report period due to the state of equipment, external conditions, administrative reasons, or a direction by NRC.
SCHEDULED OUTAGE	Planned removal of a unit from service for refueling, inspection, training, or maintenance. Those outages which do not fit the definition of "Forced Outage" performance are "Scheduled Outages."
STARTUP AND POWER ASCENSION TEST PHASE	Period following initial criticality during which the unit is tested at successively higher levels, culminating with operation at full power for a sustained period and completion of warranty runs. Following this phase, the utility generally considers the unit to be available for commercial operation.
UNIT	The set of equipment uniquely associated with the reactor, including turbine generators, and ancillary equipment, considered as a single electrical energy production facility.
UNIT AVAILABLE HOURS	The total clock hours in the report period during which the unit operated on-line or was capable of such operation. (Unit Reserve Shutdown Hours + Hours Generator On-Line.)

G L O S S A R Y (continued)

UNIT AVAILABILITY FACTOR	$\frac{\text{Unit Available Hours} \times 100}{\text{Period Hours}}$
UNIT CAPACITY FACTORS	
- Using Licensed Thermal Power	$\frac{\text{Gross Thermal Energy Generated} \times 100}{\text{Period Hours} \times \text{Lic. Thermal Power}}$
- Using Nameplate Rating	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{Nameplate Rating}}$
- Using DER	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{DER}}$
- Using MDC Gross	$\frac{\text{Gross Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Gross}}$
- Using MDC Net	$\frac{\text{Net Electrical Energy Generated} \times 100}{\text{Period Hours} \times \text{MDC Net}}$
NOTE: if MDC GROSS and/or MDC NET have not been determined, the DER is substituted for this quantity for Unit Capacity Factor calculations.	
UNIT FORCED OUTAGE RATE	$\frac{\text{Forced Outage Hours}}{\text{Unit Service Hours} + \text{Forced Outage Hours}}$
UNIT RESERVE SHUTDOWN	The removal of the unit from on-line operation for economic or other similar reasons when operation could have been continued.
UNIT RESERVE SHUTDOWN HOURS	The total clock hours in the report period during which the unit was in reserve shutdown mode.
UNIT SERVICE FACTOR	$\frac{\text{Unit Service Hours} \times 100}{\text{Period Hours}}$
UNIT SERVICE HOURS	See "Hours Generator On-Line."

NOTE:

At the end of each statement in the Enforcement Summary for any given facility may be found numbers in parentheses. These numbers are related to the inspection, e.g., 8111 (the 11th inspection of the plant in 1981); and the severity level, e.g., 4 (severity level IV). Violations are ranked by severity levels from I through V with level I being the most serious. The severity level is used in the determination of any resulting enforcement action. Gray Book lists severity level by Arabic number corresponding to the Roman numerals. Details on the various severity levels and enforcement actions can be found in Appendix C to 10 CFR Part 2 published in the Federal Register of March 9, 1982 pages 9987 through 9995, and as corrected April 14, 1982.

INDEX TO OPERATING POWER REACTORS

	PAGE		PAGE
ARKANSAS 1	2-002	NORTH ANNA 1	2-188
ARKANSAS 2	2-006	NORTH ANNA 2	2-192
BEAVER VALLEY 1	2-010	OCONEE 1	2-196
BIG ROCK POINT 1	2-014	OCONEE 2	2-200
BROWNS FERRY 1	2-018	OCONEE 3	2-204
BROWNS FERRY 2	2-024	OYSTER CREEK 1	2-208
BROWNS FERRY 3	2-030	PALISADES	2-212
BRUNSWICK 1	2-036	PEACH BOTTOM 2	2-216
BRUNSWICK 2	2-042	PEACH BOTTOM 3	2-220
CALVERT CLIFFS 1	2-048	PILGRIM 1	2-224
CALVERT CLIFFS 2	2-052	POINT BEACH 1	2-228
COOK 1	2-056	POINT BEACH 2	2-232
COOK 2	2-064	PRAIRIE ISLAND 1	2-236
COOPER STATION	2-070	PRAIRIE ISLAND 2	2-240
CRYSTAL RIVER 3	2-074	QUAD CITIES 1	2-244
DAVIS-BESSE 1	2-078	QUAD CITIES 2	2-248
DRESDEN 2	2-082	RANCHO SECO 1	2-252
DRESDEN 3	2-086	ROBINSON 2	2-258
DUANE ARNOLD	2-090	SALEM 1	2-262
FARLEY 1	2-096	SALEM 2	2-266
FARLEY 2	2-102	SAN ONOFRE 1	2-270
FITZPATRICK	2-108	SAN ONOFRE 2	2-274
FORT CALHOUM 1	2-112	SAN ONOFRE 3	2-280
FORT ST VRAIN	2-116	SEQUOYAH 1	2-286
GINNA	2-120	SEQUOYAH 2	2-292
HADDAM NECK	2-124	ST LUCIE 1	2-298
HATCH 1	2-128	ST LUCIE 2	2-302
HATCH 2	2-132	SUMMER 1	2-306
INDIAN POINT 2	2-138	SURRY 1	2-310
INDIAN POINT 3	2-142	SURRY 2	2-314
KEWAUNEE	2-146	SUSQUEHANNA 1	2-318
LA CROSSE	2-150	THREE MILE ISLAND 1	2-322
LASALLE 1	2-154	TROJAN	2-326
MAINE YANKEE	2-158	TURKEY POINT 3	2-330
MCGUIRE 1	2-162	TURKEY POINT 4	2-336
MCGUIRE 2	2-168	VERMONT YANKEE 1	2-342
MILLSTONE 1	2-172	YANKEE-ROWE 1	2-346
MILLSTONE 2	2-176	ZION 1	2-350
MONTICELLO	2-180	ZION 2	2-354
NINE MILE POINT 1	2-184		

**SECTION 1**

**CURRENT  
DATA  
SUMMARIES**

MONTHLY HIGHLIGHTS

\*\*\*\*\* 77 IN COMMERCIAL OPERATION . . . . . 59,865 CAPACITY MWe (Net) --Based upon maximum dependable  
 \* LICENSED \* (a) 2 IN POWER ASCENSION. . . . . 2,267 capacity; design elec. rating  
 \* POWER \* used if MDC not determined  
 \* REACTORS \* (b) 79 LICENSED TO OPERATE . . . . . 62,132 TOTAL  
 \*\*\*\*\* (c) 3 LICENSED FOR FUEL LOADING  
 AND LOW POWER TESTING

	MDC NET		DER		DATE	DER
(a) MCGUIRE 2	1180	(b) Excludes these plants	1. DRESDEN 1	200	(c) GRAND GULF 1	06/16/82 1250
SAN ONOFRE 3	1087	licensed for operation	2. HUMBOLDT BAY	65	LA SALLE 2	12/16/83 1078
		which are shut down	3. TMI 2	906	WASH. NUC. 2	12/20/83 1103
		indefinitely				

		REPORT MONTH	PREVIOUS MONTH	YEAR-TO-DATE
*****	1. GROSS ELECTRICAL (MWHE)	28,561,699	30,126,759	58,688,458
* POWER *	2. NET ELECTRICAL (MWHE)	27,258,287	28,789,343	56,047,630
* GENERATION *	3. AVG. UNIT SERVICE FACTOR (%)	69.6	70.3	70.0
*****	4. AVG. UNIT AVAILABILITY FACTOR (%)	69.6	70.3	70.0
	5. AVG. UNIT CAPACITY FACTOR (MDC) (%)	65.8	65.5	65.6
	6. AVG. UNIT CAPACITY FACTOR (DER) (%)	64.1	43.8	64.0
	7. FORCED OUTAGE RATE (%)	11.2	11.7	11.4

		% OF POTENTIAL PRODUCTION
*****	1. ENERGY ACTUALLY PRODUCED DURING THIS REPORT PERIOD. . . . . 27,258,287 NET	65.4
* ACTUAL VS. *	2. ENERGY NOT PRODUCED DUE TO SCHEDULED OUTAGES (NET). . . . . 7,743,760 MWHe	18.6
* POTENTIAL *	3. ENERGY NOT PRODUCED DUE TO FORCED OUTAGES (NET) . . . . . 4,801,049 MWHe	11.5
* ENERGY *	4. ENERGY NOT PRODUCED FOR OTHER REASONS (NET) . . . . . 1,862,944 MWHe	4.5
* PRODUCTION *	POTENTIAL ENERGY PRODUCTION IN THIS PERIOD BY UNITS IN COMMERCIAL OPERATION 41,666,040 MWHe	100.0% TOTAL
*****	(Using Maximum Dependable Capacity Net)	
	5. ENERGY NOT PRODUCED DUE TO NRC-REQUIRED OUTAGES . . . . . 564,029 MWHe	
	6. ENERGY NOT PRODUCED DUE TO NRC RESTRICTED POWER LEVELS. . . . . MWHe	0 UNIT(S) WITH NRC RESTRICTION

		NUMBER	HOURS	PERCENT OF CLOCK TIME	MWHE LOST PRODUCTION
*****	1. FORCED OUTAGES DURING REPORT PERIOD . . . . .	58	5,512.5	10.3	4,801,049
* OUTAGE *	2. SCHEDULED OUTAGES DURING REPORT PERIOD. . . . .	23	10,785.6	20.1	7,743,760
* DATA *					
* :*****	TOTAL	81	16,298.1	30.4	12,544,809

MWHE LOST PRODUCTION = Down time X maximum dependable capacity net

MONTHLY HIGHLIGHTS


		NUMBER	HOURS LOST
*****	A - Equipment Failure . . . . .	41	4,170.5
* REASONS *	B - Maintenance or Test . . . . .	12	1,438.6
* FOR *	C - Refueling . . . . .	15	8,132.7
* SHUTDOWNS *	D - Regulatory Restriction. . . . .	2	723.7
*****	E - Operator Training & License Examination . . . . .	0	0.0
	F - Administrative. . . . .	0	0.0
	G - Operational Error . . . . .	3	178.2
	H - Other . . . . .	8	1,654.4
	TOTAL	81	16,298.1

*****		MDC (MWe Net)	POWER LIMIT (MWe Net)	TYPE
* DERATED *	FORT ST VRAIN	330	280	Self-imposed

*****	UNIT	REASON	UNIT	REASON	UNIT	REASON	UNIT	REASON
* SHUTDOWNS *	BIG ROCK POINT 1	A	BROWNS FERRY 1	A	BROWNS FERRY 2	H	BROWNS FERRY 3	C
* GREATER *	BRUNSWICK 1	A	DRESDEN 3	C	FARLEY 1	C	FORT ST VRAIN	C
* THAN 72 HRS *	HATCH 1	A,H	HATCH 2	H	INDIAN POINT 2	A	LASALLE 1	A
* EACH *	MCGUIRE 1	C	MILLSTONE 2	A	MONTICELLO	C	NORTH ANNA 1	A
*****	NORTH ANNA 2	G	OYSTER CREEK 1	C	PALISADES	C	PEACH BOTTOM 2	B
	PILGRIM 1	C	POINT BEACH 1	C	QUAD CITIES 2	C	ROBINSON 2	C
	SALEM 1	A	SALEM 2	A	SAN ONOFRE 1	B	SAN ONOFRE 2	B
	SEQUOYAH 1	C	ST LUCIE 1	C	SURRY 1	H	SUSQUEHANNA 1	A,H
	THREE MILE ISLAND 1	D	TURKEY POINT 3	A	TURKEY POINT 4	A	ZION 1	A

# Unit Availability, Capacity, Forced Outage

Avg. Unit Percentage as of 82-29-84



Dec 1978-Feb 1984


AVERAGE DAILY POWER LEVEL FOR ALL COMMERCIALY OPERATING UNITS

This chart depicts the average daily power level for the units in commercial operation during the month.

The straight line on the graph labelled "SUM OF MDC" is plotted at the value shown by summing the separate maximum dependable capacities of the commercially operating units (in Net MWe). The plot shown below the line is calculated by summing the separate average daily power levels of the same units for each day of the month.

The scale on the left vertical axis runs in 1,000 MWe increments from 0 to 55,000 MWe (Net). The right vertical axis shows the percentage in 10% increments, up to 100% of the "SUM OF MDC".

It should be recognized that the 100% line would be obtainable only if all of the commercially operating units operated at 100% capacity, 24 hours per day, for the entire month. In other words, since any power generator must occasionally shut down to refuel and/or perform needed maintenance, and also since 100% capacity production is not always required by power demands, the 100% line is a theoretical goal and not a practical one.




FEBRUARY 1984



# Vendor Average Capacity Factors

As Of 02-29-84



NOTE: This display of average capacity factors provides a general performance comparison of plants supplied by the four nuclear steam supply system vendors. One must be careful when drawing conclusions regarding the reasons for the performance levels indicated, since plant performance may be affected by unspecified factors such as: (1) various plant designs and models are included for each vendor; (2) turbine/generators and (3) different architect/engineers are also involved.

Report Period FEB 1984

AVERAGE CAPACITY FACTORS BY VENDORS

***** CFMDC	CFMDC	CFMDC	CFMDC
* GENERAL * 59.9 BROWNS FERRY 1	62.7 BROWNS FERRY 2	0.0 BROWNS FERRY 3	86.1 BRUNSWICK 1
* ELECTRIC * 85.8 BRUNSWICK 2	88.3 COOPER STATION	91.1 DRESDEN 2	0.0 DRESDEN 3
***** 98.6 DUANE ARNOLD	93.8 FITZPATRICK	19.0 HATCH 1	0.0 HATCH 2
28.2 LASALLE 1	99.0 MILLSTONE 1	4.3 MONTICELLO	88.0 NINE MILE POINT 1
0.0 OYSTER CREEK 1	61.2 PEACH BOTTOM 2	93.1 PEACH BOTTOM 3	0.0 PILGRIM 1
96.8 QUAD CITIES 1	10.1 QUAD CITIES 2	5.6 SUSQUEHANNA 1	103.0 VERMONT YANKEE 1
***** CFMDC	CFMDC	CFMDC	CFMDC
* BABCOCK & * 91.3 ARKANSAS 1	91.7 CRYSTAL RIVER 3	97.9 DAVIS-BESSE 1	100.2 OCONEE 1
* WILCOX * 99.3 OCONEE 2	97.3 OCONEE 3	90.0 RANCHO SECO 1	0.0 THREE MILE ISLAND 1
***** CFMDC	CFMDC	CFMDC	CFMDC
* COMBUSTION * 59.9 ARKANSAS 2	102.6 CALVERT CLIFFS 1	98.0 CALVERT CLIFFS 2	99.7 FORT CALHOUN 1
* ENGINEERING * 99.7 MAINE YANKEE	77.6 MILLSTONE 2	0.0 PALISADES	43.4 SAN ONOFRE 2
***** 0.0 ST LUCIE 1	100.1 ST LUCIE 2		
***** CFMDC	CFMDC	CFMDC	CFMDC
* WESTINGHOUSE * 98.1 BEAVER VALLEY 1	86.2 COOK 1	96.7 COOK 2	33.7 FARLEY 1
***** 102.3 FARLEY 2	99.3 GINNA	101.5 HADDAM NECK	37.3 INDIAN POINT 2
68.6 INDIAN POINT 3	102.1 KEWAUNEE	74.9 MCGUIRE 1	67.3 NORTH ANNA 1
73.9 NORTH ANNA 2	0.0 POINT BEACH 1	98.8 POINT BEACH 2	100.8 PRAIRIE ISLAND 1
104.2 PRAIRIE ISLAND 2	0.0 ROBINSON 2	82.4 SALEM 1	0.0 SALEM 2
0.0 SAN ONOFRE 1	60.1 SEQUOYAH 1	86.5 SEQUOYAH 2	84.9 SUMMER 1
76.3 SURRY 1	93.3 SURRY 2	90.8 TROJAN	62.1 TURKEY POINT 3
61.1 TURKEY POINT 4	96.8 YANKEE-ROWE 1	45.6 ZION 1	97.9 ZION 2

Units excluded are:

\*\*\*\*\*  
 \* OTHER INFO \*  
 \*\*\*\*\*  
 BIG ROCK POINT  
 DRESDEN 1  
 FORT ST VRAIN  
 HUMBOLDT BAY  
 LACROSSE  
 THREE MILE ISLAND 2

Capacity factor in this page, denoted as CFMDC, is a function of the net maximum dependable capacity. See the corresponding definition in the glossary. The vendor averages are computed by the formula:

$$\frac{\text{Net Electrical Energy Produced by Vendor}}{\text{Potential Electrical Production by Vendor in this Month}} \times 100\%$$

	GE BWRs	West PWRs	Comb PWRs	B&W PWRs	ALL PWRs
NET ELECTRICAL PRODUCTION.....	6,934,975	12,582,345	3,707,674	3,974,315	20,264,334
MDC NET.....	19,226	25,508	7,929	6,760	40,197
CFMDC.....	51.8	70.9	67.2	84.5	72.4

MEMORANDA

THE FOLLOWING UNITS USE WEIGHTED AVERAGES TO CALCULATE CAPACITY FACTORS:

ITEM 22

BIG ROCK POINT 1  
CALVERT CLIFFS 1 & 2  
FARLEY 1  
FITZPATRICK  
FORT CALHOUN 1  
INDIAN POINT 2\*  
KEWAUNEE  
OYSTER CREEK 1  
POINT BEACH 1 & 2  
THREE MILE ISLAND 1  
TURKEY POINT 3 & 4

ITEM 22 & 23

GINNA  
HADDAM NECK (CONNECTICUT YANKEE)  
MAINE YANKEE  
MILLSTONE 2  
OCONEE 1, 2, & 3  
YANKEE-ROWE 1

\*COMPUTED SINCE 7/1/74, THE DATE OF COMPLETION OF A 100 DAY - 100% POWER OPERATION TEST.

THE FOLLOWING UNITS USE THE DATE OF FIRST ELECTRICAL GENERATION INSTEAD OF COMMERCIAL OPERATION,  
FOR THEIR CUMULATIVE DATA:

ITEMS 20 THROUGH 24

COOK 1 & 2  
BEAVER VALLEY 1  
SAN ONOFRE 1

ITEM 24 ONLY

BIG ROCK POINT 1

E R R A T A  
CORRECTIONS TO PREVIOUSLY REPORTED DATA

NOTE: THESE CHANGES ARE REFLECTED IN THE DATA CONTAINED IN THE CURRENT REPORT

Report Month - January 1984

	<u>Vol. 8, No. 2</u>	<u>Revised</u>
Gross Elec.	29,110,788	30,126,759
Net Elec.	27,824,839	28,789,343
Unit Serv.	70.0	70.3
Unit Avail.	70.0	70.3
Cap. Fac. (MDC)	65.5	65.5
Cap. Fac. (DER)	63.7	63.8
F. Outage Rate	11.9	11.7

The above monthly figures for January 1984 were revised.

**SECTION 2**

**OPERATING  
POWER  
REACTORS**

1. Docket: 50-313 OPERATING STATUS

2. Reporting Period: 22/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: K. L. MORTON (501) 964-3155

4. Licensed Thermal Power (Mwt): 2568

5. Nameplate Rating (Gross MWe): 1003 X 0.9 = 903

6. Design Electrical Rating (Net MWe): 850

7. Maximum Dependable Capacity (Gross MWe): 883

8. Maximum Dependable Capacity (Net MWe): 836

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>80,635.0</u>
13. Hours Restricted Critical	<u>696.0</u>	<u>1,440.0</u>	<u>53,875.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,044.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>52,690.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>817.5</u>
17. Gross Therm Ener (MWH)	<u>1,648,365</u>	<u>3,549,633</u>	<u>125,469,730</u>
18. Gross Elec Ener (MWH)	<u>554,700</u>	<u>1,194,755</u>	<u>41,333,120</u>
19. Net Elec Ener (MWH)	<u>530,977</u>	<u>1,145,442</u>	<u>39,403,829</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>65.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>66.4</u>
22. Unit Cap Factor (MDC Net)	<u>91.3</u>	<u>95.1</u>	<u>58.5</u>
23. Unit Cap Factor (DER Net)	<u>89.8</u>	<u>93.4</u>	<u>57.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>16.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,178.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ARKANSAS 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ARKANSAS 1 OPERATED WITH NO OUTAGES OR REDUCTIONS DURING FEBRUARY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ARKANSAS 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ARKANSAS  
COUNTY.....POPE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...6 MI WNW OF  
RUSSELLVILLE, AR  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 6, 1974  
DATE ELEC ENER 1ST GENER...AUGUST 17, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 19, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DARDANELLE RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHWEST POWER POOL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ARKANSAS POWER & LIGHT  
CORPORATE ADDRESS.....NINTH & LOUISIANA STREETS  
LITTLE ROCK, ARKANSAS 72203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....L. CALLAN  
LICENSING PROJ MANAGER....G. VISSING  
DOCKET NUMBER.....50-313  
LICENSE & DATE ISSUANCE...DPR-51, MAY 21, 1974  
PUBLIC DOCUMENT ROOM.....ARKANSAS TECH UNIVERSITY  
RUSSELLVILLE, ARKANSAS 72801

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED NOVEMBER 17-18, 1983 (83-30): ANNOUNCED INSPECTION OF THE SECURITY PLAN TO EXAMINE PROPOSED CHANGES. WITHIN THE 107 PROPOSED CHANGES INSPECTED, THOSE ITEMS IDENTIFIED AS REQUIRING A 10 CFR 50.90 CHANGE WILL BE SUBMITTED TO THE OFFICE OF NUCLEAR REACTOR REGULATION, NRC. SEVERAL OTHER ITEMS SUBMITTED AS 50.54(P) CHANGES WILL ALSO BE REFERRED TO OFFICE OF NUCLEAR MATERIAL SAFETY AND SAFEGUARDS FOR GUIDANCE. THE REMAINING ITEMS ARE RECOGNIZED AS 50.54(P) CHANGES TO THE AND SECURITY PLAN.

INSPECTION CONDUCTED DECEMBER 1-31, 1983, (83-34): ROUTINE, ANNOUNCED INSPECTION OF MAINTENANCE, SURVEILLANCE, OPERATIONAL SAFETY VERIFICATION, IE BULLETIN FOLLOWUP, AND FOLLOWUP ON PREVIOUSLY IDENTIFIED ITEMS. WITHIN THE AREAS INSPECTED, ONE VIOLATION WAS IDENTIFIED (USE OF A RADIATION MONITORING INSTRUMENT THAT WAS NOT CALIBRATED); AND ONE DEVIATION WAS IDENTIFIED (FAILURE TO MEET A COMMITMENT RELATIVE TO REACTOR TRIP BREAKER MAINTENANCE).

INSPECTION CONDUCTED DECEMBER 19-21, 1983, (83-36): ROUTINE, UNANNOUNCED INSPECTION OF THE QUALITY ASSURANCE PLANS, INSTRUCTIONS, AND PROCEDURES FOR A LOW-LEVEL RADIOACTIVE WASTE STORAGE FACILITY, AND THE FOLLOWING AREAS CONCERNING TRANSPORTATION ACTIVITIES AND LAND DISPOSAL OF RADIOACTIVE WASTE: MANAGEMENT CONTROLS; INDOCTRINATION AND TRAINING PROGRAMS; AUDIT PROGRAMS; PROCUREMENT AND SELECTION OF PACKAGES; PREPARATION OF PACKAGES FOR SHIPMENT; DELIVERY OF COMPLETED PACKAGES TO CARRIER; RECEIPT OF PACKAGES; RECORDS AND REPORTS; WASTE MANIFESTS; WASTE CLASSIFICATIONS; WASTE FORM AND CHARACTERIZATION; WASTE SHIPMENT LABELING; AND TRACKING OF WASTE SHIPMENTS. WITHIN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.





1. Docket: 50-368 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: LINDY BRAMLETT (501) 964-3145

4. Licensed Thermal Power (MWt): 2815

5. Nameplate Rating (Gross MWe): 943

6. Design Electrical Rating (Net MWe): 912

7. Maximum Dependable Capacity (Gross MWe): 897

8. Maximum Dependable Capacity (Net MWe): 858

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>34,464.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>823.6</u>	<u>22,496.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,430.1</u>
15. Hrs Generator On-Line	<u>688.8</u>	<u>688.8</u>	<u>21,639.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>75.0</u>
17. Gross Therm Ener (MWH)	<u>1,178,733</u>	<u>1,178,936</u>	<u>53,728,476</u>
18. Gross Elec Ener (MWH)	<u>381,460</u>	<u>381,460</u>	<u>17,398,411</u>
19. Net Elec Ener (MWH)	<u>357,446</u>	<u>357,446</u>	<u>16,563,786</u>
20. Unit Service Factor	<u>99.0</u>	<u>47.8</u>	<u>62.8</u>
21. Unit Avail Factor	<u>99.0</u>	<u>47.8</u>	<u>63.0</u>
22. Unit Cap Factor (MDC Net)	<u>59.9</u>	<u>28.9</u>	<u>56.0</u>
23. Unit Cap Factor (DER Net)	<u>56.3</u>	<u>27.2</u>	<u>52.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>19.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,378.5</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### ARKANSAS 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ARKANSAS 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
83-10	10/05/83	S	7.2	C	4		ZZ	ZZZZZ	REFUELING AND MAINTENANCE OUTAGE CONCLUDES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ARKANSAS 2 RETURNED ONLINE FEBRUARY 1ST AND OPERATED ROUTINELY THE  
REMAINDER OF THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





1. Docket: 50-334 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: J. L. HOLTZ (412) 643-1369

4. Licensed Thermal Power (MWt): 2660

5. Nameplate Rating (Gross MWe): 1026 X 0.9 = 923

6. Design Electrical Rating (Net MWe): 835

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 810

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>68,664.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,414.0</u>	<u>32,297.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>4,482.7</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,352.1</u>	<u>31,131.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,811,480</u>	<u>3,363,799</u>	<u>70,953,331</u>
18. Gross Elec Ener (MWH)	<u>587,700</u>	<u>1,091,500</u>	<u>22,520,440</u>
19. Net Elec Ener (MWH)	<u>553,128</u>	<u>1,041,605</u>	<u>20,930,403</u>
20. Unit Service Factor	<u>100.0</u>	<u>93.9</u>	<u>47.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>93.9</u>	<u>47.5</u>
22. Unit Cap Factor (MDC Net)	<u>98.1</u>	<u>89.3</u>	<u>41.1</u>
23. Unit Cap Factor (DER Net)	<u>95.2</u>	<u>86.6</u>	<u>39.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>6.1</u>	<u>30.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>87.9</u>	<u>17,765.0</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### BEAVER VALLEY 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BEAVER VALLEY 1 OPERATED ROUTINELY WITH NO OUTAGES OR  
REDUCTIONS DURING FEBRUARY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* BEAVER VALLEY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....BEAVER  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI E OF  
E. LIVERPOOL, OH  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 10, 1976  
DATE ELEC ENER 1ST GENER...JUNE 14, 1976  
DATE COMMERCIAL OPERATE...OCTOBER 1, 1976  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...OHIO RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUQUESNE LIGHT  
CORPORATE ADDRESS.....ONE OXFORD CENTRE, 301 GRANT STREET  
PITTSBURGH, PENNSYLVANIA 15279  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. TROSKOSKI  
LICENSING PROJ MANAGER.....P. TAM  
DOCKET NUMBER.....50-334  
LICENSE & DATE ISSUANCE...DPR-66, JULY 2, 1976  
PUBLIC DOCUMENT ROOM.....B.F. JONES MEMORIAL LIBRARY  
633 FRANKLIN AVENUE  
ALIQIPPA, PA 15001

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.





1. Docket: 50-155 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: SUE AMSTUTZ (616) 547-6537

4. Licensed Thermal Power (MWt): 240

5. Nameplate Rating (Gross MWe): 70.6 X 0.85 = 60

6. Design Electrical Rating (Net MWe): 72

7. Maximum Dependable Capacity (Gross MWe): 69

8. Maximum Dependable Capacity (Net MWe): 64

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>183,427.0</u>
13. Hours Reactor Critical	<u>435.1</u>	<u>1,179.1</u>	<u>128,889.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>432.8</u>	<u>1,176.8</u>	<u>126,469.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>83,473</u>	<u>227,577</u>	<u>23,713,468</u>
18. Gross Elec Ener (MWH)	<u>27,406</u>	<u>74,678</u>	<u>7,490,287</u>
19. Net Elec Ener (MWH)	<u>25,879</u>	<u>70,512</u>	<u>7,082,724</u>
20. Unit Service Factor	<u>62.2</u>	<u>81.7</u>	<u>68.9</u>
21. Unit Avail Factor	<u>62.2</u>	<u>81.7</u>	<u>68.9</u>
22. Unit Cap Factor (MDC Net)	<u>58.1</u>	<u>76.5</u>	<u>57.5*</u>
23. Unit Cap Factor (DER Net)	<u>51.6</u>	<u>68.0</u>	<u>53.6</u>
24. Unit Forced Outage Rate	<u>37.8</u>	<u>18.3</u>	<u>17.0</u>
25. Forced Outage Hours	<u>263.2</u>	<u>263.2</u>	<u>10,163.5</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: 03/17/84

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### BIG ROCK POINT 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BIG ROCK POINT 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-01	02/19/84	F	263.2	A	1		CB	VALVEX	STEAM LEAK IN THE PACKING OF A PRIMARY SYSTEM VALVE CAUSED THE INITIAL SHUTDOWN. SUBSEQUENT FAILURE OF THREE OUT OF FOUR REACTOR DEPRESSURIZATION VALVES REQUIRED ADDITIONAL REPAIRS AND TESTING PRIOR TO POWER ESCALATION.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
BIG ROCK POINT 1 SHUTDOWN ON FEBRUARY 19TH FOR A STEAM LEAK AND SUBSEQUENT FAILURE OF RDS VALVES.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BIG ROCK POI. \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
  
COUNTY.....CHARLEVOIX  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...4 MI NE OF  
CHARLEVOIX, MICH  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...SEPTEMBER 27, 1962  
  
DATE ELEC ENER 1ST GENER...DECEMBER 8, 1962  
  
DATE COMMERCIAL OPERATE...MARCH 29, 1963  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER...LAKE MICHIGAN  
  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSUMERS POWER  
  
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....G. WRIGHT  
  
LICENSING PROJ MANAGER.....R. EMCH  
DOCKET NUMBER.....50-155  
  
LICENSE & DATE ISSUANCE...DPR-6, AUGUST 30, 1962  
  
PUBLIC DOCUMENT ROOM.....CHARLEVOIX PUBLIC LIBRARY  
107 CLINTON STREET  
CHARLEVOIX, MICHIGAN 49720

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 19, - JANUARY 31, (83-19): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, LERS, TMI ITEM REVIEW, FIRE PROTECTION, AND REGIONAL REQUESTS. THE INSPECTION INVOLVED A TOTAL OF 201 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATION WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

Report Period FEB 1984

I N S P E C T I O N   S T A T U S - (CONTINUED)

\*\*\*\*\*  
\*           BIG ROCK POINT 1           \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT WAS SHUT DOWN ON 2/19/84 TO REPAIR LEAK ON RECIRCULATING PUMP SEAL COOLANT LINE, AND REMAINED SHUT DOWN THROUGH THE END OF THE MONTH.

LAST IE SITE INSPECTION DATE: JANUARY 1-31, 1984

INSPECTION REPORT NO: 84-01

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

=====

1. Docket: 50-259 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>84,002.0</u>
13. Hours Reactor Critical	<u>480.8</u>	<u>1,208.5</u>	<u>51,014.3</u>
14. Rx Reserve Shtdwn Hrs	<u>215.1</u>	<u>215.1</u>	<u>5,999.7</u>
15. Hrs Generator On-Line	<u>453.1</u>	<u>1,140.3</u>	<u>49,857.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,363,322</u>	<u>2,988,964</u>	<u>141,546,643</u>
18. Gross Elec Ener (MWH)	<u>459,170</u>	<u>1,005,810</u>	<u>46,651,430</u>
19. Net Elec Ener (MWH)	<u>444,294</u>	<u>977,541</u>	<u>45,302,868</u>
20. Unit Service Factor	<u>65.1</u>	<u>79.2</u>	<u>59.4</u>
21. Unit Avail Factor	<u>65.1</u>	<u>79.2</u>	<u>59.4</u>
22. Unit Cap Factor (MDC Net)	<u>59.9</u>	<u>63.7</u>	<u>50.6</u>
23. Unit Cap Factor (DER Net)	<u>59.9</u>	<u>63.7</u>	<u>50.6</u>
24. Unit Forced Outage Rate	<u>34.9</u>	<u>19.0</u>	<u>23.7</u>
25. Forced Outage Hours	<u>242.9</u>	<u>267.9</u>	<u>15,492.6</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### BROWNS FERRY 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BROWNS FERRY 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
270	02/02/84	S	0.0	H	5				DERATED FOR CONTROL ROD PATTERN ADJUSTMENT.
271	02/09/84	F	26.2	B	3				REACTOR SCRAM DURING THE PERFORMANCE OF SI 4.1.A.10.
272	02/14/84	F	199.4	A	2				REACTOR SCRAM FOR MODIFICATIONS TO RHRSW AIR RELEASE VALVES.
273	02/22/84	F	16.4	A	3				REACTOR SCRAM (OFF LINE) WHEN THE HIGH PRESSURE TURBINE FIRST STAGE PRESSURE EXCEEDED 142 PSIG WITH THE TSV'S CLOSED.
274	02/29/84	F	0.9	H	3				REACTOR SCRAM DUE TO POSSIBLE BUMPING OF PANEL 25-6A.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BROWNS FERRY 1 OPERATED WITH 1 REDUCTION AND 4 OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* BROWNS FERRY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....LIMESTONE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI NW OF  
DECATUR, ALA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 17, 1973  
DATE ELEC ENER 1ST GENER...OCTOBER 15, 1973  
DATE COMMERCIAL OPERATE...AUGUST 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...TENNESSEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TENNESSEE VALLEY AUTHORITY  
CORPORATE ADDRESS.....500A CHESTNUT STREET TOWER II  
CHATTANOOGA, TENNESSEE 37401  
CONTRACTOR  
ARCHITECT/ENGINEER.....TENNESSEE VALLEY AUTHORITY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....TENNESSEE VALLEY AUTHORITY  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE IDENT INSPECTOR.....J. PAULK  
LIC ENG PROJ MANAGER.....R. CLARK  
LIC IDENT NUMBER.....50-259  
LICEN & DATE ISSUANCE...DPR-33, DECEMBER 20, 1973  
FUBLI DOCUMENT ROOM.....ATHENS PUBLIC LIBRARY  
SOUTH AND FORREST  
ATHENS, ALABAMA 35611

I N S P E C T I O N     T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 23-27 (84-04): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 13 INSPECTOR-HOURS ON SITE IN THE AREAS OF STARTUP TESTING, NEW FUEL RECEIPT, PLANT TOURS, AND MSIV DEVIATIONS WERE IDENTIFIED IN FOUR AREAS.

ED INSPECTION INVOLVED 13 INSPECTOR-HOURS ON SITE IN THE AREAS OF AIR STATUS. OF THE (4) FOUR AREAS INSPECTED, NO VIOLATIONS OR

ENFORCEMENT SUMMARY

10 CFR 50.54(Q) REQUIRES THAT NUCLEAR POWER REACTOR LICENSEES FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICH MEET THE REQUIREMENTS OF APPENDIX E TO 10 CFR PART 50 AND THE PLANNING STANDARDS OF 50.47(B). TECHNICAL SPECIFICATION 6.3(A)(8) REQUIRES THAT DETAILED WRITTEN PROCEDURES, INCLUDING APPLICABLE CHECKOFF LISTS COVERING RADIOLOGICAL EMERGENCY PLAN IMPLEMENTING PROCEDURES SHALL BE PREPARED, APPROVED AND ADHERED TO. SECTION (B)(10) OF 10 CFR 50.47 REQUIRES THAT THE LICENSEE'S EMERGENCY PLANS SHALL INCLUDE INFORMATION TO DEMONSTRATE COMPLIANCE WITH THE FOLLOWING: A RANGE OF PROTECTIVE ACTIONS HAVE BEEN DEVELOPED FOR THE PLUME EXPOSURE PATHWAY EPZ FOR EMERGENCY WORKERS AND THE PUBLIC. GUIDELINES FOR THE CHOICE OF PROTECTIVE ACTIONS DURING AN EMERGENCY, CONSISTENT WITH FEDERAL GUIDANCE, ARE DEVELOPED AND IN PLACE, AND PROTECTIVE ACTIONS FOR THE INGESTION EXPOSURE PATHWAY EPZ APPROPRIATE TO THE LOCALE HAVE BEEN DEVELOPED. THE FEDERAL GUIDANCE ON PROTECTIVE ACTIONS TO BE RECOMMENDED TO OFFSITE OFFICIALS FOR GENERAL EMERGENCIES IS ADDRESSED IN APPENDIX 1 OF NUREG-0654/FEMA-REP-1, REVISION 1, ENTITLED "CRITERIA FOR PREPARATION AND EVALUATION OF RADIOLOGICAL EMERGENCY PREPAREDNESS IN SUPPORT OF NUCLEAR POWER PLANTS." THIS GUIDANCE IS CLARIFIED BY IE INFORMATION NOTICE NO. 83-28: "CRITERIA FOR PROTECTIVE ACTION RECOMMENDATIONS FOR GENERAL EMERGENCIES". CONTRARY TO THE ABOVE,



ENFORCEMENT SUMMARY

THE LICENSEE HAS FAILED TO INCORPORATE THE ABOVE GUIDANCE IN THE IMPLEMENTING PROCEDURES IN THAT, UNTIL THE RESPONSE ORGANIZATION IS MOBILIZED (I.E. CECC AND MSECC), THERE IS NO MECHANISM OR REQUIREMENT FOR CONSIDERING PROTECTIVE ACTION RECOMMENDATIONS OTHER THAN FOR SHELTERING IN THE PLUME EPZ. 10 CFR 50.54(Q) REQUIRES THAT NUCLEAR POWER REACTOR LICENSEES FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICH MEET THE REQUIREMENTS OF APPENDIX E TO 10 CFR PART 50 AND THE PLANNING STANDARDS OF 50.47(B). SECTION IV.B OF APPENDIX E REQUIRES THAT A LICENSEE'S EMERGENCY PLANS SHALL INCLUDE INFORMATION TO DEMONSTRATE COMPLIANCE WITH THE FOLLOWING: THE MEANS TO BE USED FOR DETERMINING THE MAGNITUDE OF AND FOR CONTINUALLY ASSESSING THE IMPACT OF THE RELEASE OF RADIOACTIVE MATERIAL SHALL BE DESCRIBED, INCLUDING EMERGENCY ACTION LEVELS THAT ARE TO BE USED AS CRITERIA FOR NOTIFICATION AND PARTICIPATION OF LOCAL AND STATE AGENCIES, THE COMMISSION, AND OTHER FEDERAL AGENCIES, AND THE EMERGENCY ACTION LEVELS THAT ARE TO BE USED FOR DETERMINING WHEN AND WHAT TYPE OF PROTECTIVE MEASURES SHOULD BE CONSIDERED WITHIN AND OUTSIDE THE SITE BOUNDARY TO PROTECT HEALTH AND SAFETY. 10 CFR 50.47(B)(15) REQUIRES THAT THOSE WHO MAY BE CALLED ON TO ASSIST IN AN EMERGENCY BE PROVIDED RADIOLOGICAL EMERGENCY RESPONSE TRAINING. SECTION 4.1.1 OF THE BROWNS FERRY NUCLEAR POWER PLANT EMERGENCY PLAN STATES IN PART THAT THE SITE EMERGENCY DIRECTOR HAS THE AUTHORITY TO RECOMMEND PROTECTIVE ACTIONS TO OFFSITE AUTHORITIES. SECTION 4.1 STATES IN PART THAT IN THE EVENT OF AN ACCIDENT, THE SHIFT ENGINEER IS INITIALLY THE SITE EMERGENCY DIRECTOR. CONTRARY TO THE ABOVE, SHIFT ENGINEERS, INITIALLY THE SITE EMERGENCY DIRECTORS, WERE INCAPABLE OF DETERMINING WHEN AND WHAT TYPE OF PROTECTIVE MEASURES SHOULD BE CONSIDERED OUTSIDE THE SITE BOUNDARY TO PROTECT HEALTH AND SAFETY.

(8340 4)

10 CFR 50, APPENDIX B, CRITERION VI (AS IMPLEMENTED BY TVA'S QA TOPICAL REPORT TVA TR 75-1 PARAGRAPH 17.2.6 AND OPERATIONAL QUALITY ASSURANCE MANUAL PART III SECTION 1.1) REQUIRES THAT MEASURES SHALL BE ESTABLISHED TO CONTROL THE ISSUANCE OF DOCUMENTS, INCLUDING CHANGES THERETO, WHICH PRESCRIBE ALL ACTIVITIES AFFECTING QUALITY. THESE MEASURES SHALL ASSURE THAT DOCUMENTS, INCLUDING CHANGES, ARE DISTRIBUTED TO AND USED AT THE LOCATION WHERE THE PRESCRIBED ACTIVITY IS PERFORMED. CONTRARY TO THE ABOVE, SEVERAL EXAMPLES WERE NOTED WHERE THIS REQUIREMENT WAS NOT MET IN THAT THE MUSCLE SHOALS EMERGENCY CONTROL CENTER IMPLEMENTING PROCEDURES DOCUMENT (MSECC IPD) REVISIONS WERE NOT ADEQUATELY IMPLEMENTED. EXAMPLES ARE LISTED: (1) IP-4 (NOTIFICATION PROCEDURE) WAS DELETED OCTOBER, 1982; HOWEVER, IP-4 HAS NOT BEEN REMOVED FROM THE MSECC IPD AT THE FOLLOWING LOCATIONS: BROWNS FERRY TSC (TECHNICAL SUPPORT CENTER) AND BROWNS FERRY FILE ROOM. (2) IP-5 (TRAINING/DRILL REQUIREMENTS) WAS DELETED JUNE 1983; HOWEVER, IP-5 HAS NOT BEEN REMOVED FROM CONTROL COPIES OF MSECC IPD AT THE FOLLOWING LOCATIONS: MUSCLE SHOALS EMERGENCY CONTROL CENTER AND BROWNS FERRY FILE ROOM.

(8340 5)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERIA I & XVI AS IMPLEMENTED BY THE LICENSEES QA PROGRAM (TVA-TR75-1A) OQA IS NOT ENSURING EFFECTIVE EXECUTION OF THE QA PROGRAM IN THAT ALL CONDITIONS ADVERSE TO QUALITY HAVE NOT BEEN PROMPTLY CORRECTED. THE CURRENT COMPOSITE OPEN ITEM LIST REVIEW SUMMARY CONTAINS 1 OUTSTANDING ITEM FROM 1979, 16 OUTSTANDING ITEMS FROM 1981 AND 65 OUTSTANDING ITEMS FROM 1982. REGION II HAS ISSUED FOUR VIOLATIONS SINCE FEBRUARY 1981 FOR FAILURE TO TAKE PROMPT CORRECTIVE ACTION BY MECHANISMS DEFINED WITHIN THE QA PROGRAM. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III AS IMPLEMENTED BY THE LICENSEE'S QA PROGRAM (TVA-TR75-1A), THE CONSTRUCTION ENGINEERING BRANCH HAS NOT ESTABLISHED MEASURES TO CONTROL DESIGN INTERFACES BETWEEN PARTICIPATING ORGANIZATIONS. THIS WAS IDENTIFIED IN THE LICENSEE'S AUDIT 83V-26 AND AGAIN IN AUDIT 83V-73. BOTH OF THESE AUDITS WERE CONDUCTED ON DIFFERENT VENDORS. CONTRARY TO BROWNS FERRY TECHNICAL SPECIFICATION (TS) 6.10.C, SEQUOYAH TS 6.5.2.10.C, THE LICENSEES ACCEPTED QA PROGRAM'S ENDORSEMENT OF REGULATORY GUIDE 1.144 AND ANSI N45.2.12 - 1974 OR 1977, PARAGRAPH 4.4.6 MULTIPLE EXAMPLES WERE IDENTIFIED OF FAILURE TO ISSUE AUDITS WITHIN REQUIRED TIMEFRAMES. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVIII AS IMPLEMENTED BY THE LICENSEES QA PROGRAM (TVA-TR75-1A), REGULATORY GUIDE 1.144, ANSI AND N45.2.12, PARAGRAPH 4.5.1, NUMEROUS EXAMPLES WERE IDENTIFIED WHERE THE AUDITED ORGANIZATION DID NOT RESPOND TO AUDITS FINDINGS WITHIN REQUIRED TIMEFRAMES. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II AS IMPLEMENTED BY THE LICENSEES QA PROGRAM, REGULATORY GUIDE 1.146, AND ANSI N45.2.23, MEASURES HAD NOT BEEN ESTABLISHED TO REQUIRE VERIFICATION OF MINIMUM CREDITS NEEDED TO BE A LEAD AUDITOR.

(8353 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVII AS IMPLEMENTED BY THE LICENSEE'S QA PROGRAM, REGULATORY GUIDE 1.88, AND ANSI N45.2.9 RECORDS WERE NOT MAINTAINED TO DEMONSTRATE THAT ALL AUDITORS AND LEAD AUDITORS WERE QUALIFIED TO PERFORM SAFETY-RELATED QA AUDITS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVIII IMPLEMENTED BY THE LICENSEE'S QA PROGRAM, REGULATORY GUIDE 1.144, AND ANSI N45.2.12, PROCEDURE DID NOT DELINEATE THAT PERSONS CONTACTED DURING THE AUDIT BE IDENTIFIED IN THE AUDIT REPORT.





1. Docket: 50-260                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (MWt):                      3293

5. Nameplate Rating (Gross MWe):                      1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe):                      1065

7. Maximum Dependable Capacity (Gross MWe):                      1098

8. Maximum Dependable Capacity (Net MWe):                      1065

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):                     

11. Reasons for Restrictions, If Any:                       
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>78,913.0</u>
13. Hours Reactor Critical	<u>494.6</u>	<u>1,149.8</u>	<u>51,113.7</u>
14. Rx Reserve Shtdwn Hrs	<u>201.4</u>	<u>290.2</u>	<u>14,190.5</u>
15. Hrs Generator On-Line	<u>465.0</u>	<u>1,105.2</u>	<u>49,598.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,426,819</u>	<u>3,459,852</u>	<u>143,604,897</u>
18. Gross Elec Ener (MWH)	<u>478,980</u>	<u>1,139,280</u>	<u>47,736,568</u>
19. Net Elec Ener (MWH)	<u>464,527</u>	<u>1,106,575</u>	<u>46,365,178</u>
20. Unit Service Factor	<u>66.8</u>	<u>76.8</u>	<u>62.9</u>
21. Unit Avail Factor	<u>66.8</u>	<u>76.8</u>	<u>62.9</u>
22. Unit Cap Factor (MDC Net)	<u>62.7</u>	<u>72.2</u>	<u>55.2</u>
23. Unit Cap Factor (DER Net)	<u>62.7</u>	<u>72.2</u>	<u>55.2</u>
24. Unit Forced Outage Rate	<u>33.2</u>	<u>17.5</u>	<u>24.6</u>
25. Forced Outage Hours	<u>231.0</u>	<u>233.8</u>	<u>16,288.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
JULY, 1984 REFUEL

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      BROWNS FERRY 2                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BROWNS FERRY 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
289	02/11/84	F	0.0	B	5			DERATED FOR "A" & "B" RECIRCULATION PUMP MG SET REPLACEMENT.
290	02/14/84	F	191.8	H	2			RX SCRAM FOR MODIFICATIONS ON RHRSW AIR RELEASE VALVES AND TO PLACE MAIN TRANSFORMER IN SERVICE AND TAKE SPARE TRANSFORMER OUT OF SERVICE.
291	02/22/84	F	39.2	H	3			RX SCRAM DUE TO HIGH CONTROL ROD WORTH.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BROWNS FERRY 2 OPERATED WITH 2 OUTAGES AND 1 REDUCTION DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





ENFORCEMENT SUMMARY

(8353 5)

TECHNICAL SPECIFICATION 6.3.A.10 REQUIRES THAT DETAILED WRITTEN PROCEDURES BE PREPARED, APPROVED, AND ADHFERED TO AS RELATED TO FIRE PROTECTION PROCEDURES. MECHANICAL MAINTENANCE INSTRUCTION (MMI) 122 IMPLEMENTS A HIGH PRESSURE FIRE PROTECTION SYSTEM FLUSH AND STRAINER INSPECTION PROGRAM TO ASSURE SYSTEM OPERABILITY. CONTRARY TO THE ABOVE, THE REQUIREMENT WAS NOT MET IN THAT PROCEDURAL STEPS FOR THE FIXED SPRAY SYSTEM FLUSH WERE NOT FOLLOWED DURING OBSERVATION BY THE INSPECTOR ON DECEMBER 7, 1983, IN THAT NO PROCEDURE WAS AVAILABLE AT THE WORK SITE TO ASSURE PROCEDURE COMPLIANCE. ADDITIONALLY, MMI 122, PART 1 (FIXED SPRAY FLUSH AND STRAINER INSPECTION), WAS INADEQUATE AND COULD NOT BE PERFORMED AS WRITTEN. THE PROCEDURE LISTED ISOLATION VALVES NOT ACTUALLY INSTALLED IN THE SYSTEM. THE PROCEDURE ALSO REQUIRED ACTUATION OF THE DELUGE VALVE THAT, IF ACTUATED, WOULD SPRAY PLANT EQUIPMENT. MMI 122 HAS BEEN CONDUCTED MONTHLY SINCE APRIL 1981, WITH NO APPARENT PROBLEMS NOTED BY PLANT PERSONNEL. THE PART 1 DATA SHEET FOR MMI 122, ADDITIONALLY, DOES NOT INDICATE COMPLETION OF THE QUARTERLY CLEANING OF SYSTEM STRAINERS AS REQUIRED BY MMI 122.

(8357 4)

FAILURE TO CONTROL ACCESS TO FUEL-HANDLING AREA AS COMMITTED TO IN APPROVED PHYSICAL SECURITY PLAN.

(8359 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 23-27, 1984 +

INSPECTION REPORT NO: 50-260/84-04 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-296 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: TED THOM (205) 729-0834

4. Licensed Thermal Power (Mwt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1065

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>61,368.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>43,088.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,878.1</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>42,194.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>126,285,520</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>41,597,620</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>40,376,156</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>68.8</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>68.8</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>61.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>61.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>10.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,091.4</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 08/15/84

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

BROWNS FERRY 3



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* BROWNS FERRY 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
140	09/07/83	S	696.0	C	4				EOC-5 REFUEL OUTAGE CONTINUES.

\*\*\*\*\* BROWNS FERRY 3 REMAINS SHUTDOWN IN A CONTINUING  
\* SUMMARY \* REFUELING OUTAGE.  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)







THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-325                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt):                    2436

5. Nameplate Rating (Gross MWe):                    963 X 0.9 = 867

6. Design Electrical Rating (Net MWe):                    821

7. Maximum Dependable Capacity (Gross MWe):                    815

8. Maximum Dependable Capacity (Net MWe):                    790

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>60,961.0</u>
13. Hours Reactor Critical	<u>641.1</u>	<u>1,362.8</u>	<u>37,760.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,647.1</u>
15. Hrs Generator On-Line	<u>614.3</u>	<u>1,336.0</u>	<u>35,424.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,447,183</u>	<u>3,172,514</u>	<u>71,599,800</u>
18. Gross Elec Ener (MWH)	<u>486,205</u>	<u>1,066,181</u>	<u>23,613,229</u>
19. Net Elec Ener (MWH)	<u>473,376</u>	<u>1,038,422</u>	<u>22,652,253</u>
20. Unit Service Factor	<u>88.3</u>	<u>92.8</u>	<u>58.1</u>
21. Unit Avail Factor	<u>88.3</u>	<u>92.8</u>	<u>58.1</u>
22. Unit Cap Factor (MDC Net)	<u>86.1</u>	<u>91.3</u>	<u>47.0</u>
23. Unit Cap Factor (DER Net)	<u>82.8</u>	<u>87.8</u>	<u>45.3</u>
24. Unit Forced Outage Rate	<u>11.7</u>	<u>7.2</u>	<u>20.4</u>
25. Forced Outage Hours	<u>81.7</u>	<u>104.0</u>	<u>9,023.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>REPLACING SEALS ON RECIRC PUMP - 03/03/84- 1 WK.</u>			
27. If Currently Shutdown Estimate Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### BRUNSWICK 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BRUNSWICK 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-006	01/31/84	F	81.7	A	4		XX	VESSEL	UNIT SEPARATED FROM GRID TO FIND SOURCE OF DRYWELL FLOOR AND EQUIPMENT DRAIN LEAKAGE AND REPAIR.
84-009	02/13/84	F	0.0	B	5		CB	PUMPXX	REMOVED 1A RS FEEDPUMP FROM SERVICE TO ALLOW I&C TO CHECK OUT MGU.
84-010	02/18/84	F	0.0	A	5				REDUCED POWER DUE TO HI D/F ACROSS RADWASTE AND APRM UPSCALE.
84-011	02/25/84	S	0.0	B	5				CONTROL ROD OPERABILITY COMP. 100% ROD PATTERN.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*

BRUNSWICK 1 RETURNED ONLINE FEBRUARY 4TH FROM A REPAIR OUTAGE AND OPERATED ROUTINELY THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		

\*\*\*\*\*  
\* BRUNSWICK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....BRUNSWICK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 8, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1976  
DATE COMMERCIAL OPERATE...MARCH 18, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CAPE FEAR RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....P. O. BOX 1551  
RALEIGH, NORTH CAROLINA 27602  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BROWN & ROOT  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. MYERS  
LICENSING PROJ MANAGER.....S. MACKAY  
DOCKET NUMBER.....50-325  
LICENSE & DATE ISSUANCE...DPR-71, NOVEMBER 12, 1976  
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY  
108 W. MOORE STREET  
SOUTHPORT, NORTH CAROLINA 28461

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 15, 1983-JANUARY 15, 1984 (83-42): THIS ROUTINE SAFETY INSPECTION INVOLVED 69 INSPECTOR-HOURS ON SITE IN THE AREAS OF SURVEILLANCE, MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM WALKDOWN, IN-OFFICE LICENSEE EVENT REPORTS REVIEW, INDEPENDENT INSPECTION, AND PLANT TRANSIENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.7.7.2 FOR BRUNSWICK, UNIT 1, REQUIRES THAT THE DELUGE SYSTEM FOR THE STANDBY GAS TREATMENT SYSTEM (SBGTS) TRAINS 1A AND 1B, BE OPERABLE WHENEVER THE SBGTS SYSTEM IS REQUIRED TO BE OPERABLE. ACTION STATEMENT "A" OF TS 3.7.7.2 REQUIRES THAT, WITH THE DELUGE SYSTEM INOPERABLE, A CONTINUOUS FIRE WATCH WITH BACKUP SUPPRESSION EQUIPMENT BE ESTABLISHED WITHIN ONE HOUR. CONTRARY TO THE ABOVE, THE UNIT 1 DELUGE SYSTEM FOR THE SBGTS TRAINS 1A AND 1B WAS RENDERED INOPERABLE WHEN VALVE 1-WW-V207 WAS SHUT DURING THE PERIOD OF FEBRUARY 11 TO MARCH 13, 1983 AND A CONTINUOUS FIRE WATCH WAS NOT ESTABLISHED. DURING THIS TIME THE PLANT WAS IN A CONDITION WHICH REQUIRED THE SBGTS TO BE OPERABLE. IN A RESPONSE DATED MAY 24, 1982 DESCRIBING CORRECTIVE ACTION TAKEN WITH RESPECT TO A NOTICE OF VIOLATION DATED APRIL 2, 1982, THE LICENSEE STATED THAT TABLES I AND IA OF VOLUME XI OF THE LICENSEE'S PLANT OPERATING MANUAL HAD BEEN REVISED TO ASSURE THAT ALL Q-LIST EQUIPMENT WAS CORRECTLY IDENTIFIED ON BOTH TABLES. THESE TABLES ARE USED BY LICENSEE PERSONNEL AS A REFERENCE TO DETERMINE IF A PLANT INSTRUMENT IS A Q-ITEM (I.E., SAFETY-RELATED). CONTRARY TO THE ABOVE, ON MAY 24, 1982 AND AS OF NOVEMBER 1982, NUMEROUS DISCREPANCIES EXISTED BETWEEN TABLES I AND IA OF VOLUME XI OF THE LICENSEE'S PLANT OPERATING MANUAL AND CONSEQUENTLY THE TABLES DID NOT CORRECTLY IDENTIFY ALL Q-LIST

ENFORCEMENT SUMMARY

EQUIPMENT. FOR EXAMPLE, TABLE IA DID NOT IDENTIFY PRESSURE SWITCH AS Q-LIST EQUIPMENT WHILE TABLE I DID. THUS, THE LICENSEE'S RESPONSE TO THE NRC OF MAY 24, 1982 CONTAINED A MATERIAL FALSE STATEMENT WITHIN THE MEANING OF SECTION 186 OF THE ATOMIC ENERGY ACT OF 1954, AS AMENDED. THE LICENSEE'S STATEMENT WAS FALSE IN THAT TABLES I AND IA DID NOT CORRECTLY IDENTIFY ALL Q-LIST EQUIPMENT. THE STATEMENT IS MATERIAL FOR THE NRC WOULD HAVE TAKEN FURTHER REGULATORY ACTION TO CORRECT THE TABLES HAD IT KNOWN THEY WERE INCORRECT.  
(8311 3)

TECHNICAL SPECIFICATION 3.7.8 FOR BRUNSWICK, UNITS 1 AND 2 REQUIRES THAT ALL FIRE BARRIER PENETRATIONS, FIRE DOORS AND FIRE DAMPERS, IN FIRE ZONE BOUNDARIES PROTECTING SAFETY-RELATED AREAS, SHALL BE FUNCTIONAL. TECHNICAL SPECIFICATION 3.7.8 ACTION STATEMENT "A" REQUIRES THAT, WITH ONE OR MORE OF THE FIRE BARRIER PENETRATIONS NON-FUNCTIONAL, WITHIN ONE HOUR A CONTINUOUS FIRE WATCH MUST BE ESTABLISHED ON AT LEAST ONE SIDE OF THE AFFECTED PENETRATION OR VERIFY THE OPERABILITY OF FIRE DETECTORS ON AT LEAST ONE SIDE OF THE NON-FUNCTIONAL FIRE BARRIER AND ESTABLISH AN HOURLY FIRE WATCH PATROL. CONTRARY TO THE ABOVE, DURING THE PERIOD OF FEBRUARY 13, TO APRIL 5, 1983, FIRE BARRIER PENETRATIONS PROTECTING SAFETY-RELATED AREAS IN UNITS 1 AND 2 WERE NON-FUNCTIONAL AND THE ASSOCIATED FIRE DETECTORS WERE INOPERABLE WITHOUT CONTINUOUS FIRE WATCH. TECHNICAL SPECIFICATION 6.8.1.F FOR UNITS 1 AND 2 REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING FIRE PROTECTION PROGRAM IMPLEMENTATION. CONTRARY TO THE ABOVE, PROCEDURES COVERING THE FIRE PROTECTION PROGRAM FOR UNITS 1 AND 2 WERE NOT ADEQUATELY IMPLEMENTED AS DEMONSTRATED BY THE FOLLOWING EXAMPLES: (A) FIRE PROTECTION SURVEILLANCE PROCEDURE PT-35.7 WAS INADEQUATELY IMPLEMENTED ON FEBRUARY 12, 20, AND 26 AND MARCH 7, 1983 IN THAT THE POSITION VALVE WW-V207 WAS NOT PROPERLY IDENTIFIED. THE VALVE WAS SHUT. THE POSITION WAS RECORDED AS BEING LOCKED OPEN. (B) FIRE PROTECTION SURVEILLANCE PROCEDURE PT-35.1 WAS INADEQUATELY IMPLEMENTED ON FEBRUARY 14, 21, AND 28 AND MARCH 7, 1983 IN THAT VALVE WW-V207 WAS NOT PROPERLY VERIFIED AS LOCKED OPEN. (C) FIRE PROTECTION PROCEDURES PT-35.16 AND PT-35.18 WERE NOT BEING ADEQUATELY IMPLEMENTED IN THAT SURVEILLANCE TO ENSURE THE FUNCTIONAL STATUS OF FIRE BARRIER PENETRATIONS WERE NOT BEING PERFORMED IN ACCORDANCE WITH THE ACCEPTANCE CRITERIA SPECIFIED IN THESE TESTS. TECHNICAL SPECIFICATION 6.9.1.8.6 FOR UNIT 1 REQUIRES THE REPORTING WITHIN 24 HOURS BY TELEPHONE AND CONFIRMATION BY TELEGRAPH, MAILGRAM, OR FACSIMILE TRANSMISSION TO THE DIRECTOR OF THE REGIONAL OFFICE OR HIS DESIGNEE NO LATER THAN THE FIRST WORKING DAY FOLLOWING OPERATION OF THE UNIT OR AFFECTED SYSTEM WHEN ANY PARAMETER OR OPERATION SUBJECT TO AN LCO IS LESS CONSERVATIVE THAN THE LEAST CONSERVATIVE ASPECT OF THE LCO ESTABLISHED IN THE TECHNICAL SPECIFICATION. CONTRARY TO THE ABOVE, THE LCO VIOLATION DESCRIBED IN ITEM B ABOVE WAS A REPORTABLE EVENT WHICH WAS NOT REPORTED TO THE NRC REGION II WITHIN 24 HOURS. TECHNICAL SPECIFICATION 6.9.2 FOR UNIT 1 REQUIRES A SPECIAL REPORT TO BE ISSUED WITHIN 30 DAYS AFTER A FIRE BARRIER PENETRATION HAS BEEN INOPERABLE FOR 7 DAYS. CONTRARY TO THE ABOVE, IN FOUR INSTANCES, ONCE ON JANUARY 26, TWICE ON FEBRUARY 19, AND ONCE ON MARCH 12, 1983, FIRE BARRIER PENETRATIONS WERE INOPERABLE FOR MORE THAN 7 DAYS AND THE REQUIRED SPECIAL REPORTS WERE NOT SUBMITTED.  
(8311 4)

TECHNICAL SPECIFICATION 6.8.1.A, REQUIRES WRITTEN PROCEDURES BE IMPLEMENTED FOR ACTIVITIES REFERENCED IN APPENDIX A OF REGULATORY GUIDE 1.33, NOVEMBER, 1972. THE GUIDE ITEM, H.2.B 30, REFERENCES PROCEDURES FOR PROCESS RADIATION MONITORING CALIBRATION. CONTRARY TO THE ABOVE, THE STEAM JET AIR EJECTOR RADIATION MONITOR CALIBRATION WAS NOT IMPLEMENTED, IN THAT STEP VII.B OF THE PROCEDURE PT-70, WAS NOT CORRECTLY PERFORMED. TECHNICAL SPECIFICATION 6.8.1.A, REQUIRES WRITTEN PROCEDURES BE ESTABLISHED FOR ACTIVITIES REFERENCED IN APPENDIX A OF REGULATORY GUIDE 1.33, NOVEMBER 1972. THE GUIDE ITEM B.9, REFERENCES PROCEDURES FOR SHUTDOWN. CONTRARY TO THE ABOVE, GP-01, WHICH IS USED FOR SHUTDOWN, WAS INADEQUATELY ESTABLISHED, IN THAT A PRECAUTION WAS NOT PROVIDED TO VERIFY THAT THE IRM'S ARE NOT TRIPPED PRIOR TO CHANGING THE MODE SWITCH FROM "STARTUP" MODE.  
(8341 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-324 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: FRANCES HARRISON (919) 457-9521

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 963 X 0.9 = 867

6. Design Electrical Rating (Net MWe): 821

7. Maximum Dependable Capacity (Gross MWe): 815

8. Maximum Dependable Capacity (Net MWe): 790

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           


11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>72,985.0</u>
13. Hours Reactor Critical	<u>671.6</u>	<u>1,338.4</u>	<u>46,065.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>662.1</u>	<u>1,301.0</u>	<u>43,086.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,468,832</u>	<u>2,744,288</u>	<u>81,321,002</u>
18. Gross Elec Ener (MWH)	<u>487,062</u>	<u>910,369</u>	<u>27,020,067</u>
19. Net Elec Ener (MWH)	<u>471,735</u>	<u>881,155</u>	<u>25,908,773</u>
20. Unit Service Factor	<u>95.1</u>	<u>90.3</u>	<u>59.0</u>
21. Unit Avail Factor	<u>95.1</u>	<u>90.3</u>	<u>59.0</u>
22. Unit Cap Factor (MDC Net)	<u>85.8</u>	<u>77.5</u>	<u>44.9</u>
23. Unit Cap Factor (DER Net)	<u>82.6</u>	<u>74.5</u>	<u>43.2</u>
24. Unit Forced Outage Rate	<u>4.9</u>	<u>2.7</u>	<u>17.6</u>
25. Forced Outage Hours	<u>33.9</u>	<u>35.5</u>	<u>9,638.9</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>OFF-GAS/CONDENSER RETUBING 3/10 - 10/15/84.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

## BRUNSWICK 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* BRUNSWICK 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-008	02/10/84	S	0.0	B	5				REDUCED POWER FOR SCRAM TESTING.
84-011	02/18/84	S	0.0	B	5				REDUCTION FOR ROD IMPROVEMENT.
84-012	02/18/84	S	0.0	B	5				REDUCED POWER FOR DEBRIS FILTER BACKWASH AS PER OP-29.
84-013	02/17/84	F	0.0	A	5				REDUCED POWER IN ORDER TO ESTABLISH A STABLE CONDENSER VACUUM GREATER THAN 26 INCHES.
84-016	02/22/84	F	33.9	A	3		CD	VALVOP	RX SCRAM- STEAM LINE "D" OUTBOARD MSIV SHUTTING DURING PERFORMING OF PT A22.
84-018	02/24/84	F	0.0	A	5		CH	PUMPXX	LOST 2B REACTOR FEEDPUMP.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 BRUNSWICK 2 OPERATED WITH 5 REDUCTIONS AND 1 OUTAGE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* BRUNSWICK 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....BRUNSWICK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...3 MI N OF  
SOUTHPORT, NC  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 20, 1975  
DATE ELEC ENER 1ST GENER...APRIL 29, 1975  
DATE COMMERCIAL OPERATE...NOVEMBER 3, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CAPE FEAR RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET  
RALEIGH, NORTH CAROLINA 27602  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BROWN & ROOT  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. MYERS  
LICENSING PROJ MANAGER.....S. MACKAY  
DOCKET NUMBER.....50-324  
LICENSE & DATE ISSUANCE...DPR-62, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....SOUTHPORT-BRUNSWICK COUNTY LIBRARY  
108 W. MOORE STREET  
SOUTHPORT, NORTH CAROLINA 28461

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION DECEMBER 15, 1983-JANUARY 15, 1984 (83-42): THIS ROUTINE SAFETY INSPECTION INVOLVED 68 INSPECTOR-HOURS ON SITE IN THE AREAS OF SURVEILLANCE, MAINTENANCE, OPERATIONAL SAFETY VERIFICATION, ESF SYSTEM WALKDOWN, IN-OFFICE LICENSEE EVENT REPORTS REVIEW, INDEPENDENT INSPECTION, AND PLANT TRANSIENTS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 3.7.7.2 FOR BRUNSWICK, UNIT 1, REQUIRES THAT THE DELUGE SYSTEM FOR THE STANDBY GAS TREATMENT SYSTEM (SBGTS) TRAINS 1A AND 1B, BE OPERABLE WHENEVER THE SBGTS SYSTEM IS REQUIRED TO BE OPERABLE. ACTION STATEMENT "A" OF TS 3.7.7.2 REQUIRES THAT, WITH THE DELUGE SYSTEM INOPERABLE, A CONTINUOUS FIRE WATCH WITH BACKUP SUPPRESSION EQUIPMENT BE ESTABLISHED WITHIN ONE HOUR. CONTRARY TO THE ABOVE, THE UNIT 1 DELUGE SYSTEM FOR THE SBGTS TRAINS 1A AND 1B WAS RENDERED INOPERABLE WHEN VALVE 1-WW-V207 WAS SHUT DURING THE PERIOD OF FEBRUARY 11 TO MARCH 13, 1983 AND A CONTINUOUS FIRE WATCH WAS NOT ESTABLISHED. DURING THIS TIME THE PLANT WAS IN A CONDITION WHICH REQUIRED THE SBGTS TO BE OPERABLE.  
(8311 3)

IN A RESPONSE DATED MAY 24, 1982 DESCRIBING CORRECTIVE ACTION TAKEN WITH RESPECT TO A NOTICE OF VIOLATION DATED APRIL 2, 1982, THE LICENSEE STATED THAT TABLES I AND IA OF VOLUME XI OF THE LICENSEE'S PLANT OPERATING MANUAL HAD BEEN REVISED TO ASSURE THAT ALL Q-LIS. EQUIPMENT WAS CORRECTLY IDENTIFIED ON BOTH TABLES. THESE TABLES ARE USED BY LICENSEE PERSONNEL AS A REFERENCE TO DETERMINE



ENFORCEMENT SUMMARY

IF A PLANT INSTRUMENT IS A Q-ITEM (I.E., SAFETY-RELATED). CONTRARY TO THE ABOVE, ON MAY 24, 1982 AND AS OF NOVEMBER 1982, NUMEROUS DISCREPANCIES EXISTED BETWEEN TABLES I AND IA OF VOLUME XI OF THE LICENSEE'S PLANT OPERATING MANUAL AND CONSEQUENTLY THE TABLES DID NOT CORRECTLY IDENTIFY ALL Q-LIST EQUIPMENT. FOR EXAMPLE, TABLE IA DID NOT IDENTIFY PRESSURE SWITCH AS Q-LIST EQUIPMENT WHILE TABLE I DID. THUS, THE LICENSEE'S RESPONSE TO THE NRC OF MAY 24, 1982 CONTAINED A MATERIAL FALSE STATEMENT WITHIN THE MEANING OF SECTION 186 OF THE ATOMIC ENERGY ACT OF 1954, AS AMENDED. THE LICENSEE'S STATEMENT WAS FALSE IN THAT TABLES I AND IA DID NOT CORRECTLY IDENTIFY ALL Q-LIST EQUIPMENT. THE STATEMENT IS MATERIAL FOR THE NRC WOULD HAVE TAKEN FURTHER REGULATORY ACTION TO CORRECT THE TABLES HAD IT KNOWN THEY WERE INCORRECT. TECHNICAL SPECIFICATION 3.7.8 FOR BRUNSWICK, UNITS 1 AND 2 REQUIRES THAT ALL FIRE BARRIER PENETRATIONS, FIRE DOORS AND FIRE DAMPERS, IN FIRE ZONE BOUNDARIES PROTECTING SAFETY-RELATED AREAS, SHALL BE FUNCTIONAL. TECHNICAL SPECIFICATION 3.7.8 ACTION STATEMENT "A" REQUIRES THAT, WITH ONE OR MORE OF THE FIRE BARRIER PENETRATIONS NON-FUNCTIONAL, WITHIN ONE HOUR A CONTINUOUS FIRE WATCH MUST BE ESTABLISHED ON AT LEAST ONE SIDE OF THE AFFECTED PENETRATION OR VERIFY THE OPERABILITY OF FIRE DETECTORS ON AT LEAST ONE SIDE OF THE NON-FUNCTIONAL FIRE BARRIER AND ESTABLISH AN HOURLY FIRE WATCH PATROL. CONTRARY TO THE ABOVE, DURING THE PERIOD OF FEBRUARY 13, TO APRIL 5, 1983, FIRE BARRIER PENETRATIONS PROTECTING SAFETY-RELATED AREAS IN UNITS 1 AND 2 WERE NON-FUNCTIONAL AND THE ASSOCIATED FIRE DETECTORS WERE INOPERABLE WITHOUT CONTINUOUS FIRE WATCH. TECHNICAL SPECIFICATION 6.8.1.F FOR UNITS 1 AND 2 REQUIRES THAT WRITTEN PROCEDURES SHALL BE ESTABLISHED, IMPLEMENTED AND MAINTAINED COVERING FIRE PROTECTION PROGRAM IMPLEMENTATION. CONTRARY TO THE ABOVE, PROCEDURES COVERING THE FIRE PROTECTION PROGRAM FOR UNITS 1 AND 2 WERE NOT ADEQUATELY IMPLEMENTED AS DEMONSTRATED BY THE FOLLOWING EXAMPLES: (A) FIRE PROTECTION SURVEILLANCE PROCEDURE PT-35.7 WAS INADEQUATELY IMPLEMENTED ON FEBRUARY 12, 20, AND 26 AND MARCH 7, 1983 IN THAT THE POSITION VALVE WW-V207 WAS NOT PROPERLY IDENTIFIED. THE VALVE WAS SHUT. THE POSITION WAS RECORDED AS BEING LOCKED OPEN. (B) FIRE PROTECTION SURVEILLANCE PROCEDURE PT-35.1 WAS INADEQUATELY IMPLEMENTED ON FEBRUARY 14, 21, AND 28 AND MARCH 7, 1983 IN THAT VALVE WW-V207 WAS NOT PROPERLY VERIFIED AS LOCKED OPEN. (C) FIRE PROTECTION PROCEDURES PT-35.16 AND PT-35.18 WERE NOT BEING ADEQUATELY IMPLEMENTED IN THAT SURVEILLANCE TO ENSURE THE FUNCTIONAL STATUS OF FIRE BARRIER PENETRATIONS WERE NOT BEING PERFORMED IN ACCORDANCE WITH THE ACCEPTANCE CRITERIA SPECIFIED IN THESE TESTS. TECHNICAL SPECIFICATION 6.9.1.8.6 FOR UNIT 1 REQUIRES THE REPORTING WITHIN 24 HOURS BY TELEPHONE AND CONFIRMATION BY TELEGRAPH, MAILGRAM, OR FACSIMILE TRANSMISSION TO THE DIRECTOR OF THE REGIONAL OFFICE OR HIS DESIGNEE NO LATER THAN THE FIRST WORKING DAY FOLLOWING OPERATION OF THE UNIT OR AFFECTED SYSTEM WHEN ANY PARAMETER OR OPERATION SUBJECT TO AN LCO IS LESS CONSERVATIVE THAN THE LEAST CONSERVATIVE ASPECT OF THE LCO ESTABLISHED IN THE TECHNICAL SPECIFICATION. CONTRARY TO THE ABOVE, THE LCO VIOLATION DESCRIBED IN ITEM B ABOVE WAS A REPORTABLE EVENT WHICH WAS NOT REPORTED TO THE NRC REGION II WITHIN 24 HOURS. TECHNICAL SPECIFICATION 6.9.2 FOR UNIT 1 REQUIRES A SPECIAL REPORT TO BE ISSUED WITHIN 30 DAYS AFTER A FIRE BARRIER PENETRATION HAS BEEN INOPERABLE FOR 7 DAYS. CONTRARY TO THE ABOVE, IN FOUR INSTANCES, ONCE ON JANUARY 26, TWICE ON FEBRUARY 19, AND ONCE ON MARCH 12, 1983, FIRE BARRIER PENETRATIONS WERE INOPERABLE FOR MORE THAN 7 DAYS AND THE REQUIRED SPECIAL REPORTS WERE NOT SUBMITTED.

(8311 4)

TECHNICAL SPECIFICATION 6.8.1.A, REQUIRES WRITTEN PROCEDURES BE IMPLEMENTED FOR ACTIVITIES REFERENCED IN APPENDIX A OF REGULATORY GUIDE 1.33, NOVEMBER, 1972. THE GUIDE ITEM, H.2.B.(2), REFERENCES PROCEDURES FOR CALIBRATION OF CONTAINMENT ISOLATION TESTS. CONTRARY TO THE ABOVE, THE CALIBRATION PROCEDURE FOR THE REACTOR WATER CLEANUP SYSTEM ISOLATION ON HIGH AREA TEMPERATURE (PT 2.1.15PC), WAS NOT PROPERLY IMPLEMENTED IN THAT THE PROCEDURE FAILED TO TEST THE SYSTEM'S SENSOR. THIS RESULTED IN THE SURVEILLANCE FREQUENCY OF THE "A" TRIP SYSTEM OF THE RWC SYSTEMS ISOLATION EXCEEDING ITS TECHNICAL SPECIFICATION ALLOWANCE OF 18 MONTHS.

(8342 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    BRUNSWICK 2                    \*  
\*\*\*\*\*

OTHER ITEMS

NONE.

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

ROUTINE OPERATION.

LAST IE SITE INSPECTION DATE: DECEMBER 15, 1983 - JANUARY 15, 1984 +

INSPECTION REPORT NO: 50-324/83-42 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-317 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: EVELYN BEWLEY (301) 787-5365

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1020 X 0.9 = 918

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>77,269.0</u>
13. Hours Reactor Critical	<u>669.0</u>	<u>1,395.5</u>	<u>61,362.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,887.9</u>
15. Hrs Generator On-Line	<u>669.0</u>	<u>1,389.6</u>	<u>60,135.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,771,548</u>	<u>7,669,547</u>	<u>147,811,800</u>
18. Gross Elec Ener (MWH)	<u>613,922</u>	<u>1,262,669</u>	<u>48,670,154</u>
19. Net Elec Ener (MWH)	<u>588,893</u>	<u>1,211,084</u>	<u>46,446,050</u>
20. Unit Service Factor	<u>96.1</u>	<u>96.5</u>	<u>77.8</u>
21. Unit Avail Factor	<u>96.1</u>	<u>96.5</u>	<u>77.8</u>
22. Unit Cap Factor (MDC Net)	<u>102.6</u>	<u>101.9</u>	<u>73.8*</u>
23. Unit Cap Factor (DER Net)	<u>100.1</u>	<u>99.5</u>	<u>71.1</u>
24. Unit Forced Outage Rate	<u>3.9</u>	<u>3.5</u>	<u>7.4</u>
25. Forced Outage Hours	<u>27.0</u>	<u>50.4</u>	<u>4,713.2</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/15/84

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### CALVERT CLIFFS 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-02	02/28/84	F	27.0	A	1		CB	PUMPXX	DUE TO LOSS OF TWO CHARGING PUMPS AND REPAIR LEAKING PRESSURIZER SAFETY VALVE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
CALVERT CLIFFS 1 OPERATED WITH 1 OUTAGE DURING  
FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CALVERT CLIFFS 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MARYLAND  
COUNTY.....CALVERT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI S OF  
ANNAPOLIS, MD  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 7, 1974  
DATE ELEC ENER 1ST GENER...JANUARY 3, 1975  
DATE COMMERCIAL OPERATE...MAY 8, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CHESAPEAKE BAY  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BALTIMORE GAS & ELEC  
CORPORATE ADDRESS.....P.O. BOX 1475  
BALTIMORE, MARYLAND 21203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. ARCHITZEL  
LICENSING PROJ MANAGER.....D. JAFFE  
DOCKET NUMBER.....50-317  
LICENSE & DATE ISSUANCE...DPR-53, JULY 31, 1974  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            CALVERT CLIFFS 1            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-318 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: EVELYN BEWLEY (310) 787-5365

4. Licensed Thermal Power (Mwt): 2700

5. Nameplate Rating (Gross MWe): 1012 X 0.9 = 911

6. Design Electrical Rating (Net MWe): 845

7. Maximum Dependable Capacity (Gross MWe): 860

8. Maximum Dependable Capacity (Net MWe): 825


9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

CALVERT CLIFFS 2



FEBRUARY 1984

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	696.0	1,440.0	60,624.0
13. Hours Reactor Critical	696.0	1,440.0	51,367.8
14. Rx Reserve Shtdwn Hrs	.0	.0	958.1
15. Hrs Generator On-Line	696.0	1,440.0	50,555.2
16. Unit Reserve Shtdwn Hrs	.0	.0	.0
17. Gross Therm Ener (MWH)	1,787,897	3,778,858	125,620,551
18. Gross Elec Ener (MWH)	587,882	1,245,302	41,314,588
19. Net Elec Ener (MWH)	562,435	1,192,525	39,396,287
20. Unit Service Factor	100.0	100.0	83.4
21. Unit Avail Factor	100.0	100.0	83.4
22. Unit Cap Factor (MDC Net)	98.0	100.4	79.3*
23. Unit Cap Factor (DER Net)	95.6	98.0	76.9
24. Unit Forced Outage Rate	.0	.0	5.7
25. Forced Outage Hours	.0	.0	3,045.2

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING & UNIT GENERAL INSPECTION - 04/84 - 10 WKS.

27. If Currently Shutdown Estimated Startup Date: N/A

\* Item calculated with a Weighted Average



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CALVERT CLIFFS 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-01	02/28/84	F	0.0	B	5		CB	PUMPXX	ISOLATION OF AN INSTRUMENT LINE OF 22A REACTOR COOLANT PUMP SEAL. NO. 2 UNIT EXPERIENCED LOAD REDUCTION AT VARIOUS LOADS DUE TO MOISTURE SEPARATOR REHEATER TUBE LEAKS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 CALVERT CLIFFS 2 OPERATED WITH 1 REDUCTION FOR MAINTENANCE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CALVERT CLIFFS 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MARYLAND  
COUNTY.....CALVERT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI S OF  
ANNAPOLIS, MD  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 30, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 7, 1976  
DATE COMMERCIAL OPERATE....APRIL 1, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....CHESAPEAKE BAY  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BALTIMORE GAS & ELEC  
CORPORATE ADDRESS.....P.O. BOX 1475  
BALTIMORE, MARYLAND 21203  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. ARCHITZEL  
LICENSING PROJ MANAGER.....D. JAFFE  
DOCKET NUMBER.....50-318  
LICENSE & DATE ISSUANCE....DPR-69, NOVEMBER 30, 1976  
PUBLIC DOCUMENT ROOM.....CALVERT COUNTY LIBRARY  
FOURTH STREET  
PRINCE FREDERICK, MARYLAND 20678

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            CALVERT CLIFFS 2            \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-315 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: W. T. GILLET (616) 465-5901

4. Licensed Thermal Power (MWt): 3250

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1030

7. Maximum Dependable Capacity (Gross MWe): 1056

8. Maximum Dependable Capacity (Net MWe): 1020

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>80,328.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,263.1</u>	<u>58,881.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>463.0</u>
15. Hrs Generator On-Line	<u>689.0</u>	<u>1,248.9</u>	<u>57,592.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>321.0</u>
17. Gross Therm Ener (MWH)	<u>1,940,152</u>	<u>3,683,162</u>	<u>167,764,776</u>
18. Gross Elec Ener (MWH)	<u>637,460</u>	<u>1,212,690</u>	<u>55,138,980</u>
19. Net Elec Ener (MWH)	<u>612,157</u>	<u>1,166,630</u>	<u>53,046,970</u>
20. Unit Service Factor	<u>99.0</u>	<u>86.7</u>	<u>73.6</u>
21. Unit Avail Factor	<u>99.0</u>	<u>86.7</u>	<u>73.6</u>
22. Unit Cap Factor (MDC Net)	<u>86.2</u>	<u>79.4</u>	<u>66.5</u>
23. Unit Cap Factor (DER Net)	<u>85.4</u>	<u>78.7</u>	<u>63.6</u>
24. Unit Forced Outage Rate	<u>1.0</u>	<u>13.3</u>	<u>7.9</u>
25. Forced Outage Hours	<u>7.0</u>	<u>191.1</u>	<u>4,271.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* COOK 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
212	02/01/84	F	0.0	A	5		CH	PUMPXX	A POWER INCREASE FROM 79% TO 99% WAS IN PROGRESS WHEN AT 93% THE WEST MAIN FEED PUMP, MFP, DEVELOPED A VIBRATION PROBLEM. A POWER REDUCTION TO 59% WAS STARTED IMMEDIATELY TO REMOVE THE WEST MFP FROM SERVICE.
213	02/06/84	F	7.0	A	1		CH	HTEXCH	WHILE THE WEST MFP WAS STILL OUT OF SERVICE, THE EAST MFP TURBINE CONDENSER DEVELOPED A CONDENSER TUBE LEAK. TO EFFECT REPAIRS, THE UNIT HAD TO BE REMOVED FROM SERVICE. THE REACTOR WAS MAINTAINED CRITICAL AT 6% POWER. ONE LEAKING TUBE WAS IDENTIFIED AND PLUGGED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 COOK 1 OPERATED WITH 1 REDUCTION AND 1 OUTAGE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* COOK 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI S OF  
BENTON HARBOR, MI  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 18, 1975  
DATE ELEC ENER 1ST GENER...FEBRUARY 10, 1975  
DATE COMMERCIAL OPERATE...AUGUST 27, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....INDIANA & MICHIGAN ELECTRIC  
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA  
COLUMBUS, OHIO 43216  
CONTRACTOR  
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....AMERICAN ELEC. POWER SERVICE CORP.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....E. SWANSON  
LICENSING PROJ MANAGER.....D. WIGGINTON  
DOCKET NUMBER.....50-315  
LICENSE & DATE ISSUANCE...DPR-58, OCTOBER 25, 1974  
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY  
500 MARKET STREET  
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 11, THROUGH JANUARY 20, (83-21): ROUTINE UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; AND OPERATING ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 180 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 34 INSPECTOR-HOURS OFF-SHIFTS. OF THE SIX AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO SUBMIT A SPECIAL REPORT).

INSPECTION ON JANUARY 23-27, (84-01): ROUTINE, ANNOUNCED INSPECTION OF THE DONALD C. COOK NUCLEAR PLANT EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY SIX NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION INVOLVED 116 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS AND THREE CONSULTANTS. NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED.

MANAGEMENT MEETING ON JANUARY 31, (84-03): THE PROGRESS AND STATUS OF THE LICENSEE'S REGULATORY PERFORMANCE IMPROVEMENT PROGRAM. THE MEETING INVOLVED A TOTAL OF 16 MAN-HOURS BY 8 NRC PERSONNEL.

INSPECTION ON FEBRUARY 7, (84-04): REVIEW OF DOCUMENTATION AND WALK-DOWNS PERTAINING TO EQUIPMENT REFERRED TO IN INFORMATION LETTER 81-14 DATED FEBRUARY 10, 1981. THE INSPECTION UTILIZED A TOTAL OF 16 HRS ONSITE BY TWO NRC INSPECTORS. BASED UPON THIS REVIEW AND THE ASSOCIATED WALK-DOWNS OF THE AREAS AFFECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 6.5.2.7.E REQUIRES THE NUCLEAR SAFETY AND DESIGN REVIEW COMMITTEE (NSDRC) TO REVIEW "VIOLATIONS OF CODES, REGULATIONS, ORDERS, TECHNICAL SPECIFICATIONS, LICENSE REQUIREMENTS, OR INTERNAL PROCEDURES OR INSTRUCTIONS HAVING NUCLEAR SAFETY SIGNIFICANCE." CONTRARY TO THE ABOVE, THE REVIEWS PERFORMED BY THE NSDRC DID NOT INCLUDE ALL NRC INSPECTION FINDINGS, QA AUDIT FINDINGS, AND SIGNIFICANT NON-REPORTABLE CONDITION REPORTS WHICH INVOLVED VIOLATIONS OF TECHNICAL SPECIFICATIONS OR INTERNAL PROCEDURES HAVING NUCLEAR SAFETY SIGNIFICANCE. EXAMPLES OF NRC INSPECTION FINDINGS NOT REVIEWED BY THE NSDRC INCLUDED: (A) NONCOMPLIANCE IDENTIFIED IN NRC INSPECTION REPORT 315/81-08; 316/81-12 REGARDING ADHERENCE TO PROCEDURES GOVERNING QA DOCUMENTATION OF MATERIAL; (B) NONCOMPLIANCE REGARDING VIOLATION OF THE LIMITING CONDITION FOR OPERATION ON SPRAY ADDITIVE TANKS IDENTIFIED IN NRC INSPECTION REPORT 315/81-05; 316/81-05; (C) THREE SECURITY RELATED VIOLATIONS IDENTIFIED IN NRC INSPECTION REPORT 315/81-04; 316/81-04; AND (D) VIOLATIONS DESCRIBED IN PARAGRAPHS 5 AND 7 OF NRC INSPECTION REPORT 315/81-09, 316/81-13 REGARDING THE PERFORMANCE OF SURVEILLANCES AND ADHERENCE TO PROCEDURES.

10 CFR 50, APPENDIX B, CRITERION II, REQUIRES REGULAR REVIEWS OF THE STATUS AND ADEQUACY OF THE QUALITY ASSURANCE PROGRAM. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.2.2, REQUIRES THAT THE NSDRC REGULARLY ASSESS THE SCOPE, IMPLEMENTATION, AND EFFECTIVENESS OF THE QA PROGRAM TO COMPLY WITH 10 CFR 50, APPENDIX B, CRITERIA. ANSI N18.7-1976, PARAGRAPH 4.5, STATES IN PART, "PERIODIC REVIEW OF THE AUDIT PROGRAM SHALL BE PERFORMED BY THE INDEPENDENT REVIEW BODY OR BY A MANAGEMENT REPRESENTATIVE AT LEAST SEMIANNUALLY TO ASSURE THAT AUDITS ARE BEING ACCOMPLISHED IN ACCORDANCE WITH REQUIREMENTS OF TECHNICAL SPECIFICATIONS AND OF THIS STANDARD." CONTRARY TO THE ABOVE, THE NSDRC DID NOT PERIODICALLY REVIEW THE AUDIT PROGRAM, AUDIT REPORTS, AND AUDIT RESULTS IN ORDER TO ASSESS THE SCOPE, IMPLEMENTATION, AND EFFECTIVENESS OF THE QA PROGRAM. TECHNICAL SPECIFICATION 6.5.2.7.I REQUIRES THE NSDRC TO REVIEW THE "REPORTS AND MEETING MINUTES OF THE PNSRC." CONTRARY TO THE ABOVE, THE PLANT NUCLEAR SAFETY REVIEW COMMITTEE (PNSRC) REPORTS AND MINUTES WERE NOT REVIEWED BY THE NSDRC. TECHNICAL SPECIFICATION 6.5.2.8.A REQUIRES AN AUDIT UNDER THE COGNIZANCE OF THE NSDRC OF "THE CONFORMANCE OF FACILITY OPERATION TO PROVISIONS CONTAINED WITHIN THE TECHNICAL SPECIFICATION AND APPLICABLE LICENSE CONDITIONS AT LEAST ONCE PER 12 MONTHS." CONTRARY TO THE ABOVE, NSDRC AUDITS FAILED TO EXAMINE THE TECHNICAL SPECIFICATION LIMITING CONDITIONS FOR OPERATION OR THE NSDRC ACTIVITIES. 10 CFR 50, APPENDIX B, CRITERION XVIII, REQUIRES AUDITS TO DETERMINE THE EFFECTIVENESS OF THE LICENSEE'S QA PROGRAM. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.7.4.18, REQUIRES THAT THE NSDRC CONDUCT PERIODIC AUDITS OF PLANT OPERATIONS PURSUANT TO ESTABLISHED CRITERIA. ANSI N45.2.12-1977, TO WHICH THE LICENSEE IS COMMITTED, REQUIRES IN PARAGRAPH 4.4.4 THAT EACH AUDIT REPORT INCLUDE A SUMMARY OF RESULTS WHICH INCLUDES "AN EVALUATION STATEMENT REGARDING THE EFFECTIVENESS OF THE QUALITY ASSURANCE PROGRAM ELEMENTS WHICH WERE AUDITED." CONTRARY TO THE ABOVE, MOST OF THE NSDRC AUDIT REPORTS FOR AUDITS CONDUCTED OVER THE LAST SEVERAL YEARS CONTAINED NO EVALUATION STATEMENTS. 10 CFR 50, APPENDIX B, CRITERION V, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED INSTRUCTIONS, PROCEDURES, OR DRAWINGS OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES. CRITERION XVI REQUIRES THAT MEASURES BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY ARE PROMPTLY IDENTIFIED AND CORRECTED. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTIONS 1.7.4.5 AND 1.7.4.16, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE CONDUCTED AS DIRECTED BY APPROPRIATE INSTRUCTIONS, PROCEDURES, OR DRAWINGS AND THAT CONDITIONS ADVERSE TO QUALITY BE REPORTED TO MANAGEMENT. ANSI N45.2.12-1977, PARAGRAPH 4.5.1, REQUIRES THAT "THE RESPONSE SHALL CLEARLY STATE THE CORRECTIVE ACTION TAKEN OR PLANNED TO PREVENT RECURRENCE. IN THE EVENT THAT CORRECTIVE ACTION CANNOT BE COMPLETED WITHIN THIRTY DAYS, THE AUDITED ORGANIZATION'S RESPONSE SHALL INCLUDE A SCHEDULED DATE FOR THE CORRECTIVE ACTION." CONTRARY TO THE ABOVE, THE LICENSEE'S NSDRC AUDIT PROCEDURE WAS INADEQUATE IN THAT IT ALLOWED A RESPONSE TIME OF 45 DAYS AFTER A CORRECTIVE ACTION REQUEST WAS ISSUED AND THE AUDIT COVER SHEET WAS INADEQUATE IN THAT IT ALLOWED 46 DAYS, RATHER THAN THE REQUIRED 30 DAYS. ADDITIONALLY, THERE WERE NUMEROUS EXAMPLES OF LATE RESPONSES TO CARS. (AUDIT 74 ON STAFF PERFORMANCE, QUALIFICATIONS, AND TRAINING, JULY 1981, CONTAINED FOUR CARS, NONE OF WHICH WERE RESPONDED TO IN LESS THAN 70 DAYS.) TECHNICAL SPECIFICATION 6.5.2.8.D REQUIRES AUDITS OF THE "PERFORMANCE OF ACTIVITIES REQUIRED BY THE QUALITY ASSURANCE PROGRAM TO MEET THE CRITERIA OF APPENDIX B OF 10 CFR 50..." CONTRARY TO THE ABOVE, NSDRC AUDITS WERE INSUFFICIENT AND FAILED TO EXAMINE ANY OF THE CORPORATE OFFICE ACTIVITIES RELATED TO APPENDIX B REQUIREMENTS. 10 CFR 50, APPENDIX B, CRITERION III, REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR DESIGN VERIFICATION, PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF THE DESIGN, AND THAT DESIGN CHANGES SHALL BE SUBJECT TO DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.7.4.3, REQUIRES THAT MODIFICATIONS TO THE PLANT ARE CONTROLLED TO ASSURE COMPLIANCE WITH THE EXISTING DESIGN. ANSI N45.2.11-1974, TO WHICH THE LICENSEE IS COMMITTED, REQUIRES THAT DESIGN CONTROL MEASURES BE ESTABLISHED, THAT DESIGN VERIFICATIONS BE CLEARLY DOCUMENTED WITH THE IDENTIFICATION OF THE VEHICLE CLEARLY INDICATED, AND THAT DOCUMENTATION OF THE VERIFICATION RESULTS BE AUDITABLE AGAINST THE VERIFICATION METHODS IDENTIFIED BY THE RESPONSIBLE DESIGN ORGANIZATION. THE STANDARD DEFINES SUPERVISORY TECHNICAL REVIEW AS NOT SATISFYING THE DESIGN

ENFORCEMENT SUMMARY

VERIFICATION REQUIREMENT. CONTRARY TO THE ABOVE: (A) THE LICENSEE'S PROCEDURES FOR DESIGN CONTROL WERE INADEQUATE AS EVIDENCED BY: MECHANICAL ENGINEERING DESIGN PROCEDURE NO. 10, "DESIGN CONTROL", REVISION 1, REFERENCED G-P-25 WHICH ALLOWED DESIGN VERIFICATION BY THE DISCIPLINE ENGINEER'S SECTION MANAGER FOR AEPSC PERFORMED MECHANICAL DESIGN ACTIVITIES, ELECTRICAL GENERATION - ELECTRICAL ENGINEERING PROCEDURE MANUAL, "RFC PROCEDURE", DATED MAY 22, 1981, REFERENCED GP-25 WHICH ALLOWED DESIGN VERIFICATION BY THE DISCIPLINE ENGINEERS SECTION MANAGER FOR AEPSC PERFORMED ELECTRICAL DESIGN ACTIVITIES, GP-25, "DESIGN CHANGES", REVISIONS 0 AND 1, ALLOWED DESIGN VERIFICATION BY THE DISCIPLINE ENGINEER'S SECTION MANAGER FOR ALL AEPSC PERFORMED DESIGN ACTIVITIES, AND (B) DESIGN VERIFICATIONS FOR THE FOLLOWING EMERGENCY REQUESTS FOR CHANGES (RFCs) WERE INADEQUATE: RFC 12-1803 HAD NO DOCUMENTED DESIGN VERIFICATION, AND RFC 02-1885 CONTAINED A SKETCH THAT HAD BEEN INITIALED "OK", WHICH WAS THE EXTENT OF DESIGN VERIFICATION. (8318 4)

TS 6.5.2.10.C REQUIRES THAT AUDIT REPORTS BE FORWARDED TO THE SENIOR EXECUTIVE VICE PRESIDENT WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT. ANSI N.45.2.12-1977, PARAGRAPH 4.4, REQUIRES THE AUDIT REPORT TO BE ISSUED WITHIN THIRTY DAYS AFTER THE POST-AUDIT CONFERENCE. THE NSDRC PROCEDURE REQUIRED THAT "THE COMPLETED AUDIT CHECKLIST (THE LICENSEE'S DETAILED REPORT), OTHER AUDIT DOCUMENTATION VERIFYING COMPLIANCE, AND COPIES OF ALL ISSUED CARS... BE DISTRIBUTED WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT." CONTRARY TO THE ABOVE, AUDIT REPORTS EXAMINED FOR THE LAST FOUR AND ONE-HALF YEARS REVEALED THAT THE AUDIT REPORTS HAD SELDOM BEEN ISSUED OR FORWARDED TO THE SENIOR EXECUTIVE VICE PRESIDENT WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT. TECHNICAL SPECIFICATION 6.5.2.7.A REQUIRES THAT THE NSDRC REVIEW SAFETY EVALUATIONS FOR CHANGES TO EQUIPMENT OR SYSTEMS. GP-25 "DESIGN CHANGES", REVISION 0, TEMPORARY CHANGE NO. 3 TO GP-25, REVISION 0, AND PMI-5040, "DESIGN CHANGES", REVISION 4, DESCRIBED THE PROCESSING OF RFCs, INCLUDING THE PREPARATION OF A SAFETY EVALUATION WHICH WAS SUBSEQUENTLY TO BE REVIEWED BY THE NSDRC IN ACCORDANCE WITH TS 6.5.2.7.A. CONTRARY TO THE ABOVE, SAFETY EVALUATIONS WERE REVIEWED AT THE SUBCOMMITTEE LEVEL WITHOUT REVIEW AND APPROVAL BY THE FULL NSDRC. (8318 5)

UNITS 1 AND 2 TECHNICAL SPECIFICATION 3.11.2.5 SPECIFIES LIMITS ON EXPLOSIVE GAS MIXTURES IN THE WASTE GAS HOLDUP SYSTEM. ACTION ITEM B. SPECIFIES: "WITH THE CONCENTRATION OF OXYGEN IN THE WASTE GAS HOLDUP SYSTEM OR TANK GREATER THAN 4% BY VOLUME AND GREATER THAN 4% HYDROGEN BY VOLUME WITHOUT DELAY SUSPEND ALL ADDITIONS OF WASTE GASES TO THE SYSTEM OR TANK AND REDUCE THE CONCENTRATION OF OXYGEN TO LESS THAN OR EQUAL TO 3% OR THE CONCENTRATION OF HYDROGEN TO LESS THAN OR EQUAL TO 4% WITHIN 96 HOURS IN THE SYSTEM OR TANK." CONTRARY TO THE ABOVE, ON NOVEMBER 3, 1983 AT 1400 HOURS, SAMPLES OF THE NO. 3 GAS DECAY TANK SHOWED GREATER THAN 4% BY VOLUME OF BOTH OXYGEN AND HYDROGEN, AND THE TANK WAS NOT ISOLATED UNTIL 0615 HOURS ON NOVEMBER 4, 1983.

UNIT 1 TECHNICAL SPECIFICATION 3.6.5.6 REQUIRES TWO INDEPENDENT CONTAINMENT AIR RECIRCULATION SYSTEMS BE OPERABLE IN MODES 1, 2, 3, AND 4. TECHNICAL SPECIFICATION 3.0.4 REQUIRES THAT ENTRY INTO AN OPERATIONAL MODE OR OTHER SPECIFIED APPLICABILITY CONDITION SHALL NOT BE MADE UNLESS THE CONDITIONS OF THE LIMITING CONDITION FOR OPERATION ARE MET WITHOUT RELIANCE ON PROVISIONS CONTAINED IN THE ACTION STATEMENT UNLESS OTHERWISE EXCEPTED. CONTRARY TO THE ABOVE, ON MARCH 2, 1982 AT 0447 HOURS, UNIT 1 ENTERED MODE 4 (FROM MODE 5) WITH ONE OF TWO CONTAINMENT AIR RECIRCULATION SYSTEMS INOPERABLE. THE SYSTEM WAS INOPERABLE BECAUSE A CONTROL SWITCH WAS IN THE STOP POSITION WHICH WOULD HAVE PREVENTED AUTOMATIC ACTUATION OF THE SYSTEM. 10 CFR 50 APPENDIX B, CRITERION XVI "CORRECTIVE ACTION" STATES IN PART: "...MEASURES SHALL ASSURE THAT THE CAUSE OF THE CONDITION IS DETERMINED AND CORRECTIVE ACTION TAKEN TO PRECLUDE REPETITION..." AEPSC GENERAL PROCEDURE 2.2; NONCONFORMANCE/NONCOMPLIANCE AND CORRECTIVE ACTION, SECTION 4.2.1 STATES: "CONDITIONS ADVERSE TO QUALITY (SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT, AND NONCONFORMANCES) SHALL BE PROMPTLY IDENTIFIED, AS SOON AS PRACTICAL, BY MEASURES WHICH ARE ESTABLISHED AND DOCUMENTED." SECTION 4.2.4 STATES: "MEASURES SHALL BE ESTABLISHED TO INCLUDE FOLLOWUP ACTIONS FOR CORRECTIVE ACTION THAT CANNOT BE IMMEDIATELY COMPLETED TO ASSURE; TIMELY RESOLUTION, AND/OR COMPLETION OF THE PLANNED CORRECTIVE ACTION ACTIVITY." PMI-7030, CONDITION REPORTS, STATES IN PART: "IT IS A REQUIREMENT FOR THE SAFE AND EFFICIENT OPERATION OF THE PLANT THAT AS SOMETHING IS KNOWN OR SUSPECTED TO BE NONCOMPLIANT...OR INCONSISTENT WITH THE DESIGN OF PHYSICAL COMPONENTS, SYSTEMS AND STRUCTURES, THAT THE CONDITION BE PROMPTLY IDENTIFIED, AND RESOLVED THROUGH THE USE OF A CONDITION REPORT." CONTRARY TO THE ABOVE, IN A LETTER DATED DECEMBER 7, 1981, THE LICENSEE STATED THAT THE ROOT CAUSE FOR THE DISCREPANCY BETWEEN THE CONTAINMENT VENTILATION ISOLATION SYSTEM CONSTRUCTION AND THE WAY IT WAS FUNCTIONALLY UNDERSTOOD TO WORK ON BOTH UNITS (AS REFLECTED IN THE TECHNICAL SPECIFICATIONS AND CORRESPONDENCE TO THE NRC) WAS DUE TO THE USE OF INCORRECT FUNCTIONAL LOGIC DIAGRAMS. NEITHER A NONCONFORMANCE REPORT OR A CONDITION REPORT WAS ISSUED. THE LOGIC DIAGRAMS HAVE NOT BEEN CORRECTED AND ARE STILL IN USE. NONE OF THE LICENSEE'S CORRECTIVE ACTION SYSTEMS WERE EFFECTIVE IN ENSURING THE TIMELY RESOLUTION OF THE DISCREPANT DRAWINGS. TECHNICAL SPECIFICATION 6.5.2.7.E



ENFORCEMENT SUMMARY

REQUIRES THE NUCLEAR SAFETY AND DESIGN REVIEW COMMITTEE (NSDRC) TO REVIEW "VIOLATIONS OF CODES, REGULATIONS, ORDERS, TECHNICAL SPECIFICATIONS, LICENSEE REQUIREMENTS, OR INTERNAL PROCEDURES OR INSTRUCTIONS HAVING NUCLEAR SAFETY SIGNIFICANCE." CONTRARY TO THE ABOVE, THE REVIEWS PERFORMED BY THE NSDRC DID NOT INCLUDE ALL NRC INSPECTION FINDINGS, QA AUDIT FINDINGS, AND SIGNIFICANT NON-REPORTABLE CONDITION REPORTS WHICH INVOLVED VIOLATIONS OF TECHNICAL SPECIFICATIONS OR INTERNAL PROCEDURES HAVING NUCLEAR SAFETY SIGNIFICANCE. EXAMPLES OF NRC INSPECTION FINDINGS NOT REVIEWED BY THE NSDRC INCLUDED: (A) NONCOMPLIANCE IDENTIFIED IN NRC INSPECTION REPORT 315/81-08; 316/81-12 REGARDING ADHERENCE TO PROCEDURES GOVERNING QA DOCUMENTATION OF MATERIAL; (B) NONCOMPLIANCE REGARDING VIOLATION OF THE LIMITING CONDITION FOR OPERATION ON SPRAY ADDITIVE TANKS IDENTIFIED IN NRC INSPECTION REPORT 315/81-05; 316/81-05; (C) THREE SECURITY RELATED VIOLATIONS IDENTIFIED IN NRC INSPECTION REPORT 315/81-04; 316/81-04; AND (D) VIOLATIONS DESCRIBED IN PARAGRAPHS 5 AND 7 OF NRC INSPECTION REPORT 315/81-09; 316/81-13 REGARDING THE PERFORMANCE OF SURVEILLANCES AND ADHERENCE TO PROCEDURES.

10 CFR 50, APPENDIX B, CRITERION II, REQUIRES REGULAR REVIEWS OF THE STATUS AND ADEQUACY OF THE QUALITY ASSURANCE PROGRAM. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.2.2, REQUIRES THAT THE NSDRC REGULARLY ASSESS THE SCOPE, IMPLEMENTATION, AND EFFECTIVENESS OF THE QA PROGRAM TO COMPLY WITH 10 CFR 50, APPENDIX B, CRITERIA. ANSI N18.7-1976, PARAGRAPH 4.5, STATES IN PART, "PERIODIC REVIEW OF THE AUDIT PROGRAM SHALL BE PERFORMED BY THE INDEPENDENT REVIEW BODY OR BY A MANAGEMENT REPRESENTATIVE AT LEAST SEMIANNUALLY TO ASSURE THAT AUDITS ARE BEING ACCOMPLISHED IN ACCORDANCE WITH REQUIREMENTS OF TECHNICAL SPECIFICATIONS AND OF THIS STANDARD." CONTRARY TO THE ABOVE, THE NSDRC DID NOT PERIODICALLY REVIEW THE AUDIT PROGRAM, AUDIT REPORTS, AND AUDIT RESULTS IN ORDER TO ASSESS THE SCOPE, IMPLEMENTATION, AND EFFECTIVENESS OF THE QA PROGRAM. TECHNICAL SPECIFICATION 6.5.2.7.I REQUIRES THE NSDRC TO REVIEW THE "REPORTS AND MEETING MINUTES OF THE PNSRC." CONTRARY TO THE ABOVE, THE PLANT NUCLEAR SAFETY REVIEW COMMITTEE (PNSRC) REPORTS AND MINUTES WERE NOT REVIEWED BY THE NSDRC. TECHNICAL SPECIFICATION 6.5.2.8.A REQUIRES AN AUDIT UNDER THE COGNIZANCE OF THE NSDRC OF "THE CONFORMANCE OF FACILITY OPERATION TO PROVISIONS CONTAINED WITHIN THE TECHNICAL SPECIFICATION AND APPLICABLE LICENSE CONDITIONS AT LEAST ONCE PER 12 MONTHS." CONTRARY TO THE ABOVE, NSDRC AUDITS FAILED TO EXAMINE THE TECHNICAL SPECIFICATION LIMITING CONDITIONS FOR OPERATION OR THE NSDRC ACTIVITIES. 10 CFR 50, APPENDIX B, CRITERION XVIII, REQUIRES AUDITS TO DETERMINE THE EFFECTIVENESS OF THE LICENSEE'S QA PROGRAM. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.7.4.18, REQUIRES THAT THE NSDRC CONDUCT PERIODIC AUDITS OF PLANT OPERATIONS PURSUANT TO ESTABLISHED CRITERIA. ANSI N45.2.12-1977, TO WHICH THE LICENSEE IS COMMITTED, REQUIRES IN PARAGRAPH 4.4.4 THAT EACH AUDIT REPORT INCLUDE A SUMMARY OF RESULTS WHICH INCLUDES "AN EVALUATION STATEMENT REGARDING THE EFFECTIVENESS OF THE QUALITY ASSURANCE PROGRAM ELEMENTS WHICH WERE AUDITED." CONTRARY TO THE ABOVE, MOST OF THE NSDRC AUDIT REPORTS FOR AUDITS CONDUCTED OVER THE LAST SEVERAL YEARS CONTAINED NO EVALUATION STATEMENTS. 10 CFR 50, APPENDIX B, CRITERION V, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE ACCOMPLISHED IN ACCORDANCE WITH DOCUMENTED INSTRUCTIONS, PROCEDURES, OR DRAWINGS OF A TYPE APPROPRIATE TO THE CIRCUMSTANCES. CRITERION XVI REQUIRES THAT MEASURES BE ESTABLISHED TO ASSURE THAT CONDITIONS ADVERSE TO QUALITY ARE PROMPTLY IDENTIFIED AND CORRECTED. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTIONS 1.7.4.5 AND 1.7.4.16, REQUIRES THAT ACTIVITIES AFFECTING QUALITY BE CONDUCTED AS DIRECTED BY APPROPRIATE INSTRUCTIONS, PROCEDURES, OR DRAWINGS AND THAT CONDITIONS ADVERSE TO QUALITY BE REPORTED TO MANAGEMENT. ANSI N45.2.12-1977, PARAGRAPH 4.5.1, REQUIRES THAT "THE RESPONSE SHALL CLEARLY STATE THE CORRECTIVE ACTION TAKEN OR PLANNED TO PREVENT RECURRENCE. IN THE EVENT THAT CORRECTIVE ACTION CANNOT BE COMPLETED WITHIN THIRTY DAYS, THE AUDITED ORGANIZATION'S RESPONSE SHALL INCLUDE A SCHEDULED DATE FOR THE CORRECTIVE ACTION." CONTRARY TO THE ABOVE, THE LICENSEE'S NSDRC AUDIT PROCEDURE WAS INADEQUATE IN THAT IT ALLOWED A RESPONSE TIME OF 45 DAYS AFTER A CORRECTIVE ACTION REQUEST WAS ISSUED AND THE AUDIT COVER SHEET WAS INADEQUATE IN THAT IT ALLOWED 46 DAYS, RATHER THAN THE REQUIRED 30 DAYS. ADDITIONALLY, THERE WERE NUMEROUS EXAMPLES OF LATE RESPONSES TO CARs. (AUDIT 74 ON STAFF PERFORMANCE, QUALIFICATIONS, AND TRAINING, JULY 1981, CONTAINED FOUR CARs, NONE OF WHICH WERE RESPONDED TO IN LESS THAN 70 DAYS.) TECHNICAL SPECIFICATION 6.5.2.8.D REQUIRES AUDITS OF THE "PERFORMANCE OF ACTIVITIES REQUIRED BY THE QUALITY ASSURANCE PROGRAM TO MEET THE CRITERIA OF APPENDIX B OF 10 CFR 50..." CONTRARY TO THE ABOVE, NSDRC AUDITS WERE INSUFFICIENT AND FAILED TO EXAMINE ANY OF THE CORPORATE OFFICE ACTIVITIES RELATED TO APPENDIX B REQUIREMENTS. 10 CFR 50, APPENDIX B, CRITERION III, REQUIRES THAT DESIGN CONTROL MEASURES SHALL PROVIDE FOR DESIGN VERIFICATION, PROVIDE FOR VERIFYING OR CHECKING THE ADEQUACY OF THE DESIGN, AND THAT DESIGN CHANGES SHALL BE SUBJECT TO DESIGN CONTROL MEASURES COMMENSURATE WITH THOSE APPLIED TO THE ORIGINAL DESIGN. THE QA PROGRAM FOR THE DONALD C. COOK NUCLEAR PLANT, SECTION 1.7.4.3, REQUIRES THAT MODIFICATIONS TO THE PLANT ARE CONTROLLED TO ASSURE COMPLIANCE WITH THE EXISTING DESIGN. ANSI N45.2.11-1974, TO WHICH THE LICENSEE IS COMMITTED, REQUIRES THAT DESIGN CONTROL MEASURES BE ESTABLISHED, THAT DESIGN VERIFICATIONS BE CLEARLY DOCUMENTED WITH THE IDENTIFICATION OF THE VEHICLE CLEARLY INDICATED, AND THAT DOCUMENTATION OF THE VERIFICATION RESULTS BE AUDITABLE AGAINST THE VERIFICATION METHODS IDENTIFIED BY THE RESPONSIBLE DESIGN ORGANIZATION. THE STANDARD DEFINES SUPERVISORY TECHNICAL REVIEW AS NOT SATISFYING THE DESIGN VERIFICATION REQUIREMENT. CONTRARY TO THE ABOVE: (A) THE LICENSEE'S PROCEDURES FOR DESIGN CONTROL WERE INADEQUATE AS EVIDENCED



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-316                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: W. T. GILLET (616) 465-5901

4. Licensed Thermal Power (MWt):                    3411

5. Nameplate Rating (Gross MWe):                    1333 X 0.85 = 1133

6. Design Electrical Rating (Net MWe):                    1100

7. Maximum Dependable Capacity (Gross MWe):                    1100

8. Maximum Dependable Capacity (Net MWe):                    1060

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>54,024.0</u>
13. Hours Reactor Critical	<u>672.2</u>	<u>1,416.2</u>	<u>39,201.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>663.9</u>	<u>1,407.9</u>	<u>38,208.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,235,476</u>	<u>4,671,207</u>	<u>123,124,175</u>
18. Gross Elec Ener (MWH)	<u>738,120</u>	<u>1,548,680</u>	<u>39,775,110</u>
19. Net Elec Ener (MWH)	<u>713,057</u>	<u>1,495,371</u>	<u>38,348,724</u>
20. Unit Service Factor	<u>95.4</u>	<u>97.8</u>	<u>74.0</u>
21. Unit Avail Factor	<u>95.4</u>	<u>97.8</u>	<u>76.0</u>
22. Unit Cap Factor (MDC Net)	<u>96.7</u>	<u>98.0</u>	<u>70.7</u>
23. Unit Cap Factor (DER Net)	<u>93.1</u>	<u>94.4</u>	<u>69.5</u>
24. Unit Forced Outage Rate	<u>4.6</u>	<u>2.2</u>	<u>13.5</u>
25. Forced Outage Hours	<u>32.1</u>	<u>32.1</u>	<u>5,883.0</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE-3/9/84 - 90 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \*                    COOK 2                    \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOK 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* COOK 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
146	02/18/84	F	32.1	G	3	84-002	HJ	ZZZZZZ	THE UNIT TRIPPED DUE TO AN APPARENT HIGH WATER LEVEL IN ONE OF THE MOISTURE SEPARATOR REHEATER, MSR, SHELLS. THE TRIP OCCURRED WHILE RECOVERING FROM AN AUTOMATIC ISOLATION OF THE MSR COILS DUE TO A CYCLE UPSET FOLLOWING TURBINE CONTROL VALVE TESTING. WHILE ATTEMPTING TO REPRESSURIZE THE MSR COILS AN OPERATING ERROR WAS COMMITTED WHICH RAPIDLY ADMITTED FULL PRESSURE MAIN STEAM TO THE SOUTH SET OF MSR COILS. IT IS BELIEVED THAT THIS CAUSED A VIBRATION THAT SHOOK THE MSR SHELL HIGH WATER LEVEL TRIP SWITCH WHICH RESULTED IN THE UNIT TRIP FROM A FALSE INDICATION OF HIGH LEVEL.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 COOK 2 OPERATED WITH 1 OUTAGE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* COOK 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
COUNTY.....BERRIEN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI S OF  
BENTON HARBOR, MI  
TYPE OF REACTOR.... PWR  
DATE INITIAL CRITICALITY...MARCH 10, 1978  
DATE ELEC ENER 1ST GENER...MARCH 22, 1978  
DATE COMMERCIAL OPERATE...JULY 1, 1978  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....INDIANA & MICHIGAN ELECTRIC  
CORPORATE ADDRESS.....1 RIVERSIDE PLAZA  
COLUMBUS, OHIO 43216  
CONTRACTOR  
ARCHITECT/ENGINEER.....AMERICAN ELEC. POWER SERVICE CORP.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....J. A. JONES CONSTRUCTION  
TURBINE SUPPLIER.....BROWN BOVERI

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....E. SWANSON  
LICENSING PROJ MANAGER.....D. WIGGINTON  
DOCKET NUMBER.....50-316  
LICENSE & DATE ISSUANCE...DPR-74, DECEMBER 23, 1977  
PUBLIC DOCUMENT ROOM.....MAUDE PRESTON PALENSKE MEMORIAL LIBRARY  
500 MARKET STREET  
ST. JOSEPH, MICHIGAN 49085

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 11, THROUGH JANUARY 20, (83-22): ROUTINE UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; AND OPERATING ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 180 INSPECTOR-HOURS BY TWO NRC INSPECTORS INCLUDING 34 INSPECTOR-HOURS OFF-SHIFTS. OF THE SIX AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO SUBMIT A SPECIAL REPORT).

INSPECTION ON JANUARY 23-27, (84-01): ROUTINE, ANNOUNCED INSPECTION OF THE DONALD C. COOK NUCLEAR PLANT EMERGENCY PREPAREDNESS EXERCISE INVOLVING OBSERVATIONS BY SIX NRC REPRESENTATIVES OF KEY FUNCTIONS AND LOCATIONS DURING THE EXERCISE. THE INSPECTION INVOLVED 116 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS AND THREE CONSULTANTS. NO ITEMS OF NONCOMPLIANCE, DEFICIENCIES, OR DEVIATIONS WERE IDENTIFIED.

MANAGEMENT MEETING ON JANUARY 31, (84-03): THE PROGRESS AND STATUS OF THE LICENSEE'S REGULATORY PERFORMANCE IMPROVEMENT PROGRAM. THE MEETING INVOLVED A TOTAL OF 16 MAN-HOURS BY 8 NRC PERSONNEL.

INSPECTION ON FEBRUARY 7, (84-04): REVIEW OF DOCUMENTATION AND WALK-DOWNS PERTAINING TO EQUIPMENT REFERRED TO IN INFORMATION LETTER 81-14 DATED FEBRUARY 10, 1981. THE INSPECTION UTILIZED A TOTAL OF 16 HRS ONSITE BY TWO NRC INSPECTORS. BASED UPON THIS REVIEW AND THE ASSOCIATED WALK-DOWNS OF THE AREAS AFFECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

TS 6.5.2.10.C REQUIRES THAT AUDIT REPORTS BE FORWARDED TO THE SENIOR EXECUTIVE VICE PRESIDENT WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT. ANSI N.45.2.12-1977, PARAGRAPH 4.4, REQUIRES THE AUDIT REPORT TO BE ISSUED WITHIN THIRTY DAYS AFTER THE POST-AUDIT CONFERENCE. THE NSDRC PROCEDURE REQUIRED THAT "THE COMPLETED AUDIT CHECKLIST (THE LICENSEE'S DETAILED REPORT), OTHER AUDIT DOCUMENTATION VERIFYING COMPLIANCE, AND COPIES OF ALL ISSUED CARDS...BE DISTRIBUTED WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT." CONTRARY TO THE ABOVE, AUDIT REPORTS EXAMINED FOR THE LAST FOUR AND ONE-HALF YEARS REVEALED THAT THE AUDIT REPORTS HAD SELDOM BEEN ISSUED OR FORWARDED TO THE SENIOR EXECUTIVE VICE PRESIDENT WITHIN 30 DAYS AFTER COMPLETION OF THE AUDIT. TECHNICAL SPECIFICATION 6.5.2.7.A REQUIRES THAT THE NSDRC REVIEW SAFETY EVALUATIONS FOR CHANGES TO EQUIPMENT OR SYSTEMS. GP-25 "DESIGN CHANGES", REVISION 0, TEMPORARY CHANGE NO. 3 TO GP-25, REVISION 0, AND PMI-5040, "DESIGN CHANGES", REVISION 4, DESCRIBED THE PROCESSING OF RFCS, INCLUDING THE PREPARATION OF A SAFETY EVALUATION WHICH WAS SUBSEQUENTLY TO BE REVIEWED BY THE NSDRC IN ACCORDANCE WITH TS 6.5.2.7.A. CONTRARY TO THE ABOVE, SAFETY EVALUATIONS WERE REVIEWED AT THE SUBCOMMITTEE LEVEL WITHOUT REVIEW AND APPROVAL BY THE FULL NSDRC.  
(8319 5)

UNITS 1 AND 2 TECHNICAL SPECIFICATION 3.11.2.5 SPECIFIES LIMITS ON EXPLOSIVE GAS MIXTURES IN THE WASTE GAS HOLDUP SYSTEM. ACTION ITEM B. SPECIFIES: "WITH THE CONCENTRATION OF OXYGEN IN THE WASTE GAS HOLDUP SYSTEM OR TANK GREATER THAN 4% BY VOLUME AND GREATER THAN 4% HYDROGEN BY VOLUME WITHOUT DELAY SUSPEND ALL ADDITIONS OF WASTE GASES TO THE SYSTEM OR TANK AND REDUCE THE CONCENTRATION OF OXYGEN TO LESS THAN OR EQUAL TO 3% OR THE CONCENTRATION OF HYDROGEN TO LESS THAN OR EQUAL TO 4% WITHIN 96 HOURS IN THE SYSTEM OR TANK." CONTRARY TO THE ABOVE, ON NOVEMBER 3, 1983 AT 1400 HOURS, SAMPLES OF THE NO. 3 GAS DECAY TANK SHOWED GREATER THAN 4% BY VOLUME OF BOTH OXYGEN AND HYDROGEN, AND THE TANK WAS NOT ISOLATED UNTIL 0615 HOURS ON NOVEMBER 4, 1983.

10 CFR 50 APPENDIX B, CRITERION XVI "CORRECTIVE ACTION" STATES IN PART: "...MEASURES SHALL ASSURE THAT THE CAUSE OF THE CONDITION IS DETERMINED AND CORRECTIVE ACTION TAKEN TO PRECLUDE REPETITION..." AEPSC GENERAL PROCEDURE 2.2; NONCONFORMANCE/NONCOMPLIANCE AND CORRECTIVE ACTION, SECTION 4.2.1 STATES: "CONDITIONS ADVERSE TO QUALITY (SUCH AS FAILURES, MALFUNCTIONS, DEFICIENCIES, DEVIATIONS, DEFECTIVE MATERIAL AND EQUIPMENT, AND NONCONFORMANCES) SHALL BE PROMPTLY IDENTIFIED, AS SOON AS PRACTICAL, BY MEASURES WHICH ARE ESTABLISHED AND DOCUMENTED." SECTION 4.2.4 STATES: "MEASURES SHALL BE ESTABLISHED TO INCLUDE FOLLOWUP ACTIONS FOR CORRECTIVE ACTION THAT CANNOT BE IMMEDIATELY COMPLETED TO ASSURE; TIMELY RESOLUTION, AND/OR COMPLETION OF THE PLANNED CORRECTIVE ACTION ACTIVITY." PMI-7030, CONDITION REPORTS, STATES IN PART: "IT IS A REQUIREMENT FOR THE SAFE AND EFFICIENT OPERATION OF THE PLANT THAT AS SOMETHING IS KNOWN OR SUSPECTED TO BE NONCOMPLIANT...OR INCONSISTENT WITH THE DESIGN OF PHYSICAL COMPONENTS, SYSTEMS AND STRUCTURES, THAT THE CONDITION BE PROMPTLY IDENTIFIED, AND RESOLVED THROUGH THE USE OF A CONDITION REPORT." CONTRARY TO THE ABOVE, IN A LETTER DATED DECEMBER 7, 1981, THE LICENSEE STATED THAT THE ROOT CAUSE FOR THE DISCREPANCY BETWEEN THE CONTAINMENT VENTILATION ISOLATION SYSTEM CONSTRUCTION AND THE WAY IT WAS FUNCTIONALLY UNDERSTOOD TO WORK ON BOTH UNITS (AS REFLECTED IN THE TECHNICAL SPECIFICATIONS AND CORRESPONDENCE TO THE NRC) WAS DUE TO THE USE OF INCORRECT FUNCTIONAL LOGIC DIAGRAMS. NEITHER A NONCONFORMANCE REPORT OR A CONDITION REPORT WAS ISSUED. THE LOGIC DIAGRAMS HAVE NOT BEEN CORRECTED AND ARE STILL IN USE. NONE OF THE LICENSEE'S CORRECTIVE ACTION SYSTEMS WERE EFFECTIVE IN ENSURING THE TIMELY RESOLUTION OF THE DISCREPANT DRAWINGS.  
(8320 4)

OTHER ITEMS

## SYSTEMS AND COMPONENT PROBLEMS:

NONE

## FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

## MANAGERIAL ITEMS:





THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-298 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: P. L. BALLINGER (402) 825-3811

4. Licensed Thermal Power (MWt): 2381

5. Nameplate Rating (Gross MWe): 983 X 0.85 = 836

6. Design Electrical Rating (Net MWe): 778

7. Maximum Dependable Capacity (Gross MWe): 787

8. Maximum Dependable Capacity (Net MWe): 764

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>84,745.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,414.0</u>	<u>68,417.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,396.6</u>	<u>67,314.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,459,992</u>	<u>2,838,504</u>	<u>133,351,662</u>
18. Gross Elec Ener (MWH)	<u>491,010</u>	<u>963,123</u>	<u>42,369,478</u>
19. Net Elec Ener (MWH)	<u>469,584</u>	<u>921,681</u>	<u>40,838,340</u>
20. Unit Service Factor	<u>100.0</u>	<u>97.0</u>	<u>79.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>97.0</u>	<u>79.4</u>
22. Unit Cap Factor (MDC Net)	<u>88.3</u>	<u>83.8</u>	<u>63.1</u>
23. Unit Cap Factor (DER Net)	<u>86.7</u>	<u>82.3</u>	<u>61.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>3.0</u>	<u>3.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>43.4</u>	<u>2,000.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MAINTENANCE, APRIL 7, 1984, 10 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

COOPER STATION



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

COOPER STATION OPERATED WITH NO REPORTED REDUCTIONS OR  
OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* COOPER STATION \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEBRASKA  
  
COUNTY.....NEMAHA  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...23 MI S OF  
NEBRASKA CITY, NEB  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...FEBRUARY 21, 1974  
DATE ELEC ENER 1ST GENER...MAY 10, 1974  
DATE COMMERCIAL OPERATE...JULY 1, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSOURI RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NEBRASKA PUBLIC POWER DISTRICT  
  
CORPORATE ADDRESS.....P.O. BOX 499  
COLUMBUS, NEBRASKA 68601  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BURNS & ROE  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....D. DUBOIS  
LICENSING PROJ MANAGER.....B. SIEGEL  
DOCKET NUMBER.....50-298  
  
LICENSE & DATE ISSUANCE...DPR-46, JANUARY 18, 1974  
  
PUBLIC DOCUMENT ROOM.....AUBURN PUBLIC LIBRARY  
1118 15TH STREET  
AUBURN, NEBRASKA 68305

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION CONDUCTED

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE



1. Docket: 50-302 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: D. BOGART (904) 795-6486

4. Licensed Thermal Power (MWt): 2544

5. Nameplate Rating (Gross MWe): 989 X 0.9 = 890

6. Design Electrical Rating (Net MWe): 825

7. Maximum Dependable Capacity (Gross MWe): 850

8. Maximum Dependable Capacity (Net MWe): 821

9. If Changes Occur Above Since Last Report, Give Reasons:  
MDC CHANGE BASED ON OPERATING EXPERIENCE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>61,080.0</u>
13. Hours Reactor Critical	<u>667.2</u>	<u>1,385.9</u>	<u>38,955.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,275.5</u>
15. Hrs Generator On-Line	<u>653.8</u>	<u>1,365.6</u>	<u>37,984.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,574,903</u>	<u>3,274,207</u>	<u>85,238,342</u>
18. Gross Elec Ener (MWH)	<u>549,204</u>	<u>1,142,975</u>	<u>29,069,711</u>
19. Net Elec Ener (MWH)	<u>523,896</u>	<u>1,090,241</u>	<u>27,607,324</u>
20. Unit Service Factor	<u>93.9</u>	<u>94.8</u>	<u>62.2</u>
21. Unit Avail Factor	<u>93.9</u>	<u>94.8</u>	<u>62.2</u>
22. Unit Cap Factor (MDC Net)	<u>91.7</u>	<u>92.2</u>	<u>55.1</u>
23. Unit Cap Factor (DER Net)	<u>91.2</u>	<u>91.8</u>	<u>54.8</u>
24. Unit Forced Outage Rate	<u>6.1</u>	<u>3.0</u>	<u>23.5</u>
25. Forced Outage Hours	<u>42.2</u>	<u>42.2</u>	<u>11,657.5</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

### CRYSTAL RIVER 3



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* CRYSTAL RIVER 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-06	02/01/84	F	0.0	A	5		CC	HTEXCH	POWER REDUCTION FORCED BY NECESSITY TO ISOLATE LEAKING MSR HIGH PRESSURE STEAM BUNDLE.
84-07	02/08/84	S	0.0	F	5		CC	INSTRU	REDUCED POWER TO REPAIR THE 'B' OTSG LEVEL TRANSMITTER.
84-08	02/20/84	F	32.0	B	1		CB	MOT@RX	SHUTDOWN TO INVESTIGATE OIL LEVEL ALARM ON THE 'C' RCP PUMP.
84-09	02/22/84	S	0.0	B	5		HC	HTEXCH	REDUCED POWER TO CLEAN CONDENSER TUBES.
84-10	02/27/84	S	0.0	B	5		HC	HTEXCH	REDUCED POWER TO APPLY EPOXY COATING TO 'A' CONDENSER TUBE SHEET TO PREVENT LEAKAGE.
84-11	02/28/84	F	10.2	H	3		EA	CKTBRK	LIGHTNING STRIKE CAUSED MOMENTARY LOSS OF OFF-SITE POWER AND SUBSEQUENT REACTOR SCRAM.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 CRYSTAL RIVER 3 OPERATED ROUTINELY DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* CRYSTAL RIVER 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....CITRUS  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NW OF  
CRYSTAL RIVER, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JANUARY 14, 1977  
DATE ELEC ENER 1ST GENER...JANUARY 30, 1977  
DATE COMMERCIAL OPERATE...MARCH 13, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...GULF OF MEXICO  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER CORPORATION  
CORPORATE ADDRESS.....3201 34TH STREET, SOUTH  
ST PETERSBURG, FLORIDA 33733  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....J. A. JONES CONSTRUCTION  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....T. STETKA  
LICENSING PROJ MANAGER.....R. HERNAN  
DOCKET NUMBER.....50-302  
LICENSE & DATE ISSUANCE....DPR-72, JANUARY 28, 1977  
PUBLIC DOCUMENT ROOM.....CRYSTAL RIVER PUBLIC LIBRARY  
668 N.W. FIRST  
CRYSTAL RIVER, FLORIDA 32639

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION JANUARY 30 - FEBRUARY 3 (84-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 34 INSPECTOR-HOURS ON SITE IN THE AREAS OF QUALITY ASSURANCE, TRAINING, POSTING AND LABELING, EXTERNAL EXPOSURE CONTROL, RADIATION PROTECTION PROCEDURES, PLANT TOURS, AND OUTAGE PREPLANNING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 3-30 (84-02): THIS ROUTINE INSPECTION INVOLVED 128 INSPECTOR-HOURS ON SITE BY ONE RESIDENT INSPECTOR IN THE AREAS OF PLANT OPERATIONS, SECURITY, RADIOLOGICAL CONTROLS, PLANT REVIEW COMMITTEE ACTIVITIES, LICENSEE EVENT REPORTS AND NONCONFORMING OPERATIONS REPORTS, AND LICENSEE ACTION ON PREVIOUS INSPECTION ITEMS. THIS INSPECTION ALSO DOCUMENTS UTILITY COMPLIANCE WITH THE LICENSED OPERATOR STAFFING RULE 10 CFR 50.54 (TMI ITEM I.A.1.3). NUMEROUS FACILITY TOURS WERE CONDUCTED AND FACILITY OPERATIONS OBSERVED. SOME OF THESE TOURS AND OBSERVATIONS WERE CONDUCTED ON BACK SHIFTS. TWO VIOLATIONS WERE IDENTIFIED (FAILURE TO FOLLOW RADIATION PROTECTION PROCEDURES; AND FAILURE TO MAINTAIN CALIBRATION OF INSTRUMENTATION).

ENFORCEMENT SUMMARY

CONTRARY TO TECHNICAL SPECIFICATION 6.11 RADIATION PROTECTION PROCEDURES WERE NOT ADHERED TO.  
(8402 4)

CONTRARY TO 10CFR50, APPENDIX B, CRITERION V AS IMPLEMENTED BY THE LICENSEE'S QUALITY ASSURANCE PROGRAM SECTION 1.7.1.5,



Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*            CRYSTAL RIVER 3            \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

UNCALIBRATED INSTRUMENTATION WAS UTILIZED IN THE PERFORMANCE OF QUALITY ACTIVITIES.

(8402 5)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATIONS.

LAST IE SITE INSPECTION DATE: JANUARY 3-30, 1984 +

INSPECTION REPORT NO: 50-302/84-02 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

O P E R A T I N G   S T A T U S

1. Docket: 50-346

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: BILAL SARSOUR (419) 259-5000 X384

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1069 X 0.9 = 962

6. Design Electrical Rating (Net MWe): 906

7. Maximum Dependable Capacity (Gross MWe): 918

8. Maximum Dependable Capacity (Net MWe): 874

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>48,961.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,057.1</u>	<u>28,559.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,879.3</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,035.4</u>	<u>27,188.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,732.7</u>
17. Gross Therm Ener (MWH)	<u>1,890,726</u>	<u>2,696,380</u>	<u>63,740,194</u>
18. Gross Elec Ener (MWH)	<u>626,758</u>	<u>891,050</u>	<u>21,183,243</u>
19. Net Elec Ener (MWH)	<u>595,680</u>	<u>834,609</u>	<u>19,833,308</u>
20. Unit Service Factor	<u>100.0</u>	<u>72.0</u>	<u>55.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>72.0</u>	<u>59.1</u>
22. Unit Cap Factor (MDC Net)	<u>97.9</u>	<u>66.3</u>	<u>46.3</u>
23. Unit Cap Factor (DER Net)	<u>94.5</u>	<u>64.0</u>	<u>44.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>28.0</u>	<u>19.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>403.6</u>	<u>6,987.6</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X                    DAVIS-BESSE 1                    X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### DAVIS-BESSE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

No. Date Type Hours Reason Method LER Number System Component Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DAVIS-BESSE 1 OPERATED WITH NO OUTAGES OR REDUCTIONS DURING  
THE REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DAVIS-BESSE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....OHIO  
COUNTY.....OTTAWA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...21 MI E OF  
TOLEDO, OH  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 12, 1977  
DATE ELEC ENER 1ST GENER...AUGUST 28, 1977  
DATE COMMERCIAL OPERATE...JULY 31, 1978  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...LAKE ERIE  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....TOLEDO EDISON  
CORPORATE ADDRESS.....300 MADISON AVENUE  
TOLEDO, OHIO 43652  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....W. ROGERS  
LICENSING PROJ MANAGER.....A. DEGAZIO  
DOCKET NUMBER.....50-346  
LICENSE & DATE ISSUANCE...NPF-3, APRIL 22, 1977  
PUBLIC DOCUMENT ROOM.....UNIVERSITY OF TOLEDO LIBRARY  
GOVERNMENT DOCUMENTS COLLECTION  
2801 WEST BANCROFT AVENUE  
TOLEDO, OHIO 43606

INSPECTION STATUS

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 19, THROUGH JANUARY 12, (83-24): ROUTINE UNANNOUNCED INSPECTION OF OPERATIONAL SAFETY, MAINTENANCE, SURVEILLANCE, PLANT TRIPS, MANAGEMENT MEETING AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 120 INSPECTOR-HOURS ONSITE BY ONE INSPECTOR INCLUDING 20 INSPECTOR-HOURS ONSITE DURING OFFSHIFTS. OF THE SIX AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN FOUR AREAS. ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE AREA OF PLANT TRIPS (FAILURE TO FOLLOW RESPIRATOR QUALIFICATION PROCEDURE) AND ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE AREA OF INDEPENDENT INSPECTION (FAILURE TO CONTROL DESIGN DOCUMENTS).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: NOVEMBER 19, 1983 THROUGH JANUARY 2, 1984

INSPECTION REPORT NO: 83-24

R E P O R T S   F R O M   L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
83-74/ 03L-0	12/24/83	01/24/84	BWST HI FAIL ALARM FOR SFAS CHANNEL 1 RECEIVED BY OPERATORS.
84-01/	01/03/84		REACTOR TRIP CAUSED BY AUTO. INSERTION OF AXIAL POWER SHAPING RODS.
84-02/	01/19/84	02/17/84	FUEL TRANSFER TUBE DRAIN VALVES LEFT OPEN AND UNCAPPED.

```
=====
```

1. Docket: 50-237 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: BEN SCHROEDER (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 772

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>120,960.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>93,665.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,418.1</u>	<u>89,314.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,570,780</u>	<u>3,303,982</u>	<u>180,041,578</u>
18. Gross Elec Ener (MWH)	<u>513,257</u>	<u>1,080,893</u>	<u>57,584,060</u>
19. Net Elec Ener (MWH)	<u>489,348</u>	<u>1,031,446</u>	<u>54,428,890</u>
20. Unit Service Factor	<u>100.0</u>	<u>98.5</u>	<u>73.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>98.5</u>	<u>73.8</u>
22. Unit Cap Factor (MDC Net)	<u>91.1</u>	<u>92.8</u>	<u>58.5</u>
23. Unit Cap Factor (DER Net)	<u>88.5</u>	<u>90.2</u>	<u>56.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.5</u>	<u>11.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>21.9</u>	<u>4,442.1</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
SNUBBER INSPECTION: MAY, 1984.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

## DRESDEN 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 DRESDEN 2 OPERATED WITH NO REPORTED REDUCTIONS OR OUTAGES  
 DURING FEBRUARY

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DRESDEN 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....GRUNDY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 7, 1970  
DATE ELEC ENER 1ST GENER...APRIL 13, 1970  
DATE COMMERCIAL OPERATE...JUNE 9, 1970  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER...KANKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....T. TONGUE  
LICENSING PROJ MANAGER....R. GILBERT  
DOCKET NUMBER.....50-237  
LICENSE & DATE ISSUANCE...DPR-19, DECEMBER 22, 1969  
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 18, THROUGH JANUARY 19, (83-32): ROUTINE, UNANNOUNCED INSPECTION BY THREE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; HEADQUARTERS/REGIONAL REQUESTS; OPERATIONAL SAFETY; I.E. BULLETINS; MONTHLY MAINTENANCE; MONTHLY SURVEILLANCES; REFUELING ACTIVITIES; REFUELING SURVEILLANCES; ONSITE FOLLOWUP OF EVENTS; LICENSEE EVENT REPORTS; SYSTEMATIC EVALUATION PROGRAM; PERFORMANCE APPRAISAL STAFF FINDINGS; THREE MILE ISLAND MODIFICATIONS; SPENT NUCLEAR FUEL SHIPMENTS AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 352 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 45 INSPECTOR-HOURS ONSITE DURING OFFSHIFTS. OF THE '5 AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS; TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN TWO AREAS (FAILURE TO HAVE A PROCEDURE AND FAILURE TO FOLLOW OR HAVE ADEQUATE PROCEDURES).

INSPECTION ON NOVEMBER 9-10 AND DECEMBER 5-9, 12, AND 20 (83-33): ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION PROGRAM, INCLUDING QUALIFICATIONS, TRAINING, EXPOSURE CONTROL, POSTING AND CONTROL, SURVEYS, LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, AND THE CIRCUMSTANCES SURROUNDING THE EVENT WHICH ALLOWED UNAUTHORIZED ENTRY OF TWO CONTRACT EMPLOYEES INTO A HIGH RADIATION AREA. THE INSPECTION INVOLVED 85 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. FOUR ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO GIVE TRAINING, FAILURE TO CONTROL ENTRY INTO A HIGH RADIATION AREA AND MAINTAIN LOCKED A HIGH RADIATION AREA, FAILURE TO PROVIDE PERSONAL DOSIMETERS TO PERSONS ENTERING A HIGH RADIATION AREA, AND FAILURE TO MAKE ADEQUATE SURVEYS).

SPECIAL INSPECTION ON FEBRUARY 3 - 14, (84-01): INSPECTION FOLLOWUP ON COMMONWEALTH EDISON COMPANY REMARKS TO SPECIAL INSPECTION REPORT CONCERNING ALLEGATIONS OF IMPROPER OPERATION AT DRESDEN, QUAD CITIES, AND ZION NUCLEAR POWER PLANTS. THE INSPECTION INVOLVED 14 INSPECTION-HOURS BY THREE NRC INSPECTORS. MEASURES TO CORRECT IDENTIFIED WEAKNESSES WERE TAKEN AS DESCRIBED IN THE REPONSE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.





1. Docket: 50-249 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: BEN SCHROEDER (815) 942-2920

4. Licensed Thermal Power (MWt): 2527

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 794

7. Maximum Dependable Capacity (Gross MWe): 812

8. Maximum Dependable Capacity (Net MWe): 773

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:                                     
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>110,545.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>82,835.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>79,862.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>159,963,004</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>51,952,909</u>
19. Net Elec Ener (MWH)	<u>-2,250</u>	<u>-5,010</u>	<u>49,225,573</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>72.2</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>72.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>57.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>56.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>12.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>6,415.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/15/84

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

DRESDEN 3



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
8	09/30/83	S	696.0	C	4				REFUELING, ISI AND TURBINE OVERHAUL OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DRESDEN 3 REMAINS SHUTDOWN IN A CONTINUING REFUELING AND REPAIR OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* DRESDEN 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....GRUNDY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI E OF  
MORRIS, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JANUARY 31, 1971  
DATE ELEC ENER 1ST GENER...JULY 22, 1971  
DATE COMMERCIAL OPERATE...NOVEMBER 16, 1971  
CONDENSER COOLING METHOD...COOLING LAKE  
CONDENSER COOLING WATER...KANKAKEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....T. TONGUE  
LICENSING PROJ MANAGER.....R. GILBERT  
DOCKET NUMBER.....50-249  
LICENSE & DATE ISSUANCE...DPR-25, MARCH 2, 1971  
PUBLIC DOCUMENT ROOM.....MORRIS PUBLIC LIBRARY  
604 LIBERTY STREET  
MORRIS, ILLINOIS 60450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 18, THROUGH JANUARY 19, (83-30): ROUTINE, UNANNOUNCED INSPECTION BY THREE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; HEADQUARTERS/REGIONAL REQUESTS; OPERATIONAL SAFETY; I.E. BULLETINS; MONTHLY MAINTENANCE; MONTHLY SURVEILLANCES; REFUELING ACTIVITIES; REFUELING SURVEILLANCES; ONSITE FOLLOWUP OF EVENTS; LICENSEE EVENT REPORTS; SYSTEMATIC EVALUATION PROGRAM; PERFORMANCE APPRAISAL STAFF FINDINGS; THREE MILE ISLAND MODIFICATIONS; SPENT NUCLEAR FUEL SHIPMENTS AND REPORT REVIEW. THE INSPECTION INVOLVED A TOTAL OF 352 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 45 INSPECTOR-HOURS ONSITE DURING OFFSHIFTS. OF THE 15 AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN 13 AREAS; TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN TWO AREAS (FAILURE TO HAVE A PROCEDURE AND FAILURE TO FOLLOW OR HAVE ADEQUATE PROCEDURES).

INSPECTION ON NOVEMBER 9-10 AND DECEMBER 5-9, 12, AND 20 (83-31): ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION PROGRAM, INCLUDING QUALIFICATIONS, TRAINING, EXPOSURE CONTROL, POSTING AND CONTROL, SURVEYS, LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, AND THE CIRCUMSTANCES SURROUNDING THE EVENT WHICH ALLOWED UNAUTHORIZED ENTRY OF TWO CONTRACT EMPLOYEES INTO A HIGH RADIATION AREA. THE INSPECTION INVOLVED 85 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. FOUR ITEMS OF NONCOMPLIANCE WERE IDENTIFIED (FAILURE TO GIVE TRAINING, FAILURE TO CONTROL ENTRY INTO A HIGH RADIATION AREA AND MAINTAIN LOCKED A HIGH RADIATION AREA, FAILURE TO PROVIDE PERSONAL DOSIMETERS TO PERSONS ENTERING A HIGH RADIATION AREA, AND FAILURE TO MAKE ADEQUATE SURVEYS).

SPECIAL INSPECTION ON FEBRUARY 3 - 14, (84-01): INSPECTION FOLLOWUP ON COMMONWEALTH EDISON COMPANY REMARKS TO SPECIAL INSPECTION REPORT CONCERNING ALLEGATIONS OF IMPROPER OPERATION AT DRESDEN, QUAD CITIES, AND ZION NUCLEAR POWER PLANTS. THE INSPECTION INVOLVED 14 INSPECTION-HOURS BY THREE NRC INSPECTORS. MEASURES TO CORRECT IDENTIFIED WEAKNESSES WERE TAKEN AS DESCRIBED IN THE REPONSE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.



1. Docket: 50-331 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: MATT ANDERSON (319) 851-7308

4. Licensed Thermal Power (MWt): 1658

5. Nameplate Rating (Gross MWe): 663 X 0.9 = 597

6. Design Electrical Rating (Net MWe): 538

7. Maximum Dependable Capacity (Gross MWe): 545

8. Maximum Dependable Capacity (Net MWe): 515

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>79,584.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,274.6</u>	<u>57,209.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,248.9</u>	<u>55,691.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,098,451</u>	<u>1,875,408</u>	<u>69,623,970</u>
18. Gross Elec Ener (MWH)	<u>374,414</u>	<u>636,841</u>	<u>23,330,898</u>
19. Net Elec Ener (MWH)	<u>353,529</u>	<u>601,011</u>	<u>21,837,381</u>
20. Unit Service Factor	<u>100.0</u>	<u>86.7</u>	<u>70.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>86.7</u>	<u>70.0</u>
22. Unit Cap Factor (MDC Net)	<u>98.6</u>	<u>81.0</u>	<u>53.3</u>
23. Unit Cap Factor (DER Net)	<u>94.4</u>	<u>77.6</u>	<u>51.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>13.3</u>	<u>17.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>191.1</u>	<u>11,525.4</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
 \* DUANE ARNOLD \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

DUANE ARNOLD



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
DUANE ARNOLD OPERATED AT OR NEAR FULL POWER DURING THE REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....IOWA  
  
COUNTY.....LINN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NW OF  
CEDAR RAPIDS, IA  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...MARCH 23, 1974  
  
DATE ELEC ENER 1ST GENER...MAY 19, 1974  
  
DATE COMMERCIAL OPERATE...FEBRUARY 1, 1975  
  
CONDENSER COOLING METHOD...COOLING TOWER  
  
CONDENSER COOLING WATER...CEDAR RAPIDS RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....IOWA ELECTRIC POWER & LIGHT  
  
CORPORATE ADDRESS.....I E TOWERS, P.O. BOX 351  
CEDAR RAPIDS, IOWA 52406  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....L. CLARDY  
  
LICENSING PROJ MANAGER....M. THADANI  
DOCKET NUMBER.....50-331  
  
LICENSE & DATE ISSUANCE...DPR-49, FEBRUARY 22, 1974  
  
PUBLIC DOCUMENT ROOM.....REFERENCE SERVICE  
CEDAR RAPIDS PUBLIC LIBRARY  
428 THIRD AVENUE, S.E.  
CEDAR RAPIDS, IOWA 52401

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 9-13, (84-01): ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION PROGRAM, INCLUDING: ORGANIZATION AND MANAGEMENT CONTROL; QUALIFICATIONS AND TRAINING; EXTERNAL EXPOSURE CONTROL AND PERSONAL DOSIMETRY; INTERNAL EXPOSURE CONTROL AND ASSESSMENT; ALARA; AND CONTROL OF RADIOACTIVE MATERIALS. THE INSPECTION INVOLVED 74 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JANUARY 3 - JANUARY 31, (84-02): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; PLANT TRIPS; LICENSEE IDENTIFIED ITEMS; IE BULLETINS; REGIONAL REQUESTS; PERSONNEL ERRORS; UNUSUAL EVENTS; PROCEDURES; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 88 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 12 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE 12 AREAS INSPECTED, ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN ONE AREA (FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE





Report Period FEB 1984

R E P O R T S F R O M L I C E N S E E - (CONTINUED)

\*\*\*\*\*  
\* DUANE ARNOLD \*  
\*\*\*\*\*

03L-0

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-348                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: DENNIS HERRIN (205) 899-5156

4. Licensed Thermal Power (MWt):                      2652

5. Nameplate Rating (Gross MWe):                      1045 X 0.85 = 888

6. Design Electrical Rating (Net MWe):                      829

7. Maximum Dependable Capacity (Gross MWe):                      845

8. Maximum Dependable Capacity (Net MWe):                      804

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>54,768.0</u>
13. Hours Reactor Critical	<u>240.0</u>	<u>938.0</u>	<u>36,061.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,650.7</u>
15. Hrs Generator On-Line	<u>240.0</u>	<u>904.5</u>	<u>35,007.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>631,428</u>	<u>2,360,784</u>	<u>88,462,308</u>
18. Gross Elec Ener (MWH)	<u>203,000</u>	<u>751,662</u>	<u>27,993,526</u>
19. Net Elec Ener (MWH)	<u>188,394</u>	<u>706,670</u>	<u>26,407,732</u>
20. Unit Service Factor	<u>34.5</u>	<u>62.8</u>	<u>63.9</u>
21. Unit Avail Factor	<u>34.5</u>	<u>62.8</u>	<u>63.9</u>
22. Unit Cap Factor (MDC Net)	<u>33.7</u>	<u>61.0</u>	<u>60.5*</u>
23. Unit Cap Factor (DER Net)	<u>32.7</u>	<u>59.2</u>	<u>58.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>8.1</u>	<u>15.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>79.5</u>	<u>6,246.0</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 04/14/84

\*\*\*\*\*  
\*                      F A R L E Y   1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
003	02/10/84	S	456.0	C	3	84-002-00			THE UNIT WAS TAKEN OFF LINE FOR THE CYCLE V-VI REFUELING OUTAGE. DURING NORMAL SHUTDOWN OPERATIONS, A REACTOR TRIP OCCURRED FROM 10% POWER.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FARLEY 1 SHUTDOWN ON FEBRUARY 10TH FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FARLEY 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
DOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 9, 1977  
DATE ELEC ENER 1ST GENER...AUGUST 18, 1977  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1977  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-348  
LICENSE & DATE ISSUANCE...NPF-2, JUNE 25, 1977  
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 11, 1983 - JANUARY 10, 1984 (83-33): THIS ROUTINE INSPECTION INVOLVED 90 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT STATUS, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INDEPENDENT INSPECTION EFFORT, PHYSICAL PROTECTION, TECHNICAL SPECIFICATION COMPLIANCE, LICENSEE EVENT REPORTS, OPERATOR ACTIONS FOR REACTOR TRIP AND ANTICIPATED TRANSIENTS WITHOUT A TRIP (ATWT), AND REACTOR TRIP BREAKERS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE FOUND IN SEVEN AREAS; ONE VIOLATION WAS FOUND IN ONE AREA (VIOLATION OF TECHNICAL SPECIFICATION 6.8.1, PARAGRAPH 6) AND ONE VIOLATION WAS FOUND IN ONE AREA (VIOLATION OF 10 CFR 50, APPENDIX B, CRITERION XVI, PARAGRAPH 8).

INSPECTION JANUARY 18-19 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 6 INSPECTOR-HOURS ON SITE IN THE EMERGENCY PREPAREDNESS AREA OF PROTECTIVE ACTION DECISION MAKING. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 16-20 (84-02): THE INSPECTION INVOLVED 17 INSPECTOR-HOURS ON SITE BY ONE NRC INSPECTOR. TWO INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED REVIEW OF SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AND VITAL AREAS); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROLS (PERSONNEL, PACKAGE AND VEHICLES); DETECTION AIDS (PROTECTED AND VITAL AREAS); ALARM STATIONS; AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 12 AREAS EXAMINED DURING THE INSPECTION.

INSPECTION JANUARY 11 - FEBRUARY 5 (84-03): THIS ROUTINE INSPECTION INVOLVED 80 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT STATUS, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INDEPENDENT INSPECTION







THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-364 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: DENNIS HERRIN (205) 899-5156

4. Licensed Thermal Power (MWt): 2652

5. Nameplate Rating (Gross MWe): 860

6. Design Electrical Rating (Net MWe): 829

7. Maximum Dependable Capacity (Gross MWe): 855

8. Maximum Dependable Capacity (Net MWe): 814

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>22,681.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,415.8</u>	<u>19,952.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>138.4</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,378.7</u>	<u>19,677.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,845,593</u>	<u>3,557,486</u>	<u>50,468,178</u>
18. Gross Elec Ener (MWH)	<u>607,908</u>	<u>1,164,766</u>	<u>16,151,614</u>
19. Net Elec Ener (MWH)	<u>579,714</u>	<u>1,107,326</u>	<u>15,307,352</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.7</u>	<u>86.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>95.7</u>	<u>86.8</u>
22. Unit Cap Factor (MDC Net)	<u>102.3</u>	<u>94.5</u>	<u>82.9</u>
23. Unit Cap Factor (DER Net)	<u>100.5</u>	<u>92.8</u>	<u>81.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.3</u>	<u>5.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>61.3</u>	<u>1,093.1</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FARLEY 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	------------------	---

NONE

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 FARLEY 2 OPERATED AT FULL POWER DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FARLEY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ALABAMA  
COUNTY.....HOUSTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
DOTHAN, ALA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 5, 1981  
DATE ELEC ENER 1ST GENER...MAY 25, 1981  
DATE COMMERCIAL OPERATE...JULY 30, 1981  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CHATAHOOCHEE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ALABAMA POWER CO.  
CORPORATE ADDRESS.....600 NORTH 18TH STREET  
BIRMINGHAM, ALABAMA 35203  
CONTRACTOR  
ARCHITECT/ENGINEER.....SOUTHERN SERVICES INCORPORATED  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. BRADFORD  
LICENSING PROJ MANAGER.....E. REEVES  
DOCKET NUMBER.....50-364  
LICENSE & DATE ISSUANCE...NPF-8, MARCH 31, 1981  
PUBLIC DOCUMENT ROOM.....G.S. HOUSTON MEMORIAL LIBRARY  
212 W. BURDESHAW STREET  
DOTHAN, ALABAMA 36301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 11, 1983 - JANUARY 10, 1984 (83-31): THIS ROUTINE INSPECTION INVOLVED 90 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT STATUS, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INDEPENDENT INSPECTION EFFORT, PHYSICAL PROTECTION, TECHNICAL SPECIFICATION COMPLIANCE, LICENSEE EVENT REPORTS, OPERATOR ACTIONS FOR REACTOR TRIP AND ANTICIPATED TRANSIENTS WITHOUT A TRIP (ATWT), AND REACTOR TRIP BREAKERS. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE FOUND IN SEVEN AREAS; ONE VIOLATION WAS FOUND IN ONE AREA (VIOLATION OF TECHNICAL SPECIFICATION 6.8.1, PARAGRAPH 6) AND ONE VIOLATION WAS FOUND IN ONE AREA (VIOLATION OF 10 CFR 50, APPENDIX B, CRITERION XVI, PARAGRAPH 8).

INSPECTION JANUARY 18-19 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 6 INSPECTOR-HOURS ON SITE IN THE EMERGENCY PREPAREDNESS AREA OF PROTECTIVE ACTION DECISION MAKING. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 16-20 (84-02): THE INSPECTION INVOLVED 18 INSPECTOR-HOURS ON SITE BY ONE NRC INSPECTOR. TWO INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED REVIEW OF SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AND VITAL AREAS); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROLS (PERSONNEL, PACKAGE AND VEHICLES); DETECTION AIDS (PROTECTED AND VITAL AREAS); ALARM STATIONS; AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 12 AREAS EXAMINED DURING THE INSPECTION.

INSPECTION JANUARY 11 - FEBRUARY 5 (84-03): THIS ROUTINE INSPECTION INVOLVED 80 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT STATUS, MONTHLY SURVEILLANCE OBSERVATION, MONTHLY MAINTENANCE OBSERVATION, OPERATIONAL SAFETY VERIFICATION, INDEPENDENT INSPECTION





THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-333                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: J. COOK (315) 342-3840

4. Licensed Thermal Power (MWt):                    2436

5. Nameplate Rating (Gross MWe):                    981 x 0.9 = 883

6. Design Electrical Rating (Net MWe):                    821

7. Maximum Dependable Capacity (Gross MWe):                    830

8. Maximum Dependable Capacity (Net MWe):                    810

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>75,337.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>53,968.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>52,639.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,627,008</u>	<u>3,434,472</u>	<u>111,171,058</u>
18. Gross Elec Ener (MWH)	<u>546,230</u>	<u>1,155,820</u>	<u>37,813,140</u>
19. Net Elec Ener (MWH)	<u>528,615</u>	<u>1,118,290</u>	<u>36,616,930</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>69.9</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>69.9</u>
22. Unit Cap Factor (MDC Net)	<u>93.8</u>	<u>95.9</u>	<u>63.6*</u>
23. Unit Cap Factor (DER Net)	<u>92.5</u>	<u>94.6</u>	<u>59.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>14.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>8,883.2</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


MAINTENANCE OUTAGE: 03/03/84 - 10 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    FITZPATRICK                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### FITZPATRICK



FEBRUARY 1984

\* Item calculated with a Weighted Average

PAGE 2-108



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* FITZPATRICK \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/10/84	S	0.0	B	5				REDUCED POWER FOR ROD SEQUENCE EXCHANGE.
2	02/18/84	S	0.0	B	5				REDUCE POWER FOR CONTROL ROD PATTERN ADJUSTMENT.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 THE FITZPATRICK PLANT OPERATED AT NEAR FULL THERMAL POWER FOR THIS REPORTING PERIOD WITH ONE POWER REDUCTION FOR CONTROL ROD SEQUENCE EXCHANGE AND ONE FOR ROD PATTERN ADJUSTMENT.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training & License Examination		

\*\*\*\*\*  
\* FITZPATRICK \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....NEW YORK  
COUNTY.....OSWEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...NOVEMBER 17, 1974  
DATE ELEC ENER 1ST GENER...FEBRUARY 1, 1975  
DATE COMMERCIAL OPERATE....JULY 28, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY  
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.  
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....L. DOERFLEIN  
LICENSING PROJ MANAGER.....H. ABELSON  
DOCKET NUMBER.....50-333  
LICENSE & DATE ISSUANCE....DPR-59, OCTOBER 17, 1974  
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - GOVERNMENT DOCUMENTS COL  
OSWEGO, NY 13126  
(315) 341-2323

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   FITZPATRICK                   \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-285                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: T. P. MATTHEWS (402) 536-4733

4. Licensed Thermal Power (MWt):                    1500

5. Nameplate Rating (Gross MWe):                    591 X 0.85 = 502

6. Design Electrical Rating (Net MWe):                    478

7. Maximum Dependable Capacity (Gross MWe):                    461

8. Maximum Dependable Capacity (Net MWe):                    438

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>91,441.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>72,053.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,309.5</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>70,792.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>997,883</u>	<u>2,103,771</u>	<u>88,363,485</u>
18. Gross Elec Ener (MWH)	<u>319,880</u>	<u>675,442</u>	<u>29,304,866</u>
19. Net Elec Ener (MWH)	<u>303,975</u>	<u>642,756</u>	<u>27,722,616</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>77.4</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>77.4</u>
22. Unit Cap Factor (MDC Net)	<u>99.7</u>	<u>101.9</u>	<u>66.1*</u>
23. Unit Cap Factor (DER Net)	<u>91.4</u>	<u>93.4</u>	<u>63.4</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>3.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,398.4</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>REFUELING - 03/03/84.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### FORT CALHOUN 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* FORT CALHOUN 1 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
FORT CALHOUN OPERATED AT OR NEAR FULL POWER DURING FEBRUARY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		





1. Docket: 50-267                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: C. H. FULLER (303) 785-2224

4. Licensed Thermal Power (MWt):                      842

5. Nameplate Rating (Gross MWe):                      403 X 0.85 = 343

6. Design Electrical Rating (Net MWe):                      330

7. Maximum Dependable Capacity (Gross MWe):                      342

8. Maximum Dependable Capacity (Net MWe):                      330

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): 280

11. Reasons for Restrictions, If Any:  
B-0 STARTUP TESTING.

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>40,921.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>468.0</u>	<u>26,295.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>446.6</u>	<u>18,250.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>240,819</u>	<u>9,610,571</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>77,412</u>	<u>3,230,862</u>
19. Net Elec Ener (MWH)	<u>-1,952</u>	<u>69,350</u>	<u>2,940,880</u>
20. Unit Service Factor	<u>.0</u>	<u>31.0</u>	<u>44.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>31.0</u>	<u>44.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>14.6</u>	<u>21.8</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>14.6</u>	<u>21.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.5</u>	<u>39.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>6.9</u>	<u>11,683.9</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


REFUELING - 03/01/84 THRU 05/02/84

27. If Currently Shutdown Estimated Startup Date: 05/02/84

\*\*\*\*\*  
\*                      FORT ST VRAIN                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

FORT ST VRAIN



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* FORT ST VRAIN \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-002	01/19/84	S	696.0	C	4		RC	FUELXX	REFUELING, TURBINE OVERHAUL, ROUTINE CORRECTIVE AND PREVENTIVE MAINTENANCE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 FORT ST. VRAIN REMAINS OFF-LINE IN A CONTINUING  
 REFUELING/MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* FORT ST VRAIN \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

UTILITY DESCRIPTION

LOCATION  
STATE.....COLORADO  
COUNTY.....WELD  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...35 MI N OF  
DENVER, COL  
TYPE OF REACTOR.....HTGR  
DATE INITIAL CRITICALITY...JANUARY 31, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 11, 1976  
DATE COMMERCIAL OPERATE...JULY 1, 1979  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....S. PLATTE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE OF COLORADO  
CORPORATE ADDRESS.....P.O. BOX 840  
DENVER, COLORADO 80201  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ATOMIC CORP.  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....IV  
IE RESIDENT INSPECTOR.....G. PLUMLEE  
LICENSING PROJ MANAGER.....P. WAGNER  
DOCKET NUMBER.....50-267  
LICENSE & DATE ISSUANCE...DPR-34, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....GREELEY PUBLIC LIBRARY  
CITY COMPLEX BUILDING  
GREELEY, COLORADO 80631

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION CONDUCTED JANUARY 16-20, 1984 (84-03): ROUTINE, UNANNOUNCED INSPECTION OF THE LICENSEE'S RADIOACTIVE WASTE PROGRAM INCLUDING: ORGANIZATION AND MANAGEMENT CONTROLS, TRAINING AND QUALIFICATIONS, AUDITS OF RADIOACTIVE WASTE ACTIVITIES, SOLID RADIOACTIVE WASTE PROCESSING, LIQUID AND GASEOUS RADIOACTIVE EFFLUENT RELEASES, PROCEDURES FOR CONTROLLING RADIOACTIVE EFFLUENT RELEASES, RADIOACTIVE EFFLUENT CONTROL INSTRUMENTATION, RECORDS AND REPORTS OF RADIOACTIVE EFFLUENTS, TESTING OF AIR CLEANING SYSTEMS, AND REACTOR COOLANT QUALITY. WITHIN THE TEN AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, TECHNICAL SPECIFICATION 7.4.A, AND ADMINISTRATIVE PROCEDURE P-6, THE NRC INSPECTOR DETERMINED THAT FOR CHANGE NOTICE/CONTROL WORK PERMIT CN 1295/ CWP82-122 NO MEASURE HAD BEEN ESTABLISHED TO PROVIDE UPDATED WRITTEN PROCEDURES THAT WOULD REFLECT THIS PLANT MODIFICATION APPARENTLY DUE TO THE FAILURE OF THE WORK REVIEW COMMITTEE TO EVALUATE THE EFFECT OF THIS CWP ON OTHER PLANT SYSTEMS, CONDITIONS OR OPERATIONS. CONTRARY TO 10 CFR 50, APPENDIX B, FORT ST. VRAIN FSAR COMMITMENT TO ANSI 45.2.5, AND ASTM C-94, DEVIATION REPORT 82-206-1-H HAS DELETED THE CONCRETE TRANSPORT TIME REQUIREMENT FROM SPECIFICATION 75-J-02 WITHOUT IMPOSITION OF ALTERNATE ACCEPTANCE CRITERIA.

CONTRARY TO TECHNICAL SPECIFICATION 7.4.A AND ADMINISTRATIVE PROCEDURE G-9, THE NRC INSPECTOR DETERMINED THAT CONTROL WORK PERMIT CWP 82-255 HAD BEEN SURRENDERED DUE TO WORK COMPLETION AND THE AFFECTED SYSTEM RETURNED TO SERVICE WITHOUT HAVING A WRITTEN

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    FORT ST VRAIN                    \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

PROCEDURE TO OPERATE THE MODIFIED SYSTEM, WITHOUT HAVING THE SHIFT SUPERVISOR'S SIGNATURE ON THE CWP VERIFYING WORK COMPLETION, AND WITHOUT HAVING UPDATED CONTROL ROOM/SHIFT SUPERVISOR DESIGN DOCUMENTS. CWP'S 82-48, 82-83, AND 82-173 WERE IDENTIFIED AS ADDITIONAL EXAMPLES OF THE ABOVE VIOLATION.  
(8324 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

MAJOR ELECTRICAL MODIFICATIONS TO THE AUXILIARY ELECTRICAL SYSTEM, INSTRUMENT POWER SYSTEM, 480V AC DISTRIBUTION SYSTEM, AND 4160/480V AC TRANSFORMERS ARE SCHEDULED FOR THIS REFUELING OUTAGE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THIRD REFUELING OUTAGE BEGAN JANUARY 19, 1984, AND IS STILL CONTINUING

LAST IE SITE INSPECTION DATE: JANUARY 16-20, 1984

INSPECTION REPORT NO: 50-267/84-03

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

=====



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* GINNA \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	02/18/84	F	0.0	A	5		SF	ACCUMU	POWER REDUCTION DUE TO S.I. ACCUMULATOR LOW PRESSURE.
	02/22/84	F	0.0	A	5		HB	PIPEXX	POWER REDUCTION DUE TO 2B REHEATER STEAM LEAK.
	02/24/84	S	0.0	C	5				COASTDOWN COMMENCED.
	02/24/84	F	0.0	A	5		HH	XXXXXX	POWER REDUCTION DUE TO LOSS OF A AND B HEATER DRAIN TANK PUMPS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 GINNA OPERATED WITH 4 REDUCTIONS AND NO OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* GINNA \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....WAYNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI NE OF  
ROCHESTER, NY  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 8, 1969  
DATE ELEC ENER 1ST GENER...DECEMBER 2, 1969  
DATE COMMERCIAL OPERATE...JULY 1, 1970  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....ROCHESTER GAS & ELECTRIC  
CORPORATE ADDRESS.....89 EAST AVENUE  
ROCHESTER, NEW YORK 14604  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. ZIMMERMAN  
LICENSING PROJ MANAGER.....G. DICK  
DOCKET NUMBER.....50-244  
LICENSE & DATE ISSUANCE...DPR-18, SEPTEMBER 19, 1969  
PUBLIC DOCUMENT ROOM.....ROCHESTER PUBLIC LIBRARY  
BUSINESS AND SOCIAL SCIENCE DIVISION  
115 SOUTH AVENUE  
ROCHESTER, NEW YORK 14604

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):



1. Docket: 50-213 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: R.L. EPPINGER (203) 267-2556 X274

4. Licensed Thermal Power (MWt): 1825

5. Nameplate Rating (Gross MWe): 667 X 0.9 = 600

6. Design Electrical Rating (Net MWe): 582

7. Maximum Dependable Capacity (Gross MWe): 596

8. Maximum Dependable Capacity (Net MWe): 569

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>141,696.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>122,641.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,200.5</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>117,347.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>373.7</u>
17. Gross Therm Ener (MWH)	<u>1,264,967</u>	<u>2,618,211</u>	<u>203,990,771</u>
18. Gross Elec Ener (MWH)	<u>421,078</u>	<u>871,510</u>	<u>66,984,753</u>
19. Net Elec Ener (MWH)	<u>402,159</u>	<u>832,195</u>	<u>63,732,896</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>82.8</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>83.1</u>
22. Unit Cap Factor (MDC Net)	<u>101.5</u>	<u>101.6</u>	<u>82.7*</u>
23. Unit Cap Factor (DER Net)	<u>99.3</u>	<u>99.3</u>	<u>75.8*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>6.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,158.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: 06/16/84, 10 WEEK DURATION.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HADDAM NECK



FEBRUARY 1984

\* Item calculated with a Weighted Average



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

HADDAM NECK (CONNECTICUT YANKEE) OPERATED AT FULL POWER  
DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HADDAM NECK \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....MIDDLESEX  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...13 MI E OF  
MERIDEN, CONN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 24, 1967  
DATE ELEC ENER 1ST GENER...AUGUST 7, 1967  
DATE COMMERCIAL OPERATE...JANUARY 1, 1968  
CONDENSER COOLING METHGD...ONCE THRU  
CONDENSER COOLING WATER...CONNECTICUT RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONNECTICUT YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....P. SWETLAND  
LICENSING PROJ MANAGER.....J. LYONS  
DOCKET NUMBER.....50-213  
LICENSE & DATE ISSUANCE...DPR-61, DECEMBER 27, 1974  
PUBLIC DOCUMENT ROOM.....RUSSELL LIBRARY  
119 BROAD STREET  
MIDDLETOWN, CONNECTITCUT 06457

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   HADDAM HECK                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-321 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: D.P. RAFFEDIE (912) 367-7851

4. Licensed Thermal Power (MWt): 2436

5. Nameplate Rating (Gross MWe): 1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe): 777

7. Maximum Dependable Capacity (Gross MWe): 801

8. Maximum Dependable Capacity (Net MWe): 752

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>71,568.0</u>
13. Hours Reactor Critical	<u>179.5</u>	<u>923.5</u>	<u>50,429.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>163.1</u>	<u>907.1</u>	<u>47,300.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>347,208</u>	<u>2,147,184</u>	<u>99,282,299</u>
18. Gross Elec Ener (MWH)	<u>108,350</u>	<u>707,510</u>	<u>32,156,490</u>
19. Net Elec Ener (MWH)	<u>99,187</u>	<u>673,533</u>	<u>30,524,024</u>
20. Unit Service Factor	<u>23.4</u>	<u>63.0</u>	<u>66.1</u>
21. Unit Avail Factor	<u>23.4</u>	<u>63.0</u>	<u>66.1</u>
22. Unit Cap Factor (MDC Net)	<u>19.0</u>	<u>62.2</u>	<u>56.7</u>
23. Unit Cap Factor (DER Net)	<u>18.3</u>	<u>60.2</u>	<u>54.9</u>
24. Unit Forced Outage Rate	<u>73.3</u>	<u>33.1</u>	<u>16.4</u>
25. Forced Outage Hours	<u>448.3</u>	<u>448.3</u>	<u>9,058.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/08/84

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* HATCH 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	02/03/84	S	0.0	H	5		SA	VESSEL	RAMPING DOWN TO PERFORM TORUS VENT HEADER INSPECTION.
84-6	02/03/84	S	84.6	H	2		SA	VESSEL	OUTAGE TO INSPECT TORUS VENT HEADER.
84-7	02/07/84	S	0.0	H	5		SA	VESSEL	RAMP TO RATED POWER FROM TORUS INSPECTION OUTAGE.
84-8	02/10/84	F	0.0	A	5		CB	PUMPXX	"B" RECIRC PUMP TRIPPED.
84-9	02/11/84	F	448.3	A	3		HA	TURBIN	REACTOR SCRAM FROM TURBINE HIGH VIBRATION UPON INSPECTION REVEALED 13TH STAGE LP TURBINE BUCKETS DAMAGED.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 HATCH 1 SHUTDOWN ON FEBRUARY 11TH FOR TURBINE REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HATCH 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....GEORGIA  
COUNTY.....APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 12, 1974  
DATE ELEC ENER 1ST GENER...NOVEMBER 11, 1974  
DATE COMMERCIAL OPERATE....DECEMBER 31, 1975  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER....ALTAMAHA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....333 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRLENJAK  
LICENSING PROJ MANAGER.....G. RIVENBARK  
DOCKET NUMBER.....50-321  
LICENSE & DATE ISSUANCE....DPR-57, OCTOBER 13, 1974  
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY  
301 CITY HALL DRIVE  
BAXLEY, GEORGIA 31563

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 21 - AUGUST 20 (83-25): THIS INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 24-27 (84-03): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 14 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION. OF THE AREAS INSPECTED, 1 VIOLATION WAS FOUND - FAILURE TO FOLLOW PROCEDURE FOR RECORDING LOCATION AND EXTENT OF ISI NDE EXAMINATION OF REACTOR VESSEL WELD.

INSPECTION FEBRUARY 4-7 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 17 INSPECTOR-HOURS ON SITE IN THE AREAS OF TORUS VENT HEADER CRACKING. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE



1. Docket: 50-366                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: D.P. RAFFEDIE (912) 367-7851

4. Licensed Thermal Power (MWt):                    2436

5. Nameplate Rating (Gross MWe):                    1000 X 0.85 = 850

6. Design Electrical Rating (Net MWe):                    784

7. Maximum Dependable Capacity (Gross MWe):                    806

8. Maximum Dependable Capacity (Net MWe):                    748

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>39,337.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>308.2</u>	<u>27,547.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>308.2</u>	<u>26,241.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>726,912</u>	<u>56,293,208</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>242,640</u>	<u>18,547,990</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>230,541</u>	<u>17,648,783</u>
20. Unit Service Factor	<u>.0</u>	<u>21.4</u>	<u>66.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>21.4</u>	<u>66.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>21.4</u>	<u>60.0</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>20.4</u>	<u>57.2</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,425.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 09/10/84

\*\*\*\*\*  
\*                    HATCH 2                    \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

HATCH 2



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-5	01/13/84	S	696.0	H	4		CB	PIPEXX	RECIRC PIPE REPLACEMENT OUTAGE.

\*\*\*\*\* HATCH 2 REMAINS SHUTDOWN IN A CONTINUING REPAIR STAGE.  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* HATCH 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....GEORGIA  
COUNTY.....APPLING  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI N OF  
BAXLEY, GA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JULY 4, 1978  
DATE ELEC ENER 1ST GENER...SEPTEMBER 22, 1978  
DATE COMMERCIAL OPERATE...SEPTEMBER 5, 1979  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...ALTAMAHA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GEORGIA POWER  
CORPORATE ADDRESS.....333 PIEDMONT AVENUE  
ATLANTA, GEORGIA 30308  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....GEORGIA POWER CO.  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. CRLENJAK  
LICENSING PROJ MANAGER.....G. RIVENBARK  
DOCKET NUMBER.....50-366  
LICENSE & DATE ISSUANCE...NPF-5, JUNE 13, 1978  
PUBLIC DOCUMENT ROOM.....APPLING COUNTY PUBLIC LIBRARY  
301 CITY HALL DRIVE  
BAXLEY, GEORGIA 31563

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION JULY 21 - AUGUST 20 (83-26): THIS INSPECTION INVOLVED 84 INSPECTOR-HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, OPERATOR PERFORMANCE, OVERALL PLANT OPERATIONS, QUALITY ASSURANCE PRACTICES, STATION AND CORPORATE MANAGEMENT PRACTICES, CORRECTIVE AND PREVENTIVE MAINTENANCE ACTIVITIES, SITE SECURITY PROCEDURES, RADIATION CONTROL ACTIVITIES, AND SURVEILLANCE ACTIVITIES. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 24-27 (84-03): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 15 INSPECTOR-HOURS ON SITE IN THE AREAS OF INSERVICE INSPECTION AND RECIRCULATION SYSTEM PIPING REPLACEMENT. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 4-7 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 17 INSPECTOR-HOURS ON SITE IN THE AREAS OF TORUS VENT HEADER CRACKING, FEEDWATER LINE ULTRASONIC (UT) INDICATION AND RECIRC PIPING REPLACEMENT. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CRITERION XIV OF APPENDIX B TO 10 CFR PART 50 AS IMPLEMENTED BY HATCH UNIT 2 FSAR CHAPTER 17.2.14 REQUIRES IN PART THAT MEASURES SHALL BE ESTABLISHED FOR INDICATING THE OPERATING STATUS OF STRUCTURES, SYSTEMS AND COMPONENTS TO PREVENT INADVERTENT OPERATION.





THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-247                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: E. EICH (914) 694-6000 @ I.P.

4. Licensed Thermal Power (MWt):                      2758

5. Nameplate Rating (Gross MWe):                      1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe):                      873

7. Maximum Dependable Capacity (Gross MWe):                      900

8. Maximum Dependable Capacity (Net MWe):                      864

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>84,745.0</u>
13. Hours Reactor Critical	<u>305.6</u>	<u>997.4</u>	<u>56,945.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,119.1</u>
15. Hrs Generator On-Line	<u>293.8</u>	<u>973.5</u>	<u>55,169.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>772,960</u>	<u>2,599,755</u>	<u>143,640,254</u>
18. Gross Elec Ener (MWH)	<u>238,730</u>	<u>813,190</u>	<u>44,470,766</u>
19. Net Elec Ener (MWH)	<u>224,033</u>	<u>775,379</u>	<u>42,402,471</u>
20. Unit Service Factor	<u>42.2</u>	<u>67.6</u>	<u>65.1</u>
21. Unit Avail Factor	<u>42.2</u>	<u>67.6</u>	<u>65.1</u>
22. Unit Cap Factor (MDC Net)	<u>37.3</u>	<u>62.3</u>	<u>58.2*</u>
23. Unit Cap Factor (DER Net)	<u>36.9</u>	<u>61.7</u>	<u>57.3</u>
24. Unit Forced Outage Rate	<u>57.8</u>	<u>32.4</u>	<u>9.9</u>
25. Forced Outage Hours	<u>402.2</u>	<u>466.5</u>	<u>5,842.7</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING/INSPECTION - 06/03/84.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

INDIAN POINT 2



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* INDIAN POINT 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	02/09/84	F	27.7	D	1	84-003	IB	INSTRU	CONTROL ROD POSITION INDICATOR REPAIR.
3	02/11/84	F	374.5	A	1		CC	HTEXCH	STEAM GENERATOR TUBE LEAK.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 INDIAN POINT 2 OPERATED WITH 2 OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
  
COUNTY.....WESTCHESTER  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI N OF  
NEW YORK CITY, NY  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...MAY 22, 1973  
  
DATE ELEC ENER 1ST GENER...JUNE 26, 1973  
  
DATE COMMERCIAL OPERATE....AUGUST 1, 1974  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER...HUDSON RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSOLIDATED EDISON  
  
CORPORATE ADDRESS.....4 IRVING PLACE  
NEW YORK, NEW YORK 10003  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
  
IE RESIDENT INSPECTOR.....P. KOLTAY  
  
LICENSING PROJ MANAGER.....R. PEDERSEN  
DOCKET NUMBER.....50-247  
  
LICENSE & DATE ISSUANCE....DPR-26, SEPTEMBER 28, 1973  
  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.



\*\*\*\*\*  
\* INDIAN POINT 2 \*  
\*\*\*\*\*

Report Period FEB 1984      I N S P E C T I O N      S T A T U S      (CONTINUED)

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.  
PLANT STATUS:  
NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.  
INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

1. Docket: 50-286                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: L. KELLY (914) 739-8200

4. Licensed Thermal Power (MWt):                    3025

5. Nameplate Rating (Gross MWe):                    1126 X 0.9 = 1013

6. Design Electrical Rating (Net MWe):                    965

7. Maximum Dependable Capacity (Gross MWe):                    1000

8. Maximum Dependable Capacity (Net MWe):                    965

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>65,761.0</u>
13. Hours Reactor Critical	<u>691.3</u>	<u>753.1</u>	<u>35,177.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>667.6</u>	<u>667.9</u>	<u>33,810.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,542,818</u>	<u>1,543,241</u>	<u>85,913,077</u>
18. Gross Elec Ener (MWH)	<u>482,660</u>	<u>482,665</u>	<u>26,849,276</u>
19. Net Elec Ener (MWH)	<u>460,451</u>	<u>460,451</u>	<u>25,704,629</u>
20. Unit Service Factor	<u>95.9</u>	<u>46.4</u>	<u>51.4</u>
21. Unit Avail Factor	<u>95.9</u>	<u>46.4</u>	<u>51.4</u>
22. Unit Cap Factor (MDC Net)	<u>68.6</u>	<u>33.1</u>	<u>40.5</u>
23. Unit Cap Factor (DER Net)	<u>68.6</u>	<u>33.1</u>	<u>40.5</u>
24. Unit Forced Outage Rate	<u>3.2</u>	<u>53.4</u>	<u>24.5</u>
25. Forced Outage Hours	<u>22.3</u>	<u>766.0</u>	<u>10,962.8</u>
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration): <u>NONE</u>			
27. If Currently Shutdown Estimated Startup Date:	<u>N/A</u>		

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### INDIAN POINT 3



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* INDIAN POINT 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
01	02/01/84	S	6.1	B	9		ZZ	ZZZZZZ	UNIT REMOVED FROM SERVICE FOR TURBINE OVERSPEED TRIP TEST.
02	02/09/84	F	4.6	A	3		HH	INSTRU	REACTOR TRIP CAUSED BY TRIP OF #31 & #32 HEATER DRAIN TANK PUMPS.
03	02/20/84	F	7.0	A	3		HH	VALVOP	#32 STEAM GENERATOR LOW LEVEL MISMATCH CAUSED BY A FAILED FEEDWATER REGULATING VALVE SOLENOID.
04	02/21/84	F	10.7	B	9		ZZ	ZZZZZZ	REPAIRS TO DRAIN LINE ON FEEDWATER DISCHARGE HEADER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 INDIAN POINT 3 OPERATED ROUTINELY DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Schedule	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* INDIAN POINT 3 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
  
COUNTY.....WESTCHESTER  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI N OF  
NEW YORK CITY, NY  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...APRIL 6, 1976  
  
DATE ELEC ENER 1ST GENER...APRIL 27, 1976  
  
DATE COMMERCIAL OPERATE...AUGUST 30, 1976  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER...HUDSON RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....POWER AUTHORITY OF STATE OF N.Y.  
  
CORPORATE ADDRESS.....10 COLUMBUS CIRCLE  
NEW YORK, NEW YORK 10019  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....UNITED ENG. & CONSTRUCTORS  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....WESTINGHOUSE DEVELOPMENT CORP  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
  
IE RESIDENT INSPECTOR.....T. KENNY  
  
LICENSING PROJ MANAGER.....P. POLK  
DOCKET NUMBER.....50-286  
  
LICENSE & DATE ISSUANCE...DPR-64, APRIL 5, 1976  
  
PUBLIC DOCUMENT ROOM.....WHITE PLAINS PUBLIC LIBRARY  
100 MARTINE AVENUE  
WHITE PLAINS, NEW YORK 10601

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    INDIAN POINT 3                    \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			
=====			

1. Docket: 50-305 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: G.RUITER (414) 388-2560 X207

4. Licensed Thermal Power (MWt): 1650

5. Nameplate Rating (Gross MWe): 622 X 0.9 = 560

6. Design Electrical Rating (Net MWe): 535

7. Maximum Dependable Capacity (Gross MWe): 529

8. Maximum Dependable Capacity (Net MWe): 503

9. If Changes Occur Above Since Last Report, Give Reasons:

NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>85,105.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>72,620.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,330.5</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>71,252.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>10.0</u>
17. Gross Therm Ener (MWH)	<u>1,139,329</u>	<u>2,365,226</u>	<u>111,336,312</u>
18. Gross Elec Ener (MWH)	<u>374,200</u>	<u>777,200</u>	<u>36,635,300</u>
19. Net Elec Ener (MWH)	<u>357,376</u>	<u>742,369</u>	<u>34,874,405</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>83.7</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>83.7</u>
22. Unit Cap Factor (MDC Net)	<u>102.1</u>	<u>102.5</u>	<u>78.7*</u>
23. Unit Cap Factor (DER Net)	<u>96.0</u>	<u>96.4</u>	<u>76.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>3.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,729.7</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


REFUELING - 03/16/84 - 6 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* KEWAUNEE \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

KEWAUNEE



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* Kewaunee \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
KEWAUNEE OPERATED AT FULL POWER WITH NO OUTAGES OR REDUCTIONS  
DURING THE REPORT PERIOD.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* Kewaunee \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....KEWAUNEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...27 MI E OF  
GREEN BAY, WI.  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 7, 1974  
DATE ELEC ENER 1ST GENER...APRIL 8, 1974  
DATE COMMERCIAL OPERATE...JUNE 16, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN PUBLIC SERVICE  
CORPORATE ADDRESS.....P.O. BOX 1200  
GREEN BAY, WISCONSIN 54305  
CONTRACTOR  
ARCHITECT/ENGINEER.....PIONEER SERVICES & ENGINEERING  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....PIONEER SERVICES & ENGINEERING  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. NELSON  
LICENSING PROJ MANAGER.....M. GROTENHUIS  
DOCKET NUMBER.....50-305  
LICENSE & DATE ISSUANCE...DPR-43, DECEMBER 21, 1973  
PUBLIC DOCUMENT ROOM.....KEWAUNEE PUBLIC LIBRARY  
822 JANEAU STREET  
KEWAUNEE, WISCONSIN 54216

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 19-23, JANUARY 3-6, 9-13, 30, 31, FEBRUARY 6-10, 13-15, (83-17): ROUTINE UNANNOUNCED INSPECTION BY RESIDENT INSPECTOR OF OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; INDEPENDENT INSPECTION; AND REGIONAL REQUESTS. THE INSPECTION INVOLVED 101 INSPECTOR-HOURS BY ONE INSPECTOR INCLUDING 18 INSPECTION-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE





1. Docket: 50-409                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: G. R. GADOW (608) 689-2331

4. Licensed Thermal Power (MWt):                      165

5. Nameplate Rating (Gross MWe):                      76.8 X 0.85 = 65

6. Design Electrical Rating (Net MWe):                      50

7. Maximum Dependable Capacity (Gross MWe):                      50

8. Maximum Dependable Capacity (Net MWe):                      48

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:                                     
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>125,619.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,315.7</u>	<u>82,060.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>478.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,211.7</u>	<u>76,048.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>79.0</u>
17. Gross Therm Ener (MWH)	<u>113,026</u>	<u>180,283</u>	<u>10,462,587</u>
18. Gross Elec Ener (MWH)	<u>36,817</u>	<u>57,835</u>	<u>3,115,063</u>
19. Net Elec Ener (MWH)	<u>35,051</u>	<u>54,638</u>	<u>2,881,873</u>
20. Unit Service Factor	<u>100.0</u>	<u>84.1</u>	<u>60.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>84.1</u>	<u>60.6</u>
22. Unit Cap Factor (MDC Net)	<u>104.9</u>	<u>79.0</u>	<u>47.8</u>
23. Unit Cap Factor (DER Net)	<u>100.7</u>	<u>75.9</u>	<u>45.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.8</u>	<u>9.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>22.1</u>	<u>6,865.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      LA CROSSE                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LA CROSSE



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
LACROSSE OPERATED AT FULL POWER WITH NO OUTAGES OR  
REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* LA CROSSE \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....VERNON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LACROSSE, WISC  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JULY 11, 1967  
DATE ELEC ENER 1ST GENER...APRIL 26, 1968  
DATE COMMERCIAL OPERATE...NOVEMBER 1, 1969  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DAIRYLAND POWER  
CORPORATE ADDRESS.....2615 EAST AVENUE SOUTH  
LACROSSE, WISCONSIN 54601  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...ALLIS-CHALMERS  
CONSTRUCTOR.....MAXON CONSTRUCTION COMPANY  
TURBINE SUPPLIER.....ALLIS-CHALMERS

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. WIEBE  
LICENSING PROJ MANAGER....R. DUDLEY  
DOCKET NUMBER.....50-409  
LICENSE & DATE ISSUANCE...DPR-45, AUGUST 28, 1973  
PUBLIC DOCUMENT ROOM.....LA CROSSE PUBLIC LIBRARY  
800 MAIN STREET  
LA CROSSE, WISCONSIN 54601

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 18 - JANUARY 18, (83-22): ROUTINE, UNANNOUNCED INSPECTION OF: FOLLOWUP ON PREVIOUS INSPECTION FINDINGS; LICENSEE EVENT REPORT FOLLOW-UP; OPERATIONAL SAFETY VERIFICATION; SYSTEMATIC EVALUATION PROGRAM ACTION ITEMS; TMI TASK ACTION PLAN ITEM FOLLOW-UP; REFUELING ACTIVITIES; REACTOR STARTUP; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED 92 INSPECTOR-HOURS ONSITE BY FIVE INSPECTORS INCLUDING 9 INSPECTOR-HOURS ONSITE DURING OFFSHIFTS. OF THE EIGHT AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN SEVEN AREAS. ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE AREA OF LICENSEE EVENT REPORT FOLLOW-UP (FAILURE TO CALIBRATE INSTRUMENTATION).

INSPECTION ON JANUARY 9-13, (84-01): INCLUDED A REVIEW OF SECURITY ORGANIZATION (MANAGEMENT/PERSONNEL/RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (VITAL AND PROTECTED); SECURITY SYSTEM POWER SUPPLY; ASSESSMENT AIDS; ACCESS CONTROL (PERSONNEL/PACKAGES/VEHICLES); DETECTION AIDS (PROTECTED/VITAL); ALARM STATIONS; AND COMMUNICATIONS. THE INSPECTION INVOLVED 37 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. THE INSPECTION BEGAN DURING THE DAY-SHIFT; 3 OF THE INSPECTION HOURS WERE ACCOMPLISHED DURING THE OFF-SHIFT PERIODS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THIS INSPECTION.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1984

I N S P E C T I O N    S T A T U S    -    (CONTINUED)

\*\*\*\*\*  
\*                    LA CROSSE                    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JANUARY 9-13, 1984

INSPECTION REPORT NO: 84-01

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-373                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: DIANA L. LIN (815) 357-6761 X481

4. Licensed Thermal Power (MWt):                      3323

5. Nameplate Rating (Gross MWe):                      1078

6. Design Electrical Rating (Net MWe):                      1078

7. Maximum Dependable Capacity (Gross MWe):                      1078

8. Maximum Dependable Capacity (Net MWe):                      1078

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,460.0</u>	<u>1,440.0</u>
13. Hours Reactor Critical	<u>273.7</u>	<u>817.7</u>	<u>817.7</u>
14. Rx Reserve Shtdwn Hrs	<u>407.3</u>	<u>589.4</u>	<u>589.4</u>
15. Hrs Generator On-Line	<u>267.4</u>	<u>734.9</u>	<u>734.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>1.0</u>	<u>1.0</u>
17. Gross Therm Ener (MWH)	<u>7,040,020</u>	<u>8,139,690</u>	<u>8,139,690</u>
18. Gross Elec Ener (MWH)	<u>229,288</u>	<u>576,910</u>	<u>576,910</u>
19. Net Elec Ener (MWH)	<u>211,758</u>	<u>539,632</u>	<u>539,632</u>
20. Unit Service Factor	<u>38.4</u>	<u>51.0</u>	<u>51.0</u>
21. Unit Avail Factor	<u>38.4</u>	<u>51.1</u>	<u>51.1</u>
22. Unit Cap Factor (MDC Net)	<u>28.2</u>	<u>34.8</u>	<u>34.8</u>
23. Unit Cap Factor (DER Net)	<u>28.2</u>	<u>34.8</u>	<u>34.8</u>
24. Unit Forced Outage Rate	<u>61.6</u>	<u>44.9</u>	<u>44.9</u>
25. Forced Outage Hours	<u>428.6</u>	<u>597.8</u>	<u>597.8</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/06/84

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

LASALLE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* LASALLE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	02/03/84	F	21.4	B	3				RX SCRAM DUE TO AN INADVERTENT INITIATION OF RCIC DURING PERFORMANCE OF LIS-NB-04.
6	02/13/84	F	407.2	A	3				RX SCRAM DUE TO "A" CONDENSER BOOT SEAL WHICH FAILED AND SUBSEQUENT LOSS OF CONDENSER VACUUM.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 LASALLE 1 OPERATED WITH 2 OUTAGES, SHUTTING DOWN ON FEBRUARY 13TH FOR EQUIPMENT REPAIR.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* LASALLE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LA SALLE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...11 MI SE OF  
OTTAWA, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 21, 1982  
DATE ELEC ENER 1ST GENER...SEPTEMBER 4, 1982  
DATE COMMERCIAL OPERATE....JANUARY 1, 1984  
CONDENSER COOLING METHOD...POND  
CONDENSER COOLING WATER...RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....W. GULDEMOND  
LICENSING PROJ MANAGER.....A. BOURNIA  
DOCKET NUMBER.....50-373  
LICENSE & DATE ISSUANCE....NPF-11, AUGUST 13, 1982  
PUBLIC DOCUMENT ROOM.....ILLINOIS VALLEY COMMUNITY COLLEGE  
RURAL ROUTE NO. 1  
OGLESBY, ILLINOIS 16348

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 17, THROUGH JANUARY 13, (83-53): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF LICENSEE ACTIONS ON PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; LICENSEE EVENT REPORTS; UNIT 2 LICENSE CONDITIONS; PERIODIC AND SPECIAL REPORTS; MAINTENANCE; UNIT 2 FUEL LOADING; REGIONAL REQUESTS; ONSITE FOLLOWUP OF SIGNIFICANT EVENTS; AND INDEPENDENT INSPECTION. THE INSPECTION INVOLVED A TOTAL OF 264 INSPECTOR-HOURS ONSITE BY THREE NRC INSPECTORS INCLUDING 32 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. OF THE 10 AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN 8 AREAS; TWO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN ONE AREA (FAILURE TO PERFORM A REQUIRED SURVEILLANCE; FAILURE TO FOLLOW PROCEDURES) AND ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:



OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY FOLLOWING REPAIRS TO CONDENSER.

LAST IE SITE INSPECTION DATE: JANUARY 31 THROUGH FEBRUARY 3, 1984

INSPECTION REPORT NO: 84-04

R E P O R T S   F R O M   L I C E N S E E

```

=====

```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-01	01/23/84	01/25/84	RADWASTE DISCHARGE WITH NO SAMPLE FLOW.
84-02	01/06/84	02/03/84	LOSS OF FEEDWATER CAUSING A LOW REACTOR WATER LEVEL SCRAM.
84-03	01/13/84	02/06/84	REACTOR SCRAM - MAIN GENERATOR TRIP.
84-04	01/18/84	02/10/84	SECONDARY CONTAINMENT ISOLATION.
84-05	01/16/84	02/15/84	RX SCRAM/LOSS OF MAIN CONDENSER.

```

=====

```

1. Docket: 50-309                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: S. BIEMILLER (617) 827-8100

4. Licensed Thermal Power (MWt):                      2630

5. Nameplate Rating (Gross MWe):                      864

6. Design Electrical Rating (Net MWe):                      825

7. Maximum Dependable Capacity (Gross MWe):                      850

8. Maximum Dependable Capacity (Net MWe):                      810

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>99,132.6</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,413.4</u>	<u>80,024.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,398.0</u>	<u>77,477.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,785,157</u>	<u>3,547,360</u>	<u>172,659,148</u>
18. Gross Elec Ener (MWH)	<u>581,520</u>	<u>1,157,480</u>	<u>56,510,630</u>
19. Net Elec Ener (MWH)	<u>562,062</u>	<u>1,118,625</u>	<u>53,820,327</u>
20. Unit Service Factor	<u>100.0</u>	<u>97.1</u>	<u>78.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>97.1</u>	<u>78.2</u>
22. Unit Cap Factor (MDC Net)	<u>99.7</u>	<u>95.9</u>	<u>69.2*</u>
23. Unit Cap Factor (DER Net)	<u>97.9</u>	<u>94.2</u>	<u>67.2*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.9</u>	<u>7.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>42.0</u>	<u>5,455.4</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      MAINE YANKEE                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MAINE YANKEE



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MAINE YANKEE \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	02/06/84	F	0.0	B	5		HH	HTEXCH	REDUCED POWER DUE TO CHLORIDE IN-LEAKAGE IN "D" WATERBOX AND TURBINE VALVE AND EXCESS FLOW CHECK VALVE TESTING.
	02/15/84	F	0.0	A	5		RB	CRDRVE	REDUCED POWER DUE TO DROPPED CEA #47.
	02/24/84	F	0.0	B	5		HH	HTEXCH	REDUCED POWER DUE TO CHLORIDE IN-LEAKAGE IN ALL WATERBOXES AND TURBINE VALVE AND EXCESS FLOW CHECK VALVE TESTING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 MAINE YANKEE OPERATED WITH 3 REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MAINE YANKEE \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MAINE  
COUNTY.....LINCOLN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI N OF  
BATH, ME  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 23, 1972  
DATE ELEC EMER 1ST GENER...NOVEMBER 8, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 28, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...BACK RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....MAINE YANKEE ATOMIC POWER  
CORPORATE ADDRESS.....83 EDISON DRIVE  
AUGUSTA, MAINE 04366  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....C. HOLDEN  
LICENSING PROJ MANAGER.....K. HEITNER  
DOCKET NUMBER.....50-309  
LICENSE & DATE ISSUANCE....DPR-36, JUNE 29, 1973  
PUBLIC DOCUMENT ROOM.....WISCASSET PUBLIC LIBRARY  
HIGH STREET  
WISCASSET, MAINE 04578

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   MAINE YANKEE                   \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-369 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: J. A. REAVIS (704) 373-8552

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1305

6. Design Electrical Rating (Net MWe): 1180

7. Maximum Dependable Capacity (Gross MWe): 1181

8. Maximum Dependable Capacity (Net MWe): 1180

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>19,704.0</u>
13. Hours Reactor Critical	<u>566.5</u>	<u>1,295.1</u>	<u>13,823.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>566.2</u>	<u>1,289.4</u>	<u>13,238.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,889,758</u>	<u>4,112,690</u>	<u>31,549,759</u>
18. Gross Elec Ener (MWH)	<u>641,299</u>	<u>1,442,257</u>	<u>10,959,381</u>
19. Net Elec Ener (MWH)	<u>615,331</u>	<u>1,386,041</u>	<u>10,342,296</u>
20. Unit Service Factor	<u>81.4</u>	<u>89.5</u>	<u>67.2</u>
21. Unit Avail Factor	<u>81.4</u>	<u>89.5</u>	<u>67.2</u>
22. Unit Cap Factor (MDC Net)	<u>74.9</u>	<u>81.6</u>	<u>44.5</u>
23. Unit Cap Factor (DER Net)	<u>74.9</u>	<u>81.6</u>	<u>44.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>1.6</u>	<u>19.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>20.8</u>	<u>3,106.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
CURRENTLY REFUELING.

27. If Currently Shutdown Estimated Startup Date: 04/24/84

\*\*\*\*\*  
\* MCGUIRE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MCGUIRE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
4-P	02/01/84	F	0.0	D	5		ZZ	ZZZZZZ	AXIAL FLUX DIFF PENALTY TIME.
5-P	02/01/84	F	0.0	A	5		CC	VALEX	#4 GOVERNOR VALVE ISOLATED.
3	02/24/84	S	129.8	C	1		RC	FUELXX	END OF CYCLE 1. REFUELING OUTAGE BEGINS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 MCGUIRE 1 OPERATED WITH 2 REDUCTIONS, SHUTTING DOWN ON  
 FEBRUARY 24TH FOR REFUELING.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
MCGUIRE 1  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NORTH CAROLINA  
COUNTY.....MECKLENBURG  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI N OF  
CHARLOTTE, NC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1981  
DATE ELEC ENER 1ST GENER...SEPTEMBER 12, 1981  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1981  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE NORMAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE POWER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....W. ORDERS  
LICENSING PROJ MANAGER....R. BIRKEL  
DOCKET NUMBER.....50-369  
LICENSE & DATE ISSUANCE...NPF-9, JULY 8, 1981  
PUBLIC DOCUMENT ROOM.....MS. DAWN HUBBS  
ATKINS LIBRARY  
UNIVERSITY OF NORTH CAROLINA - CHARLOTTE  
UNCC STATION,  
CHARLOTTE, NC 28223

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 20 - DECEMBER 20 (83-47): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 38 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, SURVEILLANCE TESTING, AND MAINTENANCE ACTIVITIES. OF THE THREE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN ONE AREA; TWO ITEMS OF NONCOMPLIANCE WERE FOUND IN TWO AREAS (VIOLATION - FAILURE TO USE A PROCEDURE RESULTING IN LOSS OF CONTAINMENT INTEGRITY (50-369/83-47-02) - PARAGRAPH 9; VIOLATION - FAILURE TO USE A PROCEDURE RESULTING IN LOSS OF SOURCE RANGE INSTRUMENTATION (50-369/83-47-01) - PARAGRAPH 7).

INSPECTION DECEMBER 20, 1983 - JANUARY 20, 1984 (83-48): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 74 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF OPERATIONS SAFETY VERIFICATION, SURVEILLANCE TESTING, MAINTENANCE ACTIVITIES, INDEPENDENT VERIFICATION, AND SHIFT MANNING. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; ONE VIOLATION WAS FOUND IN ONE AREA (VIOLATION - FAILURE TO ABIDE BY PROCEDURE CONCERNING EMERGENCY PLAN IMPLEMENTATION RESULTING IN INADEQUATE EMERGENCY KITS (50-369/83-48-01).

INSPECTION JANUARY 23-27 (84-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 21 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT WATER CHEMISTRY AND INSERVICE TESTING OF PUMPS AND VALVES. OF THE TWO AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 30-31 (84-03): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 6 INSPECTOR-HOURS ON SITE IN THE EMERGENCY







THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-370                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: J. A. REAVIS EXT (704) 373-7567

4. Licensed Thermal Power (MWt):                      3411

5. Nameplate Rating (Gross MWe):                      1450 X .9 = 1305

6. Design Electrical Rating (Net MWe):                      1180

7. Maximum Dependable Capacity (Gross MWe):                      1180

8. Maximum Dependable Capacity (Net MWe):                      1180

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>696.0</u>	<u>696.0</u>

13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>.0</u>
----------------------------	-----------	-----------	-----------

14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
---------------------------	-----------	-----------	-----------

15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>.0</u>
---------------------------	-----------	-----------	-----------

16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
-----------------------------	-----------	-----------	-----------

17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
----------------------------	----------	----------	----------

18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
---------------------------	----------	----------	----------

19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
-------------------------	----------	----------	----------

20. Unit Service Factor

21. Unit Avail Factor                                      NOT IN

22. Unit Cap Factor (MDC Net)                                      COMMERCIAL

23. Unit Cap Factor (DER Net)                                      OPERATION

24. Unit Forced Outage Rate

25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>.0</u>
-------------------------	-----------	-----------	-----------

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      MCGUIRE 2                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

MCGUIRE 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MCGUIRE 2 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MCGUIRE 2 IS PRESENTLY IN POWER ASCENSION.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





1. Docket: 50-245 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: GEORGE HARRAN (203) 447-1791 X4194

4. Licensed Thermal Power (Mwt): 2011

5. Nameplate Rating (Gross MWe): 735 X 0.9 = 662

6. Design Electrical Rating (Net MWe): 660

7. Maximum Dependable Capacity (Gross MWe): 684

8. Maximum Dependable Capacity (Net MWe): 654

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         


11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>116,184.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>88,204.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,775.8</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>85,457.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>26.5</u>
17. Gross Therm Ener (MWH)	<u>1,374,192</u>	<u>2,839,710</u>	<u>155,888,578</u>
18. Gross Elec Ener (MWH)	<u>471,400</u>	<u>974,100</u>	<u>52,337,296</u>
19. Net Elec Ener (MWH)	<u>450,642</u>	<u>931,064</u>	<u>49,912,321</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>73.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>73.6</u>
22. Unit Cap Factor (MDC Net)	<u>99.0</u>	<u>98.9</u>	<u>65.7</u>
23. Unit Cap Factor (DER Net)	<u>98.1</u>	<u>98.0</u>	<u>65.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>13.8</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>5,673.7</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>APRIL 15, 1984, REFUELING, 12 WEEKS.</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### MILLSTONE 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MILLSTONE 1 OPERATED WITH NO REPORTED OUTAGES OR REDUCTIONS  
IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MILLSTONE 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI SW OF  
NEW LONDON, CONN  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 26, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 29, 1970  
DATE COMMERCIAL OPERATE...MARCH 1, 1971  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LONG ISLAND SOUND  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. SHEDLOSKY  
LICENSING PROJ MANAGER.....J. SHEA  
DOCKET NUMBER.....50-245  
LICENSE & DATE ISSUANCE...DPR-21, OCTOBER 26, 1970  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
45 ROPE FERRY ROAD  
ROUTE 156  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   MILLSTONE 1                   \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-336 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: J. GIBSON (203) 447-1791 X 4419

4. Licensed Thermal Power (MWh): 2700

5. Nameplate Rating (Gross MWe): 1011 X 0.9 = 910

6. Design Electrical Rating (Net MWe): 870

7. Maximum Dependable Capacity (Gross MWe): 895

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>71,712.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,316.9</u>	<u>49,681.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,166.9</u>
15. Hrs Generator On-Line	<u>577.7</u>	<u>1,014.1</u>	<u>47,196.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
17. Gross Therm Ener (MWH)	<u>1,507,373</u>	<u>2,317,304</u>	<u>118,633,680</u>
18. Gross Elec Ener (MWH)	<u>486,800</u>	<u>735,401</u>	<u>38,532,773</u>
19. Net Elec Ener (MWH)	<u>464,632</u>	<u>692,899</u>	<u>36,909,647</u>
20. Unit Service Factor	<u>83.0</u>	<u>70.4</u>	<u>65.8</u>
21. Unit Avail Factor	<u>83.0</u>	<u>70.4</u>	<u>66.5</u>
22. Unit Cap Factor (MDC Net)	<u>77.6</u>	<u>56.0</u>	<u>61.2*</u>
23. Unit Cap Factor (DER Net)	<u>76.7</u>	<u>55.3</u>	<u>60.4*</u>
24. Unit Forced Outage Rate	<u>17.0</u>	<u>14.6</u>	<u>19.0</u>
25. Forced Outage Hours	<u>118.3</u>	<u>173.4</u>	<u>9,796.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

## MILLSTONE 2



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
2	02/13/84	F	118.3	A	1	84-006		SEVERAL REACTOR COOLANT SYSTEM RTD'S EXCEEDED THE TECH. SPEC. RESPONSE TIME. SEE LER 84-006.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
MILLSTONE 2 OPERATED WITH 1 OUTAGE FOR EQUIPMENT FAILURE IN FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MILLSTONE 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CONNECTICUT  
COUNTY.....NEW LONDON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI SW OF  
NEW LONDON, CONN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 17, 1975  
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1975  
DATE COMMERCIAL OPERATE....DECEMBER 26, 1975  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LONG ISLAND SOUND  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHEAST NUCLEAR ENERGY  
CORPORATE ADDRESS.....P.O. BOX 270  
HARTFORD, CONNECTICUT 06101  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. SHEDLOSKY  
LICENSING PROJ MANAGER....K. HEITNER  
DOCKET NUMBER.....50-336  
LICENSE & DATE ISSUANCE...DPR-65, SEPTEMBER 30, 1975  
PUBLIC DOCUMENT ROOM.....WATERFORD PUBLIC LIBRARY  
45 ROPE FERRY ROAD  
ROUTE 156  
WATERFORD, CONNECTICUT 06385

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):



1. Docket: 50-263 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: A. L. Myrabo (612) 295-5151

4. Licensed Thermal Power (MWt): 1670

5. Nameplate Rating (Gross MWe): 632 X 0.9 = 569

6. Design Electrical Rating (Net MWe): 545

7. Maximum Dependable Capacity (Gross MWe): 553

8. Maximum Dependable Capacity (Net MWe): 525

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>111,049.0</u>
13. Hours Reactor Critical	<u>66.5</u>	<u>810.5</u>	<u>89,915.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>940.7</u>
15. Hrs Generator On-Line	<u>64.8</u>	<u>808.8</u>	<u>88,003.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>57,552</u>	<u>897,898</u>	<u>141,233,814</u>
18. Gross Elec Ener (MWH)	<u>18,649</u>	<u>296,117</u>	<u>45,185,053</u>
19. Net Elec Ener (MWH)	<u>15,749</u>	<u>279,133</u>	<u>43,191,439</u>
20. Unit Service Factor	<u>9.3</u>	<u>56.2</u>	<u>79.2</u>
21. Unit Avail Factor	<u>9.3</u>	<u>56.2</u>	<u>79.2</u>
22. Unit Cap Factor (MDC Net)	<u>4.3</u>	<u>36.9</u>	<u>74.1</u>
23. Unit Cap Factor (DER Net)	<u>4.2</u>	<u>35.6</u>	<u>71.4</u>
24. Un. + Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.3</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>1,288.8</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Start-up Date: 09/14/84

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### MONTICELLO



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* MONTICELLO \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/02/84	S	0.0	B	5		HA	TURBIN	REDUCED POWER TO PERFORM TURBINE AND FEEDWATER HEATER TESTING.
2	02/03/84	S	631.2	C	1		RC	FUELXX	START OF 1984 REFUELING OUTAGE.

\*\*\*\*\* MONTICELLO SHUTDOWN ON FEBRUARY 3RD FOR REFUELING  
 \* SUMMARY \*  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* MONTICELLO \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period rEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....WRIGHT  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI NW OF  
MINNEAPOLIS, MINN  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...DECEMBER 10, 1970  
DATE ELEC ENER 1ST GENER...MARCH 5, 1971  
DATE COMMERCIAL OPERATE...JUNE 30, 1971  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....C. BROWN  
LICENSING PROJ MANAGER.....H. NICOLARAS  
DOCKET NUMBER.....50-263  
LICENSE & DATE ISSUANCE...DPR-22, JANUARY 9, 1981  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 2, 10, (83-22): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF OPERATIONAL SAFETY AND ONSITE REVIEW COMMITTEE. THE INSPECTION INVOLVED A TOTAL OF 25 INSPECTOR-HOURS ONSITE BY 1 NRC INSPECTOR INCLUDING 4 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JANUARY 11 - FEBRUARY 1, (84-01): A ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTOR OF OPERATIONAL SAFETY; LICENSEE EVENT REPORTS; IE BULLETINS; IE CIRCULARS; PREPARATION FOR REFUELING; ONSITE REVIEW COMMITTEE; AND PROCEDURES. THE INSPECTION INVOLVED A TOTAL OF 189 INSPECTOR-HOURS ONSITE BY 3 NRC INSPECTORS INCLUDING 30 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS



1. Docket: 50-220                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: JAN HALLENBECK (315) 349-2555

4. Licensed Thermal Power (MWt):                      1850

5. Nameplate Rating (Gross MWe):                      755 X 0.85 = 642

6. Design Electrical Rating (Net MWe):                      620

7. Maximum Dependable Capacity (Gross MWe):                      630

8. Maximum Dependable Capacity (Net MWe):                      610

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>125,616.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>87,742.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,204.2</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>84,928.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>20.2</u>
17. Gross Therm Ener (MWH)	<u>1,145,253</u>	<u>2,473,242</u>	<u>140,567,599</u>
18. Gross Elec Ener (MWH)	<u>385,718</u>	<u>837,348</u>	<u>46,469,130</u>
19. Net Elec Ener (MWH)	<u>373,706</u>	<u>811,557</u>	<u>45,006,316</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>67.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>67.6</u>
22. Unit Cap Factor (MDC Net)	<u>88.0</u>	<u>92.4</u>	<u>58.7</u>
23. Unit Cap Factor (DER Net)	<u>86.6</u>	<u>90.9</u>	<u>57.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>17.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,940.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUEL AND OVERHAUL MARCH 16, 1984 - 8 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      NINE MILE POINT 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NINE MILE POINT 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* NINE MILE POINT 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-4	02/04/84	S	0.0	H	5				LOAD REDUCTION TO 70.5% TO PULL CONTROL RODS.
84-5	02/25/84	S	0.0	H	5				LOAD REDUCTION TO 73.3% TO PULL CONTROL RODS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 NINE MILE POINT 1 OPERATED WITH 2 REDUCTIONS AND NO  
 OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* NINE MILE POINT 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW YORK  
COUNTY.....OSWEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...8 MI NE OF  
OSWEGO, NY  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1969  
DATE ELEC ENER 1ST GENER...NOVEMBER 9, 1969  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1969  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ONTARIO  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NIAGARA MOHAWK POWER  
CORPORATE ADDRESS.....300 ERIE BOULEVARD WEST  
SYRACUSE, NEW YORK 13202  
CONTRACTOR  
ARCHITECT/ENGINEER.....NIAGARA MOHAWK POWER CORP.  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....S. HUDSON  
LICENSING PROJ MANAGER.....R. HERMANN  
DOCKET NUMBER.....50-220  
LICENSE & DATE ISSUANCE...DPR-63, DECEMBER 26, 1974  
PUBLIC DOCUMENT ROOM.....STATE UNIVERSITY COLLEGE OF OSWEGO  
PENFIELD LIBRARY - DOCUMENTS  
OSWEGO, NY 13126  
(315) 341-2323

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           NINE MILE POINT 1           \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-338 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + Or-line Hrs: 696.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 930

8. Maximum Dependable Capacity (Net MWe): 883

9. If Changes Occur Above Since Last Report, Give Reasons:  
MDC NET CHANGED TO REFLECT SERVICE LOADS.

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>50,281.0</u>
13. Hours Reactor Critical	<u>494.6</u>	<u>708.6</u>	<u>34,295.7</u>
14. Rx Reserve Shtdwn Hrs	<u>7.1</u>	<u>7.1</u>	<u>2,182.8</u>
15. Hrs Generator On-Line	<u>490.5</u>	<u>687.8</u>	<u>33,349.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,293,539</u>	<u>1,833,192</u>	<u>86,888,969</u>
18. Gross Elec Ener (MWH)	<u>436,500</u>	<u>618,215</u>	<u>28,002,401</u>
19. Net Elec Ener (MWH)	<u>413,439</u>	<u>586,119</u>	<u>26,417,333</u>
20. Unit Service Factor	<u>70.5</u>	<u>47.8</u>	<u>66.3</u>
21. Unit Avail Factor	<u>70.5</u>	<u>47.8</u>	<u>66.3</u>
22. Unit Cap Factor (MDC Net)	<u>67.3</u>	<u>46.3</u>	<u>59.5</u>
23. Unit Cap Factor (DER Net)	<u>65.5</u>	<u>44.9</u>	<u>57.9</u>
24. Unit Forced Outage Rate	<u>29.5</u>	<u>52.2</u>	<u>14.0</u>
25. Forced Outage Hours	<u>205.5</u>	<u>752.2</u>	<u>5,320.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE 5/11/84; FALL MAINT. 11/23/84

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* NORTH ANNA 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### NORTH ANNA 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* NORTH ANNA 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
84-02	01/08/84	F	201.4	A	4			HIGH REACTOR COOLANT SYSTEM LEAK RATE OUTAGE CONTINUES FROM LAST MONTH. ENDED MONTH OF JANUARY WITH UNIT OFF-LINE. UNIT WAS ON-LINE FEBRUARY 8, 1984 AT 0924.
84-03	02/08/84	F	4.1	A	3			HIGH VIBRATION ON EHC PUMPS CAUSED A LOW EHC LEVEL TURBINE TRIP. REPAIRS MADE AND UNIT BACK ON-LINE AT 1410 FEBRUARY 8, 1984.
84-04	02/18/84	S	0.0	B	5			UNIT RAMPED DOWN FOR TURBINE VALVE FREEDOM TEST. UNIT RETURNED TO FULL POWER.
84-05	02/25/84	S	0.0	B	5			UNIT RAMPED DOWN FOR TURBINE VALVE FREEDOM TEST. UNIT RETURNED TO FULL POWER. ENDED THIS MONTH WITH UNIT AT 100% POWER.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 NORTH ANNA 1 RETURNED ONLINE FEBRUARY 8TH FROM AN EQUIPMENT REPAIR OUTAGE AND OPERATED ROUTINELY THE REMAINDER OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* NORTH ANNA 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....LOUISA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 5, 1978  
DATE ELEC EMER 1ST GENER...APRIL 17, 1978  
DATE COMMERCIAL OPERATE....JUNE 6, 1978  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE ANNA  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA ELECTRIC & POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. JOHNSON  
LICENSING PROJ MANAGER.....L. ENGLE  
DOCKET NUMBER.....50-338  
LICENSE & DATE ISSUANCE....NPF-4, APRIL 1, 1978  
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.  
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901  
& LOUISA COUNTY COURTHOUSE,  
LOUISA, VA 23093

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 6, 1983 - JANUARY 5, 1984 (83-31): THIS ROUTINE INSPECTION INVOLVED 64 INSPECTOR-HOURS ON SITE IN THE AREAS OF SURVEILLANCE AND MAINTENANCE ACTIVITIES, PREVIOUS INSPECTION FINDINGS, FOLLOW-UP OF PREVIOUSLY IDENTIFIED ITEMS, SAFETY SYSTEM WALKDOWNS, LICENSEE EVENT REPORTS, COLD WEATHER PROTECTION, FIRE PROTECTION AND PLANT OPERATIONS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS. TWO APPARENT VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO MAINTAIN PROCEDURES, PARAGRAPHS 9 AND 10 AND FAILURE TO INSPECT FIRE BARRIERS, PARAGRAPH 9).

INSPECTION FEBRUARY 6-10 (84-03): THE INSPECTION INVOLVED 14 INSPECTOR-HOURS ON SITE BY ONE NRC INSPECTOR. THE INSPECTION WAS BEGUN DURING A NORMAL SHIFT PERIOD; ONE AND ONE-HALF INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED SECURITY ORGANIZATION - PERSONNEL, SECURITY PROGRAM AUDIT, TESTING AND MAINTENANCE, PHYSICAL BARRIERS - PROTECTED AREA/VITAL AREAS, SECURITY SYSTEM POWER SUPPLY, ASSESSMENT AIDS, ACCESS CONTROL - PERSONNEL/PACKAGES/ VEHICLES, DETECTION AIDS - PROTECTED/VITAL AREAS, ALARM STATIONS, AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 14 AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEM: ACCESS CONTROL - PERSONNEL.

ENFORCEMENT SUMMARY

TECHNICAL SPECIFICATION 4.7.15A REQUIRES THAT EACH FIRE BARRIER PROTECTING SAFETY RELATED AREAS BE VERIFIED FUNCTIONAL BY A VISUAL



1. Docket: 50-339 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: JOAN N. LEE (703) 894-5151 X2527

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 947

6. Design Electrical Rating (Net MWe): 907

7. Maximum Dependable Capacity (Gross MWe): 939

8. Maximum Dependable Capacity (Net MWe): 890

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>28,152.0</u>
13. Hours Reactor Critical	<u>621.7</u>	<u>1,365.7</u>	<u>21,012.6</u>
14. Rx Reserve Shtdwn Hrs	<u>3.5</u>	<u>3.5</u>	<u>2,243.5</u>
15. Hrs Generator On-Line	<u>584.5</u>	<u>1,328.5</u>	<u>20,116.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,474,396</u>	<u>3,431,253</u>	<u>53,852,283</u>
18. Gross Elec Ener (MWH)	<u>483,285</u>	<u>1,123,980</u>	<u>17,860,347</u>
19. Net Elec Ener (MWH)	<u>457,966</u>	<u>1,065,901</u>	<u>16,917,983</u>
20. Unit Service Factor	<u>84.0</u>	<u>92.3</u>	<u>73.2</u>
21. Unit Avail Factor	<u>84.0</u>	<u>92.3</u>	<u>73.2</u>
22. Unit Cap Factor (MDC Net)	<u>73.9</u>	<u>83.2</u>	<u>67.5</u>
23. Unit Cap Factor (DER Net)	<u>72.5</u>	<u>81.6</u>	<u>66.3</u>
24. Unit Forced Outage Rate	<u>16.0</u>	<u>7.7</u>	<u>14.7</u>
25. Forced Outage Hours	<u>111.5</u>	<u>111.5</u>	<u>3,559.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MAINTENANCE 03/30/84; REFUELING 9/21/84.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* NORTH ANNA 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

NORTH ANNA 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* NORTH ANNA 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-05	02/03/84	F	111.5	G	2				RAMPED DOWN DUE TO INJECTION OF SULFURIC ACID INTO UNIT 2 CONDENSATE STREAM AND ULTIMATELY INTO THE UNIT'S STEAM GENERATORS. FOLLOWING CHEMICAL CLEAN UP THE UNIT WAS RETURNED TO SERVICE.
84-06	02/10/84	S	0.0	B	5				RAMPED DOWN FOR TURBINE VALVE FREEDOM TEST. UNIT RETURNED TO FULL POWER.
84-07	02/12/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-08	02/13/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-09	02/14/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-10	02/16/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-11	02/19/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-12	02/19/84	S	0.0	B	5				RAMPED DOWN FOR LOAD FOLLOWING. UNIT RETURNED TO FULL POWER.
84-13	02/25/84	S	0.0	B	5				RAMPED DOWN FOR TURBINE VALVE FREEDOM TEST. UNIT RETURNED TO FULL POWER. ENDED THIS MONTH WITH UNIT AT 100%.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 NORTH ANNA 2 OPERATED WITH 8 REDUCTIONS AND 1 OUTAGE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	D-Regulatory Restriction	5-Reduced Load	Licensee Event Report
	E-Operator Training & License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* NORTH ANNA 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....LOUISA  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI NW OF  
RICHMOND, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 12, 1980  
DATE ELEC ENER 1ST GENER...AUGUST 25, 1980  
DATE COMMERCIAL OPERATE...DECEMBER 14, 1980  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE ANNA  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA ELECTRIC & POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. JOHNSON  
LICENSING PROJ MANAGER.....L. ENGLE  
DOCKET NUMBER.....50-339  
LICENSE & DATE ISSUANCE...NPF-7, AUGUST 21, 1980  
PUBLIC DOCUMENT ROOM.....ALDERMAN LIBRARY/MANUSCRIPTS DEPT.  
UNIV. OF VIRGINIA/CHARLOTTESVILLE VA 22901  
& LOUISA COUNTY COURTHOUSE,  
LOUISA, VA 23093

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 6, 1983 - JANUARY 5, 1984 (83-31): THIS ROUTINE INSPECTION INVOLVED 64 INSPECTOR-HOURS ON SITE IN THE AREAS OF SURVEILLANCE AND MAINTENANCE ACTIVITIES, PREVIOUS INSPECTION FINDINGS, FOLLOW-UP OF PREVIOUSLY IDENTIFIED ITEMS, SAFETY SYSTEM WALKDOWNS, LICENSEE EVENT REPORTS, COLD WEATHER PROTECTION, FIRE PROTECTION AND PLANT OPERATIONS. OF THE NINE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN SEVEN AREAS. TWO APPARENT VIOLATIONS WERE IDENTIFIED IN THE REMAINING TWO AREAS (FAILURE TO MAINTAIN PROCEDURES, PARAGRAPHS 9 AND 10 AND FAILURE TO INSPECT FIRE BARRIERS, PARAGRAPH 9).

INSPECTION FEBRUARY 6-10 (84-03): THE INSPECTION INVOLVED 15 INSPECTOR-HOURS ON SITE BY ONE NRC INSPECTOR. THE INSPECTION WAS BEGUN DURING A NORMAL SHIFT PERIOD; ONE AND ONE-HALF INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED SECURITY ORGANIZATION - PERSONNEL, SECURITY PROGRAM AUDIT, TESTING AND MAINTENANCE, PHYSICAL BARRIERS - PROTECTED AREA/VITAL AREAS, SECURITY SYSTEM POWER SUPPLY, ASSESSMENT AIDS, ACCESS CONTROL - PERSONNEL/PACKAGES/ VEHICLES, DETECTION AIDS - PROTECTED/VITAL AREAS, ALARM STATIONS, AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 14 AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEM: ACCESS CONTROL - PERSONNEL.

ENFORCEMENT SUMMARY

NONE



1. Docket: 50-269 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt): 2568

5. Nameplate Rating (Gross MWe): 1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe): 887

7. Maximum Dependable Capacity (Gross MWe): 899

8. Maximum Dependable Capacity (Net MWe): 860

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>93,145.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>65,981.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>62,829.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,787,819</u>	<u>3,696,857</u>	<u>149,994,889</u>
18. Gross Elec Ener (MWH)	<u>626,220</u>	<u>1,297,480</u>	<u>52,165,710</u>
19. Net Elec Ener (MWH)	<u>599,828</u>	<u>1,242,415</u>	<u>49,407,966</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>67.5</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>67.5</u>
22. Unit Cap Factor (MDC Net)	<u>100.2</u>	<u>100.3</u>	<u>61.5*</u>
23. Unit Cap Factor (DER Net)	<u>97.2</u>	<u>97.3</u>	<u>59.9*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>17.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,047.6</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* OCONEE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 1



FEBRUARY 1984

\* Item calculated with a Weighted Average



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* OCONEE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2-P	02/13/84	S	0.0	F	5		ZZ	ZZZZZZ	DISPATCHER REDUCTION.
3-P	02/27/84	S	0.0	B	5		CC	VALVEX	PERIODIC TESTS (PT'S) - CONTROL VALVE AND STOP VALVE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 OCONEE 1 OPERATED AT FULL POWER WITH 2 REDUCTIONS  
 DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)
	F-Admin		
	G-Oper Error		
	H-Other		

\*\*\*\*\*  
\* OCONEE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 19, 1973  
DATE ELEC ENER 1ST GENER...MAY 6, 1973  
DATE COMMERCIAL OPERATE....JULY 15, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....LAKE KEOWEE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER....H. NICOLARAS  
DOCKET NUMBER.....50-269  
LICENSE & DATE ISSUANCE...DPR-38, FEBRUARY 6, 1973  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 6-10 (84-02): THE INSPECTION INVOLVED 11 INSPECTOR HOURS ON SITE BY ONE NRC INSPECTOR. ONE AND ONE-HALF INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED SITE ORIENTATION; REVIEW OF SECURITY PLAN REVISIONS; SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AREA); SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL (PERSONNEL, PACKAGES, AND VEHICLES); DETECTION AIDS (PROTECTED AND VITAL AREAS); ALARM STATIONS AND COMMUNICATIONS. THE INSPECTION ALSO CONSISTED OF A VISIT TO GENERAL OFFICE, DUKE POWER COMPANY. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEM: FAILURE TO MEET SPECIFIC REQUIREMENTS OF THE T&Q PLAN.

INSPECTION FEBRUARY 1-2 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 4 INSPECTOR HOURS ON SITE IN THE EMERGENCY PREPAREDNESS AREA OF PROTECTIVE ACTION DECISION MAKING. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

FAILURE TO IMPLEMENT SPECIFIC PORTIONS OF THE T & Q PLAN CONCERNING GUARD FORCE QUALIFICATIONS BY REQUIRED IMPLEMENTATION DATE OF APRIL 20, 1983.  
(8402 3)



1. Docket: 50-270                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt):                    2568

5. Nameplate Rating (Gross MWe):                    1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe):                    887

7. Maximum Dependable Capacity (Gross MWe):                    899

8. Maximum Dependable Capacity (Net MWe):                    860

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>83,065.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>58,753.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>57,600.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,790,632</u>	<u>3,699,486</u>	<u>136,190,152</u>
18. Gross Elec Ener (MWH)	<u>619,200</u>	<u>1,279,500</u>	<u>46,384,356</u>
19. Net Elec Ener (MWH)	<u>594,378</u>	<u>1,227,665</u>	<u>44,039,234</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>69.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>69.3</u>
22. Unit Cap Factor (MDC Net)	<u>99.3</u>	<u>99.1</u>	<u>61.5*</u>
23. Unit Cap Factor (DER Net)	<u>96.3</u>	<u>96.1</u>	<u>59.8*</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>16.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>10,256.1</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>NONE</u>			

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                    OCONEE 2                    \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

OCONEE 2



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3-P	02/18/84	S	0.0	B	5		CC	VALVEX	PERIODIC TESTS (PT'S) - TURBINE VALVE.

\*\*\*\*\* OCONEE 2 OPERATED AT FULL POWER WITH 1 REDUCTION DURING FEBRUARY.  
\* SUMMARY \*  
\*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* OCONEE 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
  
COUNTY.....OCONEE  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...NOVEMBER 11, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 5, 1973  
DATE COMMERCIAL OPERATE...SEPTEMBER 9, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE KEOWEE  
  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER....H. NICOLARAS  
DOCKET NUMBER.....50-270  
LICENSE & DATE ISSUANCE...DPR-47, OCTOBER 6, 1973  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 6-10 (84-02): THE INSPECTION INVOLVED 12 INSPECTOR HOURS ON SITE BY ONE NRC INSPECTOR. ONE AND ONE-HALF INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED SITE ORIENTATION; REVIEW OF SECURITY PLAN REVISIONS; SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AREA); SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL (PERSONNEL, PACKAGES, AND VEHICLES); DETECTION AIDS (PROTECTED AND VITAL AREAS); ALARM STATIONS AND COMMUNICATIONS. THE INSPECTION ALSO CONSISTED OF A VISIT TO GENERAL OFFICE, DUKE POWER COMPANY. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEM: FAILURE TO MEET SPECIFIC REQUIREMENTS OF THE T&Q PLAN.

INSPECTION FEBRUARY 1-2 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 4 INSPECTOR HOURS ON SITE IN THE EMERGENCY PREPAREDNESS AREA OF PROTECTIVE ACTION DECISION MAKING. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION V, FAILURE TO FOLLOW MAINTENANCE PROCEDURE FOR THE INSTALLATION OF SEAL STAGING COILS RESULTING IN NO RCP SEAL LEAKOFF FLOW.  
(8337 5)



1. Docket: 50-287                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: J. A. REAVIS (704) 373-7567

4. Licensed Thermal Power (MWt):                      2568

5. Nameplate Rating (Gross MWe):                      1038 X 0.9 = 934

6. Design Electrical Rating (Net MWe):                      887

7. Maximum Dependable Capacity (Gross MWe):                      899

8. Maximum Dependable Capacity (Net MWe):                      860

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>80,712.0</u>
13. Hours Reactor Critical	<u>694.9</u>	<u>1,438.9</u>	<u>58,148.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>693.0</u>	<u>1,437.0</u>	<u>57,020.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,760,898</u>	<u>3,670,368</u>	<u>139,162,931</u>
18. Gross Elec Ener (MWH)	<u>607,200</u>	<u>1,267,370</u>	<u>48,081,964</u>
19. Net Elec Ener (MWH)	<u>582,478</u>	<u>1,215,846</u>	<u>45,782,964</u>
20. Unit Service Factor	<u>99.6</u>	<u>99.8</u>	<u>70.6</u>
21. Unit Avail Factor	<u>99.6</u>	<u>99.8</u>	<u>70.6</u>
22. Unit Cap Factor (MDC Net)	<u>97.3</u>	<u>98.2</u>	<u>65.8*</u>
23. Unit Cap Factor (DER Net)	<u>94.4</u>	<u>95.2</u>	<u>64.0*</u>
24. Unit Forced Outage Rate	<u>.4</u>	<u>.2</u>	<u>14.9</u>
25. Forced Outage Hours	<u>3.0</u>	<u>3.0</u>	<u>10,145.0</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration): <u>REFUELING - MARCH 8, 1984 - 10 WEEKS</u>			
27. If Currently Shutdown Estimated Startup Date: <u>N/A</u>			

\*\*\*\*\*  
\*                      OCONEE 3                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### OCONEE 3



FEBRUARY 1984

\* Item calculated with a Weighted Average



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/16/84	F	3.0	A	3		CB	INSTRU	REACTOR COOLANT FLOW LOOP "A" FAILURE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
OCONEE 3 OPERATED AT FULL POWER WITH 1 SHORT DURATION  
OUTAGE FOR EQUIPMENT FAILURE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* OCONEE 3 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....OCONEE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...30 MI W OF  
GREENVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 5, 1974  
DATE ELEC ENER 1ST GENER...SEPTEMBER 18, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 16, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE KEOWEE  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....DUKE POWER  
CORPORATE ADDRESS.....422 SOUTH CHURCH STREET  
CHARLOTTE, NORTH CAROLINA 28242  
CONTRACTOR  
ARCHITECT/ENGINEER.....DUKE & BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....DUKE POWER  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....J. BRYANT  
LICENSING PROJ MANAGER.....H. NICOLARAS  
DOCKET NUMBER.....50-287  
LICENSE & DATE ISSUANCE...DPR-55, JULY 19, 1974  
PUBLIC DOCUMENT ROOM.....OCONEE COUNTY LIBRARY  
501 W. SOUTH BROAD ST.  
WALHALLA, SOUTH CAROLINA 29691

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION FEBRUARY 6-10 (84-02): THE INSPECTION INVOLVED 12 INSPECTOR HOURS ON SITE BY ONE NRC INSPECTOR. ONE AND ONE-HALF INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED SITE ORIENTATION; REVIEW OF SECURITY PLAN REVISIONS; SECURITY ORGANIZATION (PERSONNEL AND RESPONSE); SECURITY PROGRAM AUDIT; TESTING AND MAINTENANCE; PHYSICAL BARRIERS (PROTECTED AREA); SECURITY SYSTEM POWER SUPPLY; ACCESS CONTROL (PERSONNEL, PACKAGES, AND VEHICLES); DETECTION AIDS (PROTECTED AND VITAL AREAS); ALARM STATIONS AND COMMUNICATIONS. THE INSPECTION ALSO CONSISTED OF A VISIT TO GENERAL OFFICE, DUKE POWER COMPANY. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE AREAS EXAMINED DURING THE INSPECTION EXCEPT FOR THE FOLLOWING ITEM: FAILURE TO MEET SPECIFIC REQUIREMENTS OF THE T&Q PLAN.

INSPECTION FEBRUARY 1-2 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 4 INSPECTOR HOURS ON SITE IN THE EMERGENCY PREPAREDNESS AREA OF PROTECTIVE ACTION DECISION MAKING. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER : EMS



1. Docket: 50-219                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: JOSEPH R. MOLNAR (609) 971-4699

4. Licensed Thermal Power (MWt):                    1930

5. Nameplate Rating (Gross MWe):                    722 X .9 = 650

6. Design Electrical Rating (Net MWe):                    650

7. Maximum Dependable Capacity (Gross MWe):                    650

8. Maximum Dependable Capacity (Net MWe):                    620

9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_


11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>124,368.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>696.0</u>	<u>85,319.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>468.2</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>82,693.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>136,301,260</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>46,056,905</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>-1,991</u>	<u>44,283,692</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>66.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>66.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>57.4*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>54.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>11.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>8,916.8</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>NONE</u>		

27. If Currently Shutdown Estimated Startup Date: 06/11/84

\*\*\*\*\*  
 \* OYSTER CREEK 1 \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

### OYSTER CREEK 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
31	02/11/83	S	696.0	C	4		RC	FUELXX	REFUELING AND MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
OYSTER CREEK 1 REMAINS SHUTDOWN IN A CONTINUING REFUELING/  
MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* OYSTER CREEK 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
  
COUNTY.....OCEAN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...9 MI S OF  
TOMS RIVER, NJ  
  
TYPE OF REACTOR.....BWR  
  
DATE INITIAL CRITICALITY...MAY 3, 1969  
  
DATE ELEC ENER 1ST GENER...SEPTEMBER 23, 1969  
  
DATE COMMERCIAL OPERATE....DECEMBER 1, 1969  
  
CONDENSER COOLING METHOD...ONCE THRU  
  
CONDENSER COOLING WATER....BARNEGAT BAY  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GPU NUCLEAR CORPORATION  
  
CORPORATE ADDRESS.....100 INTERPACE PARKWAY  
PARSIPPANY, NEW JERSEY 07054  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BURNS & ROE  
  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
  
CONSTRUCTOR.....BURNS & ROE  
  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
  
IE RESIDENT INSPECTOR.....C. COWGILL  
  
LICENSING PROJ MANAGER.....J. LOMBARDO  
DOCKET NUMBER.....50-219  
  
LICENSE & DATE ISSUANCE....DPR-16, AUGUST 1, 1969  
  
PUBLIC DOCUMENT ROOM.....OCEAN COUNTY LIBRARY  
101 WASHINGTON STREET  
TOMS RIVER, NEW JERSEY 08753

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    OYSTER CREEK 1                    \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NO INPUT PROVIDED.

=====

1. Docket: 50-255 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: K. J. CAVADAS (616) 764-8913

4. Licensed Thermal Power (Mwt): 2530

5. Nameplate Rating (Gross MWe): 955 X 0.85 = 812

6. Design Electrical Rating (Net MWe): 805

7. Maximum Dependable Capacity (Gross MWe): 675

8. Maximum Dependable Capacity (Net MWe): 635

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE


10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PALISADES



	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>106,935.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>59,259.7</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>56,278.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>115,360,224</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>35,750,440</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>33,628,014</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>52.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>52.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>49.5</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>39.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>32.1</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>12,525.6</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 06/15/84

FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PALISADES \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	08/12/83	S	696.0	C	4		RC	FUELXX	REFUELING/MAINTENANCE OUTAGE CONTINUES.

\*\*\*\*\* POWER SITES REMAIN SHUTDOWN IN A CONTINUING  
 \* SUMMARY \* REFUELING/MAINTENANCE OUTAGE.  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PALISADES \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MICHIGAN  
  
COUNTY.....VANBUREN  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SOUTH HAVEN, MI  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...MAY 24, 1971  
  
DATE ELEC ENER 1ST GENER...DECEMBER 31, 1971  
  
DATE COMMERCIAL OPERATE...DECEMBER 31, 1971  
  
CONDENSER COOLING METHOD...COOLING TOWERS  
  
CONDENSER COOLING WATER...LAKE MICHIGAN  
  
ELECTRIC RELIABILITY  
COUNCIL.....EAST CENTRAL AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....CONSUMERS POWER  
  
CORPORATE ADDRESS.....212 WEST MICHIGAN AVENUE  
JACKSON, MICHIGAN 49201  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
  
IE RESIDENT INSPECTOR.....B. JORGENSON  
  
LICENSING PROJ MANAGER....W. PAULSON  
DOCKET NUMBER.....50-255  
  
LICENSE & DATE ISSUANCE...DPR-20, OCTOBER 16, 1972  
  
PUBLIC DOCUMENT ROOM.....KALAMAZOO PUBLIC LIBRARY  
315 SOUTH ROSE STREET  
REFERENCE DEPARTMENT  
KALAMAZOO, MICHIGAN 49007

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON NOVEMBER 11, AND JANUARY 17, (83-27): ROUTINE ANNOUNCED INSPECTION BY REGION III INSPECTOR OF CALCULATIONS CONCERNING ADEQUACY OF FAN COOLERS FOR THE ENGINEERED SAFEGUARDS ROOM AS REFERENCED IN LER 83-007. THIS INSPECTION INVOLVED A TOTAL OF 12 INSPECTOR-HOURS AT THE LICENSEE'S OFFICE BY ONE NRC INSPECTOR. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

INSPECTION ON JANUARY 18-20, (84-01): SPECIAL, ANNOUNCED INSPECTION OF THE RADIATION PROTECTION PROGRAM INCLUDING: AN UNEXPLAINED HIGH WHOLE BODY EXPOSURE; A LEAKING CONTAINER DURING TRANSPORT; TMI ACTION PLAN ITEMS; EMPLOYEE CONCERNS RELATED TO IE BULLETIN NO. 80-10; IMPLEMENTATION OF 10 CFR 61; STEAM GENERATOR REPAIR ACTIVITIES; OPEN ITEMS; AND HOUSEKEEPING. THE INSPECTION INVOLVED 24 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR. OF THE EIGHT AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN EACH OF THREE AREAS (PLANT ORGANIZATION NOT IN ACCORDANCE WITH TECHNICAL SPECIFICATIONS, LEAKING RADWASTE DRUM DURING TRANSPORT, AND NOBLE GAS EFFLUENT MONITOR NOT INSTALLED IN ACCORDANCE WITH MARCH 14, 1983, NRC ORDER).

INSPECTION DURING JANUARY 3 THROUGH JANUARY 31 (84-02): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTOR OF ACTION ON PREVIOUSLY IDENTIFIED ITEMS; PLANT SAFETY; MAINTENANCE; REPORTABLE EVENTS; AND MISCELLANEOUS ACTIVITIES. NON-ROUTINE INSPECTION COVERED REVIEW OF A POTENTIALLY SIGNIFICANT OPERATING EVENT INVOLVING LOSS OF BOTH OFFSITE AND ONSITE AC POWER ON JANUARY 8, 1984, WITH THE REACTOR COMPLETELY DEFUELED. THE INSPECTION INVOLVED A TOTAL OF 114 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR INCLUDING 37 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS ARE REPORTED HEREIN, FOR THE



1. Docket: 50-277                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (Mwt):                      3293

5. Nameplate Rating (Gross MWe):                      1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe):                      1065

7. Maximum Dependable Capacity (Gross MWe):                      1098

8. Maximum Dependable Capacity (Net MWe):                      1051

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>84,648.0</u>
13. Hours Reactor Critical	<u>495.1</u>	<u>1,187.9</u>	<u>60,887.0</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>481.3</u>	<u>1,150.6</u>	<u>59,162.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,467,302</u>	<u>3,611,784</u>	<u>174,166,394</u>
18. Gross Elec Ener (MWH)	<u>462,430</u>	<u>1,178,770</u>	<u>57,349,860</u>
19. Net Elec Ener (MWH)	<u>447,367</u>	<u>1,142,694</u>	<u>54,979,124</u>
20. Unit Service Factor	<u>69.2</u>	<u>79.9</u>	<u>69.9</u>
21. Unit Avail Factor	<u>69.2</u>	<u>79.9</u>	<u>69.9</u>
22. Unit Cap Factor (MDC Net)	<u>61.2</u>	<u>75.5</u>	<u>61.8</u>
23. Unit Cap Factor (DER Net)	<u>60.4</u>	<u>74.5</u>	<u>61.0</u>
24. Unit Forced Outage Rate	<u>8.0</u>	<u>9.2</u>	<u>11.9</u>
25. Forced Outage Hours	<u>41.7</u>	<u>116.4</u>	<u>7,975.6</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


REFUELING & PIPE MAINTENANCE: 04/27/84

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      PEACH BOTTOM 2                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PEACH BOTTOM 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PEACH BOTTOM 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	01/28/84	F	41.7	A	4		SA	VESSEL	SHUTDOWN CONTINUED DUE TO EXCESSIVE LEAKAGE THROUGH DRYWELL AIRLOCK DURING STARTUP PRESSURIZATION TEST.
2	02/18/84	S	173.0	B	1		CD	VALVEX	TEST ON MAIN STEAM ISOLATION VALVES AND FEEDWATER CHECK VALVES.
3	02/27/84	S	0.0	H	5		RC	ZZZZZ	CONTROL ROD PATTERN ADJUSTMENT.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 PEACH BOTTOM 2 RETURNED ONLINE FROM A REPAIR OUTAGE ON FEBRUARY 2ND AND OPERATED ROUTINELY WITH 1 OUTAGE AND 1 REDUCTION DURING THE REMAINDER OF FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	C-Refueling	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training & License Examination		

\*\*\*\*\*  
\* PEACH BOTTOM 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR.....BUR  
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1973  
DATE ELEC ENER 1ST GENER...FEBRUARY 18, 1974  
DATE COMMERCIAL OPERATE....JULY 5, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....A. BLOUGH  
LICENSING PROJ MANAGER.....G. GEARS  
DOCKET NUMBER.....50-277  
LICENSE & DATE ISSUANCE...DPR-44, DECEMBER 14, 1973  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    PEACH BOTTOM 2                    \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPU ROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NO INPUT PROVIDED.			

=====

1. Docket: 50-278 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: W. M. Alden (215) 841-5022

4. Licensed Thermal Power (MWt): 3293

5. Nameplate Rating (Gross MWe): 1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe): 1065

7. Maximum Dependable Capacity (Gross MWe): 1098

8. Maximum Dependable Capacity (Net MWe): 1035

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>80,544.0</u>
13. Hours Reactor Critical	<u>677.4</u>	<u>1,137.3</u>	<u>57,937.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>661.4</u>	<u>1,105.5</u>	<u>56,421.7</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,079,002</u>	<u>3,459,338</u>	<u>164,497,643</u>
18. Gross Elec Ener (MWH)	<u>689,900</u>	<u>1,144,170</u>	<u>53,959,290</u>
19. Net Elec Ener (MWH)	<u>670,622</u>	<u>1,110,918</u>	<u>51,774,703</u>
20. Unit Service Factor	<u>95.0</u>	<u>76.8</u>	<u>70.1</u>
21. Unit Avail Factor	<u>95.0</u>	<u>76.8</u>	<u>70.1</u>
22. Unit Cap Factor (MDC Net)	<u>93.1</u>	<u>74.5</u>	<u>62.1</u>
23. Unit Cap Factor (DER Net)	<u>90.5</u>	<u>72.4</u>	<u>60.4</u>
24. Unit Forced Outage Rate	<u>5.0</u>	<u>23.2</u>	<u>7.7</u>
25. Forced Outage Hours	<u>34.6</u>	<u>334.5</u>	<u>4,665.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### PEACH BOTTOM 3



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PEACH BOTTOM 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	02/09/84	F	34.6	A	3		CB	PUMPXX	AUTOMATIC SCRAM CAUSED BY POWER SPIKE RESULTING FROM PRESSURE SURGE ASSOCIATED WITH THE MALFUNCTIONING CONTROL CLOSING MAIN TURBINE VALVES.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 PEACH BOTTOM 3 OPERATED ROUTINELY WITH 1 OUTAGE FOR EQUIPMENT REPAIR DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PEACH BOTTOM 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....YORK  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...19 MI S OF  
LANCASTER, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...AUGUST 7, 1974  
DATE ELEC ENER 1ST GENER...SEPTEMBER 1, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 23, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PHILADELPHIA ELECTRIC  
CORPORATE ADDRESS.....2301 MARKET STREET  
PHILADELPHIA, PENNSYLVANIA 19105  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....A. BLOUGH  
LICENSING PROJ MANAGER.....G. GEARS  
DOCKET NUMBER.....50-278  
LICENSE & DATE ISSUANCE....DPR-56, JULY 2, 1974  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):



1. Docket: 50-293                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: P. HAMILTON (617) 746-7905

4. Licensed Thermal Power (MWT):                      1998

5. Nameplate Rating (Gross MWe):                      780 X 0.87 = 678

6. Design Electrical Rating (Net MWe):                      655

7. Maximum Dependable Capacity (Gross MWe):                      690

8. Maximum Dependable Capacity (Net MWe):                      670

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>98,400.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>69,733.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>67,521.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>116,932,632</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>39,228,314</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>37,693,409</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>68.6</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>68.6</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>57.2</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>58.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>9.2</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>6,842.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 09/09/84

\*\*\*\*\*  
\*                      P I L G R I M   1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

PILGRIM 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
16	12/10/83	S	695.0	C	4			SHUTDOWN FOR REFUELING AND RECIRCULATION PIPE REPAIR CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*

PILGRIM 1 REMAINS SHUTDOWN IN A CONTINUING REFUELING/REPAIR OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PILGRIM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MASSACHUSETTS  
COUNTY.....PLYMOUTH  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...4 MI SE OF  
PLYMOUTH, MASS  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...JUNE 16, 1972  
DATE ELEC ENER 1ST GENER...JULY 19, 1972  
DATE COMMERCIAL OPERATE...DECEMBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...CAPE COD BAY  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....BOSTON EDISON  
CORPORATE ADDRESS.....800 BOYLSTON STREET  
BOSTON, MASSACHUSETTS 02199  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....J. JOHNSON  
LICENSING PROJ MANAGER.....P. LEECH  
DOCKET NUMBER.....50-293  
LICENSE & DATE ISSUANCE...DPR-35, SEPTEMBER 15, 1972  
PUBLIC DOCUMENT ROOM.....PLYMOUTH PUBLIC LIBRARY  
11 NORTH STREET  
PLYMOUTH, MASSACHUSETTS 02360

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.



1. Docket: 50-266                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: C.W. FAY (414) 277-2811

4. Licensed Thermal Power (Mwt):                      1518

5. Nameplate Rating (Gross MWe):                      582 X 0.9 = 524

6. Design Electrical Rating (Net MWe):                      497

7. Maximum Dependable Capacity (Gross MWe):                      519

8. Maximum Dependable Capacity (Net MWe):                      485

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>116,736.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>94,078.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>625.4</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>91,607.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>793.5</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>123,535,312</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>41,395,980</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>39,367,882</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>78.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>79.2</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>69.0*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>67.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>2.7</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,406.3</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/19/84

\*\*\*\*\*  
\*                      POINT BEACH 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 1



FEBRUARY 1984

\* Item calculated with a Weighted Average



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	10/01/83	S	696.0	C	4		ZZ	ZZZZZZ	CONTINUATION OF 26-WEEK REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
POINT BEACH 1 REMAINS SHUTDOWN IN A CONTINUING REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

Type	Reason	Method	System & Component	
F-Forced	A-Equip Failure	F-Admin	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram	Instructions for
	C-Refueling	H-Other	3-Auto Scram	Preparation of
	D-Regulatory Restriction		4-Continued	Data Entry Sheet
	E-Operator Training		5-Reduced Load	Licensee Event Report
	& License Examination		9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* POINT BEACH 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...NOVEMBER 2, 1970  
DATE ELEC ENER 1ST GENER...NOVEMBER 6, 1970  
DATE COMMERCIAL OPERATE...DECEMBER 21, 1970  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER....T. COLBURN  
DOCKET NUMBER.....50-266  
LICENSE & DATE ISSUANCE...DPR-24, OCTOBER 5, 1970  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 11-14, 25-28, NOVEMBER 1-4 & 16, JANUARY 11, 1984 AND MANAGEMENT MEETING ON JANUARY 4 (83-21). SPECIAL ANNOUNCED INSPECTION BY REGIONAL INSPECTORS OF QA PROGRAM ADMINISTRATION, MAINTENANCE PROGRAM AND IMPLEMENTATION, DESIGN CHANGE AND MODIFICATION PROGRAM AND IMPLEMENTATION, PROCUREMENT, OFFSITE REVIEW COMMITTEE, DOCUMENT CONTROL, CALIBRATION AND CONTROL OF MEASURING AND TEST EQUIPMENT, SURVEILLANCE AND INSERVICE TESTING, CLEANLINESS CONTROL, AUDIT PROGRAM, STEAM GENERATOR REPLACEMENT PROGRAM. THE INSPECTION INVOLVED 269 INSPECTOR-HOURS ONSITE BY FOUR INSPECTORS, INCLUDING 66 INSPECTOR-HOURS AT CORPORATE HEADQUARTERS BY FOUR INSPECTORS. A MANAGEMENT MEETING WAS HELD WHICH INVOLVED 48 STAFF-HOURS. OF THE 14 AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; NINE ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THE REMAINING NINE AREAS (FAILURE TO MAINTAIN CLEANLINESS CONTROL, FAILURE TO CONTROL DOCUMENTS, FAILURE TO PROPERLY STORE RECORDS, FAILURE TO CONTROL STORED ITEMS, FAILURE TO PROPERLY CONDUCT AN AUDIT PROGRAM, FAILURE TO PERFORM 10 CFR 50.59 REVIEWS, AND FAILURE TO PROVIDE APPROPRIATE TRAINING.

SAFETY EVALUATION REPORT, DECEMBER - JANUARY (83-25): ROUTINE ANNOUNCED SAFETY EVALUATION REPORT OF SITE EMERGENCY PLAN OF NOVEMBER 11, 1983. THE INSPECTION INVOLVED 128 INSPECTOR-HOURS BY TWO NRC INSPECTORS. THE PLAN APPEARS TO MEET THE PLANNING STANDARDS OF 10 CFR PART 50.47 (B) AND THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX E; HOWEVER, CLARIFICATIONS ARE NEEDED TO CLOSE OUT SECTIONS A-D, G-J, L, AND N. ONE DEVIATION FROM A COMMITMENT WAS IDENTIFIED.

INSPECTION ON DECEMBER 1, TO JANUARY 31, (83-26): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF RECEIPT OF NEW FUEL; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; IE BULLETINS; INDEPENDENT INSPECTION; REGIONAL REQUESTS; TMI ACTION ITEMS; STEAM GENERATOR REPLACEMENT ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 434 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS INCLUDING 120

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   POINT BEACH 1                   \*  
\*\*\*\*\*

INSPECTION SUMMARY

HOURS ON OFFSHIFTS. OF THE NINE AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN EIGHT AREAS. ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS SHUTDOWN FOR REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

LAST IE SITE INSPECTION DATE: DECEMBER 1 THROUGH JANUARY 31, 1984

INSPECTION REPORT NO: 83-26

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
83-36 03L-0	12/31/83	01/30/84	DURING SURV. TEST, 1 PRESSURIZER PRESSURE TRANSMITTER ACTUATED ABOVE REACTOR TRIP SETPOINT REQUIRED BY T.S.
84-01	01/03/84	02/02/84	REACTOR TRIP.

1. Docket: 50-30 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: C.W. FAY (414) 277-2811

4. Licensed Thermal Power (MWt): 1518

5. Nameplate Rating (Gross MWe): 582 X 0.9 = 524

6. Design Electrical Rating (Net MWe): 497

7. Maximum Dependable Capacity (Gross MWe): 519

8. Maximum Dependable Capacity (Net MWe): 495

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>101,521.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>89,868.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>198.3</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>88,342.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>182.7</u>
17. Gross Therm Ener (MWH)	<u>1,052,908</u>	<u>2,162,660</u>	<u>123,057,437</u>
18. Gross Elec Ener (MWH)	<u>355,470</u>	<u>729,650</u>	<u>41,689,480</u>
19. Net Elec Ener (MWH)	<u>340,482</u>	<u>698,630</u>	<u>39,703,895</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>87.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>87.2</u>
22. Unit Cap Factor (MDC Net)	<u>98.8</u>	<u>98.0</u>	<u>79.5*</u>
23. Unit Cap Factor (DER Net)	<u>98.4</u>	<u>97.6</u>	<u>78.7</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>1.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>692.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

POINT BEACH 2



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*      POINT BEACH 2 OPERATED AT FULL POWER WITH NO OUTAGES  
\*\*\*\*\*            DURING FEBRUARY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* POINT BEACH 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....WISCONSIN  
COUNTY.....MANITOWOC  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...15 MI N OF  
MANITOWOC, WISC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MAY 30, 1972  
DATE ELEC ENER 1ST GENER...AUGUST 2, 1972  
DATE COMMERCIAL OPERATE...OCTOBER 1, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....WISCONSIN ELECTRIC POWER COMPANY  
CORPORATE ADDRESS.....231 WEST MICHIGAN STREET  
MILWAUKEE, WISCONSIN 53201  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....R. HAGUE  
LICENSING PROJ MANAGER.....T. COLBURN  
DOCKET NUMBER.....50-301  
LICENSE & DATE ISSUANCE...DPR-27, MARCH 8, 1973  
PUBLIC DOCUMENT ROOM.....JOSEPH MANN PUBLIC LIBRARY  
1516 16TH ST.  
TWO RIVERS, WISCONSIN 54241

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON OCTOBER 11-14, 25-28, NOVEMBER 1-4 & 16, JANUARY 11, 1984 AND MANAGEMENT MEETING ON JANUARY 4 (83-20). SPECIAL ANNOUNCED INSPECTION BY REGIONAL INSPECTORS OF QA PROGRAM ADMINISTRATION, MAINTENANCE PROGRAM AND IMPLEMENTATION, DESIGN CHANGE AND MODIFICATION PROGRAM AND IMPLEMENTATION, PROCUREMENT, OFFSITE REVIEW COMMITTEE, DOCUMENT CONTROL, CALIBRATION AND CONTROL OF MEASURING AND TEST EQUIPMENT, SURVEILLANCE AND INSERVICE TESTING, CLEANLINESS CONTROL, AUDIT PROGRAM, STEAM GENERATOR REPLACEMENT PROGRAM. THE INSPECTION INVOLVED 269 INSPECTOR-HOURS ONSITE BY FOUR INSPECTORS, INCLUDING 66 INSPECTOR-HOURS AT CORPORATE HEADQUARTERS BY FOUR INSPECTORS. A MANAGEMENT MEETING WAS HELD WHICH INVOLVED 48 STAFF-HOURS. OF THE 14 AREAS INSPECTED NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED IN FIVE AREAS; NINE ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN THE REMAINING NINE AREAS (FAILURE TO MAINTAIN CLEANLINESS CONTROL, FAILURE TO CONTROL DOCUMENTS, FAILURE TO PROPERLY STORE RECORDS, FAILURE TO CONTROL STORED ITEMS, FAILURE TO PROPERLY CONDUCT AN AUDIT PROGRAM, FAILURE TO PERFORM 10 CFR 50.59 REVIEWS, AND FAILURE TO PROVIDE APPROPRIATE TRAINING.

SAFETY EVALUATION REPORT, DECEMBER - JANUARY (83-23): ROUTINE ANNOUNCED SAFETY EVALUATION REPORT OF SITE EMERGENCY PLAN OF NOVEMBER 11, 1983. THE INSPECTION INVOLVED 128 INSPECTOR-HOURS BY TWO NRC INSPECTORS. THE PLAN APPEARS TO MEET THE PLANNING STANDARDS OF 10 CFR PART 50.47 (B) AND THE REQUIREMENTS OF 10 CFR PART 50, APPENDIX E; HOWEVER, CLARIFICATIONS ARE NEEDED TO CLOSE OUT SECTIONS A-D, G-J, L, AND N. ONE DEVIATION FROM A COMMITMENT WAS IDENTIFIED.

INSPECTION ON DECEMBER 1, TO JANUARY 31, (83-24): ROUTINE, UNANNOUNCED INSPECTION BY RESIDENT INSPECTORS OF RECEIPT OF NEW FUEL; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; IE BULLETINS; INDEPENDENT INSPECTION; REGIONAL REQUESTS; TMI ACTION ITEMS; STEAM GENERATOR REPLACEMENT ACTIVITIES. THE INSPECTION INVOLVED A TOTAL OF 434 INSPECTOR-HOURS ONSITE BY TWO INSPECTORS INCLUDING 120

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                   POINT BEACH 2                   \*  
\*\*\*\*\*

INSPECTION SUMMARY

HOURS ON OFFSHIFTS. OF THE NINE AREAS INSPECTED, NO ITEMS OF NONCOMPLIANCE WERE IDENTIFIED IN EIGHT AREAS. ONE ITEM OF NONCOMPLIANCE WAS IDENTIFIED IN THE REMAINING AREA (FAILURE TO FOLLOW PROCEDURES).

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: DECEMBER 1 THROUGH JANUARY 31, 1984

INSPECTION REPORT NO: 83-24

R E P O R T S   F R O M   L I C E N S E E

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

1. Docket: 50-282                    O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: DALE DUGSTAD (612) 388-1121

4. Licensed Thermal Power (MWt):                    1650

5. Nameplate Rating (Gross MWe):                    659 X 0.9 = 593

6. Design Electrical Rating (Net MWe):                    530

7. Maximum Dependable Capacity (Gross MWe):                    534

8. Maximum Dependable Capacity (Net MWe):                    503

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>89,472.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,390.4</u>	<u>73,063.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>5,571.1</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,369.0</u>	<u>71,750.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,104,603</u>	<u>2,158,322</u>	<u>112,469,484</u>
18. Gross Elec Ener (MWH)	<u>371,370</u>	<u>723,560</u>	<u>36,603,360</u>
19. Net Elec Ener (MWH)	<u>352,843</u>	<u>686,003</u>	<u>34,277,432</u>
20. Unit Service Factor	<u>100.0</u>	<u>95.1</u>	<u>80.2</u>
21. Unit Avail Factor	<u>100.0</u>	<u>95.1</u>	<u>80.2</u>
22. Unit Cap Factor (MDC Net)	<u>100.8</u>	<u>94.7</u>	<u>76.2</u>
23. Unit Cap Factor (DER Net)	<u>95.7</u>	<u>89.9</u>	<u>72.3</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>8.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,920.9</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### PRAIRIE ISLAND 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	02/05/84	S	0.0	B	5				TURBINE VALVES TEST, I OUT OF BAND.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
PRAIRIE ISLAND 1 OPERATED AT FULL POWER WITH 1 REDUCTION  
DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PRAIRIE ISLAND 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
COUNTY.....GOODHUE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
MINNEAPOLIS, MINN  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 1, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 4, 1973  
DATE COMMERCIAL OPERATE...DECEMBER 16, 1973  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401  
CONTRACTOR  
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HARD  
LICENSING PROJ MANAGER.....D. DIANNI  
DOCKET NUMBER.....50-282  
LICENSE & DATE ISSUANCE...DPR-42, APRIL 5, 1974  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 17-20, (84-01): ROUTINE UNANNOUNCED INSPECTION OF RADIOACTIVE WASTE SYSTEMS, INCLUDING: SOLID WASTE PROCESSING AND STORAGE; DISPOSAL OF SOLID LOW-LEVEL WASTES; LIQUID EFFLUENTS, LIQUID EFFLUENT INSTRUMENTATION, REACTOR COOLANT WATER QUALITY; GASEOUS EFFLUENTS; GASEOUS EFFLUENT INSTRUMENTATION; AIR CLEANING SYSTEMS; AUDITS AND APPRAISALS; AND AUDITS OF TRANSPORTATION. THE INSPECTION INVOLVED 60 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:



1. Docket: 50-306                    O P E R A T I N G   S T A T U S
2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0
3. Utility Contact: DALE DUGSTAD (612) 388-1121
4. Licensed Thermal Power (MWt):                    1650
5. Nameplate Rating (Gross MWe):                    659 X 0.9 = 593
6. Design Electrical Rating (Net MWe):                    530
7. Maximum Dependable Capacity (Gross MWe):                    531
8. Maximum Dependable Capacity (Net MWe):                    500
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE
10. Power Level To Which Restricted, If Any (Net MWe):
11. Reasons for Restrictions, If Any:             
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>80,590.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>69,690.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,516.1</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>68,733.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,130,849</u>	<u>2,324,880</u>	<u>108,056,738</u>
18. Gross Elec Ener (MWH)	<u>380,160</u>	<u>782,020</u>	<u>34,889,420</u>
19. Net Elec Ener (MWH)	<u>362,593</u>	<u>745,601</u>	<u>32,720,484</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>85.3</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>85.3</u>
22. Unit Cap Factor (MDC Net)	<u>104.2</u>	<u>103.6</u>	<u>81.2</u>
23. Unit Cap Factor (DER Net)	<u>98.3</u>	<u>97.7</u>	<u>76.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>4.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>3,315.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING OUTAGE IN AUGUST OF 1984.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

## PRAIRIE ISLAND 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* PRAIRIE ISLAND 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
	02/19/84	S	0.0	B	5				TURBINE VALVES TEST.
	02/23/84	S	0.0	F	5				POWER REDUCED TO 96% DUE TO F DELTA H APPROACHING TECH SPEC LIMIT. THIS WAS ANTICIPATED IN CORE LOAD DESIGN.

\*\*\*\*\* PRAIRIE ISLAND 2 OPERATED AT FULL POWER WITH 2 REDUCTIONS  
 \* SUMMARY \* DURING FEBRUARY.  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* PRAIRIE ISLAND 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MINNESOTA  
  
COUNTY.....GOODHUE  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...28 MI SE OF  
MINNEAPOLIS, MINN  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...DECEMBER 17, 1974  
DATE ELEC ENER 1ST GENER...DECEMBER 21, 1974  
DATE COMMERCIAL OPERATE...DECEMBER 21, 1974  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
  
ELECTRIC RELIABILITY  
COUNCIL.....MID-CONTINENT AREA  
RELIABILITY COORDINATION  
AGREEMENT

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....NORTHERN STATES POWER  
  
CORPORATE ADDRESS.....414 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....FLUOR PIONEER, INC.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....NORTHERN STATES POWER COMPANY  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. HARD  
LICENSING PROJ MANAGER....D. DIIANNI  
DOCKET NUMBER.....50-306  
LICENSE & DATE ISSUANCE...DPR-60, OCTOBER 29, 1974  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL CONSERVATION LIBRARY  
MINNEAPOLIS PUBLIC LIBRARY  
300 NICOLLET MALL  
MINNEAPOLIS, MINNESOTA 55401

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

INSPECTION ON JANUARY 17-20, (84-01): ROUTINE UNANNOUNCED INSPECTION OF RADIOACTIVE WASTE SYSTEMS, INCLUDING: SOLID WASTE PROCESSING AND STORAGE; DISPOSAL OF SOLID LOW-LEVEL WASTES; LIQUID EFFLUENTS, LIQUID EFFLUENT INSTRUMENTATION, REACTOR COOLANT WATER QUALITY; GASEOUS EFFLUENTS; GASEOUS EFFLUENT INSTRUMENTATION; AIR CLEANING SYSTEMS; AUDITS AND APPRAISALS; AND AUDITS OF TRANSPORTATION. THE INSPECTION INVOLVED 60 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    PRAIRIE ISLAND 2                    \*  
\*\*\*\*\*

OTHER ITEMS

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JANUARY 17-20, 1984

INSPECTION REPORT NO: 84-01

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

NONE

=====

1. Docket: 50-254 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: ALEX MISAK (309) 654-2241 X194

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>103,464.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,440.0</u>	<u>84,995.6</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,421.9</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,440.0</u>	<u>81,787.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>909.2</u>
17. Gross Therm Ener (MWH)	<u>1,643,681</u>	<u>3,406,884</u>	<u>168,513,590</u>
18. Gross Elec Ener (MWH)	<u>545,050</u>	<u>1,129,512</u>	<u>54,388,240</u>
19. Net Elec Ener (MWH)	<u>517,997</u>	<u>1,073,371</u>	<u>50,678,631</u>
20. Unit Service Factor	<u>100.0</u>	<u>100.0</u>	<u>79.0</u>
21. Unit Avail Factor	<u>100.0</u>	<u>100.0</u>	<u>79.9</u>
22. Unit Cap Factor (MDC Net)	<u>96.8</u>	<u>96.9</u>	<u>63.7</u>
23. Unit Cap Factor (DER Net)	<u>94.3</u>	<u>94.5</u>	<u>62.1</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>5.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>2,728.0</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### QUAD CITIES 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* QUAD CITIES 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-6	02/05/84	S	0.0	B	5		HA	XXXXXX	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-7	02/12/84	S	0.0	B	5		RB	CONROD	REDUCED LOAD FOR CONTROL ROD PATTERN ADJUSTMENTS.
84-8	02/19/84	S	0.0	B	5		HA	XXXXXX	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-9	02/26/84	S	0.0	B	5		HA	XXXXXX	REDUCED LOAD TO PERFORM WEEKLY TURBINE TESTS.
84-10	02/28/84	S	0.0	B	5		CB	INSTRU	REDUCED LOAD IN PREPARATION FOR AN ECONOMIC GENERATION CONTROL SYSTEM TEST.
84-11	02/29/84	S	0.0	B	5		CB	INSTRU	REDUCED LOAD IN PREPARATION FOR AN ECONOMIC GENERATION CONTROL SYSTEM TEST.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 QUAD CITIES 1 OPERATED WITH 6 REDUCTIONS DURING THE REPORT PERIOD.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Acto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* QUAD CITIES 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....ROCK ISLAND  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...OCTOBER 18, 1971  
DATE ELEC ENER 1ST GENER...APRIL 12, 1972  
DATE COMMERCIAL OPERATE...FEBRUARY 18, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK.

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....A. MADISON  
LICENSING PROJ MANAGER....R. BEVAN  
DOCKET NUMBER.....50-254  
LICENSE & DATE ISSUANCE...DPR-29, DECEMBER 14, 1972  
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY  
504 17TH STREET  
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 5, THROUGH JANUARY 31, (83-30): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; IE BULLETIN FOLLOWUP; REACTOR SCRAMS; DESIGN CHANGES AND MODIFICATIONS; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; PROCEDURES; REFUELING; REGIONAL REQUESTS; ACRS MEETING; SITE VISIT; AND INFORMATION NOTICES. THE INSPECTION INVOLVED A TOTAL OF 454 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS, INCLUDING 61 REGIONAL STAFF HOURS AND 22 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

SPECIAL INSPECTION ON FEBRUARY 3 - 14, (84-01): INSPECTION FOLLOWUP ON COMMONWEALTH EDISON COMPANY REMARKS TO SPECIAL INSPECTION REPORT CONCERNING ALLEGATIONS OF IMPROPER OPERATION AT DRESDEN, QUAD CITIES, AND ZION NUCLEAR POWER PLANTS. THE INSPECTION INVOLVED 14 INSPECTION-HOURS BY THREE NRC INSPECTORS. MEASURES TO CORRECT IDENTIFIED WEAKNESSES WERE TAKEN AS DESCRIBED IN THE REPONSE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    QUAD CITIES 1                    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE UNIT IS IN COASTDOWN ANTICIPATING SHUTDOWN FOR A 5 MONTH OUTAGE ON 3/11/84.

LAST IE SITE INSPECTION DATE: JANUARY 18-31, 1984

INSPECTION REPORT NO: 84-01

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

=====

1. Docket: 50-265 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: ALEX MISAK (309) 654-2241 X194

4. Licensed Thermal Power (MWt): 2511

5. Nameplate Rating (Gross MWe): 920 X 0.9 = 828

6. Design Electrical Rating (Net MWe): 789

7. Maximum Dependable Capacity (Gross MWe): 813

8. Maximum Dependable Capacity (Net MWe): 769

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>102,574.0</u>
13. Hours Reactor Critical	<u>245.5</u>	<u>245.5</u>	<u>78,163.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>2,985.8</u>
15. Hrs Generator On-Line	<u>160.3</u>	<u>160.3</u>	<u>75,370.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>702.9</u>
17. Gross Therm Ener (MWH)	<u>193,783</u>	<u>193,783</u>	<u>155,575,871</u>
18. Gross Elec Ener (MWH)	<u>58,218</u>	<u>58,218</u>	<u>49,493,976</u>
19. Net Elec Ener (MWH)	<u>53,862</u>	<u>53,338</u>	<u>46,388,212</u>
20. Unit Service Factor	<u>23.0</u>	<u>11.1</u>	<u>73.5</u>
21. Unit Avail Factor	<u>23.0</u>	<u>11.1</u>	<u>74.2</u>
22. Unit Cap Factor (MDC Net)	<u>10.1</u>	<u>4.8</u>	<u>58.8</u>
23. Unit Cap Factor (DER Net)	<u>9.8</u>	<u>4.7</u>	<u>57.3</u>
24. Unit Forced Outage Rate	<u>40.2</u>	<u>40.2</u>	<u>8.7</u>
25. Forced Outage Hours	<u>107.7</u>	<u>107.7</u>	<u>3,297.8</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### QUAD CITIES 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* QUAD CITIES 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
83-66	09/04/83	S	428.0	C	4		RC	FUELXX	UNIT TWO REMAINS SHUTDOWN FOR END OF CYCLE SIX REFUELING AND MAINTENANCE.
84-1	02/18/84	F	7.2	B	1		HA	ZZZZZ	UNIT TWO PLACED IN HOT STANDBY DUE TO HIGH TURBINE VIBRATION.
84-2	02/19/84	F	32.3	B	1		ZZ	VALVEX	UNIT TWO SHUTDOWN TO REPAIR MISCELLANEOUS VALVE PACKING LEAKS.
84-3	02/23/84	F	36.1	B	1		HA	ZZZZZ	UNIT TWO PLACED IN HOT STANDBY DUE TO HIGH TURBINE VIBRATION.
84-4	02/25/84	F	32.1	B	1		CB	MOTORX	UNIT TWO SHUTDOWN TO REPLACE THE MOTOR ON THE 'B' RECIRCULATION PUMP SUCTION VALVE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 QUAD CITIES 2 RETURNED ONLINE FEBRUARY 19TH AND OPERATED ROUTINELY THE REMAINDER OF FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* QUAD CITIES 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....ROCK ISLAND  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI NE OF  
MOLINE, ILL  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...APRIL 26, 1972  
DATE ELEC ENER 1ST GENER...MAY 23, 1972  
DATE COMMERCIAL OPERATE...MARCH 10, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...MISSISSIPPI RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....ITI  
IE RESIDENT INSPECTOR.....A. MADISON  
LICENSING PROJ MANAGER....R. BEVAN  
DOCKET NUMBER.....50-265  
LICENSE & DATE ISSUANCE...DPR-30, DECEMBER 14, 1972  
PUBLIC DOCUMENT ROOM.....MOLINE PUBLIC LIBRARY  
504 17TH STREET  
MOLINE, ILLINOIS 61265

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

INSPECTION ON DECEMBER 5, THROUGH JANUARY 31, (83-31): ROUTINE, UNANNOUNCED INSPECTION BY THE RESIDENT INSPECTORS OF PREVIOUS INSPECTION FINDINGS; OPERATIONAL SAFETY; MAINTENANCE; SURVEILLANCE; LICENSEE EVENT REPORTS; IE BULLETIN FOLLOWUP; REACTOR SCRAMS; DESIGN CHANGES AND MODIFICATIONS; REVIEW OF LICENSEE'S MONTHLY PERFORMANCE REPORT; PROCEDURES; REFUELING; REGIONAL REQUESTS; ACRS MEETING; SITE VISIT; AND INFORMATION NOTICES. THE INSPECTION INVOLVED A TOTAL OF 454 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS, INCLUDING 61 REGIONAL STAFF HOURS AND 22 INSPECTOR-HOURS ONSITE DURING OFF-SHIFTS. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

SPECIAL INSPECTION ON FEBRUARY 3 - 14, (84-01): INSPECTION FOLLOWUP ON COMMONWEALTH EDISON COMPANY REMARKS TO SPECIAL INSPECTION REPORT CONCERNING ALLEGATIONS OF IMPROPER OPERATION AT DRESDEN, QUAD CITIES, AND ZION NUCLEAR POWER PLANTS. THE INSPECTION INVOLVED 14 INSPECTION-HOURS BY THREE NRC INSPECTORS. MEASURES TO CORRECT IDENTIFIED WEAKNESSES WERE TAKEN AS DESCRIBED IN THE RESPONSE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    QUAD CITIES 2                    \*  
\*\*\*\*\*

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

UNIT WAS RETURNED TO SERVICE ON 2/20/84 FOLLOWING EXTENDED REFUELING AND MAINTENANCE OUTAGE, AND IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JANUARY 18-31, 1984

INSPECTION REPORT NO: 84-01

R E P O R T S   F R O M   L I C E N S E E

```
=====
```

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
83-14/ 03L-0	09/06/83	01/30/84	DURING LLRT, MSIV FOUND TO LEAK 34.56 SCFH.
83-18/ 01T-1	10/11/83	02/02/84	LINEAR INDICATION FOUND DURING UT EXAM.
84-01	01/03/84	01/30/84	UNIT SCRAM WHILE 'A' RPS BUS WAS OUT OF SERVICE.
84-02	01/06/84	01/27/84	UNIT 2 REACTOR SCRAM ON LOSS OF 48 VOLT BATTERY SYSTEM.

```
=====
```

1. Docket: 50-312 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: RON COLOMBO (916) 452-3211

4. Licensed Thermal Power (MWt): 2772

5. Nameplate Rating (Gross MWe): 1070 X 0.9 = 963

6. Design Electrical Rating (Net MWe): 918

7. Maximum Dependable Capacity (Gross MWe): 917

8. Maximum Dependable Capacity (Net MWe): 873

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>77,761.0</u>
13. Hours Reactor Critical	<u>689.8</u>	<u>1,433.8</u>	<u>45,785.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>9,313.8</u>
15. Hrs Generator On-Line	<u>689.8</u>	<u>1,433.8</u>	<u>43,976.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>1,210.2</u>
17. Gross Therm Ener (MWH)	<u>1,721,487</u>	<u>3,462,831</u>	<u>109,374,173</u>
18. Gross Elec Ener (MWH)	<u>577,349</u>	<u>1,163,572</u>	<u>36,559,644</u>
19. Net Elec Ener (MWH)	<u>547,078</u>	<u>1,096,211</u>	<u>34,470,535</u>
20. Unit Service Factor	<u>99.1</u>	<u>99.6</u>	<u>56.6</u>
21. Unit Avail Factor	<u>99.1</u>	<u>99.6</u>	<u>58.1</u>
22. Unit Cap Factor (MDC Net)	<u>90.0</u>	<u>87.2</u>	<u>50.8</u>
23. Unit Cap Factor (DER Net)	<u>85.6</u>	<u>82.9</u>	<u>48.3</u>
24. Unit Forced Outage Rate	<u>.9</u>	<u>.4</u>	<u>27.2</u>
25. Forced Outage Hours	<u>6.2</u>	<u>6.2</u>	<u>16,416.2</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
X RANCHO SECO 1 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

RANCHO SECO 1



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* RANCHO SECO 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	02/29/84	F	0.0	A	5		CB	PUMPXX	"A" REACTOR COOLANT PUMP UPPER AND LOWER L.O. RES. HI-LOW ALARM, REDUCED TO 65%.
4	02/29/84	F	6.2	A	3		EA	XXXXXX	PG&E LOSS OF TRANSMISSION LINES CAUSED LOW VOLTAGE FREQUENCY. PLANT COULD NOT HANDLE LOAD DEMAND ON 3 RCP OPERATION.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 RANCO SECO 1 OPERATED AT NEAR FULL POWER WITH 1 OUTAGE  
 AND 1 REDUCTION DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	H-Other	4-Continued	Data Entry Sheet
	D-Regulatory Restriction	5-Reduced Load	Licensee Event Report
	E-Operator Training	9-Other	(LER) File (NUREG-0161)
	& License Examination		

\*\*\*\*\*  
\* RANCHO SECO 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SACRAMENTO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI SE OF  
SACRAMENTO, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 16, 1974  
DATE ELEC ENER 1ST GENER...OCTOBER 13, 1974  
DATE COMMERCIAL OPERATE....APRIL 17, 1975  
CONDENSER COOLING METHOD...COOLING TOWERS  
CONDENSER COOLING WATER...FOLSOM CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SACRAMENTO MUN. UTIL. DISTRICT  
CORPORATE ADDRESS.....6201 S STREET P.O. BOX 15830  
SACRAMENTO, CALIFORNIA 95813  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....H. CANTER  
LICENSING PROJ MANAGER.....S. MINER  
DOCKET NUMBER.....50-312  
LICENSE & DATE ISSUANCE....DPR-54, AUGUST 16, 1974  
PUBLIC DOCUMENT ROOM.....BUSINESS AND MUNICIPAL DEPARTMENT  
SACRAMENTO CITY - COUNTY LIBRARY  
828 I STREET  
SACRAMENTO, CALIFORNIA 95814

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON NOVEMBER 7-18, 1983 (REPORT NO. 50-312/83-35) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON DECEMBER 5, 1983 - JANUARY 10, 1984 (REPORT NO. 50-312/83-36) AREAS INSPECTED: OPERATIONAL SAFETY VERIFICATION; MAINTENANCE OBSERVATIONS; SURVEILLANCE OBSERVATIONS; LER FOLLOWUP; FOLLOWUP ON REGIONAL REQUEST; ONSITE FOLLOWUP OF EVENTS; AND INDEPENDENT INSPECTION EFFORT. THE INSPECTION INVOLVED 154 INSPECTOR-HOURS ONSITE BY TWO NRC INSPECTORS.  
RESULTS: OF THE SEVEN AREAS INSPECTED, THERE WERE TWO ITEMS OF NONCOMPLIANCE: ONE IN THE FAILURE TO FOLLOW THE TEMPORARY CHANGE PROCEDURE AND ONE FOR THE FAILURE TO COMPLY WITH SURVEILLANCE PROCEDURE SPECIFICATION FOR OPERABILITY OF THE PRESSURIZER LEVEL INSTRUMENTS.
- + INSPECTION ON DECEMBER 27-29, 1983 (REPORT NO. 50-312/83-37) AREAS INSPECTED: A SPECIAL INSPECTION BY A REGIONAL INSPECTOR OF ALLEGATIONS CONCERNING ELECTRICAL CABLE PULL CARD INADEQUACIES. THE INSPECTION INVOLVED 21 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.  
RESULTS: THE ALLEGATIONS WERE SUBSTANTIATED IN PART BY THIS INSPECTION.
- + INSPECTION ON JANUARY 16-20 AND 26, AND TELEPHONE CONVERSATIONS ON JANUARY 31 AND FEBRUARY 2 AND 20, 1984 (REPORT NO. 50-312/84-01) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION INCLUDING FOLLOWUP ON ITEMS OF NONCOMPLIANCE AND RADIOACTIVE WASTE



Report Period FEB 1984

R E P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* RANCHO SECO 1 \*  
\*\*\*\*\*

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
83-08 01X-0	09-09-83	01-13-84	ERRORS IN METEOROLOGICAL DATA IMPACT OFFSITE DOSE CALCULATIONS (SPECIAL REPORT)

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-261                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: H. RAY NORRIS (803) 383-4524

4. Licensed Thermal Power (MWt):                      2300

5. Nameplate Rating (Gross MWe):                      854 X 0.9 = 769

6. Design Electrical Rating (Net MWe):                      700

7. Maximum Dependable Capacity (Gross MWe):                      700

8. Maximum Dependable Capacity (Net MWe):                      665

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, if Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>113,886.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>616.1</u>	<u>84,196.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>38.9</u>	<u>1,675.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>615.8</u>	<u>82,065.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>23.2</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>783,895</u>	<u>162,875,180</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>246,010</u>	<u>52,344,876</u>
19. Net Elec Ener (MWH)	<u>-2,766</u>	<u>221,513</u>	<u>49,441,137</u>
20. Unit Service Factor	<u>.0</u>	<u>42.8</u>	<u>72.1</u>
21. Unit Avail Factor	<u>.0</u>	<u>42.8</u>	<u>72.1</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>23.1</u>	<u>65.3</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>22.0</u>	<u>62.0</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>17.2</u>	<u>14.6</u>
25. Forced Outage Hours	<u>.0</u>	<u>128.2</u>	<u>8,233.5</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 01/17/85

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

ROBINSON 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
0201	01/26/84	S	696.0	C	4		RC	FUELXX	CONTINUATION OF REFUELING AND STEAM GENERATOR REPLACEMENT OUTAGE.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ROBINSON 2 REMAINS SHUTDOWN IN A CONTINUING REFUELING MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	F-Admin	1-Manual
S-Sched	B-Maint or Test	G-Oper Error	2-Manual Scram
	C-Refueling	H-Other	3-Auto Scram
	D-Regulatory Restriction		4-Continued
	E-Operator Training		5-Reduced Load
	& License Examination		9-Other
			Exhibit F & H
			Instructions for
			Preparation of
			Data Entry Sheet
			Licensee Event Report
			(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ROBINSON 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....DARLINGTON  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI NW OF  
HARTSVILLE, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...SEPTEMBER 20, 1970  
DATE ELEC ENER 1ST GENER...SEPTEMBER 26, 1970  
DATE COMMERCIAL OPERATE...MARCH 7, 1971  
CONDENSER COOLING METHOD...RECIRCULATION  
CONDENSER COOLING WATER...ROBINSON IMPOUNDMENT  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY  
LICENSEE.....CAROLINA POWER & LIGHT  
CORPORATE ADDRESS.....411 FAYETTEVILLE STREET  
RALEIGH, NORTH CAROLINA 27601  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....S. WEISE  
LICENSING PROJ MANAGER.....G. REQUA  
DOCKET NUMBER.....50-261  
LICENSE & DATE ISSUANCE...DPR-23, SEPTEMBER 23, 1970  
PUBLIC DOCUMENT ROOM.....HARTSVILLE MEMORIAL LIBRARY  
220 N. FIFTH ST.  
HARTSVILLE, SOUTH CAROLINA 29550

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 11 - FEBRUARY 10 (84-02): THIS ROUTINE, ANNOUNCED INSPECTION INVOLVED 213 INSPECTOR HOURS ON SITE IN THE AREAS OF TECHNICAL SPECIFICATION COMPLIANCE, PLANT TOUR, OPERATIONS PERFORMANCE, REPORTABLE OCCURRENCES, HOUSEKEEPING, SITE SECURITY, SURVEILLANCE ACTIVITIES, MAINTENANCE ACTIVITIES, QUALITY ASSURANCE PRACTICES, RADIATION CONTROL ACTIVITIES, OUTSTANDING ITEMS REVIEW, IE BULLETIN AND NOTICE FOLLOWUP, ENFORCEMENT ACTION FOLLOWUP, ORGANIZATION AND ADMINISTRATION, STEAM GENERATOR REPAIR PREPARATIONS, AND REACTOR TRIP FOLLOWUP. OF THE 16 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 16 AREAS.

ENFORCEMENT SUMMARY

10 CFR 50.54(9) REQUIRES THAT NUCLEAR POWER REACTOR LICENSEES FOLLOW AND MAINTAIN IN EFFECT EMERGENCY PLANS WHICH MEET THE REQUIREMENTS OF APPENDIX E TO 10 CFR PART 50 AND THE PLANNING STANDARDS OF 50.47(B). SECTION (B)(10) OF 10 CFR 50.47 REQUIRES THAT THE LICENSEE'S EMERGENCY PLANS SHALL INCLUDE INFORMATION TO DEMONSTRATE COMPLIANCE WITH THE FOLLOWING: A RANGE OF PROTECTIVE ACTIONS HAVE BEEN DEVELOPED FOR THE PLUME EXPOSURE PATHWAY EPZ FOR EMERGENCY WORKERS AND THE PUBLIC. GUIDELINES FOR THE CHOICE OF PROTECTIVE ACTIONS DURING AN EMERGENCY, CONSISTENT WITH FEDERAL GUIDANCE, ARE DEVELOPED AND IN PLACE, AND PROTECTIVE ACTIONS FOR THE INGESTION EXPOSURE PATHWAY EPZ APPROPRIATE TO THE LOCALE HAVE BEEN DEVELOPED. THE FEDERAL GUIDANCE ON THE PROTECTIVE ACTIONS TO BE RECOMMENDED TO OFFSITE OFFICIALS FOR GENERAL EMERGENCIES IS ADDRESSED IN APPENDIX 1 OF NUREG 0654/FEMA-REP-1, REVISION 1, ENTITLED "CRITERIA FOR PREPARATION AND EVALUATION OF RADIOLOGICAL EMERGENCY PREPAREDNESS IN SUPPORT OF NUCLEAR POWER PLANTS." THIS





1. Docket: 50-272 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: L. K. MILLER (609) 935-6000 X4455

4. Licensed Thermal Power (MWt): 3338

5. Nameplate Rating (Gross MWe): 1300 X 0.9 = 1170

6. Design Electrical Rating (Net MWe): 1090

7. Maximum Dependable Capacity (Gross MWe): 1124

8. Maximum Dependable Capacity (Net MWe): 1079

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>58,465.0</u>
13. Hours Reactor Critical	<u>569.4</u>	<u>1,237.6</u>	<u>34,388.8</u>
14. Rx Reserve Shtdwn Hrs	<u>54.5</u>	<u>54.5</u>	<u>3,088.4</u>
15. Hrs Generator On-Line	<u>569.4</u>	<u>1,197.8</u>	<u>32,975.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,901,969</u>	<u>3,800,023</u>	<u>99,621,600</u>
18. Gross Elec Ener (MWH)	<u>645,390</u>	<u>1,281,380</u>	<u>32,894,278</u>
19. Net Elec Ener (MWH)	<u>618,884</u>	<u>1,223,764</u>	<u>31,195,076</u>
20. Unit Service Factor	<u>81.8</u>	<u>83.2</u>	<u>56.4</u>
21. Unit Avail Factor	<u>81.8</u>	<u>83.2</u>	<u>56.4</u>
22. Unit Cap Factor (MDC Net)	<u>82.4</u>	<u>78.8</u>	<u>49.5</u>
23. Unit Cap Factor (DER Net)	<u>81.6</u>	<u>78.0</u>	<u>49.0</u>
24. Unit Forced Outage Rate	<u>18.2</u>	<u>16.8</u>	<u>30.1</u>
25. Forced Outage Hours	<u>126.6</u>	<u>242.2</u>	<u>14,465.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING: 3-1-84.

27. If Currently Shutdown Estimated Startup Date: 09/01/84

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SALEM 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SALEM 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-144	02/18/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-146	02/18/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-148	02/18/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-150	02/18/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-152	02/19/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-154	02/19/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-156	02/20/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-158	02/21/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-160	02/22/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-162	02/23/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-164	02/23/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-166	02/23/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-168	02/23/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-170	02/24/84	S	0.0	B	5		HC	HTEXCH	CONDENSER TUBE AND WATER BOX CLEANING.
84-172	02/24/84	F	126.6	A	3		HA	GENERA	SHORT IN GENERATOR WINDING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SALEM 1 OPERATED ROUTINELY, SHUTTING DOWN ON FEBRUARY 24TH FOR A REPAIR OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SALEM 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 11, 1976  
DATE ELEC ENER 1ST GENER...DECEMBER 25, 1976  
DATE COMMERCIAL OPERATE....JUNE 30, 1977  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. LINVILLE  
LICENSING PROJ MANAGER.....D. FISCHER  
DOCKET NUMBER.....50-272  
LICENSE & DATE ISSUANCE...DPR-70, DECEMBER 1, 1976  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

INSPECTION STATUS

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.



1. Docket: 50-311 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: L. K. MILLER (609) 935-6000 X4455

4. Licensed Thermal Power (MWt): 3411

5. Nameplate Rating (Gross MWe): 1162

6. Design Electrical Rating (Net MWe): 1115

7. Maximum Dependable Capacity (Gross MWe): 1149

8. Maximum Dependable Capacity (Net MWe): 1106

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>20,881.0</u>
13. Hours Reactor Critical	<u>18.6</u>	<u>18.6</u>	<u>11,727.1</u>
14. Rx Reserve Shtdwn Hrs	<u>677.4</u>	<u>1,421.4</u>	<u>3,512.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>11,417.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>4,879</u>	<u>4,879</u>	<u>33,475,951</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>10,868,290</u>
19. Net Elec Ener (MWH)	<u>-13,922</u>	<u>-18,698</u>	<u>10,298,553</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>54.7</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>54.7</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>44.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>44.2</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>33.0</u>
25. Forced Outage Hours	<u>696.0</u>	<u>1,440.0</u>	<u>5,623.1</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/84

\*\*\*\*\*  
X SALEM 2 X  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### SALEM 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SALEM 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-010	11/17/83	F	696.0	A	4		HA	GENERA	STATOR CORE IRON GENERATOR.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SALEM 2 REMAINS SHUTDOWN IN A CONTINUING REPAIR OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SALEM 2 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....NEW JERSEY  
COUNTY.....SALEM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...20 MI S OF  
WILMINGTON, DEL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 8, 1980  
DATE ELEC ENER 1ST GENER...JUNE 3, 1981  
DATE COMMERCIAL OPERATE...OCTOBER 13, 1981  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...DELAWARE RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....PUBLIC SERVICE ELECTRIC & GAS  
CORPORATE ADDRESS.....80 PARK PLACE  
NEWARK, NEW JERSEY 07101  
CONTRACTOR  
ARCHITECT/ENGINEER.....PUBLIC SERVICES & GAS CO.  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....T. LINVILLE  
LICENSING PROJ MANAGER....D. FISCHER  
DOCKET NUMBER.....50-311  
LICENSE & DATE ISSUANCE...DPR-75, MAY 20, 1981  
PUBLIC DOCUMENT ROOM.....SALEM FREE PUBLIC LIBRARY  
112 WEST BROADWAY  
SALEM, NEW JERSEY 08079

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.





1. Docket: 50-206 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: C. A. MORRIS (714) 492-7700 X56264

4. Licensed Thermal Power (MWt): 1347

5. Nameplate Rating (Gross MWe): 500 X 0.9 = 450

6. Design Electrical Rating (Net MWe): 436

7. Maximum Dependable Capacity (Gross MWe): 456

8. Maximum Dependable Capacity (Net MWe): 436

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>146,480.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>88,440.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>84,821.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>108,263,946</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>36,906,434</u>
19. Net Elec Ener (MWH)	<u>-2,330</u>	<u>-4,860</u>	<u>34,936,899</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>55.8</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>55.8</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>52.6</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>52.6</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>.0</u>	<u>21.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>11,178.3</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 06/15/84

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SAN ONOFRE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
78	02/27/82	S	696.0	B	4				EXTENDED OUTAGE TO ACCOMPLISH SEISMIC BACKFIT AND MISCELLANEOUS MAINTENANCE ITEMS.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SAN ONOFRE 1 REMAINS SHUTDOWN IN A CONTINUING MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





1. Docket: 50-361 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: C. A. MORRIS (717) 492-7700 X56264

4. Licensed Thermal Power (MWt): 3410

5. Nameplate Rating (Gross MWe): 1127

6. Design Electrical Rating (Net MWe): 1070

7. Maximum Dependable Capacity (Gross MWe): 1127

8. Maximum Dependable Capacity (Net MWe): 1070

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>4,945.0</u>
13. Hours Reactor Critical	<u>363.7</u>	<u>662.3</u>	<u>3,275.0</u>
14. Rx Reserve Shtdwn hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>330.5</u>	<u>610.4</u>	<u>3,172.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,031,289</u>	<u>1,910,666</u>	<u>10,404,201</u>
18. Gross Elec Ener (MWH)	<u>348,887</u>	<u>651,468</u>	<u>3,563,432</u>
19. Net Elec Ener (MWH)	<u>323,201</u>	<u>605,432</u>	<u>3,381,076</u>
20. Unit Service Factor	<u>47.5</u>	<u>42.4</u>	<u>64.1</u>
21. Unit Avail Factor	<u>47.5</u>	<u>42.4</u>	<u>64.1</u>
22. Unit Cap Factor (MDC Net)	<u>43.4</u>	<u>39.0</u>	<u>63.9</u>
23. Unit Cap Factor (DER Net)	<u>43.4</u>	<u>39.0</u>	<u>63.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>4.9</u>	<u>4.0</u>
25. Forced Outage Hours	<u>.0</u>	<u>31.6</u>	<u>132.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SAN ONOFRE 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### SAN ONOFRE 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SAN ONOFRE 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	01/13/84	S	365.5	B	4				UNIT WAS SHUT DOWN FOR REACTOR COOLANT PUMP SEAL REPLACEMENT.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SAN ONOFRE 2 RETURNED ONLINE FROM A REPAIR OUTAGE ON  
 FEBRUARY 16TH AND OPERATED ROUTINELY THE REMAINDER  
 OF THE MONTH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN DIEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 26, 1982  
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1982  
DATE COMMERCIAL OPERATE....AUGUST 8, 1983  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS.....P.O. BOX 800  
ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....A. CHAFFEE  
LICENSING PROJ MANAGER.....H. ROOD  
DOCKET NUMBER.....50-361  
LICENSE & DATE ISSUANCE....., SEPTEMBER 7, 1982  
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY  
242 AVENIDA DEL MAR  
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON AUGUST 22 - SEPTEMBER 16, 1983 (REPORT NO. 50-361/83-30) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON DECEMBER 12-16, 1983 (REPORT NO. 50-361/83-41) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 15-20 AND 26, 1984 (REPORT NO. 50-361/84-02) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION PROGRAM, HEALTH PHYSICS AND CHEMISTRY TRAINING, GENERAL EMPLOYEE TRAINING, AND PERSONNEL DOSIMETRY DURING OUTAGE CONDITIONS. THE INSPECTION INCLUDED A TOUR OF UNIT 2. THE INSPECTION INVOLVED 42 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JANUARY 24-26, 1984 (REPORT NO. 50-361/84-03) AREAS INSPECTED: FACILITY ORGANIZATION, FACILITY OPERATION, SHIPPING AND RECEIVING, RECORDS AND REPORTS, FOLLOWUP ON A NOTICE OF DEVIATION. THE INSPECTION INVOLVED 14 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.
- RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JANUARY 24-26, 1984 (REPORT NO. 50-361/84-04) AREAS INSPECTED: SECURITY PROGRAM AUDIT; FOLLOWUP ON ALLEGATIONS; SECURITY EVENT FOLLOWUP; INDEPENDENT INSPECTION EFFORT; AND FOLLOWUP ITEMS FROM PREVIOUS SECURITY INSPECTIONS. THE INSPECTION



Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*                    SAN ONOFRE 2                    \*  
\*\*\*\*\*

INSPECTION SUMMARY

INVOLVED 25 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 23-27, 1984 (REPORT NO. 50-361/84-05) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM AND FOLLOWUP ON LICENSEE ACTION REGARDING PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 22 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 22 - FEBRUARY 23, 1984 (REPORT NO. 50-361/84-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 27 - MARCH 1, 1984 (REPORT NO. 50-361/84-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 28 - MARCH 9, 1984 (REPORT NO. 50-361/84-08) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

LOW POWER FACILITY OPERATING LICENSE WAS ISSUED FEBRUARY 16, 1982. THE FULL POWER FACILITY OPERATING LICENSE WAS ISSUED SEPTEMBER 7, 1982, AS AMENDMENT 7 TO THE LOW POWER LICENSE. THE PLANT COMMENCED COMMERCIAL OPERATION ON AUGUST 7, 1983.

PLANT STATUS:

STEADY OPERATION AT FULL POWER; PROBLEMS BEING EXPERIENCED WITH SEALS ON ONE REACTOR COOLANT PUMP.

LAST IE SITE INSPECTION DATE: 02/28-3/09/84+

INSPECTION REPORT NO: 50-361/84-08+

Report Period FEB 1984

REPORTS FROM LICENSEE

\*\*\*\*\*  
\* SAN ONOFRE 2 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-362 OPERATING STATUS  
 2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0  
 3. Utility Contact: C.A. MORRIS (714) 492-7700 EXT 56264  
 4. Licensed Thermal Power (MWt): 3390  
 5. Nameplate Rating (Gross MWe): 1127  
 6. Design Electrical Rating (Net MWe): 1070  
 7. Maximum Dependable Capacity (Gross MWe): 1127  
 8. Maximum Dependable Capacity (Net MWe): 1070  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>3,774.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>142.8</u>	<u>1,924.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>123.0</u>	<u>1,766.6</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>415,741</u>	<u>3,964,779</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>140,226</u>	<u>1,238,523</u>
19. Net Elec Ener (MWH)	<u>-5,210</u>	<u>121,446</u>	<u>1,118,513</u>
20. Unit Service Factor			
21. Unit Avail Factor		NOT IN	
22. Unit Cap Factor (MDC Net)		COMMERCIAL	
23. Unit Cap Factor (DER Net)		OPERATION	
24. Unit Forced Outage Rate			
25. Forced Outage Hours	<u>.0</u>	<u>.0</u>	<u>556.3</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 03/08/84

\*\*\*\*\*  
 \* SAN ONOFRE 3 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SAN ONOFRE 3



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 X SAN ONOFRE 3 X  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System Component	Cause & Corrective Action to Prevent Recurrence
2	01/13/84	S	365.5	B	4			UNIT WAS SHUT DOWN FOR REACTOR COOLANT PUMP SEAL REPLACEMENT.
1	01/06/84	S	696.0	B	4			UNIT IS SHUTDOWN FOR A SURVEILLANCE AND REACTOR COOLANT PUMP SEAL OUTAGE.
1	01/06/84	S	696.0	B	4			UNIT IS SHUTDOWN FOR A SURVEILLANCE AND REACTOR COOLANT PUMP SEAL OUTAGE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SAN ONOFRE 3 REMAINS SHUTDOWN IN A CONTINUING MAINTENANCE OUTAGE.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....CALIFORNIA  
COUNTY.....SAN DIEGO  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
SAN CLEMENTE, CA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 29, 1983  
DATE ELEC ENER 1ST GENER...SEPTEMBER 25, 1983  
DATE COMMERCIAL OPERATE....\*\*\*\*\*  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....PACIFIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....WESTERN SYSTEMS  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTHERN CALIFORNIA EDISON  
CORPORATE ADDRESS.....P.O. BOX 800  
ROSEMEAD, CALIFORNIA 91770  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC COM (ENG VERSION)

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....V  
IE RESIDENT INSPECTOR.....A. CHAFFEE  
LICENSING PROJ MANAGER.....H. ROOD  
DOCKET NUMBER.....50-362  
LICENSE & DATE ISSUANCE...., NOVEMBER 15, 1982  
PUBLIC DOCUMENT ROOM.....SAN CLEMENTE LIBRARY  
242 AVENIDA DEL MAR  
SAN CLEMENTE, CALIFORNIA

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

- + INSPECTION ON AUGUST 22 - SEPTEMBER 16, 1983 (REPORT NO. 50-362/83-28) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON DECEMBER 12-16, 1983 (REPORT NO. 50-362/83-40) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.
- + INSPECTION ON JANUARY 15-20 AND 26, 1984 (REPORT NO. 50-362/84-02) AREAS INSEPECTED: ROUTINE, UNANNOUNCED INSPECTION OF RADIATION PROTECTION PROGRAM, HEALTH PHYSICS AND CHEMISTRY TRAINING, GENERAL EMPLOYEE TRAINING, AND PERSONNEL DOSIMETRY DURING OUTAGE CONDITIONS. THE INSPECTION INCLUDED A TOUR OF UNIT 3. THE INSPECTION INVOLVED 42 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.  
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JANUARY 24-26, 1984 (REPORT NO. 50-362/84-03) AREAS INSPECTED: FACILITY ORGANIZATION, FACILITY OPERATION, SHIPPING AND RECEIVING, RECORDS AND REPORTS, FOLLOWUP ON A NOTICE OF DEVIATION. THE INSPECTION INVOLVED 14 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.  
RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.
- + INSPECTION ON JANUARY 24-26, 1984 (REPORT NO. 50-362/84-04) AREAS INSEPECTED: SECURITY PROGRAM AUDIT; FOLLOWUP ON ALLEGATIONS; SECURITY EVENT FOLLOWUP; INDEPENDENT INSPECTION EFFORT; AND FOLLOWUP ITEMS FROM PREVIOUS SECURITY INSPECTIONS. THE INSPECTION

INSPECTION SUMMARY

INVOLVED 25 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 23-27, 1984 (REPORT NO. 50-362/84-05) AREAS INSPECTED: ROUTINE, UNANNOUNCED INSPECTION OF THE RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM AND FOLLOWUP ON LICENSEE ACTION REGARDING PREVIOUS INSPECTION FINDINGS. THE INSPECTION INVOLVED 22 INSPECTOR-HOURS ONSITE BY ONE NRC INSPECTOR.

RESULTS: NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

+ INSPECTION ON JANUARY 22 - FEBRUARY 23, 1984 (REPORT NO. 50-362/84-06) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

+ INSPECTION ON FEBRUARY 28 - MARCH 9, 1984 (REPORT NO. 50-362/84-07) REPORT BEING PREPARED; TO BE REPORTED NEXT MONTH.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

ABNORMALLY HIGH RADIATION LEVELS OBSERVED IN REACTOR COOLANT SYSTEM.

FACILITY ITEMS (PLANS AND PROCEDURES):

SEVEN WEEK OUTAGE FOR REPLACEMENT OF REACTOR COOLANT PUMP SEALS AND SURVEILLANCE TESTING.

MANAGERIAL ITEMS:

LOW POWER FACILITY OPERATING LICENSE WAS ISSUED NOVEMBER 15, 1982. THE FULL POWER LICENSE WAS ISSUED SEPTEMBER 16, 1983.

PLANT STATUS:

INITIAL CRITICALITY WAS AUGUST 29, 1983. POWER ASCENSION TESTING WAS COMPLETED ON JANUARY 6, 1984. THE UNIT WILL NOW BE SHUT DOWN FOR ABOUT SEVEN WEEKS FOR REPLACEMENT OF REACTOR COOLANT PUMP SEALS AND SURVEILLANCE TESTING.

ABNORMALLY HIGH LEVELS OF RADIOACTIVITY HAVE BEEN OBSERVED, AND THE CAUSE AND NECESSARY CORRECTIVE ACTIONS ARE BEING EVALUATED.

LAST IE SITE INSPECTION DATE: 02/28-03/09/84+

INSPECTION REPORT NO: 50-362/84-07+

Report Period FEB 1984

R E P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* SAN ONOFRE 3 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE			



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-327                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: MIKE EDDINGS (615) 870-6248

4. Licensed Thermal Power (MWt):                      3411

5. Nameplate Rating (Gross MWe):                      1220

6. Design Electrical Rating (Net MWe):                      1148

7. Maximum Dependable Capacity (Gross MWe):                      1183

8. Maximum Dependable Capacity (Net MWe):                      1148

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>23,377.0</u>
13. Hours Reactor Critical	<u>479.5</u>	<u>1,014.9</u>	<u>15,456.3</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>479.5</u>	<u>961.3</u>	<u>15,074.4</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,494,485</u>	<u>2,870,308</u>	<u>48,362,108</u>
18. Gross Elec Ener (MWH)	<u>501,810</u>	<u>956,150</u>	<u>16,337,286</u>
19. Net Elec Ener (MWH)	<u>480,444</u>	<u>915,067</u>	<u>15,691,995</u>
20. Unit Service Factor	<u>68.9</u>	<u>66.8</u>	<u>64.5</u>
21. Unit Avail Factor	<u>68.9</u>	<u>66.8</u>	<u>64.5</u>
22. Unit Cap Factor (MDC Net)	<u>60.1</u>	<u>55.4</u>	<u>58.5</u>
23. Unit Cap Factor (DER Net)	<u>60.1</u>	<u>55.4</u>	<u>58.5</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>21.4</u>	<u>19.5</u>
25. Forced Outage Hours	<u>.0</u>	<u>262.2</u>	<u>3,642.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 04/13/84

\*\*\*\*\*  
\*                      SEQUOYAH 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

SEQUOYAH 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
5	02/20/84	S	216.5	C	1		RC	FUELXX	REFUELING OUTAGE COMMENCES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
SEUCYAH 1 ENTERED A REFUELING OUTAGE ON FEBRUARY 20TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		



ENFORCEMENT SUMMARY

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERIA I & XVI AS IMPLEMENTED BY THE LICENSEES QA PROGRAM (TVA-TR75-1A) OQA IS NOT ENSURING EFFECTIVE EXECUTION OF THE QA PROGRAM IN THAT ALL CONDITIONS ADVERSE TO QUALITY HAVE NOT BEEN PROMPTLY CORRECTED. THE CURRENT COMPOSITE OPEN ITEM LIST REVIEW SUMMARY CONTAINS 1 OUTSTANDING ITEM FROM 1979, 16 OUTSTANDING ITEMS FROM 1981 AND 65 OUTSTANDING ITEMS FROM 1982. REGION II HAS ISSUED FOUR VIOLATIONS SINCE FEBRUARY 1981 FOR FAILURE TO TAKE PROMPT CORRECTIVE ACTION BY MECHANISMS DEFINED WITHIN THE QA PROGRAM. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION III AS IMPLEMENTED BY THE LICENSEE'S QA PROGRAM (TVA-TR75-1A), THE CONSTRUCTION ENGINEERING BRANCH HAS NOT ESTABLISHED MEASURES TO CONTROL DESIGN INTERFACES BETWEEN PARTICIPATING ORGANIZATIONS. THIS WAS IDENTIFIED IN THE LICENSEE'S AUDIT 83V-26 AND AGAIN IN AUDIT 83V-73. BOTH OF THESE AUDITS WERE CONDUCTED ON DIFFERENT VENDORS. CONTRARY TO BROWNS FERRY TECHNICAL SPECIFICATION (TS) 6.10.C, SEQUOYAH TS 6.5.2.10.C, THE LICENSEES ACCEPTED QA PROGRAM'S ENDORSEMENT OF REGULATORY GUIDE 1.144 AND ANSI N45.2.12 - 1974 OR 1977, PARAGRAPH 4.4.6 MULTIPLE EXAMPLES WERE IDENTIFIED OF FAILURE TO ISSUE AUDITS WITHIN REQUIRED TIMEFRAMES. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVIII AS IMPLEMENTED BY THE LICENSEES QA PROGRAM (TVA-TR75-1A), REGULATORY GUIDE 1.144, ANSI AND N45.2.12, PARAGRAPH 4.5.1, NUMEROUS EXAMPLES WERE IDENTIFIED WHERE THE AUDITED ORGANIZATION DID NOT RESPOND TO AUDITS FINDINGS WITHIN REQUIRED TIMEFRAMES. THIS IS A REPEAT VIOLATION. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION II AS IMPLEMENTED BY THE LICENSEES QA PROGRAM, REGULATORY GUIDE 1.146, AND ANSI N45.2.23, MEASURES HAD NOT BEEN ESTABLISHED TO REQUIRE VERIFICATION OF MINIMUM CREDITS NEEDED TO BE A LEAD AUDITOR.  
(8327 4)

CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVII AS IMPLEMENTED BY THE LICENSEE'S QA PROGRAM, REGULATORY GUIDE 1.88, AND ANSI N45.2.9 RECORDS WERE NOT MAINTAINED TO DEMONSTRATE THAT ALL AUDITORS AND LEAD AUDITORS WERE QUALIFIED TO PERFORM SAFETY-RELATED QA AUDITS. CONTRARY TO 10 CFR 50, APPENDIX B, CRITERION XVIII IMPLEMENTED BY THE LICENSEE'S QA PROGRAM, REGULATORY GUIDE 1.144, AND ANSI N45.2.12, PROCEDURE DID NOT DELINEATE THAT PERSONS CONTACTED DURING THE AUDIT BE IDENTIFIED IN THE AUDIT REPORT.  
(8327 5)

10 CFR 50, APPENDIX B, CRITERION X AND THE LICENSEE'S ACCEPTED QUALITY ASSURANCE PROGRAM (TOPICAL REPORT TVA-TR75-1) SECTION 17.2.10 REQUIRE THAT INSPECTION SHALL BE PERFORMED DURING MODIFICATION AFFECTING THE QUALITY OF CRITICAL SYSTEMS, STRUCTURES AND COMPONENTS (CSSC) ITEMS AT TVA PLANTS. MODIFICATION AND ADDITION INSTRUCTION (M&AI)-12 "INTERCONNECTING CABLE TERMINATION AND INSULATION INSPECTION", SECTION 5.0, FURTHER REQUIRES THAT QA INSPECTORS SHALL BE RESPONSIBLE FOR INSPECTING PER THIS PROCEDURE ON CSSC EQUIPMENT. CONTRARY TO THE ABOVE, INSPECTION WAS NOT PERFORMED ON CSSC EQUIPMENT AS REQUIRED BY M&AI-12 SECTION 5 IN THAT DURING THE PERFORMANCE OF WORK PLAN WP10260, WHICH REROUTED SIGNAL CABLES FROM RADIATION MONITORS 1-119, 1-120, 1-121, 2-120 AND 2-121, THE INSPECTION OF THE CABLE TERMINATION PER M&AI-12 WAS PERFORMED BY THE COGNIZANT ENGINEER INSTEAD OF A QA INSPECTOR. THE AFFECTED RADIATION MONITORS ARE CSSC EQUIPMENT. TECHNICAL SPECIFICATION 6.8.1.A REQUIRES THAT WRITTEN PROCEDURES SHALL BE IMPLEMENTED COVERING THE ACTIVITIES REFERENCED IN APPENDIX A OF REGULATORY GUIDE 1.33, REVISION 2, FEBRUARY 1978, INCLUDING DISCHARGING LIQUID RADIOACTIVE WASTE AS EFFLUENTS. SYSTEM OPERATING INSTRUCTION (SOI)-14.3 "CONDENSATE DEMINERALIZER WASTE DISPOSAL" PROVIDES REQUIREMENTS, CONDITIONS, PRECAUTIONS AND INSTRUCTIONS FOR RELEASING THE HIGH CRUD TANKS (HCT). CONTRARY TO THE ABOVE, PROCEDURE SOI-14.3 WAS NOT IMPLEMENTED IN THAT ON OCTOBER 15, 1983, DURING A PLANNED RELEASE FROM HCT "B" TO COOLING TOWER BLOWDOWN, THE TANK WAS PARTIALLY RELEASED TO THE TURBINE BUILDING SUMP BECAUSE THE VALVE ALIGNMENT WAS NOT PROPERLY COMPLETED IN ACCORDANCE WITH THE PROCEDURE. WHEN THE ERROR WAS DISCOVERED, THE RELEASE WAS STOPPED, THE VALVE ALIGNMENT CORRECTED AND THE RELEASE PROPERLY COMPLETED. THE ACTIVITY LEVELS IN THE TANK WERE LESS THAN 10 CFR 20, APPENDIX B, TABLE II LIMITS, THEREFORE, TECHNICAL SPECIFICATION RELEASE LIMITS WERE NOT EXCEEDED.  
(8329 4)

TECHNICAL SPECIFICATION 6.8.1.C. REQUIRES THAT WRITTEN PROCEDURES BE IMPLEMENTED FOR SURVEILLANCE AND TEST ACTIVITIES OF SAFETY-RELATED EQUIPMENT. SURVEILLANCE INSTRUCTION SI-166.3 "FULL STROKING OF CATEGORY "A & B" VALVES DURING COLD SHUTDOWN" PROVIDES PREREQUISITES, PRECAUTIONS AND INSTRUCTIONS FOR INSERVICE TESTING OF VARIOUS SAFETY RELATED VALVES INCLUDING 1-FCV-72-41. CONTRARY TO THE ABOVE, WRITTEN PROCEDURES FOR SURVEILLANCE ACTIVITIES OF SAFETY-RELATED EQUIPMENT WERE NOT PROPERLY IMPLEMENTED IN THAT ON DECEMBER 16, 1983 VALVE 1-FCV-72-41 WAS OPENED WITHOUT VALVES 1-HCV-74-37 AND 1-74-531 BEING SHUT AS REQUIRED BY SECTION 7.7.3.2 OF SI 166.3. THE IMPROPER VALVE ALIGNMENT RESULTED IN APPROXIMATELY 600 GALLONS OF PRIMARY COOLANT BEING SPRAYED INTO UNIT 1 CONTAINMENT. TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. RADIOLOGICAL CONTROL INSTRUCTION RCI-14



Report Period FEB 1984

R E P O R T S F R O M L I C E N S E E

\*\*\*\*\*  
\* SEQUOYAH 1 \*  
\*\*\*\*\*

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
83-113/ 83-116/ 03L-0	09/01/83 09/24/83	09/28/83 10/20/83	STEAM GENERATOR BLOWDOWN EFFLUENT LINE RADIATION MONITOR DECLARED LOSS OF P-250 COMPUTER CAUSING REACTOR COOLANT SUBCOOLING MARGIN MONITOR INOPERABLE DUE TO POWER SPIKE TO THE DISC.
83-117/ 01T-0	09/26/83	10/07/83	MONTHLY POWER RANGE INCORE-EXCORE CHANNEL COMPARISON NOT PERFORMED IN SPECIFIED TIME INTERVAL DUE TO PERSONNEL ERROR.
83-119/ 03L-0	09/10/83	10/07/83	CONTAINMENT INTERNAL PRESSURE LIMIT OF +.3 PSIG RELATIVE TO ANNULUS PRESSURE EXCEEDED DUE TO NORMAL AIR LEAKAGE.
83-120/ 03L-0	09/10/83	10/07/83	ALL ICE CONDENSER DOORS OPENED WHEN 1-FCV-63-73 WAS STROKED DURING PERFORMANCE OF SI-166.3.
83-122/ --	--	--	D/G 2A-A DECLARED INOPERABLE WHEN IT FAILED TO MAINTAIN A LOAD OF 4400KW DURING TEST-CAUSE FAULTY EXCITER TRANSFORMER.
83-123/ 03L-0	09/26/83	10/21/83	CONTROL DAMPER I-FCV-30-149 FAILED TO OPERATE DUE TO FLOW CONTROLLER FC-30-149 BEING INOPERABLE.
83-126/ 03L-0  03L-0	09/26/83	10/25/83	ICE BUILDUP ON SEVERAL INTERMEDIATE DECK DOORS DUE TO HUMIDITY ENTERING THE ICE CONDENSER.  INOPERABLE DUE TO LOSS OF EFFLUENT FLOW.

1. Docket: 50-328                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: DAVID DUPREE (615) 870-6543

4. Licensed Thermal Power (MWt):                      3411

5. Nameplate Rating (Gross MWe):                      1220

6. Design Electrical Rating (Net MWe):                      1148

7. Maximum Dependable Capacity (Gross MWe):                      1183

8. Maximum Dependable Capacity (Net MWe):                      1148


9. If Changes Occur Above Since Last Report, Give Reasons: NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>15,337.0</u>
13. Hours Reactor Critical	<u>635.8</u>	<u>1,379.8</u>	<u>11,740.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>631.6</u>	<u>1,375.6</u>	<u>11,530.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>2,077,520</u>	<u>4,613,057</u>	<u>37,031,124</u>
18. Gross Elec Ener (MWH)	<u>716,270</u>	<u>1,597,750</u>	<u>12,629,690</u>
19. Net Elec Ener (MWH)	<u>691,337</u>	<u>1,541,099</u>	<u>12,158,837</u>
20. Unit Service Factor	<u>90.7</u>	<u>95.5</u>	<u>75.2</u>
21. Unit Avail Factor	<u>90.7</u>	<u>95.5</u>	<u>75.2</u>
22. Unit Cap Factor (MDC Net)	<u>86.5</u>	<u>93.2</u>	<u>69.1</u>
23. Unit Cap Factor (DER Net)	<u>86.5</u>	<u>93.2</u>	<u>69.1</u>
24. Unit Forced Outage Rate	<u>9.3</u>	<u>4.5</u>	<u>9.2</u>
25. Forced Outage Hours	<u>64.4</u>	<u>64.4</u>	<u>1,166.2</u>
26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):	<u>NONE</u>		
27. If Currently Shutdown Estimated Startup Da	<u>N/A</u>		

\*\*\*\*\*  
 \* SEQUOYAH 2 \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT



FEBRUARY 1984



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* SEQUOYAH 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/07/84	F	64.4	A	1				STEAM GENERATOR CHEMISTRY OUT OF SPECIFICATIONS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SEQUOYAH 2 OPERATED WITH 1 OUTAGE FOR EQUIPMENT REPAIR  
 DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





ENFORCEMENT SUMMARY

VERIFICATION. CONTRARY TO THE ABOVE, ADEQUATE PROCEDURES WERE NOT AVAILABLE TO VERIFY THE ADEQUACY OF OPERATING ACTIVITIES IN THAT ON NOVEMBER 1, 1983, LEADS WERE LIFTED FROM UNIT 2 UPPER HEAD INJECTION LEVELS SWITCHES (L/S) 87-23 AND 87-24 TO SUPPORT CALIBRATION PER SI-196.2. THE LEAD LIFTING WAS NOT CONTROLLED BY SI-196.2 AND THERE WERE NO REQUIREMENT FOR INDEPENDENT VERIFICATION OF THE RETERMINATION. THE WIRES WERE RETERMINATED INCORRECTLY AND CAUSED EQUIPMENT INOPERABILITY. THE ERROR ON L/S 87-23 WAS IDENTIFIED AND CORRECTED ON NOVEMBER 8. THE ERROR ON L/S 87-24 WAS IDENTIFIED AND CORRECTED ON NOVEMBER 15. (8329 4)

TECHNICAL SPECIFICATION 6.8.1.A REQUIRES THAT WRITTEN PROCEDURES BE ESTABLISHED AND IMPLEMENTED COVERING SAFETY-RELATED ACTIVITIES INCLUDING THE OPERATION OF THE EMERGENCY CORE COOLING SYSTEM (ECCS). SYSTEM OPERATING INSTRUCTION 501-63.1 "EMERGENCY CORE COOLING SYSTEM" PROVIDES THE STANDBY MODE SYSTEM ADJUSTMENT REQUIREMENTS FOR THE RESIDUAL HEAT REMOVAL (RHR) SYSTEM. CONTRARY TO THE ABOVE, WRITTEN PROCEDURES WERE NOT PROPERLY IMPLEMENTED FOR SAFETY-RELATED ACTIVITIES IN THAT ON DECEMBER 9, 1983 THE INSPECTOR FOUND THAT VALVE 2-FCV-74-520 (2A RHR PUMP DISCHARGE VALVE) WAS OPEN BUT NOT LOCKED AS REQUIRED BY VALVE CHECKLIST 63.1D-1. THE 2A RHR PUMP WAS REQUIRED TO BE OPERABLE. TECHNICAL SPECIFICATION 3.6.1.1 REQUIRES THAT PRIMARY CONTAINMENT INTEGRITY SHALL BE MAINTAINED IN MODES 1, 2, 3 AND 4 AND THAT CONTAINMENT INTEGRITY SHALL BE DEMONSTRATED BY VERIFYING THAT ALL PENETRATIONS REQUIRED TO BE CLOSED DURING ACCIDENT CONDITIONS ARE CLOSED BY VALVES, BLIND FLANGES OR DEACTIVATED AUTOMATIC VALVES SECURED IN THEIR POSITIONS. SURVEILLANCE INSTRUCTION SI-14-2 "VERIFICATION OF CONTAINMENT INTEGRITY" DEMONSTRATES CONTAINMENT INTEGRITY BY VERIFYING THAT CERTAIN VALVES IN THE CONTAINMENT ANNULUS WHICH ISOLATE CONTAINMENT PENETRATIONS ARE LOCKED CLOSED. CONTRARY TO THE ABOVE, CONTAINMENT INTEGRITY WAS NOT PROPERLY DEMONSTRATED IN THAT ON DECEMBER 19, 1983 THE INSPECTOR CHECKED APPROXIMATELY 40 SI-14.2 VALVES IN THE UNIT 2 ANNULUS AND 12 OF THE VALVES WERE NOT LOCKED. ALL VALVES CHECKED WERE IN THEIR PROPER POSITIONS. TECHNICAL SPECIFICATION 6.11 REQUIRES THAT PROCEDURES FOR PERSONNEL RADIATION PROTECTION SHALL BE APPROVED, MAINTAINED AND ADHERED TO FOR ALL OPERATIONS INVOLVING PERSONNEL RADIATION EXPOSURE. RADIOLOGICAL CONTROL INSTRUCTION RCI-14 "RADIATION WORK PERMIT (RWP) PROGRAM" REQUIRES THAT EACH WORKER ENTERING AN RWP AREA RECORD HIS NAME, SOCIAL SECURITY NUMBER, DATE, TIME AND DOSIMETER READING EACH TIME HE ENTERS AND LEAVES THE AREA AND COMPLY WITH ANY OTHER INSTRUCTIONS OF THE RWP. CONTRARY TO THE ABOVE, PROCEDURES FOR PERSONNEL RADIATION PROTECTION WERE NOT ADHERED TO IN THAT ON DECEMBER 22, 1983, THE INSPECTOR NOTED THAT KEY CARD RECORDS FOR DOOR A-8 TO THE 2A RHR PUMP ROOM SHOWED THAT APPROXIMATELY 200 ENTRIES WERE MADE INTO THE ROOM BETWEEN NOVEMBER 19 AND DECEMBER 8, 1983. REVIEW OF RWP 02-2-00831 TIME SHEETS 34, 35, 36 AND 37 WHICH WERE IN EFFECT FOR THAT TIME PERIOD REVEALED THAT ONLY 34 ENTRIES WERE LOGGED. TECHNICAL SPECIFICATION 3.8.2.1 REQUIRES THE FOUR 120 VOLT A.C. VITAL INSTRUMENT BOARDS BE ENERGIZED FROM THEIR RESPECTIVE INVERTERS IN MODES 1, 2, 3 AND 4. WITH ONE INVERTER INOPERABLE, ENERGIZE THE ASSOCIATED VITAL INSTRUMENT POWER BOARD WITHIN 8 HOURS; RESTORE THE INOPERABLE INVERTER TO OPERABLE STATUS WITHIN 24 HOURS OR BE IN AT LEAST HOT STANDBY WITHIN THE NEXT 6 HOURS AND IN COLD SHUTDOWN WITHIN THE FOLLOWING 30 HOURS. CONTRARY TO THE ABOVE, WITH UNIT 2 IN MODE 1 WHILE PERFORMING MAINTENANCE ON VITAL INVERTER 1-I, THE INVERTER WAS TAKEN OUT OF SERVICE AT 12:08 CST ON 12/20/83, AND NOT RETURNED TO SERVICE UNTIL 8:00 A.M. ON 12/22/83. THIS IS IN EXCESS OF THE 24 HOURS ALLOWED BY THE ACTION STATEMENT TO RESTORE THE INVERTER TO OPERABILITY OR BE IN HOT STANDBY WITHIN THE NEXT 6 HOURS. POWER TO THE VITAL INSTRUMENT POWER BOARD WAS MAINTAINED DURING THIS INVERTS OUTAGE. (8331 4)

CONTRARY TO 10CFR55, APPENDIX A, PARAGRAPH 3D, EACH LICENSED OPERATOR AND SENIOR OPERATOR HAS NOT REVIEWED THE CONTENTS OF ALL ABNORMAL INSTRUCTIONS (AOI) OR EMERGENCY INSTRUCTIONS (EOI) ON A REGULARLY SCHEDULED BASIS. (8401 4)

CONTRARY TO 10CFR50, APPENDIX B, CRITERION XIII, THE LICENSEE FAILED TO PROVIDE ADEQUATE SUPPORT OF REACTOR PLANT EQUIPMENT STORED IN OUTSIDE BUILDING 1. FAILURE TO SUPPORT PROPERLY RESULTED IN A 1 3/4 INCH DEFLECTION OF THE WOODEN CONTAINER AND COULD RESULT IN DEFORMATION OF PARTS WITHIN THE CONTAINER.

(8401 5)

OTHER ITEMS



1. Docket: 50-335 OPERATING STATUS  
 2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0  
 3. Utility Contact: N. W. GRANT (305) 552-3675  
 4. Licensed Thermal Power (MWt): 2700  
 5. Nameplate Rating (Gross MWe): 1000 X 0.89 = 890  
 6. Design Electrical Rating (Net MWe): 830  
 7. Maximum Dependable Capacity (Gross MWe): 867  
 8. Maximum Dependable Capacity (Net MWe): 822  
 9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_  
 11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	696.0	1,440.0	63,048.0
13. Hours Reactor Critical	.0	.0	44,466.3
14. Rx Reserve Shtdwn Hrs	.0	.0	205.3
15. Hrs Generator On-Line	.0	.0	43,576.9
16. Unit Reserve Shtdwn Hrs	.0	.0	39.3
17. Gross Therm Ener (MWH)	0	0	108,667,938
18. Gross Elec Ener (MWH)	0	0	35,373,875
19. Net Elec Ener (MWH)	-2,759	-5,486	33,324,214
20. Unit Service Factor	.0	.0	69.1
21. Unit Avail Factor	.0	.0	69.2
22. Unit Cap Factor (MDC Net)	.0	.0	64.3
23. Unit Cap Factor (DER Net)	.0	.0	63.7
24. Unit Forced Outage Rate	.0	.0	4.6
25. Forced Outage Hours	.0	.0	2,104.7

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: 04/15/84

\*\*\*\*\*  
 \* ST LUCIE 1 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### ST LUCIE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ST LUCIE 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
3	02/26/83	S	696.0	C	4		RC	FUELXX	UNIT #1 REMAINED OUT OF SERVICE FOR REFUELING AND SCHEDULED MAINTENANCE.

\*\*\*\*\* ST. LUCIE 1 REMAINS OFFLINE IN A CONTINUING REFUELING/  
 \* SUMMARY \* MAINTENANCE OUTAGE.  
 \*\*\*\*\*

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ST LUCIE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SE OF  
FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...APRIL 22, 1976  
DATE ELEC ENER 1ST GENER...MAY 7, 1976  
DATE COMMERCIAL OPERATE...DECEMBER 21, 1976  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...ATLANTIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 529100  
MIAMI, FLORIDA 33174  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....S. ELROD  
LICENSING PROJ MANAGER.....D. SELLS  
DOCKET NUMBER.....50-335  
LICENSE & DATE ISSUANCE...DPR-67, MARCH 1, 1976  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 11 - DECEMBER 10 (83-42): THIS ROUTINE INSPECTION INVOLVED 47 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, PLANT OPERATIONS, LICENSEE EVENT REPORTS AND IE INFORMATION NOTICES. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 11, 1983 - JANUARY 10, 1984 (83-43): THIS ROUTINE INSPECTION INVOLVED 59 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF MAINTENANCE, SURVEILLANCE, PLANT OPERATIONS, AND TMI ACTION ITEM I.A.1.3. OF THE FOUR AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THREE AREAS; ONE APPARENT VIOLATION WAS IDENTIFIED IN ONE AREA, FAILURE TO MAINTAIN PROCEDURES (PARAGRAPH 5).

INSPECTION JANUARY 9-13 (84-01): THE INSPECTION INVOLVED 16 INSPECTOR HOURS ON SITE BY ONE NRC INSPECTOR. THE INSPECTION WAS BEGUN DURING AN OFFSHIFT PERIOD; 7 INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS AND IE INFORMATION NOTICES; SECURITY ORGANIZATION - MANAGEMENT/ PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; DETECTION AIDS - PROTECTED AREA; DETECTION AIDS - VITAL AREAS; ALARM STATIONS; AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 15 AREAS EXAMINED DURING THE INSPECTION.

INSPECTION JANUARY 18-20 (84-03): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS TO ASSESS ON-SHIFT PROMPT EMERGENCY CLASSIFICATION AND PROTECTIVE ACTION RECOMMENDATIONS. OF THE AREAS



INSPECTION SUMMARY

INSPECTED NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 1-3 (84-04): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 15 INSPECTOR HOURS ON SITE IN THE AREAS OF MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, PLANT OPERATIONS, PREOPERATIONAL TEST 'G, PROCEDURES, LOW POWER TESTING, POWER ASCENSION, PLANT MODIFICATION. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION FEBRUARY 6-10 (84-05): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 18 INSPECTOR HOURS ON SITE IN THE AREAS OF HEALTH PHYSICS INSTRUMENTATION, ACTION ON NUREG 0737 ITEMS, ALARA ACTIVITIES, AND FOLLOW-UP ON PREVIOUS INSPECTOR FOLLOWUP ITEMS. NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THE AREAS INSPECTED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

DURING REFUELING OUTAGE, THE THERMAL SHIELD WITHIN THE REACTOR VESSEL WAS FOUND TO BE BROKEN. THE SHIELD IS BEING REMOVED.

FACILITY ITEMS (PLANS AND PROCEDURES):

EXTENDED OUTAGE, RESTART PLANNED IN EARLY 1984.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ REFUELING.

LAST IE SITE INSPECTION DATE: FEBRUARY 6-10, 1984 +

INSPECTION REPORT NO: 50-335/84-05 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

1. Docket: 50-389 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2560

5. Nameplate Rating (Gross MWe): 0850

6. Design Electrical Rating (Net MWe): 804

7. Maximum Dependable Capacity (Gross MWe): 832

8. Maximum Dependable Capacity (Net MWe): 786

9. If Changes Occur Above Since Last Report, Give Reasons:

---

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>4,945.0</u>
13. Hours Reactor Critical	<u>687.5</u>	<u>1,421.4</u>	<u>4,648.4</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>684.5</u>	<u>1,285.6</u>	<u>4,416.0</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,721,996</u>	<u>3,197,631</u>	<u>10,855,575</u>
18. Gross Elec Ener (MWH)	<u>578,830</u>	<u>1,075,530</u>	<u>3,618,750</u>
19. Net Elec Ener (MWH)	<u>547,789</u>	<u>1,013,681</u>	<u>3,411,267</u>
20. Unit Service Factor	<u>98.3</u>	<u>89.3</u>	<u>89.3</u>
21. Unit Avail Factor	<u>98.3</u>	<u>89.3</u>	<u>89.3</u>
22. Unit Cap Factor (MDC Net)	<u>100.1</u>	<u>89.6</u>	<u>87.8</u>
23. Unit Cap Factor (DER Net)	<u>97.9</u>	<u>87.6</u>	<u>85.8</u>
24. Unit Forced Outage Rate	<u>1.7</u>	<u>8.8</u>	<u>10.2</u>
25. Forced Outage Hours	<u>11.5</u>	<u>124.3</u>	<u>498.9</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):


NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* ST LUCIE 2 \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### ST LUCIE 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ST LUCIE 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
06	02/09/84	F	11.5	A	3	84-04	HH	PUMPXX	MAIN FEEDWATER PUMP TRIPPED DUE TO LOW SUCTION PRESSURE, RESULTING IN REACTOR TRIP. A VENT PROBLEM WITH THE CONDENSATE PUMPS WAS THE CAUSE. THE DESIGN IS BEING CHANGED TO PREVENT RECURRENCE.
07	02/09/84	F	0.0	H	5		HH	ZZZZZ	HIGH STEAM GENERATOR CHLORIDE LEVEL CAUSED POWER REDUCTION.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 ST. LUCIE 2 OPERATED WITH 1 OUTAGE AND 1 REDUCTION DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ST LUCIE 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
COUNTY.....ST LUCIE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...12 MI SE OF  
FT. PIERCE, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 2, 1983  
DATE ELEC ENER 1ST GENER...JUNE 13, 1983  
DATE COMMERCIAL OPERATE...AUGUST 8, 1983  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...ATLANTIC OCEAN  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....P.O. BOX 013100  
MIAMI, FLORIDA 33101  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...COMBUSTION ENGINEERING  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....S. ELROD  
LICENSING PROJ MANAGER.....D. SELLS  
DOCKET NUMBER.....50-389  
LICENSE & DATE ISSUANCE...., JUNE 10, 1983  
PUBLIC DOCUMENT ROOM.....INDIAN RIVER COMMUNITY COLLEGE LIBRARY  
3209 VIRGINIA AVENUE  
FT. PIERCE, FLORIDA 33450

INSPECTION STATUS

INSPECTION SUMMARY

+ INSPECTION NOVEMBER 11 - DECEMBER 10 (83-70): THIS ROUTINE INSPECTION INVOLVED 48 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF MAINTENANCE OBSERVATION, SURVEILLANCE OBSERVATION, PLANT OPERATIONS, LICENSEE EVENT REPORTS, AND IE INFORMATION NOTICES. OF THE FIVE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION DECEMBER 11, 1983 - JANUARY 10, 1984 (83-71): THIS ROUTINE INSPECTION INVOLVED 60 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF MAINTENANCE, SURVEILLANCE, PLANT OPERATIONS, AND TMI ACTION ITEM I.A.1.3. OF THE FOUR AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN THREE AREAS; ONE APPARENT VIOLATION WAS IDENTIFIED IN ONE AREA, FAILURE TO MAINTAIN PROCEDURES (PARAGRAPH 5).

INSPECTION JANUARY 9-13 (84-02): THE INSPECTION INVOLVED 16 INSPECTOR HOURS ON SITE BY ONE NRC INSPECTOR. THE INSPECTION WAS BEGUN DURING AN OFFSHIFT PERIOD; 7 INSPECTION HOURS WERE ACCOMPLISHED DURING OFFSHIFT PERIODS. THE INSPECTION INCLUDED LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS AND IE INFORMATION NOTICES; SECURITY ORGANIZATION - MANAGEMENT/ PERSONNEL/RESPONSE; SECURITY PROGRAM AUDIT; PHYSICAL BARRIERS - PROTECTED AREA; PHYSICAL BARRIERS - VITAL AREAS; ASSESSMENT AIDS; ACCESS CONTROL - PERSONNEL; ACCESS CONTROL - PACKAGES; ACCESS CONTROL - VEHICLES; DETECTION AIDS - PROTECTED AREA; DETECTION AIDS - VITAL AREAS; ALARM STATIONS; AND COMMUNICATIONS. THE LICENSEE WAS FOUND TO BE IN COMPLIANCE WITH NRC REQUIREMENTS WITHIN THE 15 AREAS EXAMINED DURING THE INSPECTION.

INSPECTION JANUARY 18-20 (84-04): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS TO ASSESS ON-SHIFT PROMPT EMERGENCY CLASSIFICATION AND PROTECTIVE ACTION RECOMMENDATIONS. OF THE AREAS



1. Docket: 50-395 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: G. A. LOIGNON (803) 345-5209

4. Licensed Thermal Power (MWt): 2775

5. Nameplate Rating (Gross MWe): 0900

6. Design Electrical Rating (Net MWe): 900

7. Maximum Dependable Capacity (Gross MWe): 900

8. Maximum Dependable Capacity (Net MWe): 900

9. If Changes Occur Above Since Last Report, Give Reasons:

---

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:           

NONE


	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>1,440.0</u>
13. Hours Reactor Critical	<u>641.8</u>	<u>1,376.8</u>	<u>1,376.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>611.4</u>	<u>1,344.2</u>	<u>1,344.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,666,309</u>	<u>3,663,244</u>	<u>3,663,244</u>
18. Gross Elec Ener (MWH)	<u>554,195</u>	<u>1,222,545</u>	<u>1,222,545</u>
19. Net Elec Ener (MWH)	<u>531,912</u>	<u>1,173,800</u>	<u>1,173,800</u>
20. Unit Service Factor	<u>87.8</u>	<u>93.3</u>	<u>93.3</u>
21. Unit Avail Factor	<u>87.8</u>	<u>93.3</u>	<u>93.3</u>
22. Unit Cap Factor (MDC Net)	<u>84.9</u>	<u>90.6</u>	<u>90.6</u>
23. Unit Cap Factor (DER Net)	<u>84.9</u>	<u>90.6</u>	<u>90.6</u>
24. Unit Forced Outage Rate	<u>12.2</u>	<u>6.7</u>	<u>6.7</u>
25. Forced Outage Hours	<u>84.6</u>	<u>95.8</u>	<u>95.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
SPRING MAINTENANCE, MARCH 22, 1984, 29 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* SUMMER 1 \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

SUMMER 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SUMMER 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
2	02/07/84	F	25.4	A	3				REACTOR TRIP FROM "B" STEAM GENERATOR LO-LO LEVEL.
3	02/08/84	F	59.2	A	1				TRIPPED TURBINE BECAUSE FEEDWATER TEMPERATURE DECREASED TO BELOW 225 DEGREES F CLOSING FEEDWATER ISOLATION VALVES.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SUMMER 1 OPERATED AT FULL POWER WITH 2 OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	H-Other	5-Reduced Load	Licensee Event Report
	D-Regulatory Restriction	9-Other	(LER) File (NUREG-0161)
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* SUMMER 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....SOUTH CAROLINA  
COUNTY.....FAIRFIELD  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...26 MI NW OF  
COLUMBIA, SC  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 22, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE....JANUARY 1, 1984  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....MONTICELLO RESERVOIR  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....SOUTH CAROLINA ELECTRIC & GAS CO.  
CORPORATE ADDRESS.....P.O. BOX 764  
COLUMBIA, SOUTH CAROLINA 29202  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....DANIEL INTERNATIONAL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....  
LICENSING PROJ MANAGER.....J. HOPKINS  
DOCKET NUMBER.....50-395  
LICENSE & DATE ISSUANCE...NPF-12, NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....FAIRFIELD COUNTY LIBRARY  
GARDEN & WASHINGTON STREETS  
WINNSBORO, SOUTH CAROLINA 29180

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION JANUARY 16-19 (84-01): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 79 INSPECTOR HOURS ON SITE IN THE AREAS OF QUALITY CONTROL AND CONFIRMATORY MEASUREMENTS INCLUDING: REVIEW OF THE LABORATORY QUALITY CONTROL PROGRAM; REVIEW OF CHEMICAL AND RADIOCHEMICAL PROCEDURES; AIRBORNE EFFLUENT SAMPLING METHODOLOGY; AND COMPARISON OF THE RESULTS OF SPLIT SAMPLES ANALYZED BY THE LICENSEE AND THE NRC REGION II MOBILE LABORATORY. OF THE FOUR AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 16-20 (84-02): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 69 INSPECTOR HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 10-13 (84-03): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 32 RESIDENT INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONAL SAFETY VERIFICATION, MAINTENANCE AND SURVEILLANCE ACTIVITIES, PHYSICAL PROTECTION, TECHNICAL SPECIFICATION COMPLIANCE, LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, AND FOLLOW-UP OF LICENSEE EVENT REPORTS. OF THE 6 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE





1. Docket: 50-280 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (Mwt): 2441

5. Nameplate Rating (Gross MWe): 942 X 0.9 = 848

6. Design Electrical Rating (Net MWe): 788

7. Maximum Dependable Capacity (Gross MWe): 811

8. Maximum Dependable Capacity (Net MWe): 775


9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

\*\*\*\*\*  
\* SURRY 1 \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 1



FEBRUARY 1984

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>98,088.0</u>
13. Hours Reactor Critical	<u>571.8</u>	<u>1,310.7</u>	<u>60,409.7</u>
14. Rx Reserve Shtdwn Hrs	<u>4.2</u>	<u>9.3</u>	<u>3,774.5</u>
15. Hrs Generator On-Line	<u>566.5</u>	<u>1,280.0</u>	<u>59,146.8</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>3,736.2</u>
17. Gross Therm Ener (MWH)	<u>1,342,137</u>	<u>3,026,287</u>	<u>137,426,900</u>
18. Gross Elec Ener (MWH)	<u>433,030</u>	<u>972,425</u>	<u>44,292,268</u>
19. Net Elec Ener (MWH)	<u>411,451</u>	<u>923,876</u>	<u>42,001,612</u>
20. Unit Service Factor	<u>81.4</u>	<u>88.9</u>	<u>60.3</u>
21. Unit Avail Factor	<u>81.4</u>	<u>88.9</u>	<u>64.1</u>
22. Unit Cap Factor (MDC Net)	<u>76.3</u>	<u>82.8</u>	<u>55.3</u>
23. Unit Cap Factor (DER Net)	<u>75.0</u>	<u>81.4</u>	<u>54.3</u>
24. Unit Forced Outage Rate	<u>1.6</u>	<u>3.0</u>	<u>21.3</u>
25. Forced Outage Hours	<u>9.3</u>	<u>39.8</u>	<u>12,251.6</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
WINTER MAINTENANCE - 2-24-84 - 2 WEEKS.

27. If Currently Shutdown Estimated Startup Date: 03/09/84

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SURRY 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-3	02/06/84	F	9.3	A	3	84-003-00	LD	PSF	REACTOR TRIP CAUSED BY "A" S/G LOW LEVEL WITH A STEAM FLOW/FEED FLOW MISMATCH. THE INITIATING EVENT WAS A LOSS OF CONTROL POWER TO UNIT 1 POLISHERS AND THE SUBSEQUENT RE-ENERGIZING OF THE TRIPPED BREAKER. RE-ENERGIZING CONTROL POWER CAUSED THE ADV'S FOR THE POLISH BEDS TO GO CLOSED CAUSING A REDUCTION IN FEEDWATER FLOW. THE CORRECTIVE ACTION WAS TO REPLACE THE BREAKER THAT TRIPPED CAUSING A LOSS OF CONTROL POWER. ALSO A SIGN WILL BE POSTED BY THE BREAKER STATING THAT "DO NOT RE-ENERGIZE BREAKER UNTIL POLISH BLDG. IS BYPASSED."
84-4	02/24/84	S	120.2	H	1				SHUTDOWN FOR SNUBBER OUTAGE AND REPAIRS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SURRY 1 OPERATED ROUTINELY, SHUTTING DOWN ON FEBRUARY 24TH FOR MAINTENANCE AND REPAIRS.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	F-Admin	2-Manual Scram	Instructions for
	B-Maint or Test	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* SURRY 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....SURRY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI NW OF  
NEWPORT NEWS, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JULY 1, 1972  
DATE ELEC ENER 1ST GENER...JULY 4, 1972  
DATE COMMERCIAL OPERATE...DECEMBER 22, 1972  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...JAMES RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA ELECTRIC & POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. BURKE  
LICENSING PROJ MANAGER.....D. NEIGHBORS  
DOCKET NUMBER.....50-280  
LICENSE & DATE ISSUANCE...DPR-32, MAY 25, 1972  
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION DECEMBER 1-31 (83-37): THIS INSPECTION INVOLVED 95 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS, PLANT SECURITY, FOLLOW-UP OF EVENTS AND LICENSEE EVENT REPORTS, PERFORMANCE APPRAISAL STAFF INSPECTION FINDINGS, MAINTENANCE AND SURVEILLANCE REVIEW. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 23-25 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED TWO VIOLATIONS WERE FOUND IN TWO AREAS (INADEQUATE PROCEDURES FOR PROTECTIVE ACTION DECISIONMAKING AND FAILURE TO PROPERLY TRAIN EMERGENCY PERSONNEL IN PROTECTIVE ACTION RECOMMENDATION DECISIONMAKING). THESE ARE DISCUSSED IN PARAGRAPH 5.

INSPECTION JANUARY 30 - FEBRUARY 2 (84-03): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 11 INSPECTOR-HOURS ON SITE IN THE AREAS OF FOLLOWUP ON LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, IE BULLETIN 81-01, AND FOLLOWUP ON LICENSEE IDENTIFIED ITEMS. OF THE 3 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN TWO AREAS; ONE APPARENT VIOLATION WAS FOUND IN ONE AREA (FAILURE TO PERFORM ADDITIONAL FUNCTIONAL TESTS ON SNIPPERS PER TECHNICAL SPECIFICATION REQUIREMENTS - PARAGRAPH 3).

INSPECTION JANUARY 3-31 (84-04): THIS INSPECTION INVOLVED 100 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS AND OPERATING RECORDS, PLANT MAINTENANCE AND SURVEILLANCE, PLANT SECURITY, FOLLOWUP OF EVENTS AND LICENSEE EVENT REPORTS. OF THE FOUR AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN THREE AREAS, AND ONE VIOLATION WAS IDENTIFIED IN ONE AREA; (FAILURE TO PROPERLY MONITOR A RADIOACTIVE GASEOUS WASTE RELEASE - PARAGRAPH 5.B).



1. Docket: 50-281                    O P E R A T I N G   S T A T U S

2 Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: VIVIAN H. JONES (804) 357-3184

4. Licensed Thermal Power (MWt):                    2441

5. Nameplate Rating (Gross MWe):                    942 X 0.9 = 848

6. Design Electrical Rating (Net MWe):                    788

7. Maximum Dependable Capacity (Gross MWe):                    811

8. Maximum Dependable Capacity (Net MWe):                    775


9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

\*\*\*\*\*  
\*                    SURRY 2                    \*  
\*\*\*\*\*  
AVERAGE DAILY POWER LEVEL (MWe) PLOT

SURRY 2



FEBRUARY 1984

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>94,968.0</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,416.2</u>	<u>59,986.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>23.8</u>	<u>23.8</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,407.1</u>	<u>58,983.1</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,659,218</u>	<u>3,375,408</u>	<u>138,091,280</u>
18. Gross Elec Ener (MWH)	<u>530,760</u>	<u>1,083,220</u>	<u>44,873,079</u>
19. Net Elec Ener (MWH)	<u>503,388</u>	<u>1,027,846</u>	<u>42,534,906</u>
20. Unit Service Factor	<u>100.0</u>	<u>97.7</u>	<u>62.1</u>
21. Unit Avail Factor	<u>100.0</u>	<u>97.7</u>	<u>62.1</u>
22. Unit Cap Factor (MDC Net)	<u>93.3</u>	<u>92.1</u>	<u>57.8</u>
23. Unit Cap Factor (DER Net)	<u>91.8</u>	<u>90.6</u>	<u>56.8</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>2.3</u>	<u>13.9</u>
25. Forced Outage Hours	<u>.0</u>	<u>32.9</u>	<u>6,859.5</u>

26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
SPRING MAINTENANCE 3-16-84 - 14 DAYS.

27. If Currently Shutdown Estimated Startup Date: N/A

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SURRY 2 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-3	02/11/84	S	0.0	H	5				POWER WAS REDUCED TO 65% (505 MW'S) FOR LOAD FOLLOWING.
84-4	02/12/84	S	0.0	H	5				POWER WAS REDUCED TO 76% (615 MW'S) FOR LOAD FOLLOWING.
84-5	02/14/84	S	0.0	H	5				POWER WAS REDUCED TO 64% (500 MW'S) FOR LOAD FOLLOWING.
84-6	02/15/84	S	0.0	H	5				POWER WAS REDUCED TO 64% (500 MW'S) FOR LOAD FOLLOWING.
84-7	02/17/84	S	0.0	H	5				POWER WAS REDUCED TO 64% (500 MW'S) FOR LOAD FOLLOWING.
84-8	02/18/84	S	0.0	H	5				POWER WAS REDUCED TO 64% (500 MW'S) FOR LOAD FOLLOWING.
84-9	02/19/84	S	0.0	H	5				POWER WAS REDUCED TO 64% (500 MW'S) FOR LOAD FOLLOWING.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SURRY 2 OPERATED WITH 7 REDUCTIONS AND NO OUTAGES DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SURRY 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....VIRGINIA  
COUNTY.....SURRY  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...17 MI NW OF  
NEWPORT NEWS, VA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...MARCH 7, 1973  
DATE ELEC ENER 1ST GENER...MARCH 10, 1973  
DATE COMMERCIAL OPERATE...MAY 1, 1973  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....JAMES RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....VIRGINIA ELECTRIC & POWER  
CORPORATE ADDRESS.....P.O. BOX 26666  
RICHMOND, VIRGINIA 23261  
CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....D. BURKE  
LICENSING PROJ MANAGER.....D. NEIGHBORS  
DOCKET NUMBER.....50-281  
LICENSE & DATE ISSUANCE...DPR-37, JANUARY 29, 1973  
PUBLIC DOCUMENT ROOM.....SWEM LIBRARY  
COLLEGE OF WILLIAM AND MARY  
WILLIAMSBURG, VIRGINIA 23185

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

+ INSPECTION DECEMBER 1-31 (83-39): THIS INSPECTION INVOLVED 95 INSPECTOR-HOURS ON SITE IN THE AREAS OF OPERATIONS, PLANT SECURITY, FOLLOW-UP OF EVENTS AND LICENSEE EVENT REPORTS, PERFORMANCE APPRAISAL STAFF INSPECTION FINDINGS, MAINTENANCE AND SURVEILLANCE REVIEW. IN THE AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED.

INSPECTION JANUARY 23-25 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 10 INSPECTOR HOURS ON SITE IN THE AREAS OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED TWO VIOLATIONS WERE FOUND IN TWO AREAS (INADEQUATE PROCEDURES FOR PROTECTIVE ACTION DECISIONMAKING AND FAILURE TO PROPERLY TRAIN EMERGENCY PERSONNEL IN PROTECTIVE ACTION RECOMMENDATION DECISIONMAKING). THESE ARE DISCUSSED IN PARAGRAPH 5.

INSPECTION JANUARY 30 - FEBRUARY 2 (84-03): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 12 INSPECTOR-HOURS ON SITE IN THE AREAS OF FOLLOWUP ON LICENSEE ACTION ON PREVIOUS INSPECTION FINDINGS, IE BULLETIN 81-01, AND FOLLOWUP ON LICENSEE IDENTIFIED ITEMS. OF THE 3 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN TWO AREAS; ONE APPARENT VIOLATION WAS FOUND IN ONE AREA (FAILURE TO PERFORM ADDITIONAL FUNCTIONAL TESTS ON SNUBBERS PER TECHNICAL SPECIFICATION REQUIREMENTS - PARAGRAPH 3).

INSPECTION JANUARY 3-31 (84-04): THIS INSPECTION INVOLVED 100 RESIDENT INSPECTOR HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS AND OPERATING RECORDS, PLANT MAINTENANCE AND SURVEILLANCE, PLANT SECURITY, FOLLOWUP OF EVENTS AND LICENSEE EVENT REPORTS. OF THE FOUR AREAS INSPECTED, NO VIOLATIONS WERE IDENTIFIED IN THREE AREAS, AND ONE VIOLATION WAS IDENTIFIED IN ONE AREA; (FAILURE TO PROPERLY MONITOR A RADIOACTIVE GASEOUS WASTE RELEASE - PARAGRAPH 5.B).





1. Docket: 50-387                      O P E R A T I N G   S T A T U S

2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0

3. Utility Contact: L. A. KUCZYNSKI (717) 542-2181

4. Licensed Thermal Power (MWt):                      3293

5. Nameplate Rating (Gross MWe):                      1280 X 0.9 = 1152

6. Design Electrical Rating (Net MWe):                      1065

7. Maximum Dependable Capacity (Gross MWe):                      1068

8. Maximum Dependable Capacity (Net MWe):                      1032

9. If Changes Occur Above Since Last Report, Give Reasons:

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_

NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>6,409.0</u>
13. Hours Reactor Critical	<u>159.9</u>	<u>159.9</u>	<u>4,005.2</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>156.7</u>
15. Hrs Generator On-Line	<u>98.2</u>	<u>98.2</u>	<u>3,866.5</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>163,201</u>	<u>163,201</u>	<u>11,412,972</u>
18. Gross Elec Ener (MWH)	<u>43,470</u>	<u>43,470</u>	<u>3,710,020</u>
19. Net Elec Ener (MWH)	<u>40,180</u>	<u>40,180</u>	<u>3,576,553</u>
20. Unit Service Factor	<u>14.1</u>	<u>6.8</u>	<u>60.3</u>
21. Unit Avail Factor	<u>14.1</u>	<u>6.8</u>	<u>60.3</u>
22. Unit Cap Factor (MDC Net)	<u>5.6</u>	<u>2.7</u>	<u>54.1</u>
23. Unit Cap Factor (DER Net)	<u>5.4</u>	<u>2.6</u>	<u>52.4</u>
24. Unit Forced Outage Rate	<u>46.8</u>	<u>46.8</u>	<u>13.3</u>
25. Forced Outage Hours	<u>86.3</u>	<u>86.3</u>	<u>594.8</u>

26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):


NONE

27. If Currently Shutdown Estimated Startup Date:                      N/A

\*\*\*\*\*  
 \*                      SUSQUEHANNA 1                      \*  
 \*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### SUSQUEHANNA 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* SUSQUEHANNA 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
20	12/03/83	S	511.5	H	2		ZZ	ZZZZZZ	MANUAL SCRAM FROM 33% REACTOR POWER TO COMMENCE UNIT 1-UNIT 2 TIE-IN OUTAGE. NO ACTION REQUIRED TO PREVENT RECURRENCE; THIS WAS A SCHEDULED EVENT. OUTAGE COMPLETED AT 0728 ON 2/22/84.
1A	02/22/84	F	12.2	A	2				GENERATOR REMOVED FROM GRID FOR 12.2. HRS. ON FEB 22-23, 1984, DUE TO GENERATOR 'C' PHASE OUTPUT DISCONNECT BREAKER SWITCH IMPROPER CLOSURE CAUSING BREAKER OVERHEATING.
1B	02/25/84	F	74.1	A	2	84-010	SF	VALVOP	MANUAL SCRAM FROM 54% POWER DUE TO A SAFETY RELIEF VALVE (SRV) FAILURE TO CLOSE DURING TESTING. UNIT RESPONDED TO SCRAM AS DESIGNED. ONE SRV SOLENOID VALVE WAS REPLACED, SUCCESSFULLY RETESTED AND THE SYSTEM RETURNED TO SERVICE.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 SUSQUEHANNA 1 RETURNED ONLINE FEBRUARY 22ND FROM UNIT 1&2 TIE-IN OUTAGE AND OPERATED WITH ONE OUTAGE DUE TO EQUIPMENT FAILURE ON THE 25TH.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* SUSQUEHANNA 1 \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....LUZERNE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...7 MI NE OF  
BERWICK, PA  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...SEPTEMBER 10, 1982  
DATE ELEC ENER 1ST GENER...NOVEMBER 16, 1982  
DATE COMMERCIAL OPERATE....JUNE 8, 1983  
CONDENSER COOLING METHOD...CC,HNDCT  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY  
LICENSEE.....PENNSYLVANIA POWER & LIGHT  
CORPORATE ADDRESS.....2 NORTH NINTH STREET  
ALLENTOWN, PENNSYLVANIA 18101

CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. JACOBS  
LICENSING PROJ MANAGER.....R. PERCH  
DOCKET NUMBER.....50-387  
LICENSE & DATE ISSUANCE...., NOVEMBER 12, 1982  
PUBLIC DOCUMENT ROOM.....OSTERHOUT FREE LIBRARY  
71 SOUTH FRANKLIN STREET  
WILKES-BARRE, PENNSYLVANIA 18701

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.



1. Docket: 50-289 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: C. W. SMYTH (717) 948-8551

4. Licensed Thermal Power (Mwt): 2535

5. Nameplate Rating (Gross MWe): 968 X 0.9 = 871

6. Design Electrical Rating (Net MWe): 819

7. Maximum Dependable Capacity (Gross MWe): 840

8. Maximum Dependable Capacity (Net MWe): 776

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):           

11. Reasons for Restrictions, If Any:             
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>83,233.0</u>
13. Hours Reactor Critical	<u>.0</u>	<u>.0</u>	<u>31,731.8</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>839.5</u>
15. Hrs Generator On-Line	<u>.0</u>	<u>.0</u>	<u>31,180.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>0</u>	<u>0</u>	<u>76,531,071</u>
18. Gross Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>25,484,330</u>
19. Net Elec Ener (MWH)	<u>0</u>	<u>0</u>	<u>23,840,053</u>
20. Unit Service Factor	<u>.0</u>	<u>.0</u>	<u>37.5</u>
21. Unit Avail Factor	<u>.0</u>	<u>.0</u>	<u>37.5</u>
22. Unit Cap Factor (MDC Net)	<u>.0</u>	<u>.0</u>	<u>36.6*</u>
23. Unit Cap Factor (DER Net)	<u>.0</u>	<u>.0</u>	<u>35.0</u>
24. Unit Forced Outage Rate	<u>100.0</u>	<u>100.0</u>	<u>58.9</u>
25. Forced Outage Hours	<u>696.0</u>	<u>1,440.0</u>	<u>44,565.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### THREE MILE ISLAND 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* THREE MILE ISLAND 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	02/17/79	F	696.0	D	4		ZZ	ZZZZZZ	REGULATORY RESTRAINT ORDER CONTINUES.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
THREE MILE ISLAND 1 REMAINS SHUTDOWN FOLLOWING THE  
ACCIDENT AT UNIT 2.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sche	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* THREE MILE ISLAND \*  
\*\*\*\*\*

F A C I L I T Y   D A T A

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....PENNSYLVANIA  
COUNTY.....DAUPHIN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...10 MI SE OF  
HARRISBURG, PA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...JUNE 5, 1974  
DATE ELEC ENER 1ST GENER...JUNE 19, 1974  
DATE COMMERCIAL OPERATE...SEPTEMBER 2, 1974  
CONDENSER COOLING METHOD... COOLING TOWERS  
CONDENSER COOLING WATER...SUSQUEHANNA RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....MID-ATLANTIC  
AREA COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....GPU NUCLEAR CORP.  
CORPORATE ADDRESS.....P.O. BOX 480  
MIDDLETOWN, PENNSYLVANIA 17057  
CONTRACTOR  
ARCHITECT/ENGINEER.....GILBERT ASSOCIATES  
NUC STEAM SYS SUPPLIER...BABCOCK & WILCOX  
CONSTRUCTOR.....UNITED ENG. & CONSTRUCTORS  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....R. CONTE  
LICENSING PROJ MANAGER.....J. VANVLIET  
DOCKET NUMBER.....50-289  
LICENSE & DATE ISSUANCE...DPR-50, APRIL 19, 1974  
PUBLIC DOCUMENT ROOM.....GOVERNMENT PUBLICATIONS SECTION  
STATE LIBRARY OF PENNSYLVANIA  
FORUM BUILDING  
COMMONWEALTH AND WALNUT STREET  
HARRISBURG, PENNSYLVANIA 17105

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):



Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           THREE MILE ISLAND 1           \*  
\*\*\*\*\*

OTHER ITEMS

NO INPUT PROVIDED.

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NO INPUT PROVIDED.			

=====



Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* TROJAN \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-1	02/11/84	S	0.0	B	5				REDUCED POWER TO 50% TO INVESTIGATE FEEDWATER HEATER TUBE LEAKS.
84-2	02/18/84	F	34.6	G	3	84-03	EB	CKTBRK	AN ELECTRICAL SHORT CIRCUIT WAS CREATED BETWEEN PREFERRED INSTRUMENT BUSES Y11 AND Y22 WHILE ATTEMPTING TO REPLACE A FUSE DURING TESTING OF A CONTAINMENT ATMOSPHERE SAMPLING SYSTEM ISOLATION VALVE (SV-5643). THIS RESULTED IN A REACTOR TRIP AND INITIATION OF 'B' TRAIN SAFETY INJECTION. CORRECTIVE ACTION WAS TO REROUTE THE WIRING AND FUSING WITHIN THE PANEL TO PROVIDE MORE TRAIN SEPARATION.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 TROJAN OPERATED WITH 1 REDUCTION AND 1 OUTAGE DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)





1. Docket: 50-250 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (Mwt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>98,505.6</u>
13. Hours Reactor Critical	<u>446.1</u>	<u>1,049.2</u>	<u>69,074.5</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>844.3</u>
15. Hrs Generator On-Line	<u>432.5</u>	<u>976.7</u>	<u>66,898.9</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>121.8</u>
17. Gross Therm Ener (MWH)	<u>943,756</u>	<u>1,992,922</u>	<u>137,481,514</u>
18. Gross Elec Ener (MWH)	<u>306,200</u>	<u>640,265</u>	<u>43,850,830</u>
19. Net Elec Ener (MWH)	<u>287,728</u>	<u>600,816</u>	<u>41,513,833</u>
20. Unit Service Factor	<u>62.1</u>	<u>67.8</u>	<u>67.9</u>
21. Unit Avail Factor	<u>62.1</u>	<u>67.8</u>	<u>68.0</u>
22. Unit Cap Factor (MDC Net)	<u>62.1</u>	<u>62.6</u>	<u>65.1*</u>
23. Unit Cap Factor (DER Net)	<u>59.7</u>	<u>60.2</u>	<u>60.8</u>
24. Unit Forced Outage Rate	<u>37.9</u>	<u>22.9</u>	<u>5.7</u>
25. Forced Outage Hours	<u>263.5</u>	<u>290.2</u>	<u>3,470.3</u>


26. Shutdowns Sched Over Next 6 Months (Type,Date,Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 03/03/84

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### TURKEY POINT 3



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* TURKEY POINT 3 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
08	02/12/84	F	18.4	A	3	84-06	EB	RELAYX	ELECTRICAL RELAY MALFUNCTION CAUSED LOSS OF POWER SUPPLY TO MAIN FEED PUMP WHICH RESULTED IN A REACTOR TRIP. UNIT WAS RETURNED TO SERVICE.
09	02/16/84	F	195.2	A	3	84-07	EB	RELAYX	WHILE PREPARING TO MAKE REPAIRS TO A BREAKER, A RELAY WAS JARRED WHICH CAUSED THE LOSS OF THE POWER SUPPLIES TO FEED AND CONDENSATE PUMPS. THIS RESULTED IN A REACTOR TRIP. THE UNIT REMAINED OUT OF SERVICE FOR A COMPLETE INVESTIGATION.
10	02/27/84	F	49.9	A	1		EB	RELAYX	THE UNIT WAS REMOVED FROM SERVICE TO INSPECT, ADJUST AND REPAIR AUXILIARY AIR CURCUIT BREAKERS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 TURKEY POINT 3 OPERATED WITH 3 OUTAGES AND NO REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* TURKEY POINT 3 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....FLORIDA  
COUNTY.....DADE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...OCTOBER 20, 1972  
DATE ELEC ENER 1ST GENER...NOVEMBER 2, 1972  
DATE COMMERCIAL OPERATE....DECEMBER 14, 1972  
CONDENSER COOLING METHOD...CLOSED CANAL  
CONDENSER COOLING WATER...CLOSED CYCLE CANAL  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174

CONTRACTOR  
ARCHITECT/ENGINEER..... BECHTEL  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....BECHTEL  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
IE RESIDENT INSPECTOR.....R. VOGT LOWELL  
LICENSING PROJ MANAGER.....D. MCDONALD  
DOCKET NUMBER.....50-250  
LICENSE & DATE ISSUANCE...DPR-31, JULY 19, 1972  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

+ INSPECTION OCTOBER 18-21 (83-37): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 33 INSPECTOR HOURS ON SITE IN THE AREAS OF RADIOLOGICAL CONTROLS ASSOCIATED WITH THE UNIT 3 REFUELING OUTAGE INCLUDING EXTERNAL EXPOSURE CONTROL, INTERNAL EXPOSURE CONTROL, POSTING, LABELING AND CONTROL, SURVEYS, QUALIFICATIONS OF CONTRACT HP TECHNICIANS, ENTRY INTO THE CONTAINMENT SUMP, SPENT FUEL PIT DEMINERALIZER RESIN TRANSFER, FOLLOWUP ON UNPLANNED GASEOUS RADIOACTIVITY RELEASES AND FOLLOWUP ON PREVIOUS INSPECTOR IDENTIFIED ITEMS. OF THE 9 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 7 AREAS; ONE APPARENT VIOLATION WAS FOUND IN EACH OF 2 AREAS (FAILURE TO FOLLOW TECHNICAL SPECIFICATIONS AND FAILURE TO HAVE AN APPROVED PROCEDURE).

INSPECTION DECEMBER 3, 1983 - JANUARY 6, 1984 (83-41): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 64 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS, SURVEILLANCE TESTING, MAINTENANCE, DOCUMENTATION, LICENSEE PROGRAM IMPROVEMENTS AND FIRE PROTECTION. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; AND TWO VIOLATIONS WERE IDENTIFIED IN TWO AREAS, FAILURE TO COMPENSATE INTERMEDIATE RANGE NUCLEAR INSTRUMENTATION ADEQUATELY (PARAGRAPH 7), AND FAILURE TO MAINTAIN ADEQUATE PLANT CHANGE DOCUMENTATION (PARAGRAPH 9). FIVE EXAMPLES OF VIOLATIONS WHICH HAD BEEN PREVIOUSLY IDENTIFIED IN REPORT 250, 251/83-38 WERE IDENTIFIED IN ONE AREA.

INSPECTION JANUARY 16-18 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 9 INSPECTOR HOURS ON SITE IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED IN 2 AREAS (INADEQUATE PROCEDURES FOR PROTECTIVE ACTION DECISIONMAKING, FAILURE TO PROPERLY TRAIN EMERGENCY PERSONNEL IN PROTECTIVE ACTION RECOMMENDATION REQUIREMENTS AND IN EMERGENCY DOSE CALCULATIONS). THESE ARE DISCUSSED IN PARAGRAPHS 5, 5, AND 6, RESPECTIVELY.





Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           TURKEY POINT 3           \*  
\*\*\*\*\*

ENFORCEMENT SUMMARY

PERFORMED IN ACCORDANCE WITH APPENDIX A , IN ORDER TO DETERMINE THE CAUSE OF THE TRIP AND TO INSURE ANY SAFETY CONSIDERATIONS ARE RESOLVED PRIOR TO UNIT STARTUP. CONTRARY TO THE ABOVE, UNIT 4 WAS RESTARTED ON OCTOBER 16, 1983, WITHOUT COMPLETING A POST TRIP REVIEW.  
(8340 4)

FAILURE TO PROVIDE POSITIVE ACCESS CONTROL TO A VITAL AREA.  
(8343 4)

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE.

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

+ OPERATING.

LAST IE SITE INSPECTION DATE: JANUARY 30 - FEBRUARY 3, 1984 +

INSPECTION REPORT NO: 50-250/84-03 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
NONE.			

=====

THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-251 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: N. W. GRANT (305) 552-3675

4. Licensed Thermal Power (MWt): 2200

5. Nameplate Rating (Gross MWe): 894 X 0.85 = 760

6. Design Electrical Rating (Net MWe): 693

7. Maximum Dependable Capacity (Gross MWe): 700

8. Maximum Dependable Capacity (Net MWe): 666

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe):         

11. Reasons for Restrictions, If Any:           
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>92,233.0</u>
13. Hours Reactor Critical	<u>472.0</u>	<u>1,201.1</u>	<u>65,839.9</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>166.6</u>
15. Hrs Generator On-Line	<u>434.3</u>	<u>1,157.9</u>	<u>63,626.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>31.2</u>
17. Gross Therm Ener (MWH)	<u>931,821</u>	<u>2,522,918</u>	<u>134,278,659</u>
18. Gross Elec Ener (MWH)	<u>303,040</u>	<u>821,410</u>	<u>42,742,772</u>
19. Net Elec Ener (MWH)	<u>283,309</u>	<u>777,469</u>	<u>40,484,577</u>
20. Unit Service Factor	<u>62.4</u>	<u>80.4</u>	<u>69.0</u>
21. Unit Avail Factor	<u>62.4</u>	<u>80.4</u>	<u>69.0</u>
22. Unit Cap Factor (MDC Net)	<u>61.1</u>	<u>81.1</u>	<u>67.8*</u>
23. Unit Cap Factor (DER Net)	<u>58.7</u>	<u>77.9</u>	<u>63.3</u>
24. Unit Forced Outage Rate	<u>37.6</u>	<u>19.6</u>	<u>4.8</u>
25. Forced Outage Hours	<u>261.7</u>	<u>282.1</u>	<u>2,823.9</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
NONE

27. If Currently Shutdown Estimated Startup Date: 04/30/84

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

TURKEY POINT 4



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* TURKEY POINT 4 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
02	02/12/84	F	8.4	A	1	84-01	EB	RELAYX	ELECTRICAL RELAY MALFUNCTION CAUSED LOSS OF POWER SUPPLY TO MAIN FEED PUMP WHICH RESULTED IN A REACTOR TRIP. UNIT WAS RETURNED TO SERVICE.
03	02/12/84	F	19.4	A	3	84-02	EB	RELAYX	HIGH STEAM FLOW SIGNAL AND AN ACTUAL STEAM GENERATOR LOW LEVEL RESULTED IN A REACTOR TRIP. THE MALFUNCTIONING TRANSMITTER WAS REPLACED. UNIT WAS RETURNED TO SERVICE.
04	02/16/84	F	182.7	A	3	84-03	EB	RELAYX	WHILE PREPARING TO MAKE REPAIRS TO A BREAKER, A RELAY WAS JARRED WHICH CAUSED THE LOSS OF THE POWER SUPPLIES TO FEED AND CONDENSATE PUMPS. THIS RESULTED IN A REACTOR TRIP. THE UNIT REMAINED OUT OF SERVICE FOR A COMPLETE INVESTIGATION.
05	02/27/84	F	51.2	A	1		EB	RELAYX	THE UNIT WAS REMOVED FROM SERVICE TO INSPECT, ADJUST AND REPAIR AUXILIARY POWER AIR CIRCUIT BREAKERS.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 TURKEY POINT 4 OPERATED WITH 4 OUTAGES AND NO REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* TURKEY POINT 4 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....FLORIDA  
  
COUNTY.....DADE  
  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...25 MI S OF  
MIAMI, FLA  
  
TYPE OF REACTOR.....PWR  
  
DATE INITIAL CRITICALITY...JUNE 11, 1973  
  
DATE ELEC ENER 1ST GENER...JUNE 21, 1973  
  
DATE COMMERCIAL OPERATE....SEPTEMBER 7, 1973  
  
CONDENSER COOLING METHOD...CLOSED CANAL  
  
CONDENSER COOLING WATER....CLOSED CYCLE CANAL  
  
ELECTRIC RELIABILITY  
COUNCIL.....SOUTHEASTERN ELECTRIC  
RELIABILITY COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....FLORIDA POWER & LIGHT  
  
CORPORATE ADDRESS.....9250 WEST FLAGLER STREET P.O. BOX 013100  
MIAMI, FLORIDA 33174  
  
CONTRACTOR  
ARCHITECT/ENGINEER.....BECHTEL  
  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
  
CONSTRUCTOR.....BECHTEL  
  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....II  
  
IE RESIDENT INSPECTOR.....R. VOGT LOWELL  
  
LICENSING PROJ MANAGER....D. MCDONALD  
DOCKET NUMBER.....50-251  
  
LICENSE & DATE ISSUANCE...DPR-41, APRIL 10, 1973  
  
PUBLIC DOCUMENT ROOM.....ENVIRONMENTAL AND URBAN AFFAIRS LIBRARY  
FLORIDA INTERNATIONAL UNIVERSITY  
MIAMI, FLORIDA 33199

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

+ INSPECTION OCTOBER 18-21 (83-37): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 33 INSPECTOR HOURS ON SITE IN THE AREAS OF RADIOLOGICAL CONTROLS ASSOCIATED WITH THE UNIT 3 REFUELING OUTAGE INCLUDING EXTERNAL EXPOSURE CONTROL, INTERNAL EXPOSURE CONTROL, POSTING, LABELING AND CONTROL, SURVEYS, QUALIFICATIONS OF CONTRACT HP TECHNICIANS, ENTRY INTO THE CONTAINMENT SUMP, SPENT FUEL PIT DEMINERALIZER RESIN TRANSFER, FOLLOWUP ON UNPLANNED GASEOUS RADIOACTIVITY RELEASES AND FOLLOWUP ON PREVIOUS INSPECTOR IDENTIFIED ITEMS. OF THE 9 AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN 7 AREAS; ONE APPARENT VIOLATION WAS FOUND IN EACH OF 2 AREAS (FAILURE TO FOLLOW TECHNICAL SPECIFICATIONS AND FAILURE TO HAVE AN APPROVED PROCEDURE).

INSPECTION DECEMBER 3, 1983 - JANUARY 6, 1984 (83-40): THIS ROUTINE, UNANNOUNCED INSPECTION INVOLVED 65 INSPECTOR-HOURS ON SITE IN THE AREAS OF PLANT OPERATIONS, SURVEILLANCE TESTING, MAINTENANCE, DOCUMENTATION, LICENSEE PROGRAM IMPROVEMENTS AND FIRE PROTECTION. OF THE SIX AREAS INSPECTED, NO VIOLATIONS OR DEVIATIONS WERE IDENTIFIED IN FOUR AREAS; AND TWO VIOLATIONS WERE IDENTIFIED IN TWO AREAS, FAILURE TO COMPENSATE INTERMEDIATE RANGE NUCLEAR INSTRUMENTATION ADEQUATELY (PARAGRAPH 7), AND FAILURE TO MAINTAIN ADEQUATE PLANT CHANGE DOCUMENTATION (PARAGRAPH 9). FIVE EXAMPLES OF VIOLATIONS WHICH HAD BEEN PREVIOUSLY IDENTIFIED IN REPORT 250, 251/83-38 WERE IDENTIFIED IN ONE AREA.

INSPECTION JANUARY 16-18 (84-01): THIS SPECIAL, UNANNOUNCED INSPECTION INVOLVED 9 INSPECTOR HOURS ON SITE IN THE AREA OF EMERGENCY PREPAREDNESS. OF THE AREAS INSPECTED, TWO VIOLATIONS WERE IDENTIFIED IN 2 AREAS (INADEQUATE PROCEDURES FOR PROTECTIVE ACTION DECISIONMAKING, FAILURE TO PROPERLY TRAIN EMERGENCY PERSONNEL IN PROTECTIVE ACTION RECOMMENDATION REQUIREMENTS AND IN EMERGENCY DOSE CALCULATIONS). THESE ARE DISCUSSED IN PARAGRAPHS 5, 5, AND 6, RESPECTIVELY.



Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           TURKEY POINT 4           \*  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

COMPLETED STEAM GENERATOR REPLACEMENT.

MANAGERIAL ITEMS:

NONE.

PLANT STATUS:

NORMAL OPERATION.

LAST IE SITE INSPECTION DATE: JANUARY 30 - FEBRUARY 3, 1984 +

INSPECTION REPORT NO: 50-251/84-03 +

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
-----			
NONE.			
=====			



THIS PAGE INTENTIONALLY LEFT BLANK

1. Docket: 50-271 OPERATING STATUS

2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0

3. Utility Contact: F. J. BURGER (802) 257-7711 X136

4. Licensed Thermal Power (Mwt): 1593

5. Nameplate Rating (Gross MWe): 626 X 0.9 = 563

6. Design Electrical Rating (Net MWe): 514

7. Maximum Dependable Capacity (Gross MWe): 535

8. Maximum Dependable Capacity (Net MWe): 504

9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>100,298.8</u>
13. Hours Reactor Critical	<u>696.0</u>	<u>1,332.6</u>	<u>81,031.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>696.0</u>	<u>1,306.7</u>	<u>78,799.2</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>1,103,861</u>	<u>2,028,043</u>	<u>114,188,715</u>
18. Gross Elec Ener (MWH)	<u>376,040</u>	<u>688,148</u>	<u>37,981,226</u>
19. Net Elec Ener (MWH)	<u>361,147</u>	<u>660,655</u>	<u>36,025,671</u>
20. Unit Service Factor	<u>100.0</u>	<u>90.7</u>	<u>78.6</u>
21. Unit Avail Factor	<u>100.0</u>	<u>90.7</u>	<u>78.6</u>
22. Unit Cap Factor (MDC Net)	<u>103.0</u>	<u>91.0</u>	<u>71.3</u>
23. Unit Cap Factor (DER Net)	<u>101.0</u>	<u>89.3</u>	<u>69.9</u>
24. Unit Forced Outage Rate	<u>.0</u>	<u>9.3</u>	<u>7.4</u>
25. Forced Outage Hours	<u>.0</u>	<u>133.3</u>	<u>5,024.5</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING MAINTENANCE OUTAGE - 06/16/84 - 8 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

VERMONT YANKEE 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

No.   Date   Type   Hours   Reason   Method   LER Number   System   Component   Cause & Corrective Action to Prevent Recurrence

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
VERMONT YANKEE OPERATED AT FULL POWER WITH NO OUTAGES  
OR REDUCTIONS IN FEBRUARY.

<u>Type</u>	<u>Reason</u>	<u>Method</u>	<u>System &amp; Component</u>
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* VERMONT YANKEE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

UTILITY & CONTRACTOR INFORMATION

LOCATION  
STATE.....VERMONT  
COUNTY.....WINDHAM  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...5 MI S OF  
BRATTLEBORO, VT  
TYPE OF REACTOR.....BWR  
DATE INITIAL CRITICALITY...MARCH 24, 1972  
DATE ELEC ENER 1ST GENER...SEPTEMBER 20, 1972  
DATE COMMERCIAL OPERATE...NOVEMBER 30, 1972  
CONDENSER COOLING METHOD...COOLING TOWER  
CONDENSER COOLING WATER...CONNECTICUT RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY  
LICENSEE.....VERMONT YANKEE NUCLEAR POWER  
CORPORATE ADDRESS.....1671 WORCESTER ROAD  
FRAMINGHAM, MASSACHUSETTS 01701  
CONTRACTOR  
ARCHITECT/ENGINEER.....EBASCO  
NUC STEAM SYS SUPPLIER...GENERAL ELECTRIC  
CONSTRUCTOR.....EBASCO  
TURBINE SUPPLIER.....GENERAL ELECTRIC

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....W. RAYMOND  
LICENSING PROJ MANAGER.....V. ROONEY  
DOCKET NUMBER.....50-271  
LICENSE & DATE ISSUANCE...DPR-28, FEBRUARY 28, 1973  
PUBLIC DOCUMENT ROOM.....BROOKS MEMORIAL LIBRARY  
224 MAIN STREET  
BRATTLEBORO, VERMONT 05301

I N S P E C T I O N S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.

Report Period FEB 1984

I N S P E C T I O N   S T A T U S   -   (CONTINUED)

\*\*\*\*\*  
\*           VERMONT YANKEE 1           \*  
\*\*\*\*\*

OTHER ITEMS

MANAGERIAL ITEMS:

NO INPUT PROVIDED.

PLANT STATUS:

NO INPUT PROVIDED.

LAST IE SITE INSPECTION DATE: NO INPUT PROVIDED.

INSPECTION REPORT NO: NO INPUT PROVIDED.

R E P O R T S   F R O M   L I C E N S E E

=====

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
--------	------------------	-------------------	---------

-----

NO INPUT PROVIDED.

=====

1. Docket: 50-029                      O P E R A T I N G   S T A T U S
2. Reporting Period: 02/01/84    Outage + On-line Hrs: 696.0
3. Utility Contact: S. WHIPPLE (617) 872-8100
4. Licensed Thermal Power (Mwt):                      600
5. Nameplate Rating (Gross MWe):                      185 X 1.0 = 185
6. Design Electrical Rating (Net MWe):                      175
7. Maximum Dependable Capacity (Gross MWe):                      180
8. Maximum Dependable Capacity (Net MWe):                      169
9. If Changes Occur Above Since Last Report, Give Reasons:  
ITEM 7 CHANGED TO REFLECT WINTER PERIOD
10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_
11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	<u>696.0</u>	<u>1,440.0</u>	<u>204,141.0</u>
13. Hours Reactor Critical	<u>679.5</u>	<u>1,248.8</u>	<u>162,773.1</u>
14. Rx Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
15. Hrs Generator On-Line	<u>674.7</u>	<u>1,244.0</u>	<u>158,156.3</u>
16. Unit Reserve Shtdwn Hrs	<u>.0</u>	<u>.0</u>	<u>.0</u>
17. Gross Therm Ener (MWH)	<u>393,961</u>	<u>731,669</u>	<u>85,615,263</u>
18. Gross Elec Ener (MWH)	<u>121,318</u>	<u>225,330</u>	<u>25,948,196</u>
19. Net Elec Ener (MWH)	<u>113,819</u>	<u>211,453</u>	<u>24,279,842</u>
20. Unit Service Factor	<u>96.9</u>	<u>86.4</u>	<u>77.5</u>
21. Unit Avail Factor	<u>96.9</u>	<u>86.4</u>	<u>77.5</u>
22. Unit Cap Factor (MDC Net)	<u>96.8</u>	<u>87.4</u>	<u>73.3*</u>
23. Unit Cap Factor (DER Net)	<u>93.4</u>	<u>83.9</u>	<u>69.8*</u>
24. Unit Forced Outage Rate	<u>3.1</u>	<u>13.6</u>	<u>5.3</u>
25. Forced Outage Hours	<u>21.3</u>	<u>196.0</u>	<u>7,682.4</u>


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
REFUELING - 04/01/84 - 8 WEEKS.

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\*                      YANKEE-ROWE 1                      \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

YANKEE-ROWE 1



FEBRUARY 1984

\* Item calculated with a Weighted Average

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* YANKEE-ROWE 1 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
84-1	01/24/84	F	21.3	A	4	84-1			PIN HOLE THRU-WALL LEAK REPAIR CONCLUDED.

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
YANKEE-ROWE 1 RETURNED ONLINE FEBRUARY 1ST FROM A REPAIR  
OUTAGE AND OPERATED ROUTINELY THE REMAINDER OF FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continu-4	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		

\*\*\*\*\*  
\* YANKEE-ROWE 1 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....MASSACHUSETTS  
COUNTY.....FRANKLIN  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR....25 MI NE OF  
PITTSFIELD, MASS  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...AUGUST 19, 1960  
DATE ELEC ENER 1ST GENER...NOVEMBER 10, 1960  
DATE COMMERCIAL OPERATE....JULY 1, 1961  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER....DEERFIELD RIVER  
ELECTRIC RELIABILITY  
COUNCIL.....NORTHEAST POWER  
COORDINATING COUNCIL

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....YANKEE ATOMIC ELECTRIC  
CORPORATE ADDRESS.....1671 WORCESTER RD.  
FRAMINGHAM, MASSACHUSETTS 01701

CONTRACTOR  
ARCHITECT/ENGINEER.....STONE & WEBSTER  
NUC STEAM SYS SUPPLIER..WESTINGHOUSE  
CONSTRUCTOR.....STONE & WEBSTER  
TURBINE SUPPLIER.....WESTINGHOUSE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....I  
IE RESIDENT INSPECTOR.....H. EICHENHOLZ  
LICENSING PROJ MANAGER.....P. ERICKSON  
DOCKET NUMBER.....50-029  
LICENSE & DATE ISSUANCE....DPR-3, DECEMBER 24, 1963  
PUBLIC DOCUMENT ROOM.....GREENFIELD COMMUNITY COLLEGE  
1 COLLEGE DRIVE  
GREENFIELD, MASSACHUSETTS 01301

I N S P E C T I O N   S T A T U S

INSPECTION SUMMARY

NO INSPECTION INPUT PROVIDED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENTS:

NO INPUT PROVIDED.

FACILITY ITEMS (PLANS AND PROCEDURES):

NO INPUT PROVIDED.





1. Docket: 58-285      OPERATING STATUS
2. Reporting Period: 02/01/84    Outage + On-line Hrs: 596.0
3. Utility Contact: SEBBI AUSTIN (312) 746-2084
4. Licensed Thermal Power (MWt): 5250
5. Nameplate Rating (Gross MWe): 1220 X 0.9 = 1098
6. Design Electrical Rating (Net MWe): 1040
7. Maximum Dependable Capacity (Gross MWe): 1085
8. Maximum Dependable Capacity (Net MWe): 1040
9. If Changes Occur Above Since Last Report, Give Reasons:  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_


NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	595.0	1,540.0	89,112.0
13. Hours Reactor Critical	520.7	520.7	62,596.8
14. Rx Reserve Shutdown Hrs	.0	.0	2,621.8
15. Hrs Generator On-Line	630.2	430.2	60,835.5
16. Unit Reserve Shutdown Hrs	.0	.0	.0
17. Gross Therm Ener (MWH)	1,088,987	1,088,987	171,010,470
18. Gross Elec Ener (MWH)	350,548	350,548	55,070,427
19. Net Elec Ener (MWH)	330,243	330,243	52,233,548
20. Unit Service Factor	61.8	29.9	68.3
21. Unit Avail Factor	61.8	29.9	68.3
22. Unit Cap Factor (MOC Net)	45.6	22.1	56.4
23. Unit Cap Factor (DER Net)	45.6	22.1	56.4
24. Unit Forced Outage Rate	38.2	55.5	13.8
25. Forced Outage Hours	265.8	537.3	9,149.3
26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):	<u>330243</u>		

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
 \* ZION 1 \*  
 \*\*\*\*\*  
 AVERAGE DAILY POWER LEVEL (MWe) PLOT

ZION 1



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
 \* ZION 1 \*  
 \*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
1	01/28/84	F	208.1	A	4				CONTINUED OUTAGE FOR REACTOR COOLANT LEAK AT THE SEAL TABLE.
2	02/22/84	F	19.5	A	3				MAIN TURBINE GOVERNOR VALVE WENT SHUT AND CAUSED STEAM GENERATOR LOW-LEVEL REACTOR TRIP WITH STEAM FLOW MISMATCH.
3	02/23/84	F	8.4	A	2				HANUAL TRIP DUE TO ROD URGENT ALARM, RGDS WOULD NOT MOVE WHILE ATTEMPTING TO GO CRITICAL.
4	02/23/84	F	7.5	A	3				MALFUNCTION OF FEED REGULATOR VALVE CAUSED REACTOR TRIP HIGH LEVEL ON B STEAM GENERATOR.
5	02/24/84	F	22.1	A	3				1C FEEDWATER PUMP FAILED TO MINIMUM SPEED CAUSING A REACTOR TRIP ON 1D STEAM GENERATOR WITH LOW LEVEL AND STEAM FLOW FEED FLOW MISMATCH.

\*\*\*\*\*  
 \* SUMMARY \*  
 \*\*\*\*\*  
 ZION 1 RETURNED ONLINE FEBRUARY 9TH FROM A REPAIR OUTAGE AND OPERATED ROUTINELY THE REMAINDER OF FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	F-Admin	3-Auto Scram	Preparation of
	G-Oper Error	4-Continued	Data Entry Sheet
	C-Refueling	5-Reduced Load	Licensee Event Report
	H-Other	9-Other	(LER) File (NUREG-0161)
	D-Regulatory Restriction		
	E-Operator Training		
	& License Examination		



\*\*\*\*\*  
M ZION 1  
\*\*\*\*\*

OTHER ITEMS

FACILITY ITEMS (PLANS AND PROCEDURES):

NONE

MANAGERIAL ITEMS:

NONE

PLANT STATUS:

THE PLANT RESUMED OPERATION ON 2/06/84, AND IS OPERATING NORMALLY.

LAST IE SITE INSPECTION DATE: JANUARY 18-31, 1984

INSPECTION REPORT NO: 84-01

REPORTS FROM LICENSEE

NUMBER	DATE OF EVENT	DATE OF REPORT	SUBJECT
84-01	01/06/84	02/02/84	REACTOR TRIP.
84-02	01/07/84	02/02/84	REACTOR TRIP.
84-03	01/16/84	02/14/84	REACTOR TRIP.
84-04	01/20/84	02/17/84	PLANT CONDITIONS NOT BOUNDED BY SAFETY ANALYSES.
84-05	01/20/84	02/17/84	INCORE INSTRUMENTATION, SEAL TABLE HI PRESSURE SEAL FAILURE.

1. Docket: 58-388 OPERATING STATUS
2. Reporting Period: 02/01/84 Outage + On-line Hrs: 696.0
3. Utility Contact: GERRI AUSTIN (312) 744-2884
4. Licensed Thermal Power (MWt): 3250
5. Nameplate Rating (Gross MWe): 3228 X 0.9 = 1018
6. Design Electrical Rating (Net MWe): 1040
7. Maximum Dependable Capacity (Gross MWe): 1085
8. Maximum Dependable Capacity (Net MWe): 1050
9. If Changes Occur Above Since Last Report, Give Reason\*  
NONE

10. Power Level To Which Restricted, If Any (Net MWe): \_\_\_\_\_

11. Reasons for Restrictions, If Any: \_\_\_\_\_  
NONE

	MONTH	YEAR	CUMULATIVE
12. Report Period Hrs	696.0	1,440.0	82,825.0
13. Hours Reactor Critical	696.0	1,405.2	60,633.2
14. Rx Reserve Shtdwn Hrs	.0	.0	226.1
15. Hrs Generator On-Line	696.0	1,391.0	58,918.3
16. Unit Reserve Shtdwn Hrs	.0	.0	.0
17. Gross Therm Ener (MWh)	2,265,666	4,624,079	169,340,162
18. Gross Elec Ener (MWh)	737,590	1,448,912	54,152,969
19. Net Elec Ener (MWh)	708,524	1,399,713	51,467,658
20. Unit Service Factor	100.0	96.7	71.1
21. Unit Avail Factor	100.0	96.7	71.1
22. Unit Cap Factor (MDC Net)	97.9	92.0	59.8
23. Unit Cap Factor (DER Net)	97.9	92.9	59.8
24. Unit Forced Outage Rate	.0	3.3	17.3
25. Forced Outage Hours	.0	48.2	12,424.9


26. Shutdowns Sched Over Next 6 Months (Type, Date, Duration):  
MAINTENANCE - 03/27/84

27. If Currently Shutdown Estimated Startup Date: N/A

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

AVERAGE DAILY POWER LEVEL (MWe) PLOT

### ZION 2



FEBRUARY 1984

Report Period FEB 1984

UNIT SHUTDOWNS / REDUCTIONS

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

No.	Date	Type	Hours	Reason	Method	LER Number	System	Component	Cause & Corrective Action to Prevent Recurrence
-----	------	------	-------	--------	--------	------------	--------	-----------	---

NONE

\*\*\*\*\*  
\* SUMMARY \*  
\*\*\*\*\*  
ZION 2 OPERATED AT NEAR FULL POWER WITH NO OUTAGES OR REDUCTIONS DURING FEBRUARY.

Type	Reason	Method	System & Component
F-Forced	A-Equip Failure	1-Manual	Exhibit F & H
S-Sched	B-Maint or Test	2-Manual Scram	Instructions for
	C-Refueling	3-Auto Scram	Preparation of
	D-Regulatory Restriction	4-Continued	Data Entry Sheet
	E-Operator Training	5-Reduced Load	Licensee Event Report
	& License Examination	9-Other	(LER) File (NUREG-0161)

\*\*\*\*\*  
\* ZION 2 \*  
\*\*\*\*\*

FACILITY DATA

Report Period FEB 1984

FACILITY DESCRIPTION

LOCATION  
STATE.....ILLINOIS  
COUNTY.....LAKE  
DIST AND DIRECTION FROM  
NEAREST POPULATION CTR...40 MI N OF  
CHICAGO, ILL  
TYPE OF REACTOR.....PWR  
DATE INITIAL CRITICALITY...DECEMBER 24, 1973  
DATE ELEC ENER 1ST GENER...DECEMBER 26, 1973  
DATE COMMERCIAL OPERATE...SEPTEMBER 17, 1974  
CONDENSER COOLING METHOD...ONCE THRU  
CONDENSER COOLING WATER...LAKE MICHIGAN  
ELECTRIC RELIABILITY  
COUNCIL.....MID-AMERICA  
INTERPOOL NETWORK

UTILITY & CONTRACTOR INFORMATION

UTILITY  
LICENSEE.....COMMONWEALTH EDISON  
CORPORATE ADDRESS.....P.O. BOX 767  
CHICAGO, ILLINOIS 60690  
CONTRACTOR  
ARCHITECT/ENGINEER.....SARGENT & LUNDY  
NUC STEAM SYS SUPPLIER...WESTINGHOUSE  
CONSTRUCTOR.....COMMONWEALTH EDISON  
TURBINE SUPPLIER.....NONE

REGULATORY INFORMATION

IE REGION RESPONSIBLE.....III  
IE RESIDENT INSPECTOR.....J. WATERS  
LICENSING PROJ MANAGER.....J. NORRIS  
DOCKET NUMBER.....50-304  
LICENSE & DATE ISSUANCE....DPR-48, NOVEMBER 14, 1973  
PUBLIC DOCUMENT ROOM.....ZION - BENTON PUBLIC LIBRARY  
2400 GABRIEL AVENUE  
ZION, ILLINOIS 60099

INSPECTION SUMMARY

I N S P E C T I O N S T A T U S

SPECIAL INSPECTION ON FEBRUARY 3 - 14, (84-01): INSPECTION FOLLOWUP ON COMMONWEALTH EDISON COMPANY REMARKS TO SPECIAL INSPECTION REPORT CONCERNING ALLEGATIONS OF IMPROPER OPERATION AT DRESDEN, QUAD CITIES, AND ZION NUCLEAR POWER PLANTS. THE INSPECTION INVOLVED 14 INSPECTION-HOURS BY THREE NRC INSPECTORS. MEASURES TO CORRECT IDENTIFIED WEAKNESSES WERE TAKEN AS DESCRIBED IN THE RESPONSE. NO ITEMS OF NONCOMPLIANCE OR DEVIATIONS WERE IDENTIFIED.

ENFORCEMENT SUMMARY

NONE

OTHER ITEMS

SYSTEMS AND COMPONENT PROBLEMS:

NONE





THIS PAGE INTENTIONALLY LEFT BLANK

**SECTION 3**

**APPENDIX**

\*\*\*\*\*

\* PRESSURIZED\* STATUS OF SPENT FUEL STORAGE CAPABILITY  
 \* WATER \*  
 \* REACTORS \* (a)

FACILITY *****	CORE SIZE (NO. OF ASSEMBLIES) *****	PRESENT AUTH. STORAGE POOL CAP. (FUEL ASSEMBLIES) *****	NO. OF ASSEMBLIES STORED *****	REMAINING CAPACITY (NO. OF ASSEMBLIES) *****	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES) *****		NEXT REFUEL SCHED. DATE *****	WILL FILL PRESENT AUTH. CAPACITY *****
						(b)		
ARKANSAS 1	177	968	316	652				1998
ARKANSAS 2	177	988	168	820			N/S	2003
BEAVER VALLEY 1	157	833	52	781			N/S	1995
CALVERT CLIFFS 1	217	1830(c)	796(c)	1034(c)(m)	1170		03-85	1991
CALVERT CLIFFS 2	217						04-84	1991
COOK 1	193	2050(c)	494(c)	1556(c)			N/S	1994
COOK 2	193						03-84	
CRYSTAL RIVER 3	177	1163	171	992			N/S	1997
DAVIS-BESSE 1	177	735	140	595			N/S	1993
DIABLO CANYON 1								
FARLEY 1	157	675	62	613	1345		02-84	1991
FARLEY 2	157	675	62	613	1345		N/S	1994
FORT CALHOUN 1	133	483	265	218	463		03-84	1985
GINNA	121	595	300	295			03-84	1992
HADDAM NECK	157	1168	493	675			06-84	1994
INDIAN POINT 1	0	288	160	128			N/S	
INDIAN POINT 2	193	482	268	214	980		05-84	1984
INDIAN POINT 3	193	837	140	697			N/S	1993
KEWAUNEE	121	990	228	762(m)			03-84	1991
MAINE YANKEE	217	953	577	376	1678		N/S	1987
MCGUIRE 1	193	500	31	469(n)			02-84	1990
MCGUIRE 2								
MILLSTONE 2	217	667	376	291			N/S	1987
NORTH ANNA 1	157	966(c)	116(c)	850			05-84	1991
NORTH ANNA 2	157						03-84	1990
OCONEE 1	177	1312(c)	1123	189(c)(n)			N/S	1991
OCONEE 2	177						N/S	
OCONEE 3	177	825	0	825			03-84	
PALISADES	204	784	480	304			N/S	1988
POINT BEACH 1	121	1058(c)	484(c)	1078(c)			N/S	1995
POINT BEACH 2	121						N/S	
PRAIRIE ISLAND 1	121	1017(c)	561(c)	456(c)(n)	720		N/S	1988
PRAIRIE ISLAND 2	171						N/S	
RANCHO SECO 1	1, 1	579	280	299			08-84	
ROBINSON 2	157	276	152	124(e)	431		10-84	1987
SALEM 1	193	1170	212	958			N/S	1985(g)
SALEM 2	193	1170	72	1098			05-84	1996
SAN ONOFRE 1	157	216	94	122			N/S	2000
SAN ONOFRE 2	217	800	0	800			N/S	1985
SAN ONOFRE 3	217	800	0	800			N/S	
SEQUOYAH 1	193	800	0	800			N/S	
SEQUOYAH 2(d)	193	800	65	735			02-84	1993
ST LUCIE 1	217	728	332	376			N/S	1994
ST LUCIE 2							N/S	1990
SUMMER 1	157	682	0	682	1276		N/S	
SURRY 1	157	1044(c)	556(c)	484(c)			N/S	1987
SURRY 2	157						N/S	
THREE MILE ISLAND 1	177	752	288	544			N/S	1986
THREE MILE ISLAND 2	177	442	0	442			N/S	1986

Report Period FEB 1984

```

*****
W PRESSORIZED*
W WATER W
W REACTORS W
*****
(a)
CORE SIZE PRESENT AUTH. NO. OF
(NR. OF STORAGE POOL CAP. ASSEMBLIES REMAINING CAPACITY
ASSEMBLIES) (FUEL ASSEMBLIES) STORED (NR. OF ASSEMBLIES)
*****
FACILITY ASSEMBLIES) *****
TROJAN 193 651 248 403
TURKEY POINT 3 157 621 445 175(m)
TURKEY POINT 4 157 621 378 243
YANKEE-ROGUE 1 76 391 225 166
ZION 1 193 2152(c) 795(c) 1317(c)
ZION 2 193
*****
REMAINING CAPACITY
IF PENDING REQUEST
APPROVED
*****
(b)
NEXT REFUEL WILL FILL PRESENT
SCHEM. DATE AUTH. CAPACITY
*****
04-84 1990
N/S 1987
03-84 1988
04-84 1988
N/S 1992
04-84 1992
*****
496

```

S T A T U S O F S P E N T F U E L S T O R A G E C A P A B I L I T Y									
FACILITY	CORE SIZE (NO. OF ASSEMBLIES)	PRESENT AUTH. (NO. OF STORAGE POOL CAP. FUEL ASSEMBLIES)	NO. OF ASSEMBLIES STORED	REMAINING CAPACITY IF PENDING REQUEST APPROVED (NO. OF ASSEMBLIES)	NEXT REFUEL WILL FILL PRESENT AUTH. CAPACITY SCHED. DATE	(b)	REMAINING CAPACITY		
							IF PENDING REQUEST APPROVED	IF PENDING REQUEST APPROVED	IF PENDING REQUEST APPROVED
BIG ROCK POINT 1	84	193	152	41	08-84	1986			
BROWNS FERRY 1	764	3471	1948	2423	07-84	1985			
BROWNS FERRY 2	764	3471	889	861(m)	08-84	1985			
BROWNS FERRY 3	764	3471	1529	3987(m)	N/S	1985			
BRUNSWICK 1	568	(F)		2116	N/S	1986			
BRUNSWICK 2	568	1607WR+656BUR		2208	N/S	1986			
COOPER STATION	548	848	848	1518	N/S	1996			
DRESDEN 1	484	872	221	451	N/S	1990			
DRESDEN 2	724	2659(c)	2014 (c)	946(c)	N/S	1985			
DRESDEN 3	724				N/S	1985			
DURANE ARNOLD	568	2150	576	1474	N/S	1998			
FITZPATRICK	568	2264	816	1428	N/S	1991			
HATCH 1	568	3021	0	3021	N/S	1999			
HATCH 2	568	2750	1284	1466	N/S	1999			
HUMBOLDT BAY	172	487	251	236	N/S	1999			
LA CROSSE	72	440	287	233	N/S	1990			
LASALLE 1	580	2184	1136	1048	04-84	1991			
MILLSTONE 1	484	2237	1816	1221	02-84	1991			
MONTICELLO	532	1984	1044	940	03-84	1990			
NINE MILE POINT 1	568	1800	1375	425	N/S	1987	1965		
PEACH BOTTOM 2	764	2819	1170	1646	N/S	1990	1225		
PEACH BOTTOM 3	764	2816	1212	1604	02-84	1991			
PILGRIM 1	580	2528	1788	821(m)	N/S	1991			
ROAD CITIES 1	724	3657	1738	1927	N/S	1990			
ROAD CITIES 2	724	3897	412	3485	N/S	2003			
INDEPENDENT SPENT FUEL STORAGE INSTALLATIONS(m)									
MORRIS OPERATIONS		758 MTU(j)	315	385 MTU(j)					
NFS(i)		250 MTU	170 MTU	80 MTU					
1490 MTU(j)									

(a) At each refueling outage approximately 1/3 of a PWR core and 1/4 of a BWR core is off-loaded.

(b) Some of these dates have been adjusted by staff assumptions.

(c) This is the total for both units.

(d) Plant not in commercial operation.

(e) Some spent fuel stored at Brunswick.

(f) Authorized a total 27.2 BWR and 1232 PWR assemblies for both pools.

(g) Robinson 2 assemblies being shipped to Brunswick for storage.

(h) Capacity is in metric tons of uranium: 1 MTU = 2 PWR assemblies or 5 BWR assemblies.

(i) No longer accepting spent fuel.

(j) Racked for 700 MTU.

(k) Reserved.

(l) This is the station total.

(m) Installed capacity is less than that authorized.

(n) McGuire 1 authorized to accept Oconee fuel assemblies.

Report Period FEB 1984

N/S = Not Scheduled



INCLUDES BOTH LICENSED AND NON-LICENSED UNITS)

REACTOR YEARS OF EXPERIENCE

	YEARS GENERATE	1ST ELEC	YEARS GENERATE	1ST ELEC	YEARS GENERATE	15V ELEC
	UNIT	UNIT	UNIT	UNIT	UNIT	UNIT
*****	9.58	08/11/74	5.08	12/26/78	7.71	06/14/76
* LICENSED	21.23	12/08/62	10.38	10/15/73	9.51	08/28/74
* OPERATING	7.47	08/12/76	7.24	12/04/76	8.84	04/29/75
* ELECTRICAL	9.96	01/03/75	9.81	05/10/74	9.05	02/10/75
* PRODUCING	5.94	03/22/78	13.88	04/13/78	7.88	01/30/77
* UNITS	6.51	08/28/77	6.54	08/18/77	12.61	07/22/71
*****	9.78	05/19/74	10.52	08/25/73	2.72	05/25/81
* LICENSED	9.88	02/01/75	16.57	08/07/67	7.22	12/11/76
* OPERATING	14.25	12/02/69	10.68	04/26/73	9.30	11/11/74
* ELECTRICAL	9.90	04/08/74	15.85	04/28/68	7.86	04/27/76
* PRODUCING	11.31	11/08/72	2.67	06/30/81	1.49	09/04/82
* UNITS	13.25	11/29/78	8.31	11/09/75	.77	05/23/83
*****	14.31	11/03/68	5.87	04/17/78	12.99	03/05/71
* LICENSED	10.82	05/06/73	10.24	12/05/73	3.52	08/25/80
* OPERATING	16.44	09/23/69	12.17	12/31/71	9.50	09/01/74
* ELECTRICAL	9.50	09/01/74	11.62	07/19/72	10.03	02/18/74
* PRODUCING	11.58	08/02/72	10.24	12/04/73	13.32	11/06/70
* UNITS	11.89	04/12/72	11.77	05/23/72	9.19	12/21/74
*****	13.43	08/28/78	7.18	12/25/76	9.38	10/13/74
* LICENSED	16.63	07/16/67	1.45	09/26/82	2.74	06/03/81
* OPERATING	3.61	07/22/83	2.19	12/23/81	.43	09/25/83
* ELECTRICAL	.72	06/13/83	1.29	11/16/82	7.82	05/01/76
* PRODUCING	10.98	03/18/73	1.29	11/16/82	11.66	07/04/72
* UNITS	8.19	12/23/75	11.33	11/02/72	9.70	06/19/74
*****	11.44	08/28/72	23.58	11/10/60	10.69	06/21/73
* LICENSED	10.18	12/26/73			10.67	06/28/73
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING						
* UNITS						
*****						
* LICENSED						
* OPERATING						
* ELECTRICAL						
* PRODUCING				</		



\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
ALABAMA	TUSKEGEE	TUSKEGEE INSTITUTE	AGN-201 #102	50-406	R-122	08-30-74	0.0001
ARIZONA	TUCSON	UNIVERSITY OF ARIZONA	TRIGA MARK I	50-113	R-52	12-05-58	100.0
CALIFORNIA	BERKELEY	UNIVERSITY OF CALIFORNIA, BERKELEY COLLEGE	TRIGA MK. III	50-224	R-101	08-10-66	1000.0
	CANOGA PARK	ROCKWELL INTERNATIONAL CORP.	L-85	50-375	R-188	01-05-72	0.003
	HAWTHORNE	NORTHROP CORP. LABORATORIES	TRIGA MARK F	50-187	R-90	03-04-63	1000.0
	IRVINE	UNIVERSITY OF CALIFORNIA, IRVINE	TRIGA MARK I	50-326	R-116	11-24-69	250.0
	LOS ANGELES	UNIVERSITY OF CALIFORNIA, L.A.	ARGONAUT	50-142	R-71	10-03-60	100.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK F	50-163	R-67	07-01-60	1500.0
	SAN DIEGO	GENERAL ATOMIC COMPANY	TRIGA MARK I	50-089	R-38	05-03-58	250.0
	SAN JOSE	GENERAL ELECTRIC COMPANY	NTR	50-073	R-33	10-31-57	100.0
	SAN LUIS OBISPO	CALIFORNIA STATE POLYTECHNIC COLLEGE	AGN-201 #100	50-394	R-121	05-16-73	0.0001
	SAN RAMON	AEROTEST OPERATIONS, INC.	TRIGA (INDUS)	50-228	R-98	07-02-65	250.0
SANTA BARBARA	UNIVERSITY OF CALIFORNIA, SANTA BARBARA	L-77	50-433	R-124	12-03-74	0.01	
COLORADO	DENVER	U.S. GEOLOGICAL SURVEY DEPARTMENT	TRIGA MARK I	50-274	R-113	02-24-69	1000.0
DELAWARE	NEWARK	UNIVERSITY OF DELAWARE	AGN-201 #113	50-098	R-43	07-03-58	0.0001
DIST OF COLUMBIA	WASHINGTON	THE CATHOLIC UNIVERSITY OF AMERICA	AGN-201 #101	50-077	R-31	11-15-67	0.0001
FLORIDA	GAINESVILLE	UNIVERSITY OF FLORIDA	ARGONAUT	50-083	R-56	05-21-59	100.0
GEORGIA	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	AGN-201 #104	50-276	R-111	04-19-68	0.0001
	ATLANTA	GEORGIA INSTITUTE OF TECHNOLOGY	HEAVY WATER	50-160	R-97	12-29-64	5000.0
IDAHO	POCATELLO	IDAHO STATE UNIVERSITY	AGN-201 #103	50-284	R-110	10-11-67	0.0001
ILLINOIS	URBANA	UNIVERSITY OF ILLINOIS	LOPRA	50-356	R-117	12-27-71	10.0
	URBANA	UNIVERSITY OF ILLINOIS	TRIGA	50-151	R-115	07-22-69	1500.0
	ZION	WESTINGHOUSE ELECTRIC CORP.	NTR	50-087	R-119	01-28-72	10.0
INDIANA	LAFAYETTE	PURDUE UNIVERSITY	LOCKHEED	50-182	R-87	08-16-62	10.0
IOWA	AMES	IOWA STATE UNIVERSITY	UTR-10	50-116	R-59	10-16-59	10.0
KANSAS	LAWRENCE	UNIVERSITY OF KANSAS	LOCKHEED	50-148	R-78	06-23-61	250.0
	MANHATTAN	KANSAS STATE UNIVERSITY	TRIGA	50-188	R-88	10-16-62	250.0
MARYLAND	BETHESDA	ARMED FORCES RADIOBIOLOGY RESEARCH INSTITUTE	TRIGA	50-170	R-84	06-26-62	1000.0
	COLLEGE PARK	UNIVERSITY OF MARYLAND	TRIGA	50-166	R-70	10-14-60	250.0

\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON-POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OL ISSUED	AUTHORIZED POWER LEVEL (KW)
MASSACHUSETTS	CAMBRIDGE	MASSACHUSETTS INSTITUTE OF TECHNOLOGY	HWR REFLECTED	50-020	R-37	06-09-58	5000.0
	LOWELL	UNIVERSITY OF LOWELL	GE	50-223	R-125	12-24-74	1000.0
	WORCESTER	WORCESTER POLYTECHNIC INSTITUTE	GE	50-134	R-61	12-16-59	10.0
MICHIGAN	ANN ARBOR	UNIVERSITY OF MICHIGAN	POOL	50-002	R-28	09-13-57	2000.0
	EAST LANSING	MICHIGAN STATE UNIVERSITY	TRIGA MARK I	50-294	R-114	03-21-69	250.0
	MIDLAND	DOW CHEMICAL COMPANY	TRIGA	50-264	R-108	07-03-67	100.0
MISSOURI	COLUMBIA	UNIVERSITY OF MISSOURI, COLUMBIA	TANK	50-186	R-103	10-11-66	10000.0
	ROLLA	UNIVERSITY OF MISSOURI	POOL	50-123	R-79	11-21-61	200.0
NEBRASKA	OMAHA	THE VETERANS ADMINISTRATION HOSPITAL	TRIGA	50-131	R-57	06-26-59	18.0
NEW MEXICO	ALBUQUERQUE	UNIVERSITY OF NEW MEXICO	AGN-201M #112	50-252	R-102	09-17-66	0.005
NEW YORK	BRONX	MANHATTAN COLLEGE - PHYSICS DEPT.	TANK	50-199	R-94	03-24-64	0.0001
	BUFFALO	STATE UNIVERSITY OF NEW YORK	PULSTAR	50-057	R-77	03-24-61	2000.0
	ITHACA	CORNELL UNIVERSITY	TRIGA MARK II	50-157	R-80	01-11-62	500.0
	ITHACA	CORNELL UNIVERSITY	ZPR	50-097	R-89	12-11-62	0.1
	NEW YORK	COLUMBIA UNIVERSITY IN THE CITY OF NEW YORK	TRIGA MARK II	50-208	R-128	04-14-77	250.0
	TUXEDO	UNION CARBIDE CORP	POOL	50-054	R-81	09-07-61	5000.0
NORTH CAROLINA	RALEIGH	NORTH CAROLINA STATE UNIVERSITY AT RALEIGH	PULSTAR	50-297	R-120	08-25-72	1000.0
OHIO	COLUMBUS	OHIO STATE UNIVERSITY	POOL	50-150	R-75	02-24-61	10.0
OKLAHOMA	NORMAN	THE UNIVERSITY OF OKLAHOMA	AGN-211 #102	50-112	R-53	12-29-58	0.100
OREGON	CORVALLIS	OREGON STATE UNIVERSITY	TRIGA MARK II	50-243	R-106	03-07-67	1000.0
	PORTLAND	REED COLLEGE	TRIGA MARK I	50-288	R-112	07-02-68	250.0
PENNSYLVANIA	UNIVERSITY PARK	PENNSYLVANIA STATE UNIVERSITY	TRIGA MK. III	50-005	R-2	07-08-55	1000.0
RHODE ISLAND	NARRAGANSETT	RHODE ISLAND NUCLEAR SCIENCE CENTER	GE POOL	50-193	R-95	07-21-64	2000.0
TENNESSEE	MEMPHIS	MEMPHIS STATE UNIVERSITY	AGN-201 #108	50-538	R-127	12-10-76	0.0001
TEXAS	AUSTIN	UNIVERSITY OF TEXAS	TRIGA MARK I	50-192	R-92	08-02-63	250.0
	COLLEGE STATION	TEXAS A&M UNIVERSITY	AGN-201M #106	50-059	R-23	08-26-57	0.005
	COLLEGE STATION	TEXAS A&M UNIVERSITY	TRIGA	50-128	R-83	12-07-61	1000.0
UTAH	PROVO	BRIGHAM YOUNG UNIVERSITY	L-77	50-262	R-109	09-07-67	0.01

\*\*\*\*\*  
 \* RESEARCH \*  
 \* REACTORS \*  
 \*\*\*\*\*

NON - POWER REACTORS IN THE U. S.

STATE	CITY	LICENSEE	REACTOR TYPE	DOCKET	LICENSE NUMBER	DATE OF ISSUED	AUTHORIZED POWER LEVEL (KW)
UTAH	SALT LAKE CITY	THE UNIVERSITY OF UTAH	TRIGA MARK I	50-407	R-126	09-30-75	100.0
	SALT LAKE CITY	UNIVERSITY OF UTAH	AGN-201M #107	50-072	R-25	09-12-57	0.005
VIRGINIA	BLACKSBURG	VIRGINIA POLYTECHNIC INSTITUTE	UTR-10	50-124	R-62	12-18-59	100.0
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	CAVALIER	50-396	R-123	09-24-74	0.1
	CHARLOTTESVILLE	UNIVERSITY OF VIRGINIA	POOL	50-062	R-66	06-27-60	2000.0
	LYNCHBURG	BABCOCK & WILCOX COMPANY	LPR	50-099	R-47	09-05-58	1000.0
WASHINGTON	PULLMAN	WASHINGTON STATE UNIVERSITY	TRIGA	50-027	R-76	03-06-61	1000.0
	SEATTLE	UNIVERSITY OF WASHINGTON	ARGONAUT	50-139	R-73	03-31-61	100.0
WISCONSIN	MADISON	UNIVERSITY OF WISCONSIN	TRIGA	50-156	R-74	11-23-60	1000.0

\*\*\*\*\*  
 \* EXPERIMENTAL AND TEST REACTORS \*  
 \*\*\*\*\*

CALIFORNIA	SAN JOSE	GENERAL ELECTRIC COMPANY	GETR	50-070	TR-1	01-07-59	50,000.0
DIST OF COLUMBIA	WASHINGTON	NATIONAL BUREAU OF STANDARDS	TEST	50-184	TR-5	06-30-70	10,000.0

\*\*\*\*\*  
 \* CRITICAL EXPERIMENT FACILITIES \*  
 \*\*\*\*\*

NEW YORK	TROY	RENSSELAER POLYTECHNIC INSTITUTE		50-225	CX-22	07-03-64	0.0
VIRGINIA	LYNCHBURG	BABCOCK & WILCOX COMPANY		50-013	CX-10	10-22-58	0.0
WASHINGTON	RICHLAND	BATTELLE MEMORIAL INSTITUTE		50-360	CX-26	11-29-71	0.0

**BIBLIOGRAPHIC DATA SHEET**

NUREG-0020 Volume 8 Number 3

2 Leave blank

3 TITLE AND SUBTITLE

Licensed Operating Reactors  
Status Summary Report

4 RECIPIENT'S ACCESSION NUMBER

5 DATE REPORT COMPLETED

MONTH	YEAR
APRIL	1984

6 AUTHOR(S)

7 DATE REPORT ISSUED

MONTH	YEAR
APRIL	1984

8 PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis  
Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

9 PROJECT/TASK/WORK UNIT NUMBER

10 FIN NUMBER

11 SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code)

Division of Budget and Analysis  
Office of Resource Management  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

12a TYPE OF REPORT

12b PERIOD COVERED (Inclusive dates)

FEBRUARY 1984

13 SUPPLEMENTARY NOTES

Status Summary Report

14 ABSTRACT (200 words or less)

The OPERATING UNITS STATUS REPORT - LICENSED OPERATING REACTORS provides data on the operation of nuclear units as timely and accurately as possible. This information is collected by the Office of Resource Management from the Headquarters staff of NRC's Office of Inspection and Enforcement, from NRC's Regional Offices, and from utilities. The three sections of the report are: monthly highlights and statistics for commercial operating units, and errata from previously reported data; a compilation of detailed information on each unit, provided by NRC's Regional Offices, IE Headquarters and the utilities; and an appendix for miscellaneous information such as spent fuel storage capability, reactor-years of experience and non-power reactors in the U.S. It is hoped the report is helpful to all agencies and individuals interested in maintaining an awareness of the U.S. energy situation as a whole.

15a KEY WORDS AND DOCUMENT ANALYSIS

15b DESCRIPTORS

16 AVAILABILITY STATEMENT

Unlimited

17 SECURITY CLASSIFICATION

(This report)  
Unclassified

18 NUMBER OF PAGES

19 SECURITY CLASSIFICATION

(7/m page)  
Unclassified

20 PRICE

\$

DISTRIBUTION LIST - NRC

INTERNAL DISTRIBUTION

Office of the Commissioners	5
Atomic Safety and Licensing Appeal Panel	3
Advisory Committee on Reactor Safeguards	6
Office of Inspector and Auditor	1
Office of Policy Evaluation	1
Office of the General Counsel	1
Office of Public Affairs	21
Office of Congressional Affairs	3
Office of the Executive Director for Operations	7
Office of Administration	2
Office of the Executive Legal Director	2
Office of Analysis and Evaluation of Operational Data	2
Office of International Programs	3
Office of State Programs	1
Office of Resource Management	19
Office of Nuclear Material Safety and Safeguards	2
- Division of Fuel Cycle and Material Safety	3
- Division of Safeguards	2
Office of Nuclear Reactor Regulation	138
- Division of Engineering	
- Division of Safety Technology	
- Division of Licensing	
- Division of Systems Integration	
- Division of Human Factors Safety	
Office of Nuclear Regulatory Research	4
Office of Inspection and Enforcement	7
- Region I	11
- Region II	10
- Region III	10
- Region IV	10
- Region V	7
	<u>281</u>

EXTERNAL DISTRIBUTION

SPECIAL REQUESTS

Air Force	1
Congress	10
Department of Energy	32
Government Accounting Office	1
Environmental Protection Agency	1
Electric Power Research Institute	1
Argonne National Laboratory	3
Bureau of Mines	1
Department of Agriculture	1
Department of the Commerce	1
Department of the Interior	1
	<u>53</u>

OTHER

GPO Depository	440
GPO Stores	75
National Technical Information Service	25
Subscriptions (NTIS)	250
Colleges and Libraries (including Public Document Rooms)	128
Utilities and Other Requests	227
	<u>1145</u>

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

FIRST CLASS MAIL  
POSTAGE & FEES PAID  
USNRC  
WASH D C  
PERMIT No. 667

OFFICIAL BUSINESS  
PENALTY FOR PRIVATE USE, \$300

120555078877 1 IANINU  
US NRC  
ADM-DIV OF TIDC  
POLICY & PUB MGT BR-PDR NUREG  
W-501  
WASHINGTON DC 20555