

April 30, 1984

Docket No. 50-352

Philadelphia Electric Company  
ATTN: Mr. S. L. Daltroff  
Vice President  
Electric Production  
2301 Market Street  
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Report of Enforcement Conference Held April 12, 1984 for Limerick  
Generating Station ; Meeting Report No. 50-352/84-33

This refers to the subject Enforcement Conference held in the NRC Region I office on April 12, 1984, and attended by you and members of your staff and Dr. T. Murley, Regional Administrator and other members of the Region I staff. At this conference, we discussed concerns regarding the role and responsibilities of System Startup Engineers (SSEs) during system turn over. These concerns are identified in NRC Inspection Report 50-352/ 84-12, which was forwarded to you by our letter dated April 10, 1984.

As a result of this event, an apparent violation of NRC requirements is cited in the enclosed Appendix A and is categorized under the NRC Enforcement Policy (10 CFR 2, Appendix C). A reply is required and should be prepared in accordance with Appendix A. It is exempt from the Office of Management and Budget's clearance procedures under the Paperwork Reduction Act of 1980, PL 96-511.

As discussed in the Enforcement Conference, we are concerned about: (1) the impact of inadequate SSE walkdowns on safety related system; (2) management's ability to determine whether the SSEs are doing acceptable jobs during system turn over; (3) the apparent difference in perception between management and the SSEs, regarding the SSE's responsibilities; and, (4) the training program for SSEs. You are requested to address these concerns along with your written response to Appendix A.

In accordance with 10 CFR 2.790(a), a copy of this letter and the enclosures will be placed in the NRC Public Document Room unless you notify this office by telephone, within ten (10) days of the date of this letter and submit written application to withhold information contained therein within thirty (30) days of the date of this letter. Such application must be consistent with the requirements of 2.790(b)(1). The telephone notification of your intent to

8405220390 830430  
PDR ADOCK 05000352  
Q PDR

IE01  
11

request withholding, or any request for an extension of the ten (10) day period which you believe necessary, should be made to the Supervisor, Files, Mail and Records, US NRC Region I, at (215) 337-5223.

Your cooperation is appreciated.

Sincerely,

**ORIGINAL SIGNED BY**

Thomas T. Martin, Director  
Division of Engineering and  
Technical Programs

Enclosures:

1. Appendix A, Notice of Violation
2. NRC Region I Meeting Report 50-352/84-33

cc w/encl:

V. S. Boyer, Senior Vice President, Nuclear Power  
J. S. Kemper, Vice President, Engineering and Resource  
Troy B. Conner, Jr., Esquire  
Eugene J. Bradley, Esquire  
Limerick Hearing Service List  
Public Document Room (PDR)  
Local Public Document Room (LPDR)  
Nuclear Safety Information Center (NSIC)  
NRC Resident Inspector  
Commonwealth of Pennsylvania

bcc:

Region I Docket Room (with concurrences)  
Senior Operations Officer (w/o encls)  
J. Gutierrez, RI  
Section Chief, DPRP  
Jane Grant, DPRP  
L. Briggs

*R*  
DETP  
Eapen  
4/17/84  
*DETP*  
Boyer  
4/18/84

OFFICIAL RECORD COPY

*DETP*  
Conner  
4/19/84  
*DETP*  
Holody  
4/19/84

*SE*  
DETP  
Ebnetter