



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

May 4, 1984

NUCLEAR PRODUCTION DEPARTMENT

U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 2900
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File: 0260/L-835.0
Special Report 83-104/1 - Update
Report - Fire Rated Penetration
CE-515D Found Open
AECM-84/0220

This is an update to a previous report submitted on November 30, 1983. The condition for which the report was submitted occurred on October 24, 1983, when fire rated penetration CE-515D, located in the west wall of Room OC403 on elevation 148 feet in the Control Building, was discovered open. Penetration CE-515D was previously identified on MNCR 103-83 as a nonconformance. However, due to incomplete identification on the penetration the wrong penetration (CE-515D A) was sealed. To preclude similar occurrences we are in the process of permanently labeling all penetrations to differentiate between mechanical and architecture drawings by adding the suffix letter "A" to all penetrations shown on architecture drawings.

Fire watches were established in accordance with Technical Specification 3.7.7 until the penetration was resealed on December 1, 1983. The condition was reported pursuant to Technical Specification 6.9.2 as the seven (7) day time limit of Technical Specification 3.7.7 was exceeded. This is a final report.

Yours truly,

L. F. Dale
Manager of Nuclear Services

EBS/SHH:rg

cc: See next page

8405240229 840504
PDR ADGCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IF 22/10

MISSISSIPPI POWER & LIGHT COMPANY

AECM-84/0220

Page 2

cc: Mr. J. B. Richard
Mr. R. B. McGehee
Mr. N. S. Reynolds
Mr. G. B. Taylor

Mr. Richard C. DeYoung, Director
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555