apparails Sxh. 41

A-4/ n/83

Procedure M-41 PAGE CS- 1 REVISION 5


DUKE POWER COMPANY
CONSTRUCTION DEPARTMENT

PROGRAM

OF ACCOMPTENCY OF THE PROCEDURE OF THE PROCEDU

LIST OF PAGES, FORMS, & ATTACHMENTS VALID FOR THIS REVISION:

\*Page CS-1 Page 1 \*Page 2 Form M-41A Form M-41B



NUCLEAR SAFETY RELATED

\* Changes included in this revision

NOT FOR CONSTRUCTION

SUPERSEDED

PROCEDURE M-41

PAGE

REVISION 4

MS Kisida 4/29/7

DUEZ POWER COMPANY

QUALITY ASSURANCE PROGRAM

1. PURPOSE

The purpose of this procedure is to establish the requirements for inspection and documentation for electrical equipment installation.

2. SCOPE

This procedure covers the inspection and documentation for the installation of all nuclear safety related electrical equipment. Any other electrical equipment, as deemed necessary by Duke Power Compnay Management may be included to effect a quality installation. Receiving inspection shall be covered under Procedure P-1. Storage inspection shall be covered under Procedure P-3.

3. RESPONSIBILITY

The Senior Quality Control Engineer shall be responsible for carrying out the inspection requirements of this procedure and for documenting these inspections. He shall also be responsible to initiate corrective action forms when found necessary during the course of inspection.

The Project Senior Quality Assurance Engineer shall be responsible for initiating nuclear safety related Supplemental Inspection Instructions (Form M-418) and approving all Form M-418's and for reviewing and approving all inspection documentation.

The Project Engineer shall be responsible for initiating non-nuclear safety related M-418's and for approving safety related M-418's.

4. INSPECTION

Quality Control Inspectors certified in accordance with Construction Quality Assurance Procedures shall verify that the installation of electrical equipment is in accordance with approved Design Engineering and Construction installation information. Supplemental information may be obtained from approved manufacturer's drawings.

Detailed inspection instructions for each type of electrical equipment shall be provided by Supplemental Inspection Instructions (Form M-41B). Nuclear safety related M-41B's shall be prepared by Project Quality Assurance Staff, non-nuclear safety related M-41B's shall be prepared by the Project Engineer's Staff, and all M-41B's shall be approved by the Project Senior Quality Assurance Engineer and Project Engineer. Nuclear safety related M-41B's may be used as instructions for the inspection of non-nuclear safety related electrical equipment if designated by the Project Engineer TOPLE CONSTRUCTION (M-41B's shall be controlled in accordance with Procedure (CONSTRUCTION)

Installation inspection shall be

SUPERSEDED

4

documented on Form M-41A and any supplemental forms required by M-41B's. Calibrated equipment specified by M-41B's shall be calibrated in accordance with Procedure 0-1 for nuclear safety related inspections.

- 5. CORRECTIVE ACTION

  Corrective action shall be as specified in Procedure M-40.
- Form M-41A Equipment Installation Inspection.

  Form M-41B Supplemental Inspection Instructions.

  Form 1-40C Random Inspection Worksheet.

CONSTRUCTION DEPARTMENT PROJECT MC GUIRE UNIT

## ELECTRICAL EQUIPMENT INSTALLATION INSPECTION

THE FOLLOWING ELECTRICAL EQUIPMENT HAS BEEN INSPECTED

AND FOUND TO BE INSTALLED IN ACCORDANCE WITH THE INDICATED DRAWINGS AND INSTRUCTIONS.	
EQUIPMENT DESCRIPTION ESSENTIAL MOTOR CONTINUES	
CENTER IEMXA	_
E. P. P.	
4//4	
LOCATION EL 750 COL FF-54	_
DRAWING NUMBER (S) MC 1887-01 R-14, MC 1903-01 R-20 MC 1908-01 R-11	_
REFERENCE INSTRUCTIONS M-46 R-2, CP 308 R-4	
REMARKS BASE ANCHORS TORQUED WITH SN 3226	
OMICONTROLLED COPY	
HST FOR CONSTRUCTION	_
SUPERSED	
Q. C. INSPECTOR/NDE Q C Crede DATE 3/26/76 Q. C. INSPECTOR/ELEC. IT Square DATE 3/26/76	
Q A APPROVAL Q Q Elec DATE 3/26/76	

	FORM	M-418	REVISION	1
==	20110111	·		

Sheet 1 of 1

DUKE POWER COMPANY CONSTRUCTION DEPARTMENT PROJECT \_\_MCGuire

Serial no. 7
Revision no. 0

## SUPPLEMENTAL INSPECTION INSTRUCTIONS

EQUIPMENT DESCRIPTION	Electrical Cable Tray and	Conduit
TYPE OF INSPECTION	Installation	
DOCUMENTATION REQUIRED	M-41A	

## INSPECTION INSTRUCTIONS:

- Verify, on a sampling basis, that conduit which have been cut are free of burrs.
- 2. Verify that conduit supports are correctly fabricated and anchored.
- 3. Verify that cable tray is the correct size, at the correct elevation, in the correct location, with the correct spacing. Generally, an eyeball measurement is adequate although a ruler may be required in some questionable areas. The most critical location dimension is minimum horizontal and vertical spacing between trays.
- 4. Verify that cable tray hangers are constructed from the correct materials, dimensionally correct (the most critical dimension is spacing between rungs), and assembled correctly (bolted or welded).
- 5. Verify that the cable tray hangers are anchored correctly (welding to embedded plate is acceptable in Dieurof boiled concrete anchors) in the correct location along the tray within tolerances specified on the design drawings. If not specified this tolerance shall be + 6 inches.
- 6. Verify that splice plates and tray clamps are correctly installed.
- 7. Verify that there is no apparent physical damage.
- 8. Verify, on a sampling basis, that torque requirements specified area of cable tray and conduit are met. The type torque delicities serial number shall be entered under remarks.
- 9. Inspect welds and perform NDE as specified on drawings.

## SUPERSEDED

PREPARED	SAFETY RELATED	NON SAFETY RELATED
CONST APPROVAL	KD Parker	DATE 3/2/77
Q. A. APPROVAL _	HM Itamufin	DATE 5/2/77

