



GULF STATES UTILITIES COMPANY

POST OFFICE BOX 2951 • BEAUMONT, TEXAS 77704

AREA CODE 713 838-6631

May 21, 1984
RBG-17,856
File Code G9.5, G9.8.6.2,
G9.33.4

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Denton:

River Bend Station - Unit 1
Docket No. 50-458

On April 24, 1984 Gulf States Utilities Company (GSU) submitted the River Bend Station Safety Parameter Display System (SPDS) safety analysis report for your review. Corrected copies are being provided for insertion into the report which correct typographical errors.

Sincerely,

William J. Leedy
for J. E. Booker
Manager - Engineering
Nuclear Fuels & Licensing,
River Bend Nuclear Group

JEB/RJK/je

Attachments

*Book
1/40*

INTRODUCTION

The accident at Three Mile Island Unit 2 has served to focus Industry attention on the need for adequate instrumentation and human-factored displays for plant operators to follow and help mitigate the consequences of various plant transients. The NRC Staff and the Industry have commissioned several studies (References 1, 2, 4, 5, 7, and 8) to identify the subject instrumentation. River Bend Station (RBS) has reviewed the existing literature on this subject and has within this study documented a listing of needed instrumentation which is specific to the plant. This report establishes a listing of RBS-specific plant variables which is used as a basis upon which to compare the Safety Parameter Display System (SPDS) database and the inventory of main control room instrumentation to be reviewed by the Detailed Control Room Design Review (DCRDR) study.

OBJECTIVE

The objective of this study is to validate an RBS-specific listing of parameters that will be available for monitoring to furnish control room operators with sufficient information to mitigate or limit the consequences of abnormal and accident events. Additionally, the study endeavors to describe the basis upon which RBS believes that the listing is necessary and sufficient to assess the safety status of the plant. The listing delineates specific instruments which are used to monitor each identified parameter.

It is intended that this study will serve as the licensing basis for demonstrating compliance with the guidance provided by the NRC Staff in Generic Letter 82-33 Item 4.2.a.

METHODOLOGY

The validation of an RBS-specific listing of accident monitoring variables required an action plan depicted in Figure 1 and described below to insure a necessary and sufficient list of variables:

- 1) Several event tree analysis studies (References 1 and 2) were reviewed for information and a tabulation of variables to be monitored was developed.

Additionally, the RBS emergency operating procedures (EOP's) were reviewed to define specific instrumentation needs for implementing required operator actions defined therein.

- 2) The two lists generated (Appendix A and B) were merged with the variable list identified in Table 2 of Regulatory Guide 1.97, Revision 3 to form a composite variable list (Table 1) which would encompass the monitoring of a large number of possible events.

TABLE 1 LEGEND

SEQUENCE NO. - Each distinct variable is identified by a unique sequence number for reference purposes.

SOURCE - An "X" is placed in the appropriate column if a variable was identified by the particular method shown.

INSTRUMENT ID - This is the alphanumeric designator assigned by Stone & Webster Engineering Corporation (SWEC) for the sending instrument(s).

CATEGORY - This is the category designation assigned by GSU Engineering from its independent review delineated in Appendix D. The numbering convention definitions are the same as those used in R.G. 1.97, Revision 3.

MCR DISPLAY BENCHBOARD - The SWEC identification number is shown for the panel(s) where the instrument channel display is located.

SPDS SIG ID - This alphanumeric number is the unique identifier assigned by General Electric (GE) to identify the variable monitored by the SPDS database. GE is furnishing the RBS SPDS.

RANGE - The current design range of each listed instrument is given.

REFERENCE NOTES - Table 1 is furnished with a REFERENCE NOTES section at the end of the table for inclusion of technical comments.

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|---|---------|-----|------|--|----------|----------------------------|--|---|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 1 | Reactor Vessel Water Level | X | X | X | 1B21*LTN044C,D *PTN062A,B *LTN081C *LTN027 1C33*LTN017 *LTN004A,B,C | 1 | 1H13*P601 1H13*P680 | B21EA001 007 C33EA024 027 | 209 - 409 in (Fuel Zone) 521 - 581 in (Narrow) 361 - 581 in (Wide Range) 521 - 921 in (Shutdown) 521 - 701 in (Upset) | 1 |
| 2 | Reactor Vessel Pressure | X | X | X | 1C33*PTN005 *PTN008A 1B21*PTN062A,B | 1 | 1H13*P680 1H13*P601 | B21EA008 013 C33EA028 033 | 0-1200 psig 850-1050 psig 0-1500 psig | |
| 3 | Drywell Pressure | X | X | X | 1CMS*PT2A,B | 1 | 1H13*P808 | CMSPY024 025 | 0-50 psia | |
| 4 | Containment/Drywell Hydrogen Concentration | X | X | X | 1CMS*AT25A,B | 1 | 1H13*P808 | CMSYY001 002 | 0 - 10% Hydrogen (Narrow) 0 - 30% Hydrogen (Wide) | 2 |
| 5 | Suppression Pool Level | X | X | X | 1CMS*LIT23A,B | 1 | 1H13*P808 | CMSLY028 029 | minus 18 - 4 ft measured from normal pool level | 3 |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|--|---------|-----|------|--|----------|---------------------------|--------------------------|---|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 6 | Suppression Pool Temperature | X | X | X | 1CMS*TT24A,C,E *TT24B,D,F *TT24G,J *TT24H,K *TT40A,C *TT40B,D | 1 | 1H13*P808 ↓ 018 | CMSTY005 ↓ 018 | 0-200°F | |
| 7 | Control Rod Position (Typical for 145 Rods) | X | X | X | 1B13-D124 Channel A & B | 3 | 1H13*P680 | C11EC004 | Full In/Discrete Inter- mediate Positions/Full Out | 4 |
| 8 | LPCS Flow | X | X | X | 1E21*FTN003 | 2 | 1H13*P601 | E21EA001 | 0-7000 gpm | |
| 9 | Condensate Storage Tank Level | X | X | X | 1CNS-LT110 | 3 | 1H13*P680 | CNMLY006 | Top to Bottom | 20 |
| 10 | SLCS Tank Level | X | X | X | 1C41*LTN001 | 2 | 1H13*P601 | C41EA002 | 0-5000 gal | |
| 11 | SRV Position | X | X | X | 1SVV*ZE10 A-H, J-N, P-R | 2 | 1H13*P601 | B21EC042 ↓ 060 | Full Closed/Intermediate/ Full Open | 19 |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|---|---------|-----|------|------------------------|----------|---------------------------|---|-----------|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 12 | Primary Containment Radiation | X | X | X | | 1 | 1H13*P879 *P878 | | | 5 |
| | Primary Containment Atmosphere | | | | 1RMS*RE16A,B *RE111 | | | $1.0 - 10^7$ R/hr $10^{-11} - 10^{-1}$ Ci/cc | | |
| | Drywell Atmosphere | | | | 1RMS*RE112 | | | $10^{-11} - 10^{-1}$ Ci/cc | | |
| | Drywell Area | | | | 1RMS*RE20A,B | | | $1.0 - 10^7$ R/hr | | |
| | Drywell Personnel Airlock | | | | 1RMS-RE138 | | | $1.0 - 10^5$ mr/hr | | |
| 13 | Containment Effluent Radioactivity | X | X | X | 1RMS*RE125 *RE5A,B | 2 | | $10^{-7} - 10^5$ Ci/cc | | 6 |
| 14 | Radiation Level in Circu- lating Primary Coolant | | X | | | | | | | 21 |
| 15 | Drywell Atmosphere Temperature | X | X | | 1CMS*RTD41A,B,C,D | 1 | 1H13*P808 | CMSTY026 027 | 0 - 446°F | 29 |
| 16 | Containment/Drywell Oxygen Concentration | X | X | | | | | | | 7 |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|---|----------|-----|------|--|----------|---------------------------|-----------------------------|---|--------------------|
| | | RG 1, 97 | EOP | TREE | | | | | | |
| 17 | Drywell Equipment and Floor Drain Sump Water Level | X | X | | 1E31*LTN093 *LTN094 *LTN095 *LTN096 *LTN097 | 2 | 1H13*P632 | DFRLY001 005 DERLY003 | 5 - 25 gpm | |
| 18 | Neutron Flux LPRM Detectors | X | X | X | 1C51*JEN011 *JEN012 *JEN013 *JEN014 | 1 | 1H13*P680 | C51EA003 | 1 - 120 percent full power | 8 |
| | IRM Detectors | | | | 1C51*JEN002A *JEN002B *JEN002C *JEN002D *JEN002E *JEN002F *JEN002G *JEN002H | | | 010 021 024 | 5×10^{-4} - 10.0 percent full power | |
| | SRM detectors | | | | 1C51*JEN001A,B,C,D | | | | 10^{-7} - 10^{-3} percent full power | |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SFDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|--|---------|-----|------|---|----------|-----------------------------|----------------------|-------------------------------------|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 19 | Main Steam Line Radiation | | X | | 1D17*REN003A,B,C,D | 3 | 1H13*P680 | | 1.0 - 10 ⁶ mr/hr | 9 |
| 20 | Status of HPCS DG | | | X | | 3 | 1H13*F601 | | Available/Unavailable | 10 |
| 21 | RHR HX Inlet/Outlet Temperatures | X | | X | 1E12*TEN004A,B *TEN002A,B *TEN027A,B *TEN005A,B *TEN003A,B 1RHS*RTD47A,B | 2 | 1H13*P601 | E12EA124 ↓ 129 | 0 ^o - 600 ^o F | |
| 22 | Containment Isolation Valve Positions | X | | X | | 1 | 1H13*P863 *P601 *P870 | | Open/Intermediate/Closed | 11 |
| 23 | RPV Boron Concentration (grab) | X | | X | | 3 | | | | 12 |
| 24 | RHR Flow | X | X | | 1E12*FTN015A,B,C | 2 | 1H13*P601 | E12EA005 ↓ 007 | 0 - 8,000 gpm | |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|------------------------------------|---------|-----|------|---------------------------------------|----------|---------------------------|--|--------------------------------|--------------------|
| | | RG 1.97 | LOP | TREE | | | | | | |
| 25 | MSIV Positions | | X | X | 1B21*AOVFO2A,B,C,D *AOVFO28A,B,C,D | 1 | 1H13*P601 | B21EC070 ↓ 074 076 077 079 080 082 083 085 086 088 089 091 092 | Open/Closed | 13 |
| 26 | RCIC Flow | X | | X | 1E51*FTN003 | 2 | 1H13*P601 | E51EA005 006 | 0-800 gpm | |
| 27 | Feedwater Flow Pump A Pump B | X | | X | 1C33-FTN002A -FTN002B | 3 | 1H13*P680 | C33EA019 020 | 0 - 8 X 10 ⁶ lbm/hr | |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|--|---------|-----|------|--------------------------------|----------|---------------------------|-----------------|------------------------|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 28 | HPCS Flow | X | | X | 1E22*FTN005 | 2 | 1H13*P601 | E22EA001 006 | 0-7000 gpm | |
| 29 | Area Radiation | X | X | | | 3 | 1RMS- DSPL230 | | | 14 |
| 30 | Airborne Radioactivity Releases | X | X | | 1RMS*RE125 *RE5A,B -RE6A | 2 | 1RMS- DSPL230 | | $10^{-7} - 10^5$ Ci/cc | 15 |
| 31 | Core Temperature | X | | X | | | | | | 16 |
| 32 | Suppression Pool Hydrogen/ Oxygen Concentration | | X | | | 3 | | | | 27 |
| 33 | Containment Water Level | | X | | | 3 | | | | 17 |
| 34 | Containment Atmosphere Temperature | X | X | | 1CMS*RTD42A-G,J | 3 | 1H13*P808 | CMSTY028 037 | 0° - 200°F | |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|------------------------------------|---------|-----|------|--------------------------------------|-----------|---------------------------|-------------------------------|--------------|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 35 | Primary Containment Pressure | X | X | X | | | | | | 25 |
| | Annulus Differential | | | | 1HVR*PDT60A thru F | | HVRPY222 223 | | | |
| | Drywell Differential | | | | 1CMS*PDT29A,B | 1H13*P808 | CMSPY019 020 | minus 15 - 30 psid | | |
| | Absolute | | | | 1CMS*PT4A,B | 1H13*P808 | | 0 - 75 psia | | |
| 36 | RCIC Turbine Speed | | X | | 1E51*PC002-1 | 3 | 1H13*P601 | E51EA014 | 0 - 6000 rpm | |
| 37 | Reactor Cooldown Rate | | X | | 1B21-N029A,B -N030A,B -N050A,B | 3 | 1H13*P614 | B21EA022 | 0 - 600°F | 26 |
| 38 | Turbine Stop Valve Positions | | X | | 1C71*ZSN006A-H | 3 | 1H13*P870 | N32EA001 002 003 004 | Open/Closed | 9 |
| 39 | Turbine Control Valve Positions | | X | | 1MSS-HYVCV1 -HYVCV4 | 3 | 1H13*P870 | N32EA005 ↓ 008 | Open/Closed | 9 |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHBOARD | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|--|---------|-----|------|----------------------------------|----------|---------------------------|-----------------|------------------------------|--------------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 55 | SLCS Discharge Pressure | X | X | | 1C41*PTN004 | 2 | 1H13*P601 | C41EA003 | 0-1800 psig | 31 |
| 56 | Condensate Pump Discharge Pressure | | | X | 1CNM-PT105 | 3 | 1H13*P680 | CNMPY010 | 0-800 psig | |
| 57 | Cumulative Boron Injected | | X | | 1C41*LTN001 | 3 | 1H13*P601 | | 0-5000 gal | 30 |
| 58 | HPCS Key Valve Positions | | | X | | 3 | 1H13*P601 | | Open/Closed | 18 |
| 59 | SSW Key Valve Positions | | | X | | 3 | 1H13*P870 | | Open/Closed | 18 |
| 60 | RCIC Key Valve Positions | | | X | | 3 | 1H13*P601 | | Open/Closed | 18 |
| 61 | Liquid Effluent Radioactivity | | X | | | 3 | | | | |
| | RHR HX Service Water Cooling Tower Blowdown Liquid Radwaste Effluent | | | | 1RMS*RE15A,B -RE108 -RE107 | | 1H13*P879 *P878 | | 10^{-7} to 10^{-2} Ci/cc | |
| 62 | SSW Temperature to ESF Components | X | | | 1SWP*TT31A,B | 2 | 1H13*P870 | SWPTY017 018 | 0-125°F | |

TABLE 1

COMPOSITE LIST OF ACCIDENT MONITORING VARIABLES

| SEQUENCE NO. | VARIABLE | SOURCE | | | INSTRUMENT ID | CATEGORY | MCR DISPLAY BENCHMARK | SPDS SIG ID | RANGE | REFERENCE NOTES |
|--------------|--|---------|-----|------|---|----------|-----------------------|---|-----------------------|-----------------|
| | | RG 1.97 | EOP | TREE | | | | | | |
| 65 | Liquid Radwaste Tank Levels | X | | | ILWS-LT113A,B,C -LT8A,B,C,D -LT26A,B -LT521A,B,C,D -LT320 -LT24A,B | 3 | | | Top to bottom of tank | 25 |
| 66 | Emergency Ventilation Damper Positions | X | | | | 2 | 1H13*P863 | HVREX001 004 009 010 HVWBX001 | Open/Closed | 23 |
| 67 | Status of Standby Power | X | | | | 2 | 1H13*P808 *P877 | | | 24 |

TABLE 1 NOTES

| <u>Description</u> | <u>Instrument ID</u> |
|---|--------------------------------|
| (9) Standby Switchgear 125 VDC Bus Voltage | V-1ENBA03 B03 1E22*VR618 |

25. The present design of River Bend Station does not provide for direct or indirect readout of the subject variable in the main control room.
26. The instrument readout is a timed, strip chart, multi-pen recorder. Operators ascertain the cooldown rate visually by observing chart slopes. The plant is also provided with a permanent record for later analysis as required.
27. RBS will provide for grab sampling of the suppression pool water inventory. On-site chemistry facilities are equipped to measure the subject variables in a timely fashion commensurate with the needs of MCR operators.
28. The following plant areas are monitored for the subject variable:
- Main Steam Line Pipe Tunnel
 - RHR Equipment Areas
 - RCIC Equipment Areas
 - RWCU Equipment Areas
29. Heatup calculations performed for RBS Unit 1 predict a maximum drywell temperature not to exceed 320° F. Therefore, the existing instrumentation has sufficient range to function as an information source during accident or abnormal conditions.
- The range specified is that of the sending instrument. The actual recording range will be determined at a later time prior to fuel load.
30. RBS EOP's instruct the operator to ascertain this variable by measuring the SLCS tank level drop thus inferring the quantity of sodium pentaborate solution which is injected into the vessel.
31. RBS does not measure SLCS flow directly owing to sensing instrument problems arising from sodium pentaborate contamination of moving parts. Measurement of SLCS pump discharge header pressure is deemed sufficient to ascertain SLCS flow when used in conjunction with other variables such as SLCS tank level.