

NORTHERN STATES POWER COMPANY

DOCKET NO. 50-263

MONTICELLO NUCLEAR GENERATING PLANT

AMENDMENT TO PROVISIONAL OPERATING LICENSE

Amendment No. 28
License No. DPR-22

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Northern States Power Company (the licensee) dated May 5, 1977, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

OFFICE →						
SURNAME →						
DATE →						

2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the Attachment to this license amendment and Paragraph 3.B of Provisional Operating License No. DPR-22 is hereby amended to read as follows:

3.B Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. , are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

Don K. Davis, Acting Chief
Operating Reactors Branch #2
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance:

OFFICE ➤						
SURNAME ➤						
DATE ➤						

ATTACHMENT TO LICENSE AMENDMENT NO. 28

PROVISIONAL OPERATING LICENSE NO. DPR-22

DOCKET NO. 50-263

Replace page 192 of the Technical Specifications contained in Appendix A of the above-indicated license with the attached page 192. The changed area on the revised page is reflected by a marginal line.

OFFICE →						
SURNAME →						
DATE →						

6.0 ADMINISTRATIVE CONTROLS

6.1 Organization

- A. The Plant Manager has the overall full-time onsite responsibility for safe operation of the facility. During periods when the Plant Manager is unavailable, he may delegate this responsibility to other qualified supervisory personnel.
- B. The Northern States Power corporate organizational structure relating to the operation of this plant is shown in Figure 6.1.1.
- C. The minimum functional organization for operation of the plant shall be as shown in Figure 6.1.2. The minimum shift complement for special plant conditions shall be as follows:
 - 1. The unit shutdown and the reactor contains fuel: a Licensed Senior Operator on site; a Licensed Operator in the control room; and a plant operator on site.
 - 2. During cold startup, while shutting down the reactor and during recovery from any reactor trip: a Licensed Senior Operator in the plant and a minimum of two Licensed Operators in the control room.
 - 3. Fuel handling operations: a Licensed Senior Operator shall be directly in charge of any refueling operation, alteration of the reactor core, and handling of irradiated fuel and shall have no other concurrent duties.
 - 4. Any fuel on site: an individual qualified in radiation protection shall be on site at all times that there is fuel on site.
- D. Minimum qualifications, training, replacement training and retraining of plant personnel shall be in accordance with that stated in the "Standard for Selection and Training of Personnel for Nuclear Power Plants" ANSI N18.1-1971. The Radiation Protection supervisor shall meet the minimum qualifications in Regulatory Guide 1.8, September, 1975. The minimum frequency of the retraining program shall be every two years. The training program shall be under the direction of a designated member of the plant staff.