

NORTHERN STATES POWER COMPANY
Monticello, Minnesota 55302

November 14, 1973



Mr. J. G. Keppler, Regional Director
Directorate of Regulatory Operations
Region III
United States Atomic Energy Commission
799 Roosevelt Road
Glen Ellyn, Illinois 61073

Dear Mr. Keppler:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

On November 13, 1973, it was discovered that standby liquid control tank level indicators were improperly calibrated. This improper calibration has caused Technical Specification volume-concentration requirements (Figure 3.4.1) to be violated. Our records indicate that on August 28, 1973, solution volume was 2570 gallons. The Technical Specification requires 2585 gallons for the same solution concentration. Solution has been added and the level indicators are being recalibrated to insure compliance.

Yours very truly,

C. E. Larson
Plant Manager
NORTHERN STATES POWER COMPANY

CEL/kik

cc: J F O'Leary
G Charnoff
Minnesota Pollution Control Agency
Attn: Ken Dzugan

Copies sent by telecopier to Keppler and O'Leary.

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 8249

FILE: _____

FROM: Northern States Power Company Monticello, Minn. 55362 C. E. Larson		DATE OF DOC 11-14-73	DATE REC'D 11-14-73	LTR	MEMO	RPT	OTHER Facsimile
TO: J. G. Keppler		ORIG 1	CC	OTHER	SENT AEC PDR _____ X SENT LOCAL PDR _____ X		
CLASS	UNCLASS XXXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: 50-263		

DESCRIPTION:
Facsimile reporting an abnormal occurrence on 11-13-73, in which standby liquid control tank level indicators were improperly calibrated.....

ENCLOSURES:

ACKNOWLEDGED

DO NOT REMOVE

PLANT NAME: Monticello

FOR ACTION/INFORMATION 11-15-73 GC

- | | | | |
|------------------------|---------------------------|----------------------------|-----------------------|
| BUTLER(L)
W/ Copies | SCHWENCER(L)
W/ Copies | ✓ZIEMANN(L)
W/ 7Copies | REGAN(E)
W/ Copies |
| CLARK(L)
W/ Copies | STOLZ(L)
W/ Copies | DICKER(E)
W/ Copies | W/ Copies |
| GOLLER(L)
W/ Copies | VASSALLO(L)
W/ Copies | KNIGHTON(E)
W/ Copies | W/ Copies |
| KNIEL(L)
W/ Copies | SCHEMEL(L)
W/ Copies | YOUNGBLOOD(E)
W/ Copies | W/ Copies |

INTERNAL DISTRIBUTION

- | | | | | |
|-------------------|-------------|-------------|----------------|---------------|
| ✓REG FILE | TECH REVIEW | DENTON | LIC ASST | A/T IND |
| ✓AEC PDR | ✓HENDRIE | GRIMES | ✓DIGGS (L) | BRAITMAN |
| ✓OGC, ROOM P-506A | SCHROEDER | GAMMILL | GEARIN (L) | SALTZMAN |
| ✓MUNIZING/STAFF | ✓MACCARY | KASTNER | GOULBOURNE (L) | B. HURT |
| ✓CASE | ✓KNIGHT | BALLARD | LEE (L) | PLANS |
| GIAMBUSSO | ✓PAWLICKI | SPANGLER | MAIGRET (L) | MCDONALD |
| BOYD | ✓SHAO | | SERVICE (L) | DUBE |
| MOORE (L)(BWR) | ✓STELLO | ENVIRO | SHEPPARD (E) | INFO |
| DEYOUNG(L)(PWR) | ✓HOUSTON | MULLER | SMITH (L) | C. MILES |
| ✓SKOVHOLT (L) | ✓NOVAK | DICKER | TEETS (L) | ✓B. KING (RO) |
| P. COLLINS | ✓ROSS | KNIGHTON | WADE (E) | |
| ✓REG OPR | ✓IPPOLITO | YOUNGBLOOD | WILLIAMS (E) | |
| FILE & REGION(3) | ✓TEDESCO | REGAN | WILSON (L) | |
| ✓MORRIS | ✓LONG | PROJECT LDR | | |
| ✓STEELE | ✓LAINAS | | | |
| | ✓BENAROYA | HARLESS | | |
| | ✓VOLLMER | | | |

EXTERNAL DISTRIBUTION

- | | | |
|--|------------------------------|------------------------|
| 1 - LOCAL PDR Minneapolis, Minn. | (1) (2X10) NATIONAL LAB'S | 1-PDR-SAN/LA/NY |
| 1 - DTIE (ABERNATHY) | 1-ASLBP(E/W Bldg, Rm 529) | 1-GERALD LELLOUCHE |
| 1 - NSIC (BUCHANAN) | 1-W. PENNINGTON, Rm E-201 GT | BROOKHAVEN NAT. LAB |
| 1 - ASLB (YORE/SAYRE/
WOODARD/"H" ST. | 1-CONSULTANT'S | 1-AGMED (Ruth Gussman) |
| 16 - CYS ACRS XXXXXX SENT TO LIC. ASST. | NEWMARK/BLUME/AGBABIAN | RM-B-127, GT. |
| 11-15-73 DIGGS | 1-GERALD ULRIKSON... ORNL | 1-RD..MULLER..F-309 GT |