

**TEXAS UTILITIES GENERATING COMPANY**

SKYWAY TOWER \* 400 NORTH OLIVE STREET, L.B. 81 \* DALLAS, TEXAS 75201

May 24, 1984

Mr. B. J. Youngblood  
Licensing Branch No. 1  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION  
DOCKET NOS. 50-445 and 50-446  
CLASS "A" FIRE DETECTOR CIRCUITS

Dear Sir:

Texas Utilities letter TXX-4151 dated April 13, 1984 provided justifications for two exceptions (7a and 7b) to the use of class "A" detection circuits.

We have determined that the detection systems in question meet the requirements of Section 3540 of NFPA 72D 1975, the edition of NFPA 72D to which CPSES is committed to comply.

We therefore withdraw the exceptions transmitted by the above letter.

Should you have additional questions please contact this office.

Sincerely,



H. C. Schmidt

BSD:bjm

8405300142 840524  
PDR ADDCK 03000445  
F PDR

3002  
1/0