Duquesne Light Company May 17, 1991 U. S. Nuclear Regulatory Commission Attn: Document Control Desk Washington, DC 20555 Subject: Beaver Valley Power Station, Unit No. 1 Docket No. 50-334, License No. DPR-66 NRC Bulletin 88-11 By letter dated May 2, 1991 (TAC No. 72110), the NRC approved a leak-before-break (LBB) analysis of the Beaver Valley Unit 1 (BV-1) presgurizer surge line piping which allows the shims to be removed from the surge line pipe whip restraints. However, this approval was contingent upon the condition that the pressurizer surge line satisfies NRC Bulletin 88-11. Prior to this approval, the BV-1 pressurizer surge line satisfied NRC Bulletin 88-11. This was accomplished by meeting the ASME Section III code requirements for stress and fatigue for the 40 year plant design life with the limitation of a 200°F delta temperature between the pressurizer and hot leg imposed during pressurizer bubble formation and collapse. The LBB analysis was performed to justify removal of the shims from the surge line whip restraints and to allow the 200°F limitation This LBB analysis was approved by the May 2, to be discontinued. 1991 NRC letter and its supporting safety evaluation. Therefore, during the current outage, the BV-1 pressurizer surge line whip restraint shims will be removed and the 200°F limitation discontinued. The pressurizer surge line will continue to meet ASME Section III requirements after this modification is completed. If you have any questions concerning this matter, please contact Mr. Brian Sepelak at (412) 393-5282. Sincerely, Vice President Nuclear Group Mr. J. Beall, Sr. Resident Inspector Mr. T. T. Martin, NRC Region I Administrator Mr. A. W. DeAgazio, Project Manager 105310073 910517

\*NRC 'Bulletin 88-11 ND1NSM:5091 Page 2

## References:

LER 89-011-00 ND1NSM:3911 WCAP-12277 ND1ISI:0956 ND1NSM:4317 9/20/90 NRC Letter WCAP-12727 ND1MNE:5602 ND1NSM:4932 5/2/91 NRC Letter