NORTHEAST UTILITIES

NU

MEMO

April 4, 1990
MP-SEC-90-14

TO: William Raymond
USNRC Senior Resident Inspector
Millstone

FROM: Patricia L Weekley
Security Manager
Ext 4329

SUBJECT: Follow up to CO2 Information Memo MP-SEC-89-89

In the above referenced memo dated July 14, 1989 I indicated that telephones would be installed in the area of the Unit 3 cable tunnels (Security Doors 303 and 304). Further assessment of the benefit of installing telephone communication in this area was conducted by Station Services Engineering and Maintenance. Because the area in question must have the CO2 system locked out prior to entry, it was determined that the benefit of installing phones would be minimal. Security does not respond to these areas without the CO2 System being locked. The officers are dispatched and monitored by the Central Alarm Station. In the event the Officer does not respond in a timely manner or does not punch the card reader, additional personnel are dispatched to ascertain the officer's well being. This coupled with the CCTV located in the area provides a high degree of safety for the Security Officers involved.

While a plan to enhance telephone communication on Unit 3 in general is still an open issue there is currently no plan for additional telephones to be installed in this area for safety reasons.

H/4

OS70 REV 7-85
BP9.1

9203310223 910926
PDR FOIA
GUILD91-162 PDR

SITE: MILLSTONE 1, 2 & 3

ALLEGATION NO.: RI-89-A-0085

DATE: 7/19/89 (Mtg. 1 2 3 4 5)

PRIORITY: High Medium Low

SAFETY SIGNIFICANCE: Yes No Unknown

CONCURRENCE TO CLOSEOUT: DD BC SC

CONFIDENTIALITY GRANTED: Yes No

PANEL ATTENDEES:

Chairman - W. KANE

Branch Chief -

Section Chief - E. MCCABE

M. FORMAN, MGMT ASST

ACTION:

1) REFERRAL TO LICENSEE (ECD 9/15/89).

2)

3)

4)

5)

6)

H/5