

OCT 26 1983

Tennessee Valley Authority  
ATTN: Mr. H. G. Parris  
Manager of Power  
500A Chestnut Street Tower II  
Chattanooga, TN 37401

Gentlemen:

SUBJECT: REPORT NOS. 50-438/83-10 AND 50-439/83-10

Thank you for your response of August 26, 1983, to our Notice of Deviation issued on May 23, 1983, concerning activities conducted under NRC Construction Permit Nos. CPPR-122 and CPPR-123. We have evaluated your response and found that the corrective action proposed for Deviation Items A (438, 439/83-10-03), B.1.(b) (438, 439/83-10-01) and C (438, 439/83-10-05) is satisfactory. We will examine the implementation of your corrective actions during future inspections.

Your denial and comments on Deviation Items B.1.(a) and B.2.(a) (438, 439/83-10-01) are being forwarded to the NRR for evaluation. We will advise you as to the results of this evaluation.

Your response to Deviation Item B.2.(b) (438, 439/83-10-01) concerning the supervision of the automatic sprinkler system piping is not acceptable. The requirement for air supervision of sprinkler system piping has previously been established with your staff for the Watts Bar facility. This information was forwarded to you by NRC's letter of August 31, 1983, from Thomas M. Novak, regarding fire protection issues at Watts Bar. Therefore, the sprinkler piping at Bellefonte should be provided with air supervision. This supervision should be operational prior to fuel load for the applicable unit.

We appreciate your cooperation with us and if you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Richard C. Lewis, Director  
Division of Project and  
Resident Programs

cc: (See page 2)

8405300234 840507  
PDR ADUCK 05000438  
Q PDR

OCT 26 1983

cc: H. J. Green, Director of Nuclear Power  
 A. M. Qualls, Plant Superintendent  
 L. S. Cox, Project Manager  
 Ms. K. D. Mali, Project Engineer  
 D. L. Williams, Jr., Supervisor  
 Licensing Section  
 H. N. Culver, Chief, Nuclear Safety  
 Review Staff  
 J. W. Anderson, Manager  
 Office of Quality Assurance  
 W. R. Brown, Jr.

bcc: NRC Resident Inspector  
 Document Control Desk  
 State of Alabama  
 V. Benaroya, NRR/CEB

*RII PJ  
 PE Fredrickson  
 10/25/83*

RII *MOB for*  
 WHMiller:sa 10/20/83  
 RII *MOB for*  
 TECorlon 10/20/83

RII *AR*  
 ARHerdt 10/20/83  
 RII *AR*  
 JAOlshinski 10/24/83

~~RII~~  
~~CAJillian 10/1/83~~  
 RII *DM*  
 DMVerrellii 10/25/83

RII *R*  
 RCLewis 10/25/83