

Appendix A

Notice of Violation

Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant, Units 1 and 2

Docket Nos. 50-317/50-318
License Nos. DPR-53/DPR-69

During an NRC inspection conducted from January 27 to January 31, 1992, violations of NRC requirements were identified. In accordance with "General Statement of Policy and Procedure for Enforcement Actions," 10 CFR, Part 2, Appendix C (1990), the following violation was identified.

Calvert Cliffs Technical Specification (TS) 6.8.1.f. requires that written procedures for the Fire Protection Program shall be established and implemented. Calvert Cliffs Fire Protection Plan, CCI-133, Sections IV.A & B, which, in part, implements this TS requirement, states that all Fire Brigade members shall: (1) participate in training sessions every calendar quarter; (2) be evaluated by the Supervisor, Safety and Fire Protection Unit, for continued brigade membership if quarterly training is missed; (3) have their qualification evaluated twice a year, and (4) participate in at least two quarterly fire drills per year.

Contrary to the above, as of January 28, 1992, CCI-133 was not adequately implemented in that: (1) seventeen Fire Brigade members missed their required quarterly training; (2) evaluations for continued brigade membership were not conducted and documented when training was missed; (3) twice a year evaluations of qualifications were not performed and documented, and (4) five Fire Brigade members did not participate in at least two quarterly fire drills per year.

This is a Severity Level IV violation (Supplement I).