

NSP

NORTHERN STATES POWER COMPANY

MINNEAPOLIS, MINNESOTA 55401

August 3, 1977

Mr D K Davis, Acting Chief
Operating Reactors Branch No. 2
Division of Operating Reactors
c/o Distribution Services Branch, DDC, ADM
U S Nuclear Regulatory Commission
Washington, DC 20555



Regulatory

File Cy.

Dear Mr Davis:

MONTICELLO NUCLEAR GENERATING PLANT
Docket No. 50-263 License No. DPR-22

Corrected Information on
Reactor Vessel Material Surveillance Program

Our letter to you dated July 22, 1977 provided you with a copy of a General Electric Report entitled, "Reactor Vessel Material Surveillance Program." Very recently, General Electric has received additional information on electroslag welds in some BWR vessels which modifies the report. The overall conclusions reached in the report, however, remain unchanged.

A copy of the revised report is attached.

Yours very truly,

L O Mayer, PE
Manager of Nuclear Support Services

LOM/DDM/ak

Attachment

cc: J G Keppler
G Charnoff
MPCA - Attn: J W Ferman

9106100526 770803
PDR ADDCK 05000263
P PDR

772200249

Attachment
NSP letter dated August 3, 1977
L O Mayer, NSP, to D K Davis, USNRC

REACTOR VESSEL MATERIAL SURVEILLANCE PROGRAM

Reference: Letter, D K Davis, NRC to L O Mayer, NSP,
dated 5/20/77

The referenced letter has requested the Monticello Nuclear Generating Plant to provide a detailed list of materials relative to the reactor pressure vessel. The staff's concern is that the materials used in reactor vessel fabrication may have a wider variation in sensitivity to radiation damage than originally anticipated. In addition, some reactor vessels incorporate more than one heat of materials, including weld materials in their belt line region, but all of these heats may not be included in the reactor vessel material surveillance program. The purpose of this paper is to show that General Electric's program of reactor vessel surveillance is completely responsive to 10CFR50, Appendix H. Further, it will be shown that the effect on adjusted reference temperature for the most adverse materials in BWR/2 through BWR/4 plants irradiated to the maximum 40-year fluence observed is very small.

General Electric has addressed the problem of obtaining representative surveillance specimens since the beginning of its reactor pressure vessel surveillance program. The material for base metal specimens has been taken from a plate used in the vessel beltline region or from a plate of the same heat of material. The same plate used for base metal specimens is used for production of heat-affected zone specimens, and the weld specimens are produced by the identical weld practice and procedures used in the vessel fabrication. For vessels constructed from plate, the vessel longitudinal welds are represented; while for vessels fabricated from forged rings, the girth welds are represented. When widely varying weld practices such as submerged metal arc and electroslag welding are used jointly in a vessel, both are represented in the surveillance program material. Thus, the surveillance specimens do represent the materials and processing of the vessel beltline region.

The procedures described above were used to select surveillance materials and to prepare specimens for all operating BWR 2 through 4 plants. Examination of this method of selection, even in light of the most recent data, reveals that the reactor pressure vessel surveillance specimens currently in use still provide a reasonable representation of the limiting materials in the reactor vessel beltline region.

The production of the vessel beltline region is generally accomplished by the welding of several plates and, most often, several heats of steel are involved. The vessel surveillance specimens are produced from one of these heats. The possible variation of the other beltline heats, however, is limited by the characteristic range of compositions resulting from the material production practices. Consultation with the domestic heavy-section pressure vessel steel mill, Lukens Steel, concerning process capability and a survey of 10 BWR vessels reveals that the residual element of major importance, copper, lies consistently within the 0.15 to 0.20 weight percent range when special low-copper scrap selection procedures are not invoked on the mill process.

Examination of the predicted effect of residual element composition on the irradiation behavior of pressure vessel steels as provided in Regulatory Guide 1.99 and a preliminary analysis of GE data in the BWR fluence range from 10 operating BWR's representing copper contents in the range .01 to 0.30 weight percent and phosphorous contents in the range .007 to 0.02 weight percent reveals a minimal impact due to the possible variation in base metal composition that could be present in the vessel beltline. Data at the upper end of the copper range (0.30%) was obtained from an atypical source. It represents a foreign plant with a forged ring produced by foreign practice. It does, however, provide additional support for predicting the maximum effect of elevated copper contents.

For most operating BWR 2 through 4 vessels, with some exceptions, the predicted end of 40-year life fluence at the vessel wall 1/4T location is below 2×10^{18} nvt (> 1 MeV). For this fluence range, an estimated end of life variance of approximately 15°F in transition temperature shift would be indicated for a copper composition range of 0.15 to 0.20 weight percent copper. This variance represents the expected deviation in predicted transition temperature shift due to compositional differences. That is, at the end of life fluence, the predicted shift in transition temperature could vary by 15°F depending on the composition of the heat of plate material in question. Thus, even with the maximum predicted variability of copper content for the beltline plate material, a minimal variation in predicted transition temperature shift is expected.

For the one plant with a predicted 1/4T fluence value of 3×10^{18} nvt (> 1 MeV) at the end of life, the effect of the maximum expected variation of copper content would be approximately a 30°F variation in predicted transition temperature shift. This variation, while larger than that expected for all other operating BWR/2 through 4 plants is not prohibitively large, particularly since it represents the worst case of surveillance specimens with 0.15% Cu while other heats in the beltline contain 0.20% copper.

Similarly, the variability of weld metal properties within the beltline region does not present a major obstacle to their effective representation by the current surveillance specimens. Typically, the range of residual element compositions present in weld metal falls within several major bands determined by weld process, electrode coating, and flux type. This variability inherent to process characteristic is already taken into account by the fact that the identical weld process and procedures used in vessel manufacture are used to produce the surveillance weld specimens. The copper content range resulting strictly from heat to heat variations of filler metal composition within a given process, however, would still require the surveillance specimens to adequately represent a limited range of weld metal composition which could be present in the vessel beltline region when more than one heat of filler metal was used for fabrication of this region.

Discussions with the major reactor pressure vessel fabricators and a survey of weld practices used in 10 BWR pressure vessels has characterized the ranges of copper contents expected for the weld metal in the vessel beltline. The copper content range for electroslag welds and submerged arc welds made without copper coated electrodes is expected to be 0.15 to 0.20 weight percent copper. For shielded metal arc welds, a copper content of less than 0.15 weight percent should result; while for submerged metal arc welds made with copper coated

electrodes, a typical range of 0.25 to 0.30 weight percent copper with maximum outside limits of 0.20 to 0.40 weight percent would be expected.

The net effect of the characteristic variations in copper content for each of these weld procedures can be estimated by the prediction methods of Regulatory Guide 1.99 and by the preliminary analysis of extensive GE data in the BWR fluence range. The shielded metal arc welds, electroslag welds, and submerged metal arc welds made without copper coated electrodes would exhibit approximately a 10 to 50°F variation in transition temperature response due to residual element composition at the maximum 1/4T end-of-life fluence expected for BWR/2, 3 and 4 plants.

For submerged metal arc welds made with copper coated electrodes, a larger variation is expected. The typical copper content of 0.25 to 0.3 weight percent exhibited by these welds would result in a 25°F variation in transition temperature shift at 2×10^{18} nvt (>1 MeV). The maximum range of copper contents exhibited by this process (0.20 to 0.40 weight percent) would result in approximately a 50°F variation in transition temperature at the 2×10^{18} nvt 1/4T end-of-life fluence value. Because of the steps taken to assure duplication of the exact vessel weld procedure and welding parameters in making the surveillance weld, however, the typical range of 0.25 to 0.30 weight percent rather than the maximum process range of 0.20 to 0.40 weight percent should be expected to characterize the variation between surveillance samples and vessel welds for any given vessel. Thus, a variation of approximately 25°F would be the best estimate of the variation in transition temperature response for submerged metal arc welds made with copper coated filler wires at end-of-life due to compositional variations between the weld metal in the surveillance samples and the actual welds in the pressure vessel.

Based on the preceding discussion, the selection of materials for the reactor pressure vessel surveillance programs in BWR 2, 3 and 4's does reasonably represent the materials in the beltline region of the vessel. The steps taken by General Electric to assure adequate representation of the welds process and all subsequent material processing steps seen by the vessel materials limits the only possible variation between surveillance specimens and vessel material to the heat to heat variability of base metal and weld metal. The net, end of 40-year life effect of these possible variations, is projected to be only a 10° to 25°F variability in the predicted transition temperature shift for the BWR fluence range. Included in the analysis of the behavioral variations due to compositional variations is a major factor of conservatism. The maximum expected composition range for each material condition is used as a basis for the estimated effects of composition. Rarely will the heat of surveillance sample material happen to fall at the exact bottom of the expected copper content range while the vessel materials from the other heats in the beltline fall at the top of the same copper range. Thus, the estimated effects projected in this paper will tend to be minimized by the actual conditions in the field.

Although it is still important to know the residual element composition of the vessel steel and surveillance specimens for complete analysis of surveillance test results, this information can easily be obtained by chemical analysis of archive material and analysis of specimens at the time of testing. General Electric believes that the steps taken during the production of BWR pressure vessel surveillance specimens adequately assure reasonable representation of the vessel material and that any variations in irradiation behavior between the surveillance materials and additional heats of vessel materials would be minimal in the BWR fluence range.

NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL

FILE NUMBER

TO:
Mr. D. K. Davis

FROM:
Northern States Power Company
Minneapolis, Minnesota
L. O. Mayer

DATE OF DOCUMENT
8/3/77

DATE RECEIVED
8/8/77

LETTER
 ORIGINAL
 COPY

NOTORIZED
 UNCLASSIFIED

PROP

INPUT FORM

NUMBER OF COPIES RECEIVED

100

DESCRIPTION

RE TRAIL 7-22-77

ACKNOWLEDGED

DO NOT REMOVE (1-P)

ENCLOSURE

Consists of revised report "Reactor Vessel Material Surveillance Program".....

(3-P)

PLANT NAME: Monticello
RJL 8/8/77

SAFETY	FOR ACTION/INFORMATION	ENVIRONMENTAL
ASSIGNED AD:		ASSIGNED AD: V. MOORE (LTR)
BRANCH CHIEF:	DAVIS	BRANCH CHIEF:
PROJECT MANAGER:	SWAIDER	PROJECT MANAGER:
LICENSING ASSISTANT:	Biggs	LICENSING ASSISTANT:
Zwetzig		B. HARLESS

INTERNAL DISTRIBUTION			
REG FILES	SYSTEMS SAFETY	PLANT SYSTEMS	SITE SAFETY & ENVIRON ANALYSIS
T & P (2)	HEINEMAN	TEDESCO	DENTON & MULLER
FIELD	SCHROEDER	BENAROYA	CRUTCHFIELD
GOSSICK & STAFF	ENGINEERING	LAINAS	
HANAHER	KNIGHT	IPPOLITO	ENVIRO TECH.
MTPC	BOSNAK	F. ROSA	ERNST
CASE	SIHWELL	OPERATING REACTORS	BALLARD
BOYD	PAWLICKI	STELLO	YOUNGBLOOD
		EISENHUT	
PROJECT MANAGEMENT	REACTOR SAFETY	SHAO	SITE TECH.
SKOVHOLT	ROSS	BAER	GAMMILL (2)
P. COLLINS	NOVAK	BUTLER	
HOUSTON	ROSZTOCZY	GRIMES	SITE ANALYSIS
MELTZ	CHECK	Hazleton	VOLLMER
HEITEMES		HOGE	BUNCH
SK	AT&I	R. GAMBLE	J. COLLINS
	SALTZMAN	RANDALL	KREGER
	RUTBERG		

EXTERNAL DISTRIBUTION	CONTROL NUMBER
LPDR: Minneapolis, MN	
TIC NSIC	
NAT LAB	
REG IV (J. HANCHETT)	
16 CYS ACRS SENT CATEGORY	
	772200249
	B