

ATTACHMENT 2

PROPOSED TEST FREQUENCY FOR MEGGER TESTING (Cont.)

MOTOR CONTROL CENTERS

- Feeder cables to safety related and non-safety related MCC:
Every third refuel or every 5 years

MISCELLANEOUS

- Feeder cables to non-safety and safety-related miscellaneous loads fed from unit substations (480 VAC), motor control centers (480 VAC) and DC switchgear (125 VDC).
Every third refuel or every 5 years