PROPOSED TECHNICAL SPECIFICATION CHANGES

3/4.2 POWER DISTRIBUTION LIMITS 3/4,2,1 LINEAR HEAT RATE LIMITING CONDITION FOR OPERATION 3.2.1 The linear heat rate limit shall be maintained by either: Maintaining COLSS calculated core power less than or equal to COLSS calculated core power operating limit based on linear heat rate (when COLSS is in service); or Operating within the region of acceptable operation of Figure 3.2-1 using any operable CPC Channel (when COLSS is out of service). APPLICABILITY: MODE 1 above 20% of RATED THERMAL POWER. ACTION: With COLSS in service and the linear heat rate limit not being maintained as indicated by COLSS calculated core power exceeding the COLSS calculated core power operating limit based on linear heat rate, within 15 minutes initiate corrective action to reduce the linear heat rate to within the limit and either: 1. Restore the linear heat rate to within its limits within I hour of the initiating event, or Reduce THERMAL POWER to less than or equal to 20% of RATED THERMAL POWER within the next 6 hours. With COLSS out of service and the linear heat rate limit not being maintained as indicated by operation outside the region of acceptable operation in Figure 3.2-1, either: Restore the linear heat rate to within its limits within 2 hours of the initiating event, or Reduce THERMAL POWER to less than or equal to 20% of RATED THERMAL POWER within the next 6 hours. SURVEILLANCE REQUIREMENTS 4.2.1.1 The provisions of Specification 4.0.4 are not applicable. 4.2.1.2 The linear heat rate shall be determined to be within its limits when THERMAL POWER is above 20% of RATED THERMAL POWER by continuously monitoring the core power distribution with the Core Operating Limit Supervisory System (COLSS) or, with the COLSS out of service, by verifying at least once per 2 hours that the linear heat rate, as indicated on any OPERABLE CPC channel, is within the limit shown on Figure 3.2-1. 4.2.1.3 At least once per 31 days, the COLSS Margin Alarm shall be verified to actuate at a THERMAL POWER level less than or equal to the core power operating limit based on linear heat rate. Amendment No. 24, 79 3/4 2-1 ARKANSAS - UNIT 2

# POWER DISTRIBUTION LIMITS

## DNBR MARGIN

### LIMITING CONDITION FOR OPERATION

- The DNBR limit shall be maintained by one of the following 3.2.4 methods:
  - Maintaining COLSS calculated core power less than or equal to A. COLSS calculated core power operating limit based on DNBR (when COLSS is in service, and at least one CEAC is operable); or
  - Maintaining COLSS calculated core power less than or equal to b. COLSS calculated core power operating limit based on DNBR decreased by 13.0% (when COLSS is in service and neither CEAC is operable); or
  - Operating within the region of acceptable operation of Figure 0. 3.2-2 using any operable CPC channel (when COLSS is out of service and at least one CEAC is operable); or
  - Operating within the region of acceptable operation of Figure d. 3.2-3 using any operable CPC channel (when COLSS is out of service and neither CEAC is operable).

APPLICABILITY: MODE 1 above 20% of RATED THERMAL POWER.

#### ACTION:

- With COLSS in service and the DNBR limit not being maintained as indicated by COLSS calculated core power exceeding the COLSS calculated core power operating limit based on DNBR, within 15 minutes initiate corrective action to reduce the DNBR to within the limits and either:
  - Restore the DNBR to within its limits within 1 hour of tha initiating event, or
  - Reduce THERMAL POWER to less than or equal to 20% of RATED THERMAL POWER within the next 6 hours.
- With COLSS out of service and the DNBR limit not being maintained as indicated by operation outside the region of acceptable operation in Figure 3.2-2 or 3.2-3 as applicab , either:
  - Restore the DNBR to within its limits within 2 hours of the initiating event, or
  - Reduce THERMAL POWER to less than or equal to 20% of RATED THERMAL POWER within the next 6 hours.

### SURVEILLANCE REQUIREMENTS

4.2.4.1 The provisions of Specification 4.0.4 are not applicable.