

Vermont Yankee Nuclear Power Station  
Cycle 16  
Core Operating Limits Report  
Revision 0

February 1992

Reviewed 92-12 JML/WMA 3-5-92  
Plant Operations Date  
Review Committee

Approved R. J. Godin for PDR 3-5-92  
Plant Manager Date

Approved W. J. Murphy 3/16/92  
Senior Vice President Date  
Operations

Controlled Copy No. \_\_\_\_\_

R40\8

9204030095 920331  
PDR ADOCK 05000271  
P PDR

REVISION RECORD

<u>Cycle</u>	<u>Revision</u>	<u>Date</u>	<u>Description</u>
14	0	10/89	Initial printing. Reviewed by PORC and approved by management.
15	0	9/90	Cycle 15 revisions. Reviewed by PORC and approved by management.
15	1	11/91	Incorporate new MCPR limits to allow operation within the exposure window. Reviewed by PORC and approved by management.
16	0	3/92	Cycle 16 revisions. Reviewed by PORC and approved by management.

ABSTRACT

This report presents the cycle-specific operating limits for the operation of Cycle 16 of the Vermont Yankee Nuclear Power Station. The limits are the maximum average planar linear heat generation rate, maximum linear heat generation rate, and minimum critical power ratio.

TABLE OF CONTENTS

	<u>Page</u>
REVISION RECORD . . . . .	ii
ABSTRACT . . . . .	iii
LIST OF TABLES . . . . .	v
LIST OF FIGURES . . . . .	vi
1.0 INTRODUCTION . . . . .	1
2.0 CORE OPERATING LIMITS . . . . .	2
2.1 Maximum Average Planar Linear Heat Generation Rate Limits . . . . .	2
2.2 Minimum Critical Power Ratio Limits . . . . .	3
2.3 Maximum Linear Heat Generation Rate Limits . . . . .	3
3.0 REFERENCES . . . . .	11

LIST OF TABLES

<u>Number</u>	<u>Title</u>	<u>Page</u>
Table 2.1-1	MAPLHGR Versus Average Planar Exposure for BD324B Fuel	4
Table 2.1-2	MAPLHGR Versus Average Planar Exposure for BD326B Fuel	5
Table 2.1-3	MAPLHGR Versus Average Planar Exposure for BP8DWB311-10GZ and ANF-IX-3.04B-EGZ Fuel	6
Table 2.1-4	MAPLHGR Versus Average Planar Exposure for BP8DWB311-11GZ Fuel	7
Table 2.2-1	Minimum Critical Power Ratio Operating Limits	8
Table 2.3-1	Maximum Allowable Linear Heat Generation Rate Limits	9

LIST OF FIGURES

<u>Number</u>	<u>Title</u>	<u>Page</u>
Figure 2.2-1	$K_f$ Versus Percent of Rated Core Flow Rate	10

## 1.0 INTRODUCTION

This report provides the cycle-specific limits for operation of the Vermont Yankee Nuclear Power Station in Cycle 16. It includes the limits for the maximum average planar linear heat generation rate, maximum linear heat generation rate, and minimum critical power ratio. If any of these limits are exceeded, action will be taken as defined in the Technical Specifications.

This report has been prepared in accordance with the requirements of Technical Specification 6.7.A.4. The core operating limits have been developed using the NRC-approved methodologies listed in References 1 through 16 and in Technical Specification 6.7.A.4. The bases for these limits are in References 11 and 12, and 17 through 20.

## 2.0 CORE OPERATING LIMITS

The Cycle 16 operating limits have been defined using NRC-approved methodologies. The Cycle 16 must be operated within the bounds of these limits and all others specified in the Technical Specifications.

### 2.1 Maximum Average Planar Linear Heat Generation Rate Limits

During steady-state power operation, the Maximum Average Planar Linear Heat Generation Rate (MAPLHGR) for each fuel type, as a function of the average planar exposure, shall not exceed the limiting values shown in Tables 2.1-1 through 2.1-4. For single recirculation loop operation, the limiting values shall be the values from these Tables listed under the heading "Single Loop Operation." These values are obtained by multiplying the values for two loop operation by 0.83. The source of these values is identified on each table. These tables only list the limits for fuel types in Cycle 16. The ANF-IX bundle will be monitored as if it were a BP8DWB311-10GZ bundle. Therefore, the limits for the ANF-IX bundle are the same as the BP8DWB311-10GZ bundle.

The MAPLHGR values are the most limiting composite of the fuel mechanical design analysis MAPLHGR and the ECCS MAPLHGR. The fuel mechanical design analysis, using the methods in Reference 12, demonstrates that all fuel rods in a lattice, operating at the bounding power history, meet the fuel design limits specified in Reference 12. The LOCA analysis performed in accordance with 10CFR50, Appendix K, demonstrates that the MAPLHGR values comply with the ECCS limits specified in 10CFR50.46.

The MAPLHGR actually varies axially, depending upon the specific combination of enriched uranium and gadolinia that comprises a fuel bundle cross section at a particular axial node. Each particular combination of



enriched uranium and gadolinia is called a lattice type. Each lattice type has a set of MAPLHGR values that vary with fuel burnup. The process computer will verify that these lattice MAPLHGR limits are not violated. Tables 2.1-1 through 2.1-4 provide a limiting composite of MAPLHGR values for each fuel type, which envelope the lattice MAPLHGR values employed by the process computer. When hand calculations are required, these MAPLHGR values are used for all lattices in the bundle.

## 2.2 Minimum Critical Power Ratio Limits

During steady-state power operation, the Minimum Critical Power Ratio (MCPR) shall be equal to, or greater than, the limits shown in Table 2.2-1. The MCPR limits are also valid during coastdown beyond 9845 MWd/St.

For single recirculation loop operation, the MCPR limits at rated flow shall be the values from the Table listed under the heading, "Single Loop Operation." The single loop values are obtained by adding 0.01 to the two loop operation values. For core flows other than the rated condition, the MCPR limit shall be the appropriate value from Table 2.2-1 multiplied by  $K_f$ , where  $K_f$  is given in Figure 2.2-1 as a function of the flow control method in use. These limits are only valid for the fuel types in Cycle 16.

## 2.3 Maximum Linear Heat Generation Rate Limits

During steady-state power operation, the Linear Heat Generation Rate (LHGR) of any rod in any fuel bundle at any axial location shall not exceed the maximum allowable LHGR limits in Table 2.3-1. The ANF-IX bundle will be monitored as if it were a BP8DWB311-10GZ bundle. Therefore, the limits for the ANF-IX bundle are the same as the BP8DWB311-10GZ bundle. This table only lists the limits for fuel types in Cycle 16.

Table 2.1-1

MAPLHGR Versus Average Planar Exposure for BD324B Fuel

Plant: Vermont Yankee

Fuel Type: BD324B

Average Planar Exposure (MWd/ST)	MAPLHGR (kW/ft)	
	<u>Two Loop Operation</u>	<u>Single Loop Operation*</u>
200.0	11.22	9.31
3,000.0	11.83	9.81
8,000.0	12.69	10.53
10,000.0	12.80	10.62
15,000.0	12.74	10.57
20,000.0	12.05	10.00
25,000.0	11.39	9.45
35,000.0	10.12	8.39
45,000.0	8.46	7.02
50,000.0	5.99	4.97

Source: NEDE-21697, Supplement 1, November 1987, Reference 11.

Technical Specification References: 3.6.G.1a and 3.11.A.

---

\* MAPLHGR for single loop operation is obtained by multiplying MAPLHGR for two loop operation by 0.83.

Table 2.1-2

MAPLHGR Versus Average Planar Exposure for B0326B Fuel

Plant: Vermont Yankee

Fuel Type: B0326B

<u>Average Planar Exposure (Mwd/ST)</u>	<u>MAPLHGR (kW/ft)</u>	
	<u>Two Loop Operation</u>	<u>Single Loop Operation*</u>
200.0	11.26	9.34
3,000.0	11.72	9.72
8,000.0	12.76	10.59
10,000.0	12.90	10.70
15,000.0	12.82	10.64
20,000.0	12.12	10.05
25,000.0	11.44	9.49
35,000.0	10.15	8.42
45,000.0	8.63	7.16
50,000.0	6.17	5.12

Source: NEDE-21697, Supplement 1, November 1987, Reference 11.

Technical Specification References: 3.6.G.1a and 3.11.A.

---

\* MAPLHGR for single loop operation is obtained by multiplying MAPLHGR for two loop operation by 0.83.

Table 2.1-3

MAPLHGR Versus Average Planar Exposure for BP8DWB311-10GZ  
and ANF-IX-3.04B-EGZ Fuel

Plant: Vermont Yankee

Fuel Type: BP8DWB311-10GZ  
ANF-IX-3.04B-EGZ

<u>Average Planar Exposure (MWd/ST)</u>	<u>MAPLHGR (kW/ft)</u>	
	<u>Two Loop Operation</u>	<u>Single Loop Operation*</u>
200.0	11.00	9.13
6,000.0	11.92	9.89
7,000.0	12.11	10.05
8,000.0	12.34	10.24
10,000.0	12.83	10.64
12,500.0	13.00	10.79
20,000.0	12.24	10.15
25,000.0	11.55	9.58
45,000.0	8.76	7.27
50,740.0	5.91	4.90

Source: NEDE-21697, Supplement 2, May 1990, Reference 11, and ANF-90-048, Reference 19.

Technical Specification References: 3.6.G.1a and 3.11.A.

---

\* MAPLHGR for single loop operation is obtained by multiplying MAPLHGR for two loop operation by 0.83.

Table 2.1-4

MAPLHGR Versus Average Planar Exposure for BP8DWB311-11GZ Fuel

Plant: Vermont Yankee

Fuel Type: BP8DWB311-11GZ

<u>Average Planar Exposure (MWd/ST)</u>	<u>MAPLHGR (kW/ft)</u>	
	<u>Two Loop Operation</u>	<u>Single Loop Operation*</u>
200.0	11.00	9.13
6,000.0	11.92	9.89
7,000.0	12.11	10.05
8,000.0	12.34	10.24
10,000.0	12.83	10.64
12,500.0	12.90	10.70
15,000.0	12.81	10.63
35,000.0	10.24	8.49
45,000.0	8.76	7.27
50,740.0	5.91	4.90

Source: NEDE-21697, Supplement 2, May 1990, Reference 11.

Technical Specification References: 3.5.G.1a and 3.11.A.

---

\* MAPLHGR for single loop operation is obtained by multiplying MAPLHGR for two loop operation by 0.83.

Table 2.2-1

Minimum Critical Power Ratio Operating Limits

Value of "N" in RBM Equation (A) <sup>1</sup>	Average Control Rod Scram Time	Cycle Exposure Range	<sup>2</sup> MCPR Operating Limits	
			Two Loop Operation	Single Loop Operation <sup>2</sup>
42%	Equal or better than L.C.O. 3.3 C.1.1	0 to 9845 Mwd/St	1.32	1.33
	Equal or better than L.C.O. 3.3 C.1.2	0 to 9845 Mwd/St	1.32	1.33
41%	Equal or better than L.C.O. 3.3 C.1.1	0 to 9845 Mwd/St	1.28	1.29
	Equal or better than L.C.O. 3.3 C.1.2	0 to 9845 Mwd/St	1.28	1.29
≤40%	Equal or better than L.C.O. 3.3 C.1.1	0 to 9845 Mwd/St	1.23	1.24
	Equal or better than L.C.O. 3.3 C.1.2	0 to 8241 Mwd/St 8241 to 9845 Mwd/St	1.23 1.24	1.24 1.25

Sources: Cycle 16 Core Performance Analysis Report, YAEC-1844, Reference 18, and End-of-Full-Power-Life Sensitivity Study for the Revised BWR Licensing Methodology, YAEC-1822, Reference 20.

Technical Specification References: 3.6.G.1a and 3.11.C.

1 The Rod Block Monitor (RBM) trip setpoints are determined by the equation shown in Table 3.2.5 of the Technical Specifications.

2 MCPR Operating Limits are increased by 0.01 for single loop operation.

Table 2.3-1

Maximum Allowable Linear Heat Generation Rate Limits

<u>Fuel Type</u>	<u>Maximum Allowable Linear Heat Generation Rate (kW/ft)</u>
BD324B	14.4
BD326B	14.4
BP8DWB311-10GZ	14.4
BP8DWB311-11GZ	14.4
ANF-IX-3.04B-EGZ	14.4

Source: NEDE-24011-P-A, Reference 12, and ANF-90-048, Reference 19.

Technical Specification References: 2.1.A.1a, 2.1.B.1, and 3.11.B.




Figure 2.2-1

K<sub>f</sub> Versus Percent of Rated Core Flow Rate  
(Technical Specification Reference 3.11.C)



### 3.0 REFERENCES

1. Report, S. P. Schultz and K. E. St. John, Methods for the Analysis of Oxide Fuel Rod Steady-State Thermal Effects (FROSSTEY) Code/Model Description Manual, YAEC-1249P, April 1981.
2. Report, S. P. Schultz and K. E. St. John, Methods for the Analysis of Oxide Fuel Rod Steady-State Thermal Effects (FROSSTEY): Code Qualifications and Applications, YAEC-1255P, June 1981.
3. Report, A. A. F. Ansari, Methods for the Analysis of Boiling Water Reactors: Steady-State Core Flow Distribution Code (FIBWR), YAEC-1234, December 1980.
4. Report, A. A. F. Ansari and J. T. Cronin, Methods for the Analysis of Boiling Water Reactors: A System Transient Analysis Model (RETRAN), YAEC-1233, April 1981.
5. Report, A. A. F. Ansari, K. J. Burns and D. K. Beller, Methods for the Analysis of Boiling Water Reactors: Transient Critical Power Ratio Analysis (RETRAN-TCPYA01), YAEC-1299P, March 1982.
6. Report, A. S. DiGiovine, et al., CASMO-3G validation, YAEC-1363-A, April 1988.
7. Report, A. S. DiGiovine, J. P. Gorski, and M. A. Tremblay, SIMULATE-3 Validation and Verification, YAEC-1659-A, September 1988.
8. Report, R. A. Woehlike, et al., MICBURN-3/CASMO-3/TABLES-3/SIMULATE-3 Benchmarking of Vermont Yankee Cycles 9 through 13, YAEC-1683-A, March 1989.
9. Report, J. T. Cronin, Method for Generation of One-Dimensional Kinetics Data for RETRAN-02, YAEC-1694-A, June 1989.
10. Report, V. Chandola, M. P. LeFrancois and J. D. Robichaud, Application of One-Dimensional Kinetics to Boiling Water Reactor Transient Analysis Methods, YAEC-1693-A, Revision 1, November 1989.
11. Report, Loss-of-Coolant Accident Analysis for Vermont Yankee Nuclear Power Station, NEDO-21697, August 1977, as amended; NEDE-21697, Supplement 1, November 1987; and NEDE-21697, Supplement 2, May 1990.
12. Report, General Electric Standard Application for Reactor Fuel (GESTARII), NEDE-24011-P-A-10, GE Company Proprietary, February 1991, as amended.
13. Letter, USNRC to VYNPC, SER, November 27, 1981.
14. Letter, USNRC to VYNPC, SER, NVY 82-157, September 15, 1982.

15. Letter, USNRC to VYNPC, SER, NVY 85-205, September 27, 1985.
16. Letter, USNRC to VYNPC, SER, November 30, 1977.
17. Report, Vermont Yankee Nuclear Power Station Single Loop Operation, NEDO-30060, February 1983.
18. Report, M. A. Sironen, Vermont Yankee Cycle 16 Core Performance Analysis Report, YAEC-1844, February 1992.
19. Report, M. E. Garrett, K. D. Hartley, and M. H. Smith, Vermont Yankee 9X9-IX Qualification Fuel Assembly Safety Analysis Report, ANF-90-048, May 1990.
20. Report, B. Y. Hubbard, et al., End-of-Full-Power-Life Sensitivity Study for the Revised BWR Licensing Methodology, YAEC-1822, October 1991.