

ENCLOSURE 1

NOTICE OF VIOLATION

Tennessee Valley Authority
Sequoyah Nuclear Plant

Docket Nos. 50-327 and 50-328
License Nos. DPR-77 and DPR-79

The following violations were identified during an inspection conducted on February 7-10, 1984. The Severity Levels were assigned in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C).

10 CFR 50, Appendix E, Paragraph V requires that licensees who are authorized to operate a nuclear power facility shall submit one copy of any changes to the emergency plan or procedures to the Administrator of the appropriate Regional Office, specified in Appendix D, 10 CFR Part 20, and two copies to the Document Control Desk within 30 days of such changes.

Contrary to the above, revisions to the Central Emergency Control Center Implementing Procedures Document dated November 9, 1983, the Division of Nuclear Power Emergency Center Implementing Procedures Document dated November 9 and November 10, 1983, and the Muscle Shoals Emergency Center Implementing Procedures Document dated October 4, 1983, were sent to the appropriate NRC offices on January 3, 1984.

This is a Severity Level V violation (Supplement I).

Pursuant to 10 CFR 2.201, you are required to submit to this office within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violations; (2) the reasons for the violations if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved.

Security or safeguards information should be submitted as an enclosure to facilitate withholding it from public disclosure as required by 10 CFR 2.790(d) or 10 CFR 73.21.

Date: MAR 05 1984

8405300506 840502
PDR ADOCK 05000327
Q PDR