

U.S. NUCLEAR REGULATORY COMMISSION
FLORIDA POWER CORPORATION
CRYSTAL RIVER UNIT 3 NUCLEAR GENERATING PLANT
DOCKET NO. 50-302

RECEIPT OF PETITION FOR DIRECTOR'S DECISION UNDER 10 CFR 2.206

Notice is hereby given that by Petition of June 25, 1991, Edward S. Wollesen requested that the U.S. Nuclear Regulatory Commission take action regarding the Florida Power Corporation (FPC) Crystal River Unit 3 plant. Petitioner requests that the NRC institute a proceeding in accordance with Section 2.206 of Title 10 of the Code of Federal Regulations (10 CFR 2.206) to suspend or revoke FPC's license for the Crystal River facility or to take such other action as may be proper.

Petitioner asserts as bases for his request the following:

- (1) 1,500 to 3,000 instruments in the plant, most of which are safety-related, are not properly identified and are not in a proper calibration program. There are no controlled calibration data sheets for the instruments, making it impossible to determine if the instruments are within engineering design standards. Moreover, engineering diagrams do not include these instruments, as required by the NRC.
- (2) In recent quality audit reports FPC stated that its security and fire protection programs comply with NRC requirements, although the programs are not sufficiently defined to be auditable in accordance with NRC requirements.

- (3) FPC has not adequately defined and does not know the exact requirements of the technical specifications for the plant.
- (4) Contrary to American National Standards Institute (ANSI) Standard N45.2.10-1973, the FPC Plant Review Committee Guidelines Manual, an uncontrolled manual, includes mandatory instructions for nuclear operations.
- (5) There is no assurance that safety-related instruments are in calibration. When informed of this problem, plant management ignored it.


Petitioner asserts that these deficiencies render ineffective the quality assurance program, the fire protection program, and other programs critical to nuclear safety.

The Petition has been referred to the Director of the Office of Nuclear Reactor Regulation pursuant to 10 CFR 2.206. As provided by Section 2.206, appropriate action will be taken with regard to the specific issues raised by the Petition within a reasonable time.

A copy of the Petition is available for inspection at the Commission's Public Document Room at 2120 L Street, NW., Washington, DC 20555, and at the local public document room for the Crystal River facility located at the Coastal Region Library, 8619 W. Crystal Street, Crystal River, Florida 32629.

Dated at Rockville, Maryland this 31 day of July , 1991.

FOR THE NUCLEAR REGULATORY COMMISSION



Thomas E. Murley, Director
Office of Nuclear Reactor Regulation