



GPU Nuclear Corporation
Post Office Box 388
Route 9 South
Forked River, New Jersey 08731-0388
609 971-4000
Writer's Direct Dial Number:

May 17, 1984

Mr. Dennis M. Crutchfield, Chief
Operating Reactors Branch #5
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Crutchfield:

Subject: Oyster Creek Nuclear Generating Station
Docket No. 50-219
SEP Topic No. III-4B Turbine Missiles

During the integrated assessment of the subject SEP topic, GPUN agreed to provide a volumetric inspection frequency for low pressure turbine discs based on the results of the inspection conducted by General Electric in 1983. The safety objection of this SEP topic is to ensure that the structures, systems, and components important to safety have adequate protection against potential turbine missiles either because of structural barriers or a high degree of assurance that failures at design or destructive overspeed will not occur.

In April and June, 1983, inspections were performed by General Electric on the shrunk-on wheels from LPA, LPB and LPC rotors. Included were a visual examination, and ultrasonic examinations of the tangential entry dovetails, wheel bores and keyways. The ultrasonic examination on wheel bores and keyways showed indications. However, General Electric concluded that they do not affect the structural integrity of the wheels and keyways. GPU Nuclear reviewed their evaluation and concurred with their conclusion.

8405300683 840517
PDR ADCK 05000219
Q PDR

A035
1/0

Based on the examination, General Electric recommended GPUN perform a complete ultrasonic inspection of the LPA, LPB and LPC wheels after approximately 6 years of additional operation. It was also recommended that a magnetic particle inspection of the exterior wheel surfaces be conducted.

GPUN will follow the recommendations made by General Electric and perform the ultrasonic and magnetic particle inspection within 6 years of additional operation.

Very truly yours,



P. B. Fiedler
Vice President and Director
Oyster Creek

PBF/slk

cc: Administrator
Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

NRC Resident Inspector
Oyster Creek Nuclear Generating Station
Forked River, NJ 08731