



Westinghouse
Electric Corporation

Energy Systems

Box 355
Pittsburgh Pennsylvania 15230-0355

July 29, 1991
ET-NRC-91-3612
ET-NSL-OPL-I-91-439

US Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

Attention: Mr. J. E. Richardson
Director, Division of Engineering & Systems Technology

Subject: North Anna Unit 1 Steam Generator Operating Cycle Evaluation

Dear Mr. Richardson:

Enclosed are ten copies of Westinghouse Report No. NSD-TAP-1093, "North Anna Unit 1 Operating Cycle Evaluation" (Proprietary) which is to be used for the review of the condition of the North Anna Unit 1 steam generators with ongoing tube wall degradation.

The enclosed report contains information which is proprietary to Westinghouse Electric Corporation. Accordingly, we request that this information be withheld from public disclosure.

We will comply with the requirements of 10 CFR 2.790 to provide proprietary and non-proprietary versions of the above material together with an affidavit as soon as the proprietary information contained in the submittal has been specifically identified and the proprietary and non-proprietary versions have been prepared. We will submit the total required number of copies of the proprietary and non-proprietary versions of the information and the required affidavit at that time.

In the meantime, we have provided sufficient copies for your information and use. Mr. M. P. Siemien, Esq., of the NRC Office of the General Counsel, has advised Westinghouse that he concurs with this procedure.

9108090174 910806
PDR ADOCK 05000338
PDR


0213J:DLG/072991

ET-NRC-91-3612
July 29, 1991
Page 2

We expect to be able to fully comply with the requirements for the proprietary and non-proprietary versions of the information and an accompanying affidavit within four weeks.

Very truly yours,

WESTINGHOUSE ELECTRIC CORPORATION



S. R. Tritch, Manager
Engineering Technology

Enclosures

cc: M. P. Siemien, Esq.
Office of the General Counsel, NRC

M. Fields, 1L, 1A
M. Chatterton, 1L, 1A
T. E. Collings, 1L, 1A