

RBS FSAR


ENVIRONMENTAL QUALIFICATION DOCUMENT

Remove and replace existing pages, including the front and back covers and the spine, with the new material provided.

With this amendment, The Environmental Qualification Document is no longer part of the FSAR and is considered a separate document.

8405310098 840525
PDR ADOCK 05000458
A PDR

RIVER BEND STATION ENVIRONMENTAL QUALIFICATION DOCUMENT



RIVER BEND
STATION
ENVIRONMENTAL
QUALIFICATION
DOCUMENT



RIVER BEND STATION ENVIRONMENTAL QUALIFICATION DOCUMENT



RBS EQD

TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1-1
2	ENVIRONMENTAL CONDITIONS	2-1
2.1	TEMPERATURE, PRESSURE, HUMIDITY ENVIRONMENT	2.1-1
2.2	RADIATION ENVIRONMENT	2.2-1
2.3	CHEMICAL ENVIRONMENT	2.3-1
2.4	SUBMERGENCE	2.4-1
3	FUNCTIONAL PERFORMANCE REQUIREMENTS	3.1-1
3.1	ACCIDENT/SYSTEM MATRIX	3.1-1
3.2	POST-ACCIDENT OPERABILITY TIME	3.2-1
4	QUALIFICATION METHODOLOGY	4.1-1
4.1	HARSH ENVIRONMENT	4.1-1
4.1.1	BOP Equipment	4.1-1
4.1.1.1	Electrical	4.1-1
4.1.1.2	Mechanical	4.1-4
4.1.2	NSSS Equipment	4.1-6
4.1.2.1	Electrical	4.1-6
4.1.2.2	Mechanical	4.1-8
4.2	MILD ENVIRONMENT	4.2-1
4.2.1	BOP Equipment	4.2-2
4.2.2	NSSS Equipment	4.2-2
5	QUALIFICATION DOCUMENTATION	5.1-1
5.1	MASTER LISTS (ML)	5.1-1
5.2	SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEET	5.2-1
5.3	AUDITABLE FILE	5.3-1
6	MAINTENANCE/SURVEILLANCE PROGRAM	6-1
7	REFERENCES	7-1
APPENDIXES		
A	EQUIPMENT QUALIFICATION DATA MASTER LISTS	
A.1	SAFETY-RELATED ELECTRICAL EQUIPMENT - BOP	
A.2	SAFETY-RELATED ELECTRICAL EQUIPMENT - NSSS	
A.3	SAFETY-RELATED MECHANICAL EQUIPMENT - BOP	

TABLE OF CONTENTS (Cont)

<u>Section</u>	<u>Title</u>	<u>Page</u>
A.4	SAFETY-RELATED MECHANICAL EQUIPMENT - NSSS	
B	SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEETS	

RBS EQD

LIST OF TABLES

<u>Table Number</u>	<u>Title</u>
2-1	STANDARDIZED HARSH ENVIRONMENTAL ZONE DESCRIPTIONS
2-2	STANDARDIZED MILD ENVIRONMENTAL ZONE DESCRIPTIONS
2-3	PLANT ZONES
2.4-1	CLASS 1E EQUIPMENT SUBJECTED TO SUBMERGENCE ZONES CT-SF. CT-2
3.1-1	SYSTEMS AND SUBSYSTEMS REQUIRED TO MITIGATE ACCIDENT
3.1-2	ACCIDENT/SYSTEM MATRIX
3.1-3	SWEC/GE SYSTEM CROSS REFERENCE
3.1-4	SYSTEMS ASSOCIATED WITH CONTAINMENT ISOLATION
3.1-5	SYSTEMS INCLUDED IN THE STANDBY POWER SYSTEM
4.1-1	ACTIVE SAFETY-RELATED MECHANICAL EQUIPMENT CATEGORIES
5.1-1	ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
5.1-2	MANUFACTURER NAMES AND MANUFACTURER CODES
5.1-3	EMERGENCY CONDITION CODES
5.1-4	SAFETY FUNCTION CODES
5.1-5	OPERABILITY CODES

RBS EQD

LIST OF FIGURES

<u>Figure Number</u>	<u>Title</u>
2-1	ENVIRONMENTAL ZONE MAP
2-2	ENVIRONMENTAL ZONE MAP
2-3	ENVIRONMENTAL ZONE MAP
2-4	ENVIRONMENTAL ZONE MAP
5.1-1	RBS EQD MASTER LIST HEADING FORMAT
5.2-1	EQD SCEW SHEET

RBS EQD

SECTION 1

INTRODUCTION

The purpose of this document is to establish the methodologies and summarize the results of the environmental qualification program for River Bend Station. The information supports Section 3.11 of the Final Safety Analysis Report (FSAR) and is provided in accordance with 10CFR50.49 and the guidance of Appendix E, NUREG 0588, Interim Staff Position on Environmental Qualification of Safety-Related Electrical Equipment, December 1979.

SECTION 2

ENVIRONMENTAL CONDITIONS

The Environmental Design Criteria (EDC)⁽¹⁾ document specifies the indoor environmental design conditions for River Bend Station for normal, abnormal, and accident conditions.

The scope of the EDC is limited to establishing the environmental conditions of temperature, pressure, humidity, and radiation (beta, gamma, and neutron). Seismic and hydrodynamic loading conditions are not within the scope of the EDC.

The data of this document summarize the environmental conditions which have been used to establish the design basis for the plant. The data do not contain margin.

Tables 2-1, 2-2, and 2-3 list and describe the harsh and mild environmental zones. Illustrations of the physical zones are provided in the environmental zone maps, Figures 2-1 through 2-4.

The environmental data for temperature, pressure, humidity, and radiation are defined in the EDC for each building zone. Data are listed for normal operating conditions, abnormal operating conditions, and for the accident event that impacts the zone ambient environment. Normal conditions list maximum, minimum, and applicable average conditions. The duration column is applicable to the abnormal and accident conditions. Frequency is indicated for the abnormal condition only.

TABLE 2-1

STANDARDIZED HARSH ENVIRONMENTAL ZONE DESCRIPTIONS

<u>Zone</u>	<u>Description</u>
<u>Drywell</u>	
DW-1	Outside RPV Shield Wall, Outside DW-2 (El 81'-3/4" to 162'-3")
DW-2	Outside RPV Shield Wall, to a radius of 17'-0" from RPV centerline (El 110'-0" to 122'-0")
DW-3	Under RPV (El 73'-1/4" to 102'-0")
DW-4	Drywell Dome (El 162'-3" to 175'-3 3/4")
DW-5	Outside RPV Skirt (El 100'-8" to 108'-6")
DW-6	Between RPV Insulation and Primary (Biological) Shield Wall (El 108'-6" to 147'-6")
<u>Containment</u>	
CT-1	Upper Containment Dome (El 235'-0" to 256'-3")
CT-2	Immediately Above Suppression Pool (El 90'-0" to 114'-0")
CT-3	HCU Floor (El 114'-0" to 141'-0")
CT-4	SLCS Areas (El 141'-0" to 162'-3")
CT-5	WCS Area - Backwash Receiving Tank and Pump Cubicles (El 141'-0" and 162'-3")
CT-5A	Walkway Adjacent to Zone CT-5
CT-6	Drywell Personnel Hatch Area (El 130'-7")
CT-7	WCS Heat Exchanger Cubicle (El 141'-0" to 162'-3", AZ-327° to 33°)
CT-7A	Walkway Adjacent to Zone CT-7
CT-8	Fuel Transfer Tube, Isolation Valve Room (El 128'-1 3/4")
CT-9	Inside Main Steam Tunnel (El 114'-0")
CT-10	SFC Pipe and Valve Room (El 130'-7" and El 162'-3")
CT-11	WCS - Filter Cubicles (El 162'-3")
CT-SP	Suppression Pool (El 70'-0" to 90'-0")
CT-G*	General Area (El 114'-0", 141'-0", 162'-3", and 186'-3")
<u>Annulus</u>	
AN-1	All Areas El 114'-0" and Above
AN-2	All Areas Immediately Below El 114'-0"
AN-3	Vicinity of SFC Piping (El 114'-0" to 141'-0", AZ-155° to 185°)

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Building</u>	
Elevation: 70'-0"	
AB-070-1	CSL Area
AB-070-2	RHS-P1A Pump Room
AB-070-3*	ICS Pump Room
AB-070-4	RHS-P1C Pump Room
AB-070-5	RHS-P1B Pump Room
AB-070-6	HPCS Pump Room
AB-070-7	Elevator Area
AB-070-8	RPCCW Area
AB-070-G	General Area
Elevation: 95'-9"	
AB-095-1	CSL Hatch Area
AB-095-2	RHS Heat Exchanger Area (West)
AB-095-3*	WCS Area
AB-095-4	Hoist Area
AB-095-5	RHS Heat Exchanger Area (East)
AB-095-6	HPCS Hatch Area
AB-095-7	Elevator Area
AB-095-8	RPCCW Area
AB-095-9	CRD Work Area
AB-095-10*	Main Steam Tunnel
AB-095-G	General Area
Elevation: 114'-0"	
AB-114-1	MCC Area (West)
AB-114-2*	Main Steam Tunnel (North)
AB-114-3	MCC Area (East)
AB-114-4	Post Accident Sampling Station
AB-114-5	Elevator Room
AB-114-6	RPCCW Area
AB-114-7*	Main Steam Tunnel (Loops)
AB-114-8	RHS Equipment Removal Cubicle
AB-114-G	General Area
Elevation: 141'-0"	
AB-141-1	Equipment Area (West)
AB-141-2	Equipment Area (East)
AB-141-3	Elevator Area

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
AB-141-4	RPCCW Area
AB-141-5	Standby Gas Treatment Filter (West)
AB-141-6	Standby Gas Treatment Area (East)
AB-141-G	General Area
Elevation: 170'-0"	
AB-170-1	Annulus Mixing System Fan Area
AB-170-3	Elevator Machine Room
<u>Fuel Building</u>	
Elevation: 70'-0"	
FB-070-1	Fuel Pool Cooling Pumps and Heat Exchanger
FB-070-2	SFT Drain Tank Area
FB-070-3	Backwash Receiving Room
FB-070-4	Fuel Pool Purification
Elevation: 95'-0"	
FB-095-1	Fuel Pool Demineralizer Filter and Tank Rooms
FB-095-2	SFC Heat Exchanger Cubicles
FB-095-G	General Area
Elevation: 113'-0"	
FB-113-1	Cask Loading and Shipping Area
FB-113-3	Pipe Chase
FB-113-4	Fuel Transfer Tube Mid-Support Room
FB-113-G	General Area
Elevation: 148'-0"	
FB-148-1	Charcoal Filter Rooms
FB-148-G	General Area
<u>Radwaste Building</u>	
Elevation: 65'-0"	
RW-065-1	Tank Rooms
RW-065-2	Valve and Pump Rooms
RW-065-G	General Area

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation: 90'-0"	
RW-090-1	Tank Area
RW-090-2	Valve and Pump Rooms
Elevation: 106'-0"	
RW-106-4	Cask Fill and Storage Area
RW-106-5	Valve and Pump Area
RW-106-6	Waste Sludge Tank Area
Elevation: 117'-0", 120'-0", and 128'-6"	
RW-117-1	Valve and Pump Area
RW-117-2	Filter and Demineralizer Cubicles
RW-120-1	Valve and Pump Room
RW-128-1	Clean Cask Storage
Elevation: 136'-0"	
RW-136-1	Bridge Crane Area
RW-136-2	Evaporator and Reboiler Areas
RW-136-4	Flat Bed Filter and Pump Area
Elevation: 166'-0"	
RW-166-1	HVW Filter Room
RW-166-2	Evaporator Area
<u>Turbine Building Including Off-Gas Area</u>	
Elevation: 67'-6"	
TB-067-1	Heater Bay Cubicles
TB-067-3	Turbine and Condenser Area
Elevation: 95'-0"	
TB-095-1	Heater Bay Cubicles
TB-095-2	Moisture Separator and Reheat Area
TB-095-3	Turbine and Condenser Area
TB-095-4	Air Ejector Cubicle
TB-095-5	Decontamination Area
TB-095-6	Steam Packing Exhauster Area

TABLE 2-1 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation:	123'-6" and 180'-0"
TB-123-1	Moisture Separator and Reheat Area
TB-123-2	Turbine Shield Wall Well Area
TB-123-3	Steam Seal Evaporator Cubicle
TB-123-4	Radwaste Reboiler Cubicle
TB-123-5	HVT Filter Room
TB-123-C	General Area
TB-180-G	Area Immediately Below Turbine Building Roof
Elevation:	67'-6"
OG-067-1	Condensate Demineralizer Regeneration Area
Elevation:	95'-0"
OG-095-1	Condensate Demineralizer Area
Elevation:	123'-6"
OG-123-1	Sample Rooms
OG-123-2	Off-Gas Equipment Areas
OG-123-3	Charcoal Adsorber Cubicle
Elevation:	148'-6"
OG-148-1	Charcoal Adsorbers
OG-148-2	Holdup Pipe Room
OG-148-3	Filter Area
<u>Piping Tunnels</u>	
PT-2	Tunnel Bordered by AB, RB, and RW Buildings
PT-3	AB Tunnel
PT-7	Tunnel Bordered by RW and AC Buildings

*Contains high-energy piping; failure is postulated.

TABLE 2-2

STANDARDIZED MILD ENVIRONMENTAL ZONE DESCRIPTIONS

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Building</u>	
AB-170-2	Continuous Filter Room
AB-170-G	General Area
<u>Fuel Building</u>	
Elevation:	70'-0"
FB-070-G	General Area
Elevation:	113'-0"
FB-113-2	Fuel Handling - Operating Floor
Elevation:	148'-0"
FB-148-2	Equipment Area
<u>Control Building</u>	
Elevation:	70'-0"
CB-070-1	Cable Vault Area
CB-070-2	HVAC Rooms
CB-070-G	General Area
Elevation:	98'-0"
CB-098-1	Switchgear Area
CB-098-2	Mechanical Equipment Room
CB-098-G	General Area
Elevation:	115'-0"
CB-115-1	HVAC Rooms
CB-115-G	General Area
Elevation:	116'-0"
CB-116-1	Battery Room
CB-116-2	Cable Vent and Switchgear, Inverter Rooms
CB-116-G	General Area

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation: 136'-0"	
CB-136-1	Control Room
CB-136-G	General Area
<u>Radwaste Building</u>	
Elevation: 90'-0"	
RW-090-G	General Area
Elevation: 106'-0"	
RW-106-1	Solid Waste Treatment Area
RW-106-2	Solid Waste Compacting and Storage Area
RW-106-3	Sample Room
RW-106-G	General Area
Elevation: 117'-0"	
RW-117-G	General Area
Elevation: 136'-0"	
RW-136-3	Laundry Room
RW-136-G	General Area
Elevation: 166'-0"	
RW-166-G	General Area
<u>Turbine Building Including Off-Gas Area</u>	
Elevation: 67'-6"	
TB-067-2	Sample Room
TB-067-4	Reactor Feed Pump Area
TB-067-G	General Area
Elevation: 95'-0"	
TB-095-G	General Area

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
Elevation:	123'-6"
TB-123-6	Passageway
Elevation:	67'-6"
OG-067-G	General Area
Elevation:	95'-0"
OG-095-G	General Area
Elevation:	123'-6"
OG-123-G	General Area
Elevation:	148'-6"
OG-148-G	General Area
<u>Diesel Generator Building</u>	
Elevation:	98'-0"
DG-098-1	Diesel Operating Area
DG-098-2	Diesel Generator Control Rooms
DG-098-G	General Area
<u>Normal Switchgear Building</u>	
Elevation:	67'-6", 98'-0", and 123'-6"
NS-067-1	Cable Tray Room
NS-098-1	Normal Switchgear and Load Center
NS-098-2	Passageway - Normal Switchgear
NS-123-1	Battery Rooms
NS-123-2	Computer Rooms
NS-123-3	Mechanical Equipment and Switchgear Rooms
NS-123-4	Passageway - Normal Switchgear

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Auxiliary Boiler Building</u>	
Elevation: 95'-0" and 123'-6"	
BA-095-1	Auxiliary Boiler Area
BA-095-2	Switchgear Area
BA-123-1	Deaerator Area
<u>Auxiliary Control Building</u>	
Elevation: 95'-0"	
AC-095-1	Hot Machine Shop
AC-095-2	Passageway
AC-095-3	Decontamination Room
AC-095-4	I & C Electrical Hot Shop
Elevation: 123'-6"	
AC-123-1	Mechanical Equipment
AC-123-2	Passageway
AC-123-3	Auxiliary Control Room
<u>Standby Service Water Pumphouse</u>	
SW-1	Standby Service Water Pump Rooms
SW-2	Transformer Rooms
SW-3	Remote Air Intake Room
<u>Administration Complex</u>	
AD-1	Office Building
AD-2	Warehouse
AD-3	Cafeteria/Lockers/Offices
AD-4	Lab/Health Physics/Decontamination Areas
AD-5	Mechanical Room
AD-6	Machine Shops
AD-7	Electrical Load Center
AD-8	Primary Access Point
AD-9	Auxiliary Access Point
AD-10	Technical Support Center (TSC)
<u>Fire Pumphouse Building</u>	
FP-1	Fire Pumphouse

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Makeup Water Intake Structure</u>	
MK-1	Battery Rooms
MK-2	Pump Room
MK-3	Switchgear Room
<u>Circulating Water Pumphouse</u>	
CW-1	Circulating Water Pumphouse
<u>MG Set Building</u>	
MG-1	MG Set
<u>Water Treatment Building</u>	
WT-1	Water Treatment
<u>Transformer Yard 2A</u>	
TY-1	Fire Protection Sprinkler Building
<u>Hypochlorite Area</u>	
HA-1	Switchgear House
<u>Blowdown Area</u>	
BP-1	Blowdown Pit
<u>Cooling Tower</u>	
CL-1	Switchgear House (1A)
CL-2	Switchgear House (1B)
CL-3	Switchgear House (1C)
CL-4	Switchgear House (1D)
<u>Clarifier Area</u>	
CA-1	Switchgear House
CA-2	Tank Room
<u>Demineralized Water Building</u>	
DI-1	Demineralized Water Pumphouse

TABLE 2-2 (Cont)

<u>Zone</u>	<u>Description</u>
<u>Piping Tunnels</u>	
PT-1	Standby Service Water Tower Tunnel
PT-4	Tunnel Bordered by AB, CB, and DG Buildings
PT-5	Tunnel Bordered by NS and CB Buildings
PT-6	Tunnel Bordered by TB and NS Buildings
PT-8	Tunnel Bordered by FB Building
PT-9	Tunnel Bordered by FB and RB Buildings

RBS EQD


TABLE 2-3

PLANT ZONES


The following plant zones are mild environment plant zones served by the special control room charcoal air filters:








CB-136-1 Control Room


CB-136-G General Area



Ⓜ - MILD ENVIRONMENT







Also Available On Aperture Card





TI APERTURE CARD

FIGURE 2-3

ENVIRONMENTAL ZONE MAP

RIVER BEND STATION

ENVIRONMENTAL QUALIFICATION DOCUMENT






FIGURE 2-4

ENVIRONMENTAL ZONE MAP

RIVER BEND STATION

ENVIRONMENTAL QUALIFICATION DOCUMENT

2.1 TEMPERATURE, PRESSURE, HUMIDITY ENVIRONMENT

The plant ventilation/air-conditioning system is designed to maintain maximum normal operating temperature and pressure conditions for all normal reactor operating modes, including startup, power range, hot-standby, shutdown, and refueling. Average (expected) normal temperatures are also listed in the EQD. However, the humidity is uncontrolled unless otherwise specified. The normal conditions are assumed to persist continuously (i.e., steady state) until an abnormal or accident condition occurs, in which case the abnormal or accident condition persists for the duration specified. After the abnormal or accident condition is terminated, normal conditions are again assumed to exist.

Abnormal operating conditions are any reasonably expected or anticipated deviations from normal conditions (excluding accident conditions). Abnormal operating conditions include:

1. Transients that result from a single HVAC equipment malfunction or a single operator action which was not planned, such as:
 - a. Pump, fan, or chiller inadvertently tripped by operator or tripped on overload
 - b. Main steam isolation valve isolation event (loss of condenser vacuum, turbine trip, MSIV closure including stuck open relief valve)
 - c. Unplanned loss of non-Class 1E HVAC
2. Transients caused by loss of offsite power for a duration of 4 hr. Five of these transients are assumed to occur during the life of the plant.

An accident is defined in FSAR Chapter 15 and is postulated for analysis purposes to occur from unlikely but possible situations and that has the potential to cause a release of radioactivity to the environs which could endanger public safety if not mitigated. A reactor coolant pressure boundary rupture is an example of an accident.

Failure of high energy and moderate piping has been postulated in accordance with NRC Regulatory Guide 1.46, Branch Technical Positions MEB 3-1 and APCS 3-1.

2.2 RADIATION ENVIRONMENT

Integrated radiation environments are specified in terms of rads for gamma and beta radiation. The gamma values are based on energy deposition in tissue (rads) or exposure in air (roentgen). However, the corresponding absorbed dose which would occur in equipment materials (e.g., carbon) when exposed to the environment would differ only slightly in magnitude. For equipment qualification testing, the equivalence of 1 rad to 1 roentgen is an appropriate assumption. The beta environment is stated in terms of a surface air dose and does not account for any shielding between the airborne or plateout activity and the material of interest. The total integrated dose equals the normal plus the accident conditions. Neutron environments are specified in terms of neutron fluence (neutrons/cm²) for that portion of the spectrum ≥ 1 Mev.

For normal operating condition, the radiological environments are specified as doses integrated over a 40-yr plant life for gamma and beta radiation. A plant capacity factor of 0.8 is used to develop the integrated doses for all equipment which operates in conjunction with normal reactor operation. Expected operation time over the 40-yr life of the plant is used to determine integrated doses in the vicinity of other auxiliary systems and equipment, such as radwaste and fuel handling systems. Radiation dose contributions due to abnormal conditions that are expected during the life of the plant are included in the 40-yr normal operating conditions.

For abnormal condition, radiation dose contributions due to abnormal conditions are for the MSIV isolation event resulting from a transient caused by a loss of condenser vacuum, an MSIV closure, or a turbine trip. The integrated dose contribution from this event is included in the normal 40-yr values.

For accident conditions, accident radiological doses are in addition to normal operational conditions. The accident dose contribution is determined for the single most limiting accident. Dose profiles as a function of time (t) following the accident are specified. The actual accident dose is determined based on the required operation time of the equipment following an accident. In most cases, the post-LOCA (DBA) environmental conditions will be the basis for the radiological requirements. High energy pipe breaks and fuel handling accidents are also considered. Accident integrated doses include combined dose contributions from airborne and contained sources and represent the maximum dose for the area specified.

2.3 CHEMICAL ENVIRONMENT

Engineered Safety Feature (ESF) systems are designed to perform their safety functions in the temperature, pressure, and humidity conditions described in the EDC.

River Bend Station does not utilize any chemical additives to the water recirculated by the ECCS during normal or accident conditions.

Following an accident, the containment and drywell atmospheres are maintained below 4 percent (by volume) hydrogen, as discussed in FSAR Section 6.2.5.

The water in these systems is not chemically inhibited. The maximum limits for the suppression pool water are compatible with those of the primary coolant and are listed as follows:

<u>Parameter</u>	<u>Reactor Water Limits Shutdown Condition</u>	<u>Pressure Suppression Pool Water Quality Expected</u>	<u>Suppression Pool Water Maximum Limit</u>
Conductivity	≤10 umho/cm @ 25°C	≤3 umho/cm @ 25°C	≤10 umho/cm @ 25°C
Chlorides (as Cl ⁻)	≤0.5 ppm	≤0.2 ppm	≤0.2 ppm
pH	5.3 to 8.6 @ 25°C	5.3 to 8.6 @ 25°C	5.3 to 8.6 @ 25°C
Total suspended solids		≤1 ppm	≤5 ppm

During reactor shutdown cooling, the RHR system is lined up with the reactor coolant pressure boundary (RCPB). The shutdown cooling piping and equipment in the RHR system are flushed with demineralized water from the condensate storage tank prior to commencing shutdown cooling.

RBS EQD

During layup, the RHR system is filled with water of the following limits:

<u>Parameter</u>	<u>RHR System Maximum Limit</u>
Conductivity	≤ 3 umho/cm @ 25°C
Chlorides (as Cl-)	≤ 0.05 ppm
pH	5.3 to 7.5 @ 25°C

2.4 SUBMERGENCE

The approach to design of River Bend Station is to locate devices above expected submergence levels. At the present time, the flood levels are being determined for the buildings, and for the compartments within the buildings, for the natural phenomena and accident conditions that could cause flooding, in order to verify that the electrical equipment is above submergence levels. Upon completion of the analyses, if any Class 1E electrical equipment is found to be located at or below the submergence level, an analysis will be performed to determine the safety significance of the failure of this electrical equipment and the effect on its Class 1E electrical power source as a result of such submergence. If the results of this analysis show a detrimental effect on the safety system, the electrical equipment will be relocated. If it is not possible to relocate the electrical equipment above the submergence level, it will be demonstrated to be qualified to withstand submergence, or it will be appropriately protected and a qualification by test or analysis will be used to demonstrate the adequacy of such protection.

Table 2.4-1 identifies known equipment subjected to submergence.

TABLE 2.4-1

CLASS 1E EQUIPMENT SUBJECTED TO SUBMERGENCE
ZONES CT-SP, CT-2

<u>Mark No.</u>	<u>Description</u>	<u>Manufacturer</u>	<u>Remarks</u>
1E22*LTN055C	Level Transmitter	GE/Barton	
1E22*LTN055G	Level Transmitter	GE/Barton	
1CMS*RTD24A	RTD	PYCO	
1CMS*RTD24B	RTD	PYCO	
1CMS*RTD24C	RTD	PYCO	
1CMS*RTD24D	RTD	PYCO	
1CMS*RTD24E	RTD	PYCO	
1CMS*RTD24F	RTD	PYCO	
1CMS*RTD24G	RTD	PYCO	
1CMS*RTD24H	RTD	PYCO	
1CMS*RTD24J	RTD	PYCO	
1CMS*RTD24K	RTD	PYCO	
1CMS*RTD40A	RTD	PYCO	
1CMS*RTD40B	RTD	PYCO	
1CMS*RTD40C	RTD	PYCO	
1CMS*RTD40D	RTD	PYCO	
1CMS*RTD42B	RTD	PYCO	
1CMS*RTD42C	RTD	PYCO	
1E51*LTN036A	Level Transmitter	GE	
1E51*LTN036E	Level Transmitter	GE	

SECTION 3

FUNCTIONAL PERFORMANCE REQUIREMENTS

3.1 ACCIDENT/SYSTEM MATRIX

The systems and subsystems required to mitigate an accident are listed in Table 3.1-1. The accident/system matrix is given in Table 3.1-2.

The system and accident descriptions are consistent with the descriptions provided in Table 3.1-2 and Chapter 15 of the FSAR. They are provided in this document to clarify the RBS equipment identification as listed in Appendix A.

Some of the systems are described as follows. The only portion of the HVY system which is required to operate for an accident is the portion servicing the standby service water pumphouse to ensure that an adequate environment is provided for the SWP pumps and associated components.

The SFC system is indicated as being required for all accidents since it must operate to remove decay heat whenever spent fuel is stored in the spent fuel pool. It is not required to directly mitigate the consequences of any of the listed accidents. In addition, the HVF system must operate to ensure an adequate environment for the SFC system, and to maintain secondary containment integrity.

The SLS system is required to operate only in the event the normal scram system (RFS) or control rods do not function to shut down the reactor. Since each accident listed results in a scram, the SLS is not required for all accidents, but is considered to be available.

The containment isolation system includes the containment isolation valves associated with the systems listed in Table 3.1-3. The SWEC/GE system cross reference is given in Table 3.1-4.

The standby power system is capable of supplying ac power for electrical loads which are required for safe shutdown of the reactor. The systems included in the SPS are listed in Table 3.1-5.

The remote shutdown system includes the Divisions I and II remote shutdown panels, and is designed to achieve safe shutdown from either panel. The RSS utilizes some of the existing systems used for normal reactor shutdown operation to shut down the reactor from outside the main control room.

TABLE 3.1-1

SYSTEMS AND SUBSYSTEMS REQUIRED TO MITIGATE ACCIDENT

CSH	High Pressure Core Spray (HPCS) System
CSL	Low Pressure Core Spray (LPCS) System
RHS	Residual Heat Removal (LPCI, SPCM, SCM) System
SVV	Nuclear Boiler (Main Steam Safety and Relief Valves, Automatic Depressurization (ADS) System)
ICS	Reactor Core Isolation Cooling (RCIC) System
RPS	Reactor Protection System
MSI	Main Steam Positive Leakage Control System
LSV	Penetration Valve Leakage Control System
RPC	Reactor (Rod Pattern Control) System
NMS	Neutron Monitoring System
SWP	Standby Service Water and Normal Service Water Systems
SLS	Standby Liquid Control System
GTS	Standby Gas Treatment System
HVR	Containment, Drywell, and Auxiliary Building Ventilation, Annulus Mixing, Annulus Pressure Control, Containment and Drywell Purge (Reactor Plant Ventilation) System
CMS	Containment Atmosphere Monitoring System
CPM	Combustible Gas Control (Hydrogen Mixing) System
HCS	Combustible Gas Control (Hydrogen Recombiner) System
SFC	Fuel Pool Cooling and Cleanup System
EGF	Fuel Oil Storage and Transfer (Emergency Generator Fuel) System

TABLE 3.1-1 (Cont)

EGA	Diesel Generator (Air Startup - Standby Diesel Generator) Systems
HVC	Control Building Ventilation Air Conditioning System
HVK	Control Building Chilled Water System
HVN	Ventilation Chilled Water System
HVF	Fuel Building Ventilation System
HVP	Diesel Generator (Diesel Generator Building Ventilation) Systems
HVY	Standby Service Water Pumphouse Ventilation (Yard Structures Ventilation) System
RMS	Process and Area Radiation Monitoring Systems
SPS	Standby Electrical Power (Diesel Generator System)
CCP	Reactor Plant Component Cooling Water System
SSR	Reactor Plant Sampling System (Post Accident Sampling System)
LDS	Leak Detection System
RSS	Remote Shutdown System
CPP	Combustible Gas Control (Containment Hydrogen Purge) System
CES	Residual Heat Removal (LPCI, SPCM, SCM) System Auxiliary AC Power Systems (Class 1E) 125-Volt DC Power Systems (Class 1E)

RBS EQD

TABLE 3.1-2

ACCIDENT/SYSTEM MATRIX

Accidents	Systems Required to Mitigate Accident														
	HPCS	LPCS	LPCI	ADS	RCIC	CIS	RPS	MSI	LSV	RPCS	NMS	SPCM	SWP	SLS	SCM
1. Steam Line Break Outside Containment	X	X	X	X	X	X	X						X	X	X
2. Feedwater Line Break Outside Containment	X	X	X	X	X	X	X						X	X	X
3. LOCA	X	X	X	X		X	X	X	X			X	X	X	
4. High Energy Line Break Outside Containment (RWCU/RCIC)						X	X						X		
5. Rod Drop	X	X	X	X	X	X	X			X	X		X	X	X
6. Fuel Handling													X		
7. Recirculation Pump Seizure	X	X	X	X	X		X						X	X	X
8. Recirculation Pump Shaft Break	X	X	X	X	X		X						X	X	X
9. Main Condenser Gas Treatment System Failure				X	X		X						X	X	X

RBS EQD

TABLE 3.1-2 (Cont)

Accidents	Systems Required to Mitigate Accident																
	GTS	HVR	CMS	CPM	HCS	SFC	EGF	EGA	SPS	HVK	HVC	HVF	HVP	HVY	RMS	LDS	PAM
1. Steam Line Break Outside Containment	X	X	X			X	X	X	X	X	X	X	X	X	X		
2. Feedwater Line Break Outside Containment						X	X	X	X	X	X	X	X	X	X		
3. LOCA	X	X	X	X	X	X	X	X	X	X	X	X	X	X	X		X
4. High Energy Line Break Outside Containment (RWCU/RCIC)	X	X				X			X	X	X			X	X	X	
5. Rod Drop	X	X	X			X	X	X	X	X	X	X	X	X	X		
6. Fuel Handling						X	X	X	X	X	X	X	X	X	X		
7. Recirculation Pump Seizure	X	X	X			X	X	X	X	X	X	X	X	X	X		
8. Recirculation Pump Shaft Break	X	X	X			X	X	X	X	X	X	X	X	X	X		
9. Main Condenser Gas Treatment System Failure		X	X			X	X	X	X	X	X	X	X	X	X		

RBS EQD

TABLE 3.1-2 (Cont)

<u>Accidents</u>	<u>Systems Required to Mitigate Accident</u>					
	<u>HVN</u>	<u>CCP</u>	<u>SSR</u>	<u>CPP</u>	<u>RSS</u>	<u>CES</u>
1. Steam Line Break Outside Containment					X	X
2. Feedwater Line Break Outside Containment					X	X
3. LOCA	X	X	X	X	X	X
4. High Energy Line Break Outside Containment (RWCU/RCIC)					X	X
5. Rod Drop					X	X
6. Fuel Handling						X
7. Recirculation Pump Seizure					X	X
8. Recirculation Pump Shaft Break					X	X
9. Main Condenser Gas Treatment System Failure					X	X

RBS EQD

TABLE 3.1-3

SWEC/GE SYSTEM CROSS REFERENCE

<u>SWEC</u>	<u>GE</u>
MSS	B21
FWS	E21
SVV	B21
DTM	B21
RDS	C11
SLS	C41
RHS	E12
CSL	E21
CSH	E22
MSI	E33
ICS	E51
WCS	G33
RCS	B33
LDS	E31

TABLE 3.1-4

SYSTEMS ASSOCIATED WITH CONTAINMENT ISOLATION

MSS	Nuclear Boiler System - Power Conversion (Main Steam) System
MSI	Main Steam Positive Leakage Control System
DTM	Nuclear Boiler (Turbine Plant Miscellaneous Drains) System
FWS	Nuclear Boiler (Feedwater) System
RHS	Residual Heat Removal System
WCS	Reactor Water Cleanup System
CSH	High Pressure Core Spray (HPCS) System
CSL	Low Pressure Core Spray (LPCS) System
ICS	Reactor Core Isolation Cooling (RCIC) System
SFC	Fuel Pool Cooling and Cleanup System
RDS	CRD Hydraulic (Control Rod Drive) System
HVR	Containment, Drywell, and Auxiliary Building Ventilation, Annulus Mixing, Annulus Pressure Control, Containment and Drywell Purge (Reactor Plant Ventilation) System
CPP	Combustible Gas Control (Containment Hydrogen Purge) System
DFR	Equipment and Floor Drainage (Reactor Plant Floor Drains) System
DER	Equipment and Floor Drainage (Reactor Building Equipment Drains) System
FPW	Fire Protection - Water System
SAC	Service Air System
IAS	Instrument Air System
CCP	Reactor Plant Component Cooling Water System

TABLE 3.1-4 (Cont)

SWP	Standby Service Water and Normal Service Water Systems
SVV	Nuclear Boiler (Main Steam Safety and Relief Valves, Automatic Depressurization) System
CMS	Containment Atmosphere Monitoring System
LMS	Containment Leakage Monitoring System
LSV	Penetration Valve Leakage Control System
HVN	Ventilation Chilled Water System
CNS	Condensate Makeup and Drawoff System

RBS EQD

TABLE 3.1-5

SYSTEMS INCLUDED IN THE STANDBY POWER SYSTEM

EGS	Emergency Diesel Generator System
EJS	Standby 480-V Electrical System
ENB	Standby 125-V DC Control Supply
ENS	Standby 4.16-kV Electrical System
RCP	Reactor Containment Electrical Penetrations
SCM	Station Control Monitoring (Vital) - Indication
SCV	Station Control Bus (Vital) - Ac supply including transformer and transfer switch
VBS	Vital Bus System (incoming supply from inverter)

3.2 POST-ACCIDENT OPERABILITY TIME

Equipment must be qualified for the length of time it is required to perform its safety function and must remain in a safe mode after the function is performed. The length of time the equipment is required to function following the onset of an accident is its post-accident operability time (PAOT).

The required PAOT is determined by an analysis of the functional performance requirements of a device for each applicable event listed in FSAR Chapter 15. For each device, the required active function time, based upon the intended safety function, is determined. The determined operability time ranges from very short periods, where safety functions are performed early in the event and subsequent actions are not called for, to longer periods of time where process variables are stabilized. For long periods of required operability, the parameters selected to environmentally qualify needed products assure the capability to bring the reactor to, and maintain a safe shutdown condition.

For equipment within the BOP scope of supply, an accident/system matrix, described in Section 3.1, has been developed to determine the PAOT as explained above.

The PAOT is provided in the EQD Master List (see Table 5.1-1).

SECTION 4

QUALIFICATION METHODOLOGY

4.1 HARSH ENVIRONMENT

4.1.1 BOP Equipment

4.1.1.1 Electrical

The methodology established for the RBS equipment qualification program is in accordance with the guidelines provided in NUREG-0588 for Category I plants, and in compliance with the regulation of 10CFR50.49. The methodology consists of developing the Environmental Design Criteria (EDC)⁽¹⁾, which establishes the temperature, pressure, humidity, and radiation dose levels, for normal, abnormal, and accident conditions. Post-accident operability time is developed to assure that the equipment will be qualified to maintain a safety function during a post-accident event.

These requirements are included in the procurement specification for the electrical equipment important to safety. The specification mandates that the qualification will be accomplished in accordance with IEEE 323-1974 and in accordance with the quality assurance program referenced in 10CFR50 Appendix B.

Based on these requirements the equipment manufacturer develops an equipment qualification program.

The environmental qualification documents for the equipment are obtained for engineering evaluation from equipment vendors, equipment manufacturers and/or testing facilities. These documents, in the form of qualification procedures, reports, and supplementary information, are evaluated in accordance with NUREG-0588, IEEE 323-1974. Review of these documents includes assurance that they are technically adequate and conform to the environmental qualification requirements of the applicable emergency conditions, operability times, and service conditions.

As each vendor qualification document is reviewed and assessed, a Supplier Document Data Form (SDDF) number is assigned. This number, as well as numbers of other support documents, is referenced on the System Component Evaluation Work (SCEW) Sheet where the results of the review of the

qualification documents are summarized for each equipment listed on the Master List (ML). Support documentation for qualification of any ML item can be accessed through the equipment number on the ML which references the SCEW sheet, or through the manufacturer/model designation of the SCEW sheet itself.

Aging

The effects of age are documented as part of the qualification program.

Arrhenius aging methodology is the preferred method for evaluating equipment aging and in general is used as a basis for determining qualified life. When other methods are used, appropriate justification is provided. The thermal aging methodology used for qualifying BOP safety-related devices is described in the qualification test reports referenced in the SCEW sheets.

Prior to simulating seismic and DBA event, equipment or its age-sensitive components were preconditioned to their end-of-qualified life condition.

If it was known that aging improved performance capability, new or partially aged devices were used in testing.

Advanced life conditioning was accomplished by applying an appropriate combination of operational and environmental cycling to simulate the expected service listed in the equipment specification and by subjecting the device to physical and chemical stresses that are known to degrade the device. Normal cycling of in-plant conditions was performed in any combination aging procedure.

In the case where accelerated aging was used, the procedure employed considered the expected application and design life of the device being tested.

Synergistic effects were considered when these effects were known to have a significant effect on equipment performance.

Where required, a maintenance or replacement schedule consistent with qualified life is provided as part of the support documentation and is referenced on the SCEW sheets.

When type testing was selected as the qualification method, the type test was run on the device(s) in a specified sequence that was set down as part of the written test procedure. All sequential testing was performed on the same

unit(s), including aging. The sequence given in IEEE 323-1974, paragraph 6.3.2, is generally used. However, other sequences used are justifiable on the basis that it is severe enough to verify that the device qualified will perform its intended functions within the requirements of the purchase specification before, during, and after a design basis accident. The test specimen has been subjected to all normal manufacturing and QA procedures and is representative of the devices supplied.

Margin

Margins are not included in the parameters given in the equipment specifications. However, the specification does include an insert which requires that margin be added to comply with IEEE 323-1974 requirements.

Qualification type test results were reviewed to verify that adequate margin exists between the most severe specified service conditions for the equipment and the conditions used in type testing. Margins are in addition to any conservatism applied during the derivation of local environmental conditions of the equipment. Margin accounts for production variations of equipment and inaccuracies in test instrumentation. Increased levels of testing, number of test cycles, and test duration are among the methods used for ensuring adequate margin.

Some equipment is required by the design to perform its safety function only within the first 10 hrs of an accident. For this equipment in general, a time margin of at least 1 hr in excess of the time assumed in the accident analysis was used.

Dose Rate and Synergistic Effects

Qualification for radiation was based on the calculated total integrated dose. Safety-related electrical equipment qualified for use in a nuclear radiation environment was exposed to radiation which simulated the conservatively calculated integrated dose (normal and accident) that the equipment is expected to withstand prior to completion of its intended safety function. In general, a gamma radiation source, typically CO-60, is used to simulate expected radiation exposure. Where beta and gamma radiation exposure is expected, beta radiation is taken into account either during simulated exposure (directly or as a gamma equivalent) or during evaluation of the results. Reduction in the total beta dose was allowed only after considering appropriate shielding factors. If the beta radiation dose

contribution to the equipment or component was calculated to be less than 10 percent of the total gamma radiation dose to which the equipment or component had been qualified, then the equipment or component was considered qualified for the beta and gamma radiation environment.

Dose rate effects were considered when these effects were known to have a significant effect on equipment performance.

The dose rate, energy spectrum, or particle type was addressed to arrive at a gamma equivalent total dose to which the equipment must be exposed. Actual testing using dose rate, energy spectrum, or particle type as qualification parameters was not considered.

Therefore, synergistic effects involving dose rate are not addressed. However; where synergistic effects of radiation and temperature were identified prior to the initiation of qualification, they are included in the program.

4.1.1.2 Mechanical

The Mechanical Equipment Qualification (MEQ) Program provides a documented analysis of the nonmetallic materials, used in active safety-related mechanical equipment, to demonstrate that the environmental effects due to plant operation and postulated accidents would not degrade these materials in such a way as to prevent this equipment from performing its required safety function.

The MEQ Program details the environmental design conformance review of active safety-related mechanical equipment located in the harsh environment identified in Table 2-1. The conformance review includes nonmetallic subcomponents of active mechanical equipment. Equipment categories included in this review are listed in Table 4.1-1. Active safety-related mechanical equipment is detailed in Appendix A.3. Environmental conditions listed in the EDC are used as the basis for the MEQ review.

Generally, mechanical equipment has not been shown to be as sensitive to radiation exposure as electrical components. Metallic portions of the equipment are particularly resistant to radiation. Nonmetallic parts of mechanical equipment, while more sensitive to radiation and temperature, are used in the equipment so that the degradation of mechanical properties will not substantially affect the required active safety function of the component.

Methodology

The review consists of the following five-step process.

1. Identification of active safety-related mechanical equipment
2. Identification of nonmetallic components
3. Identification of environmental design conditions
4. Identification of nonmetallic material capabilities
5. Evaluation of environmental effects

The MEQ Program consists of analyses of active safety-related equipment located in systems required for the following functions:

1. Emergency reactor shutdown
2. Emergency core cooling (short term)
3. Reactor core cooling (long term post accident)
4. Primary containment isolation
5. Containment integrity
6. Prevention of release of radioactive material

To accomplish the above functions, complete systems and portions of systems are included in the MEQ Program.

Category I active mechanical equipment within those systems that are located in a harsh environment, and required for performance of the above functions, are included in the MEQ Program. The review is performed by using the specifications, SWEC drawings, vendor drawings, and manuals.

Of the environmental conditions (temperature, pressure, humidity, and radiation) only radiation and temperature were considered in the review. Pressure and humidity were not considered relevant since the design of nonmetallic portions of mechanical equipment for these parameters is governed by system process conditions which have been addressed in the specification.

Each material identified was examined to determine the effect of the environmental conditions on the material

properties. For initial screening, it was conservatively chosen to use the threshold radiation level and maximum service temperature. Materials handbooks, textbooks, and industry and government reports were researched to obtain material data. In some cases vendor data were utilized to supplement the above sources.

A conservative initial screening of the nonmetallic components was made by the comparison of the material capabilities (threshold radiation level and maximum service temperature) with the maximum postulated environmental conditions. Those items which were not shown to be acceptable based on the comparison were evaluated in further detail considering:

1. Degree of material degradation
2. Material properties affected
3. Equipment/component function
4. Degree of functional degradation

Acceptance Criteria

In order to be considered acceptable, nonmetallic portions of mechanical equipment must either be shown to be acceptable for the plant environment by:

1. Exhibiting threshold radiation values and maximum service temperatures above the maximum postulated environmental conditions.
2. Demonstrating that the safety function of the component is not compromised and noted as "Justified."

4.1.2 NSSS Equipment

4.1.2.1 Electrical

Safety-related electric NSSS equipment located in a harsh environment includes all three categories of 10CFR50.49(b). A Master List of this equipment is provided in Appendix A.2.

Category 1, 10CFR50.49(b) equipment is that equipment classified by the NSSS vendor as safety-related in the Master Parts List (MPL). Category 2, 10CFR50.49(b) equipment has been identified through review of the electrical connections for all equipment classified as

RBS EQD

nonsafety-related in the MPL. Those items connected to ESF or RPS power without being electrically separated in accordance with Regulatory Guide 1.75 are included in the qualification program⁽³⁾. Category 3, 10CFR50.49(b) equipment has been identified and is included in the qualification program.

The approach taken by General Electric to environmentally qualify safety-related equipment within the NSSS Scope of Supply for RBS to a level consistent with NUREG-0588 is described in the GE Licensing Topical Report NEDE-24326-1-P⁽⁴⁾. This report has been approved by the NRC. The methodology described in this report is consistent with applicable Regulations (10CFR50 Appendix A); applicable Regulatory Guides; and with applicable consensus national standards (ANSI and IEEE). The work performed under this guidance is controlled in a manner consistent with the commitments contained in the NRC-approved GE Licensing Topical Report on Quality Assurance.

The approach to qualification described in NEDE-24326-1-P⁽⁴⁾ is predicated on type testing being the preferred approach. Depending upon either the unique characteristics of the specific devices or on the availability of other sources of qualification data, other approaches such as partial type test with justification by analysis, operating experience, analysis or combination of the above mentioned approaches may be used. For any of these approaches the eventual approach used is justified in the accompanying qualification report. This justification is based on the demonstrated ability of the product to meet its intended safety function.

Where type testing is performed, the approach taken is to assure the device is functional under normal conditions as well as under extremes of such conditions; the devices next age to an end-of-qualified life condition, next the device is subjected to dynamic simulation; next the device is subjected to design basis event conditions and post design basis event conditions; and lastly the device is inspected for failures which may not have been apparent during the operational testing which occurs during each exposure to an environmental extreme. When a product is tested, where practical, the interface associated with the product is included in the test. The specific sequences of environments applied during the testing are determined, using engineering judgment, to best select the sequence to which the product would be subjected during actual installation. Furthermore, where synergisms between environments are known, these effects are taken into consideration during the planning and conducting of the

test. All tests that are conducted include adequate margins as required in NUREG-0588. NRC personnel from the Region IV Office of Inspection Enforcement have routinely audited General Electric's environmental qualification efforts and have found no indication that what was being performed for RBS did not demonstrate adequate qualification.

Following the completion of the tests all of the associated documentation that led to the test and was generated during the test is formally assembled into a qualification report. That report is available for NRC audit.

For devices not qualified by test (e.g., devices classified as safety-related solely because they perform a pressure boundary function; devices that perform their safety function prior to the onset of harsh environments in which they do not contribute to the mitigation of the event after performance of the intended safety function, etc) qualification reports are also prepared demonstrating the adequacy of their qualification. As with devices qualified by test, these qualification reports are in an auditable form. The last step of qualification is to ensure that the device tested is similar to the device installed in the field. Therefore, before full qualification can be assured, there is a verification of the similarity between the tested device and the installed device.

4.1.2.2 Mechanical

The NSSS mechanical equipment qualification program encompasses all safety-related active pumps and valves supplied by the NSSS vendor. A Master List (ML) of this equipment is provided in Appendix A.4.

The qualification program is based on a review of the nonmetallic materials in each of the items identified on the ML. The review also determines the functional requirements of the equipment and defines the contribution of each nonmetallic part to the equipment safety function.

Material data necessary to support the qualification evaluation are obtained from the NSSS vendor files or from original equipment vendors. The data are incorporated into the qualification evaluation as necessary to support qualification conclusions.

RBS EQD

Using the RBS specific ambient environmental conditions as reported in the EDC⁽¹⁾, a qualification evaluation is performed as follows:

1. Define the environment that exists locally to all nonmetallic parts.
2. Examine part capability relative to the threshold for degradation. Parts for which the environmental exposure is less than the threshold require no further evaluation.
3. Parts that cannot be exempted by the evaluation under paragraph 2 are evaluated in detail. If failure can be tolerated, no further evaluation is required. If failure cannot be tolerated, acceptability is demonstrated by analysis or test data, or a combination of both, that proves the part will support the equipment safety function when exposed to normal, abnormal, and accident environments.

For each item shown on the ML a qualification evaluation report is prepared which includes the following information:

1. Summary statement of the results of the evaluation and qualification status.
2. Definition of any recommended maintenance or other conditions necessary to maintain qualification.
3. Definition of the applicable RBS environmental conditions.
4. Equipment safety function and function time.
5. Nonmetallic material lists related to the equipment item.
6. Analysis performed.
7. Reference material not commonly available.

The report is maintained in an auditable file as described in Section 5.3.

TABLE 4.1-1

ACTIVE SAFETY-RELATED MECHANICAL EQUIPMENT CATEGORIES

Fans
Dampers
Air Treatment Units
Hydrogen Recombiner
Unit Coolers
Pumps
Valves - Relief
Valves - Check
Valves - Motor Operated
Valves - Air Operated

4.2 MILD ENVIRONMENT

Mild environment plant areas are listed in Table 2-2. These areas or zones were selected based on the following guidelines and criteria:

1. Safety-related equipment in these zones is located outside of containment, and is not subject to accident environments due to a LOCA or pipe breaks.
2. Environmental conditions: 10CFR50.49 paragraph c. (iii) defines a mild environment as: An environment that would at no time be significantly more severe than the environment that would occur during normal plant operation, including anticipated operational occurrences. Anticipated operational occurrences, as defined in 10CFR50 Appendix A means those conditions of normal operation which are expected to occur one or more times during the life of the nuclear power unit and include, but are not limited to, loss of power to all recirculation pumps, tripping of the turbine generator set, isolation of the main condenser, and loss of all offsite power.

There is no significant change in environmental conditions, except radiation, in these zones during an accident.

- a. Temperature, pressure, and humidity: The accident environments are no worse and, in many cases, are less severe than the maximum normal or abnormal conditions. The maximum normal or abnormal conditions include and envelop conditions of anticipated operational occurrences.
- b. Radiation: The total integrated dose for normal 40-yr service plus 180-days accident is less than 10^4 rads, which is lower than the threshold damage level for organic materials. Electronic components in particular metal oxide semiconductor devices, may have a threshold damage level at somewhat lower doses. Justification for the use of these electronic components in the specified radiation environment shall be provided. Plant zones listed in Table 2-3 are served by the special control room charcoal air filters and will not experience any significant

increase in radiation during normal 40-yr service or accident; therefore, the use of electronic equipment in these zones is considered justified.

Equipment located in the zones listed in Table 2-2 are not exposed to environmental conditions that may cause common mode failures due to environmental conditions during DBE. Immediate access following a DBE is not required other than normal and periodic maintenance. Therefore, these plant zones may be considered mild environment areas.

4.2.1 BOP Equipment

Safety-related equipment located in a mild environment meeting the following requirements is considered adequately qualified.

1. A Certificate of Compliance (C of C) which incorporates the qualification requirements specified and states that the functional requirements of the equipment subjected to the specified RBS environmental conditions have been met.
2. The C of C shall identify the supplied equipment by equipment mark number.
3. The equipment has been manufactured in accordance with a quality assurance program that meets the requirements of 10CFR50, Appendix B and states compliance with 10CFR21.
4. The requirements for any scheduled surveillance, maintenance calibration, periodic tests, and parts replacements necessary to maintain qualification.

4.2.2 NSSS Equipment

Safety-related NSSS vendor-supplied equipment that is located in a mild environment is considered qualified if:

1. The equipment manufacturer's design environmental parameters envelop the RBS specific environment.
2. The equipment manufacturer's design functional characteristics envelop the RBS application specific functional performance requirements.

3. The NSSS vendor provides a Product Quality Certification (PQC) in accordance with NEDO 11209⁽⁵⁾.

The PQC establishes a tie between the supplied item and the respective equipment purchase part drawing which in turn provides further reference to the applicable environmental and functional performance specifications.

QUALIFICATION DOCUMENTATION

5.1 MASTER LISTS (ML)

The equipment and components that are within the scope of 10CFR50.49(b) and require qualification on RBS are listed in the ML, Appendix A.

This list includes and identifies 10CFR50.49(b) equipment categories 1, 2, and 3.

One important feature of the ML is its capability to identify all qualification documentation associated with any of the listed safety-related electrical equipment or components through reference to the associated System Component Evaluation Work (SCEW) sheets for that particular equipment or component (see Section 5.2). The identity of any qualification document associated with any of the listed items can be accessed through either the individual equipment identification number such as service water pump 1SWP*P2A or through a generic equipment manufacturer and model number such as Rosemount 1153B pressure transmitter.

Examples of documentation accessible through this ML reference to the SCEW sheets are purchase specifications, vendor records such as test plans and test reports, and SWEC-generated documentation such as aging analyses of mechanical equipment and equipment operability periods.

The ML contains the majority of the required summary qualification information such as operability period, operability code, location, equipment specification, and other pertinent information, as shown in Appendix A.

For each device, the ML provides a summary of the key elements of the Environmental Qualification Program. Table 5.1-1 and Figure 5.1-1 contain the heading for the ML, with a description of each entry. The first four characters of the device indicate the unit number and the major system in which the device is used. The subsequent characters are used to further segregate the devices by specific type and number. Tables 5.1-2 through 5.1-5 define the various codes used in the ML.

TABLE 5.1-1

ENVIRONMENTAL QUALIFICATION DATA MASTER LIST

<u>Number</u>	<u>Title</u>	<u>Description</u>
1	MARK NO.	Indicates identifying number of SWEC equipment (the first four characters of which correspond to the unit number and major system in which the equipment is used).
2	EQUIPMENT DESCRIPTION	Brief description of equipment.
3	VENDOR	Indicates supplier filling purchase order.
4	PANEL/RACK	Mark Number of the panel/rack in which instruments are located.
5	SPEC. NO.	Indicates procurement specification number.
6	MAKE/MANUFACTURER	A four-digit code indicating the manufacturer (not necessarily the same as the vendor) (Table 5.1-2 of this document).
7	MODEL/CATALOG NO.	Manufacturer's Identification Number.
8	REMARKS	Indicates where special notes or further data may be entered concerning the device and its qualification.

TABLE 5.1-1 (Cont)

<u>Number</u>	<u>Title</u>	<u>Description</u>
9	ENV ZONE	Indicates environmental condition associated with the device.
10	SUBMRG	Indicates if equipment is subjected to submergence.
11	EMRGCN	Indicates harsh environmental condition through which the device must be operable to perform the safety function (Table 5.1-3).
12	ENVTYP	Indicates type of environment, i.e., harsh, mild.
13	SFN1 SFN2 SFN3	Indicates the safety functions of the device when exposed to harsh environments (Table 5.1-4). Although three code lines are provided, there may not be three safety functions per device. A dash provided in the space indicates that the extra safety function spaces do not apply.
14	OPTIME	Indicates period of time following the onset of an accident during which the device must remain capable of performing its safety function (operability time).

TABLE 5.1-1 (Cont)

<u>Number</u>	<u>Title</u>	<u>Description</u>
15	OC	Indicates the operability code category associated with the device with regard to Appendix E, NUREG 0588, Item 2 (Table 5.1-5).
16	QRN1 QRN2 QRN3	Indicates the qualification reference number of the SCEW (System Component Evaluation Work Sheet) applicable to the device.

TABLE 5.1-2

MANUFACTURER NAMES AND MANUFACTURER CODES

<u>Manufacturer Name</u>	<u>Manufacturer Code</u>
American Corp/CP Div.	AAFC
American Air Filter	AAAC
Anaconda	ASCO
Asco	ACOT
Atlas COPCO Turbinetics	ATTO
Atwood-Morrill	BORG
Borg Warner	BNRX
Brand Rex	ERBO
Brown Boveri Electric	BERG
Buffalo Forge	CARR
Carrier	CRMC
Ceramic	COMS
COMSIP Inc.	CONX
Conax	COVI
Copes Vulcan Inc.	CRDE
Crane-Deming	DLVL
Delaval	ELEC
Electro-Mechanics	ELGR
Elgar	PRTC
E. P. Porter	FOXB
Foxboro	FCTL
Fisher Controls	FCII
Fluid Components Inc.	GECO
General Electric	GACO
General Atomic Corp.	GLDI
Gould	GLDP
Goulds Pumps	HATY
Haywood-Tyler	INDC
Indeeco	JMSB
Jamesbury	LMTQ
Limitorque	MERC
Mercury	NMCO
Namco	NELE
Nelson Elect.	NUTH
Nu-therm	OKON
Okonite	POSI
Posi-Seal	PCPI
Power Conversion Products, Inc.	PECP
Powell Electric Corp.	PYCO
Pyco	QADE
Quality Air Design	RELI
Reliance	

TABLE 5.1-2 (Cont)

<u>Manufacturer Name</u>	<u>Manufacturer Code</u>
Rockbestos	ROCK
Rosemount	RSMT
RTE Delta	RTED
Siemens Allis	SALS
Southern Transformers	SXFR
Square D	SQRD
Super Pressure	SUPR
Target Rock	TRCP
Technology for Energy Corp.	TEEC
Thermexchanger	THRM
Transamerica Delaval	TRND
Velan	VLAN
Westinghouse	WEST

RBS EQD

TABLE 5.1-3

EMERGENCY CONDITION CODES

<u>Condition</u>	<u>Code</u>
Normal	NORM
Abnormal	ABNO
High-energy line breaks inside and outside of containment:	
Inside containment	HLBI
Outside containment	HLBO
Fuel handling accident	FHA
Main steam line break	MSLB
Transient caused by HLBI or HLBO (radiation and temperature)	TRNS

TABLE 5.1-4

SAFETY FUNCTION CODES

<u>Code</u>	<u>Description</u>
ADS	Automatic Depressurization System
BCNT	System Boundary Control
CCGC	Containment Combustible Gas Control
CISL	Containment Isolation
DISP	Safety-related Display Instrumentation
EMPW	Emergency Power/Electrical Distribution
ESA	Engineered Safeguards Actuation
HPCS	High-pressure Core Spray
HVAC	Ventilation, Heat, A/C (general/safety-related)
HVC	Main Control Room HVAC
HVR	Containment Ventilation
LCS	Leakage Control System
LPCI	Low-Pressure Coolant Injection
LPCS	Low-Pressure Core Spray
MSI	Main Steam Isolation
PAM	Post-Accident Monitoring
PANL	Panel - Seismic Support, Protection, Termination and Display Point for Class 1E Devices
PNET	Electrical Penetration
RACK	Seismic Support, Protection, and Termination of Class 1E Devices
RCIC	Reactor Core Isolation Cooling
RHR	Residual Heat Removal
RMS	Radiation Monitoring System
RPRT	Reactor Protection
RTRP	Reactor Trip
SFC	Spent Fuel Cooling
SGTS	Standby Gas Treatment System
SW	Service Water

TABLE 5.1-5

OPERABILITY CODES
(NUREG 0588, Appendix E, Section 2 Categories)

<u>Operability Code</u>	<u>Equipment Type</u>
A	Equipment that will experience environmental conditions of design basis accidents for which it must function to mitigate such accidents and that will be qualified to demonstrate operability in the accident environment for the time required for accident mitigation with safety margin to failure.
B	Equipment that will experience environmental conditions of design basis accidents through which it need not function for mitigation of such accidents but through which it must not fail in a manner detrimental to plant safety or accident mitigation and that will be qualified to demonstrate the capability to withstand any accident environment for the time during which it must not fail with safety margin to failure.
C	Equipment that will experience environmental conditions of design basis accidents through which it need not function for mitigation of such accidents and whose failure (in any mode) is deemed not detrimental to plant safety or accident mitigation and need not be qualified for any accident environment.

NOTE: If Categories B and C are found to be necessary, a "basis" for inclusion in those categories has been developed on a case-by-case basis.




FIGURE 5.1-1

RBS EQD
 MASTER LIST HEADING
 FORMAT

RIVER BEND STATION
 ENVIRONMENTAL QUALIFICATION DOCUMENT

5.2 SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEET

The SCEW sheet presents a description of the individual equipment and its location. A comparison is made, in summary, of the actual environmental zone specified, with the environmental parameters encompassed in the qualification program. It also contains references to all of the supportive environmental qualification documents which demonstrate that the equipment is qualified to perform its safety function in the postulated environmental conditions.

The SCEW sheet format is shown on Figure 5.2-1.

Reference to the qualification documents which contain detailed supporting information, including test data, can be found listed in the individual equipment or component SCEW sheet.

Documents that are referenced are test reports, maintenance/surveillance documents, Certificates of Compliance (C of C), and other such items that are retained in Supplier's Document Data Form (SDDF) files. Other documents which may be referenced are equipment specifications (SPEC), calculations (CALC) of composite environmental zone profiles, qualified life and supplemental analyses.

The SCEW sheets are compiled in Appendix B.

RIVER BEND STATION - UNIT 1
DOCKET NUMBER 50-458

SYSTEM COMPONENT EVALUATION WORK SHEET

SHEET 1
OF

QUAL REF # _____ REV _____

EQUIPMENT DESCRIPTION		ENVIRONMENTAL CONDITIONS AND QUALIFICATION				REMARKS
PARAMETER	SPECIFIED VALUE	DUALIFIED VALUE	SPECIFIED	DUALIFIED	DUAL METHOD	
EQUIP NO. 1						
SPEC NO. 1						
SYSTEM						
TYPE: (DESCRIPTION)						NOTE 1
MANUFACTURER:						NOTE 1
MODEL NO. 1						NOTE 1
SAFETY FUNCTION:						NOTE 1, 2
TOP. CODE						
ACCURACY						
SPEC						
GENS						
ZONE NO. 1						
FLOOD LEVEL						
ELEVATION						
ABOVE FLOOD						
LEVEL						
DOCUMENTATION ACCEPTABILITY						
NUMER. 0586, CAT						
PAINT/SURVEILL						
REFERENCE						
QUALIFIED LIFE						
(YEARS)						
REFERENCE						

NOTES: 1.-FOR COMPLETE ENVIRONMENTAL CONDITIONS,
SEE THE DOCUMENT REFERENCED.
2.SEE CALCULATION
FOR EQUIVALENT TTD GAMMA.

4/24

FIGURE 5.2-1

EOD SCHEM SHEET

RIVER BEND STATION
ENVIRONMENTAL QUALIFICATION DOCUMENT

RBS EQD

5.3 AUDITABLE FILE

LATER

RBS EQD

SECTION 6

MAINTENANCE AND SURVEILLANCE

LATER

SECTION 7

REFERENCES

1. Environmental Design Criteria (EDC) for River Bend Station - Unit 1. Stone & Webster Engineering Corporation, Document No. 215.150, Revision 2, 1984.
2. Title 10, Code of Federal Regulations, Paragraph 50.49, Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants. Federal Register, Vol. 48, No. 15. January 21, 1983.
3. Regulatory Guide 1.75, Physical Independence of Electric Systems, Rev. 2, September 1978.
4. Shirley, N.C. et al. General Electric Qualification Program, Licensing Topical Report NEDE-24326-1-P, January 1983.
5. General Electric Nuclear Energy Business Group, BWR Quality Assurance Program, NEDO-11209-04A, March 1978.

RBS EQD

APPENDIX A.1

SAFETY-RELATED ELECTRICAL EQUIPMENT - BOP

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRCON	SFN1	OP TIME	QRN1	
	VENDOR	MODEL/CATALOG NO.	SUBHRG	ENVTYP	SFN2	OC BASIS	QRN2	
	PANEL/RACK	SPEC.NO	REMARKS		SFN3		QRN3	

621 NUCLEAR BOILER STEAM								
1B21*MOV027D	MOTOR OPERATED VALVE VELAN	LMTQ SHC-04-2	AB-114-2	HLBO HARSH	LCS	1 HR		
	228.214				-	A	-	
1B21*MOV065A	MOTOR OPERATED VALVE VELAN	LMTQ SHB-4-250	AB-114-7	HLBO HARSH	BCNT	1 HR		
	228.212				-	A	-	
1B21*MOV065B	MOTOR OPERATED VALVE VELAN	LMTQ SHB-4-250	AB-114-7	HLBO HARSH	BCNT	1 HR		
	228.212				-	A	-	
1B21*MOV067A	MOTOR OPERATED VALVE VELAN	LMTQ SB-00-5	AB-114-2	HLBO HARSH	BCNT	1 HR		
	228.214				-	A	-	
1B21*MOV067B	MOTOR OPERATED VALVE VELAN	LMTQ SB-00-5	AB-114-2	HLBO HARSH	BCNT	1 HR		
	228.214				-	A	-	
1B21*MOV067C	MOTOR OPERATED VALVE VELAN	LMTQ SB-00-5	AB-114-2	HLBO HARSH	BCNT	1 HR		
	228.214				-	A	-	
1B21*MOV067D	MOTOR OPERATED VALVE VELAN	LMTQ SB-00-5	AB-114-2	HLBO HARSH	BCNT	1 HR		
	228.214				-	A	-	
1B21*MOV085	MOTOR OPERATED VALVE VELAN	LMTQ SHB-00-10	AB-114-2	HLBO HARSH	CISL	1 HR		
	228.212				-	A	-	
1B21*MOV086	MOTOR OPERATED VALVE VELAN	LMTQ SHB-00-10	AB-114-7	HLBO HARSH	CISL	1 HR		
	228.212				-	A	-	
1B21*MOV098A	MOTOR OPERATED VALVE VELAN	LMTQ SHB-4-250	AB-114-7	HARSH		1 HR		
	228.212							

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBGRG	EMROCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QTN1 QTN2 QTN3

B21 NUCLEAR BOILER STEAM								
1B21*MOV098B	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-4-250	AB-114-7	HARSH		1 HR	
1B21*MOV098C	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-4-250	AB-114-7	HARSH		1 HR	
1B21*MOV098D	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-4-250	AB-114-7	HARSH		1 HR	
B33 REACTOR RECIRC VALVE FLOW CONTROL								
1B33*AOVF019	AIR OPERATED VALVE FISHER CONTROLS	247.491	FCTL,NHCO DBQ,EA180	DW-1	HLBI HARSH	BCNT	1 HR	
1B33*AOVF020	AIR OPERATED VALVE FISHER CONTROLS	247.491	FCTL,NHCO DBQ,EA180	CT-3	HLBI HARSH	BCNT	1 HR	
1B33*SOVF019	SOLENOID VALVE FISHER CONTROLS	247.491	ASCO NP8320	DW-1	HLBI HARSH	BCNT	1 HR	
1B33*SOVF020	SOLENOID VALVE FISHER CONTROLS	247.491	ASCO NP8320	CT-3	HLBI HARSH	BCNT	1 HR	
CCP COMPONENT COOLING - PRIMARY CONTAINMENT OR REACTOR								
1CCP*MOV129	MOTOR OPERATED VALVE JAMESBURY	228.243	LHTQ SMB-000-5	AB-070-8	HARSH		1000	
1CCP*MOV130	MOTOR OPERATED VALVE JAMESBURY	228.243	LHTQ SMB-000-5	AB-070-8	HARSH		1000	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```
*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN      SFN1  OP TIME  CRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG    ENVYTP      SFN2  OC BASIS  CRN2
              PANEL/RACK                SPEC.NO            REMARKS                                     SFN3      CRN3
*****
```

CCP COMPONENT COOLING - PRIMARY CONTAINMENT OR REACTOR

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCN	SFN1	OP TIME	CRN1
1CCP#MOV138	MOTOR OPERATED VALVE VELAN 228.212	LHTQ SHB-0-25	AB-114-6	HLBO HARSH	CISL -	1HR A -	-
1CCP#MOV142	MOTOR OPERATED VALVE JAMESBURY 228.243	LHTQ SHB-000-2	CT-G	HARSH		1HR	
1CCP#MOV143	MOTOR OPERATED VALVE JAMESBURY 228.243	LHTQ SHB-000-2	CT-G	HARSH		1HR	
1CCP#MOV144	MOTOR OPERATED VALVE JAMESBURY 228.243	LHTQ SHB-000-2	DW-1	HARSH		1HR	
1CCP#MOV158	MOTOR OPERATED VALVE VELAN 228.212	LHTQ SHB-0-25	CT-G	HLBI HARSH	CISL -	1HR A -	-
1CCP#MOV159	MOTOR OPERATED VALVE VELAN 228.212	LHTQ SHB-0-25	AB-114-6	HLBO HARSH	CISL -	1HR A -	-
1CCP#MOV16A	MOTOR OPERATED VALVE JAMESBURY 228.243	LHTQ SHB-000-5	AB-070-8	HARSH		100D	
1CCP#MOV16B	MOTOR OPERATED VALVE JAMESBURY 228.243	LHTQ SHB-000-5	AB-070-8	HARSH		100D	
1CCP#MOV163	MOTOR OPERATED VALVE VELAN 228.214	LHTQ SHB-000-2	FB-070-6	HLBO HARSH	BLNT -	100D A -	-
1CCP#MOV169	MOTOR OPERATED VALVE VELAN 228.214	LHTQ SHB-000-2	FB-070-6	HLBO HARSH	BCNT -	100D A -	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVYTP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

CHS CONTAINMENT ATMOSPHERE MONITORING								
1CHS*AI25A	HYDROG. ANALYZER INDICATOR CONSHIP 1CHS*PNL12A	247.421	API 7045-N5-4702-0000	AB-141-1	HLBO HARSH	DISP -	30 D B A	
1CHS*AI25B	HYDROG ANALYZER INDICATOR CONSHIP 1CHS*PNL10B	247.421	API 7045-N5-4702-0000	AB-141-1	HLBO HARSH	DISP -	30 D B A	
1CHS*AT25A	HYDROG. ANALYZER IND. TRANSH. CONSHIP 1CHS*PNL10A	247.421	DELP BS REG.G.1.97	AB-141-1	HLBO HARSH	PAM -	30 D A -	
1CHS*AT25B	HYDROG. ANALYZER IND. TRANSH. CONSHIP 1CHS*PNL10B	247.421	DELP BS REG.G.1.97	AB-141-1	HLBO HARSH	PAM -	30 D A -	
1CHS*LT23A	LEVEL TRANS & REMOTE SEAL ROSEMOUNT 247.481		RSMT 1153DB5PG, 1159C60A REG.G.1.97	CT-2	HARSH		1000	
1CHS*LT23B	LEVEL TRANS & REMOTE SEAL ROSEMOUNT 247.481		RSMT 1153DB5PG, 1159C60A REG.G.1.97	CT-2	HARSH		1000	
1CHS*PDT29A	DIFF PRESSURE TRANSMITTER ROSEMOUNT LJPB*RAK4	247.481	RSMT 1153DB6	AB-141-2	HLBO HARSH	PAM -	1000 A -	
1CHS*PDT29B	DIFF PRESSURE TRANSMITTER ROSEMOUNT LJPB*RAK3	247.481	RSMT 1153DB6	AB-141-2	HLBO HARSH	PAM -	1000 A -	
1CHS*PNL10A	REMOTE CABINET CONSHIP 247.421		COMS NONE, UNIQUE	AB-141-1	HLBO HARSH	PANL -	1000 A -	
1CHS*PNL10B	REMOTE CABINET CONSHIP 247.421		COMS NONE, UNIQUE	AB-141-1	HLBO HARSH	PANL -	1000 A -	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

 MARK NO EQUIPMENT DESCRIPTION MAKE/MANUFACTURER ENV. ZONE EMBRCON SFN1 CP TIME CRN1
 VENDOR MODEL/CATALOG NO. SUBMRG ENVTYP SFN2 CC BASIS CRN2
 PANEL/RACK SPEC.NO REMARKS SFN3 CRN3

CHS CONTAINMENT ATMOSPHERE MONITORING

1CHS*RTD24E	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD24F	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD24G	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD24H	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD24J	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD24K	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	DISP	100D	
		247.461				-	A	-
1CHS*RTD40A	RTD PYCO		PYCO 122-3046-12 REG.G.1.97	CT-2	HLBI HARSH	PAM	100D	
		247.461				-	A	-
1CHS*RTD40B	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	PAM	100D	
		247.461				-	A	-
1CHS*RTD40C	RTD PYCO		PYCO 122-3046-12	CT-2	HLBI HARSH	PAM	100D	
		247.461				-	A	-
1CHS*RTD40D	RTD PYCO		PYCO 122-3046-12 REG.G.1.97	CT-2	HLBI HARSH	PAM	100D	
		247.461				-	A	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUSHRG    ENV TYP     SFN2  CC BASIS  QRN2
              PANEL/RACK          SPEC.NO            REMARKS
*****
  
```

CHS CONTAINMENT ATMOSPHERE MONITORING

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCN	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUSHRG	ENV TYP	SFN2	CC BASIS	QRN2
	PANEL/RACK	SPEC.NO	REMARKS		SFN3		QRN3
1CHS*SOV31A	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	AB-114-6	HLBO HARSH	CISL PAM	30 D A -	-
	247.501						
1CHS*SOV31B	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	AB-141-3	HLBO HARSH	CISL PAM	30 D A -	-
	247.501						
1CHS*SOV31C	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	AB-114-6	HLBO HARSH	CISL PAM	30 D A -	-
	247.501						
1CHS*SOV31D	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	AB-141-3	HLBO HARSH	CISL PAM	30 D A -	-
	247.501						
1CHS*SOV32A	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	CT-6	HLBI HARSH	PAM	1000 A -	-
	247.501						
1CHS*SOV32G	SOLENOID VALVE TARGET ROCK	TRCP 77KK-002	CT-6	HLBI HARSH	PAM	1000 A -	-
	247.501						
1CHS*SOV33A	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	1000 A -	-
	247.501						
1CHS*SOV33AA	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-2	HLBI HARSH	PAM	1000 A -	-
	247.501						
1CHS*SOV33B	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	1000 A -	-
	247.501						
1CHS*SOV33BB	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-2	HLBI HARSH	PAM	1000 A -	-
	247.501						

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN  SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG    ENVTYP  SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC. NO          REMARKS   SFN3                      QRN3
*****
  
```

CHS CONTAINMENT ATMOSPHERE MONITORING

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCN	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUBMRG	ENVTYP	SFN2	OC BASIS	QRN2
	PANEL/RACK	SPEC. NO	REMARKS		SFN3		QRN3
1CHS*SOV33C	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33D	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33E	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33F	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-1	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33G	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-5	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33H	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-5	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33J	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-10	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33K	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-10	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33S	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-5	HLBI HARSH	PAM	100D A -	
		247.501					
1CHS*SOV33T	SOLENOID VALVE TARGET ROCK	TRCP 77KK-003	CT-5	HLBI HARSH	PAM	100D A -	
		247.501					

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	ENRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

CHS CONTAINMENT ATMOSPHERE MONITORING								
1CHS*SOV35A	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77KK-002	CT-G	HLBI HARSH	CISL PAM	30 D A -	-
1CHS*SOV35B	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77KK-002	CT-G	HLBI HARSH	CISL PAM	30 D A -	-
1CHS*SOV35C	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77KK-002	CT-G	HLBI HARSH	CISL PAM	30 D A -	-
1CHS*SOV35D	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77KK-002	CT-G	HLBI HARSH	CISL PAM	30 D A -	-
CNS CONDENSATE - MAKE-UP AND DRAINOFF								
1CNS*MOV125	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-00-10	AB-114-6	HLBC HARSH	CISL LCS	1HR A -	-
1CNS*MOV130	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-00-10	AB-114-6	HLBO HARSH	CISL LCS	1HR A -	-
CPH CONTAINMENT HYDROGEN MIXING								
1CPH*FN1A	FAN MOTOR BUFFALO FORGE	215.400	WEST TBFC 145T	CT-G	HLBI HARSH	BCNT	30 D A -	-
1CPH*FN1B	FAN MOTOR BUFFALO FORGE	215.400	WEST TBFC 145T	CT-G	HLBI HARSH	BCNT	30 D A -	-
1CPH*MOV1A	MOTOR OPERATED VALVE POSI-SEAL	228.241	LMTQ SMB-000-2	CT-G	HARSH		1 HR	

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

 MARK NO EQUIPMENT DESCRIPTION VENDOR PANEL/RACK SPEC. NO NAME/MANUFACTURER MODEL/CATALOG NO. REMARKS ENV. ZONE SUBSRG ENVTYP EIRGCN SFM1 SFM2 SFM3 OF TIME QRN1 QRN2 QRN3 *****

CFM CONTAINMENT HYDROGEN MIXING

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC. NO	NAME/MANUFACTURER	MODEL/CATALOG NO.	REMARKS	ENV. ZONE	SUBSRG	ENVTYP	EIRGCN	SFM1	SFM2	SFM3	OF TIME	QRN1	QRN2	QRN3
ICPH*HOV1B	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV2A	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV2B	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV3A	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV3B	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV4A	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			
ICPH*HOV4B	MOTOR OPERATED VALVE POSI-SEAL			228.241	LMTQ	SHB-000-2		CT-G		HARSH					1 HR			

CFP CONTAINMENT PURGE

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC. NO	NAME/MANUFACTURER	MODEL/CATALOG NO.	REMARKS	ENV. ZONE	SUBSRG	ENVTYP	EIRGCN	SFM1	SFM2	SFM3	OF TIME	QRN1	QRN2	QRN3
ICPP*HOV104	MOTOR OPERATED VALVE VELAN			228.212	LMTQ	SHB-000-5		CT-G		HLDI HARSH					N/R A			
ICPP*HOV105	MOTOR OPERATED VALVE VELAN			228.212	LMTQ	SHB-000-5		CT-G		TRNS HARSH					N/R A			

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

CPP CONTAINMENT PURGE								
1CPP*PNL102	PANEL ELECTROMECHANICS	242.444	ELEC NONE, UNIQUE	AB-141-3	HLBO HARSH	PANL -	N/A A -	
1CPP*SOV140	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77KH-004	AB-114-6	HLBO HARSH	CISL -	100D A -	
CSH CORE SPRAY - HIGH PRESSURE								
1CSH*SOV103	SOLENOID VALVE ATHOOD & MORRILL	228.218	WITH 1E22*AOVF005 N/R FOR SAFETY FUNCTION	DW-1	HARSH		N/R	
CSL CORE SPRAY - LOW PRESSURE								
1CSL*SOV103	SOLENOID VALVE ATHOOD & MORRILL	228.218	WITH 1E21*AOVF006 N/R FOR SAFETY FUNCTION	DW-1	HARSH		N/R	
C11 CONTROL ROD DRIVE HYDRAULIC CONTROL SYSTEM								
1C11*HOVF083	MOTOR OPERATED VALVE VELAN	228.216	LHTQ SHB-000-5	FB-113-6	FHA HARSH	CISL -	1 HR A -	
C41 STANDBY LIQUID CONTROL SYSTEM								
1C41*HOVF001A	MOTOR OPERATED VALVE VELAN	228.216	LHTQ SHB-000-2	DW-1	HLBI HARSH	BCNT -	1 HR A -	
1C41*HOVF001B	MOTOR OPERATED VALVE VELAN	228.216	LHTQ SHB-000-2	DW-1	HLBI HARSH	BCNT -	1 HR A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```
*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER      ENV. ZONE      EMRGCH      SFN1  OP TIME  QRN1
              VENDOR                          MODEL/CATALOG NO.      SUBGRG      ENVTYP      SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC.NO      REMARKS              SFN3              QRN3
*****
```

DER DRAINS - REACTOR BLDG EQUIPMENT

```
1DER*AOV126  AIR OPERATED VALVE      FCTL,NMCO      CT-3      HLBI      DISP  1HR
              FISHER CONTROLS      ET,EA180      HARSH      -      A      -
              247.491      QUAL FOR LMTS 33-1DERB03 ONLY      -

1DER*AOV127  AIR OPERATED VALVE      FCTL,NMCO      FB-113-G   FHA      DISP  1HR
              FISHER CONTROLS      ET,EA180      HARSH      -      A      -
              247.491      QUAL FOR LMTS 33-1DERA03 ONLY      -

1DER*SOV126  SOLENOID VALVE          ASCO      CT-3      HLBI      CISL  1HR
              FISHER CONTROLS      NP8320      HARSH      -      A      -
              247.491

1DER*SOV127  SOLENOID VALVE          ASCO      FB-113-G   FHA      CISL  1HR
              FISHER CONTROLS      NP8320      HARSH      -      A      -
              247.491
```

DFR DRAINS - REACTOR PLANT FLOOR

```
1DFR*AOV101  AIR OPERATED VALVE      FCTL,NMCO      CT-3      HLBI      DISP  1HR
              FISHER CONTROLS      ET,EA180      HARSH      -      A      -
              247.491      QUAL FOR LMTS 33-1DFRB04 ONLY      -

1DFR*AOV102  AIR OPERATED VALVE      FCTL,NMCO      AB-114-6   HLBO      DISP  1HR
              FISHER CONTROLS      ET,EA180      HARSH      -      A      -
              247.491      QUAL FOR LMTS 33-1DFRA04 ONLY      -

1DFR*LT134   LEVEL TRANSH & REMOTE SEAL  RSHT      AB-070-1   HARSH      1HR
              ROSEMOUNT          1153DB4PG, 1159C30A

1DFR*LT135   LEVEL TRANSH & REMOTE SEAL  RMST      AB-070-2   HARSH      1HR
              ROSEMOUNT          1153DB4PG, 1159C30A
              247.481

1DFR*LT136   LEVEL TRANSH & REMOTE SEAL  RSHT      AB-070-3   HARSH      1HR
              ROSEMOUNT          1153DB4PG, 1159C30A
              247.481
```

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  EMOGON  SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG     ENVTYP  SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC.NO           REMARKS    SFN3                      QRN3
*****

```

DFR DRAINS - REACTOR PLANT FLOOR

1DFR*LT137	LEVEL TRANSH & REMOTE SEAL ROSEMOUNT	RSMT 1153DB4PG, 1159C30A	AB-070-4				1HR	
	247.481							
1DFR*LT139	LEVEL TRANSH & REMOTE SEAL ROSEMOUNT	RSMT 1153DB4PG, 1159C30A	AB-070-5	HLBO HARSH	DISP	1HR A		
	247.481							
1DFR*LT139	LEVEL TRANSH & REMOTE SEAL ROSEMOUNT	RSMT 1153DB4PG, 1159C30A	AB-070-6	HLBO HARSH	DISP	1HR A		
	247.481							
1DFR*SOV101	SOLENOID VALVE FISHER CONTROLS	ASCO NP 8320	CT-3	HLBI HARSH	CISL	1HR A -		
	247.491							
1DFR*SOV102	SOLENOID VALVE FISHER CONTROLS	ASCO NP 8320	AB-114-6	HLBO HARSH	CISL	1HR A -		
	247.491							
1EHS*HCC2A	STANDBY MOTOR CONTROL CENTERS GOULD INC	GLDI SERIES 5600	AB-141-4	HLBO HARSH	EMPW	1000 A -		
	242.562							
1EHS*HCC2B	STANDBY MOTOR CONTROL CENTERS GOULD INC	GLDI SERIES 5600	AB-141-2	HLBO HARSH	EMPW	1000 A -		
	242.562							
1EHS*HCC2C	STANDBY MOTOR CONTROL CENTERS GOULD INC	GLDI SERIES 5600	AB-141-4	HLBO HARSH	EMPW	1000 A -		
	242.562							
1EHS*HCC2D	STANDBY MOTOR CONTROL CENTERS GOULD INC	GLDI SERIES 5600	AB-141-2	HLBO HARSH	EMPW	1000 A -		
	242.562							

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RDS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

PAGE 21

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUDHRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

E12 RESIDUAL HEAT REMOVAL								
1E12*HOVF003A	MOTOR OPERATED VALVE VELAN	228.212	LMTQ	AB-070-2	HLBO HARSH	RHR -	1000 A	-
1E12*HOVF003B	MOTOR OPERATED VALVE VELAN	228.212	LMTQ	AB-070-5	HLBO HARSH	RHR -	1000 A	-
1E12*HOVF004A	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-0-25 N/R FOR SAFETY FUNCTION	AB-070-7	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF004B	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-0-25 N/R FOR SAFETY FUNCTION	AB-070-7	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF006A	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-0-25 N/R FOR SAFETY FUNCTION	AB-070-2	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF006B	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-0-25 N/R FOR SAFETY FUNCTIONS	AB-070-5	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF008	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SB-C-60 N/R FOR SAFETY FUNCTION	AB-114-2	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF009	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SB-2-60 N/R FOR SAFETY FUNCTIONS	DW-1	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF011A	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-00-5 N/R FOR SAFETY FUNCTION	AB-095-8	HLBO HARSH	RHR -	N/R A	-
1E12*HOVF011B	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SHB-00-5 N/R FOR SAFETY FUNCTION	AB-095-7	HLBO HARSH	RHR -	N/R A	-

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBGRG	EMOCON ENV TYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QPN1 QPN2 QPN3
E12 RESIDUAL HEAT REMOVAL								
1E12*HOVF021	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SB-3-60 N/R FOR SAFETY FUNCTION	AB-095-7	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF023	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SB-095-5 N/R FOR SAFETY FUNCTION	AB-095-4	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF024A	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-1-60	AB-095-8	HLBO HARSH	RHR -	1000 A -	-
1E12*HOVF024B	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-1-60	AB-095-7	HLBO HARSH	RHR -	1000 A -	-
1E12*HOVF026A	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-00-10 N/R FOR SAFETY FUNCTION	AB-070-2	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF026B	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-00-10 N/R FOR SAFETY FUNCTION	AB-070-5	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF027A	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-0-40 N/R FOR SAFETY FUNCTION	AB-114-6	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF027B	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-0-40 N/R FOR SAFETY FUNCTION	AB-114-5	HLBO HARSH	RHR -	N/R A -	-
1E12*HOVF037A	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-1-25 N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RHR -	N/R A -	-
1E12*HOVF037B	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SMB-1-25 N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RHR -	N/R A -	-

04/23/84
REVISION: 0-D
ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	VEHICLE	PANEL/RACK	SPEC. NO	REMARKS	MODEL/CATALOG NO.	ENV. ZONE	EMRGCH	ENVTP	SFN1	OP TIME	GRN1	SFN2	O. BASIS	CRP	SFN3	C7N3
E12	RESIDUAL HEAT REMOVAL																
1E12*MOV040	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ SB-005-15 N/R FOR SAFETY FUNCTION	AB-070-2	HLBO HARSH		RHR	N/R	-	-	-	-	-	-
1E12*MOV042A	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ SB-2-60	CT-6	HLBI HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV042B	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ SB-2-60	CT-6	HLBI HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV042C	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ SB-2-60	AB-114-5	HLBO HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV047A	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ S/B-1-40	AB-095-2	HLBO HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV047B	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ S/B-1-40	AB-095-5	HLBO HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV048A	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ S/B-3-60	AB-070-2	HLBO HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV048B	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ S/B-3-60	AB-070-5	HLBO HARSH		RHR	100D	-	-	-	-	-	-
1E12*MOV049	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ SB-005-15 N/R FOR SAFETY FUNCTION	AB-070-2	HLBO HARSH		RHR	N/R	-	-	-	-	-	-
1E12*MOV052A	MOTOR OPERATED VALVE	VELAN		228.212		LMTQ S/B-2-40 N/R FOR SAFETY FUNCTION	AB-114-8	HLBO HARSH		RHR	N/R	-	-	-	-	-	-

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - MARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC. NO	REMARKS	MAKE/MANUFACTURER	ENV. ZONE	EMISSION	SFNI	CP TIME	CFNI
						MODEL/CATALOG NO.	SOURC	ENVTYP	SFNI	OC BASIS	CFNI
									SFNI		CFNI
512	RESIDUAL HEAT REMOVAL										
1E12*HOVF05CB	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SIS-2-40 N/R FOR SAFETY FUNCTION	AB-114-0	HLEO MARSH	RHR	N/R	-
1E12*HOVF05TA	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SIS-3-80 N/R FOR SAFETY FUNCTION	AB-095-2	HLEO MARSH	RHR	N/R	-
1E12*HOVF05TB	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SIS-3-80 N/R FOR SAFETY FUNCTION	AB-095-5	HLEO MARSH	RHR	N/R	-
1E12*HOVF06AA	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SS-005-10	AB-070-2	HLEO MARSH	RHR	1000	-
1E12*HOVF06AB	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SS-005-10	AB-070-5	HLEO MARSH	RHR	1000	-
1E12*HOVF06AC	MOTOR OPERATED VALVE	VELAN		228.212		LHTQ SS-005-10	AB-070-4	HLEO MARSH	RHR	1000	-
1E12*HOVF06SA	MOTOR OPERATED VALVE	JAMESBURY		228.243		LHTQ SIS-00-10	PT-3	HLEO MARSH	RHR	1000	-
1E12*HOVF06SB	MOTOR OPERATED VALVE	JAMESBURY		228.243		LHTQ SIS-00-10	PT-3	HLEO MARSH	ECNT	A	-
1E12*HOVF073A	MOTOR OPERATED VALVE	VELAN		228.214		LHTQ SIS-000-2 N/R FOR SAFETY FUNCTION	AB-095-8	HLEO MARSH	RHR	N/R	-
1E12*HOVF073B	MOTOR OPERATED VALVE	VELAN		228.214		LHTQ SIS-000-2 N/R FOR SAFETY FUNCTION	AB-095-7	HLEO MARSH	RHR	N/R	-

RSS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY PWRK NO - RUSH ENVIROMENT ONLY

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04-23/84

WTRK NO	EQUIPMENT DESCRIPTION	MANUFACTURER	QTY	ZONE	ENVTYP	SFNC	CP TYLE	ENSN
PANEL/RACK	SPEC NO	REVIEWS		NOVING				
E12	RESIDUAL HEAT REMOVAL							
1E12*SDW070A	MOTOR OPERATED VALVE VELAN	LMTQ SIB-000-2 N/R FOR SAFETY FUNCTION	208-214	AS-095-2	MLEO MURSH	RHR	N/R A	-
1E12*SDW070B	MOTOR OPERATED VALVE VELAN	LMTQ SIB-000-2 N/R FOR SAFETY FUNCTION	208-214	AS-095-5	MLEO MURSH	RHR	N/R A	-
1E12*SDW087A	MOTOR OPERATED VALVE VELAN	LMTQ SIB-2-40 N/R FOR SAFETY FUNCTION	208-212	AS-114-8	MLEO MURSH	RHR	N/R A	-
1E12*SDW087B	MOTOR OPERATED VALVE VELAN	LMTQ SIB-2-40 N/R FOR SAFETY FUNCTION	208-212	AS-114-8	MLEO MURSH	RHR	N/R A	-
1E12*SDW089A	MOTOR OPERATED VALVE VELAN	LMTQ SIB-0-15	208-212	AS-095-5	MLEO MURSH	RHR	1000 A	-
1E12*SDW089B	MOTOR OPERATED VALVE VELAN	LMTQ SIB-0-25	208-212	AS-095-5	MLEO MURSH	RHR	1000 A	-
1E12*SDW105	MOTOR OPERATED VALVE VELAN	LMTQ SIB-0-25 N/R FOR SAFETY FUNCTION	208-212	AS-070-7	MLEO MURSH	RHR	N/R A	-
1E12*SDW003	RHE FCCS SUBSYSTEM FILL PUMP SOLER PUMPS	WEST FRAME 1841 - TEVC	237-160	AS-070-4	MLEO MURSH	RHR	1000 A	-
1E12*SDW051A	SOLENOID VALVE FISHER CONTROLS	ASCO NFB120	247-491	AS-114-8	MURSH		1000	
1E12*SDW051B	SOLENOID VALVE FISHER CONTROLS	ASCO NFB120	247-491	AS-114-8	MURSH		1000	

RDS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

 MARK NO EQUIPMENT DESCRIPTION VENDOR PANEL/RACK SPEC NO REMARKS

 MAKE/MANUFACTURER MODEL/CATALOG NO. ENV. ZONE ENGGCN ENVTYP SFN1 OP TIME GRN1
 SFN2 OC BASIS GRN2 SFN3 GRN3

E33 MAIN STEAM ISOLATION VALVE SEALS

1E33*NOVF008	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SIB-000-5	AB-114-2	HLEO HARSH	LCS 1000 A
1E33*NOVF005	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SIB-000-5	AB-114-3	HLEO HARSH	LCS 1000 A
1E33*NOVF006	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SIB-000-2	AB-114-8	HLEO HARSH	LCS 1000 A
1E33*NOVF007	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SIB-000-5	AB-114-7	HLEO HARSH	LCS 1000 A
1E33*NOVF008	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SIB-000-5	AB-114-7	HLEO HARSH	LCS 1000 A
1E33*PVF002	CONTROL VALVE FISHER CONTROLS	247.497	FCTL, BORG EC ELECTRONICS(CB-116-2)	AB-114-8	HLEO HARSH	LCS 30 D A
1E33*PVF022	CONTROL VALVE FISHER CONTROLS	247.497	FCTL, BORG EC ELECTRONICS(CB-116-2)	AB-114-8	HLEO HARSH	LCS 30 D A
1E33*SOVF014	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77NK-005	AB-141-3	HLEO HARSH	LCS 30 D BCNT A
1E33*SOVF034	SOLENOID VALVE TARGET ROCK	247.501	TRCP 77NK-005	AB-141-3	HLEO HARSH	LCS 30 D BCNT A

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	ENRGCN ENVTP	SF01 SF02 SF03	OP TIME OC BASIS	QR01 QR02 QR03

E51 REACTOR CORE ISOLATION COOLING SYSTEM								
1E51*AOVF004	CONTROL VALVE FISHER CONTROLS	247.491	FCTL,NMCO ES, EA180 QUAL FOR LMTS ONLY	AB-070-3	HLBO HARSH	DISP	70 M A	
1E51*AOVF005	CONTROL VALVE FISHER CONTROLS	247.491	FCTL,NMCO ES, EA180 QUAL FOR LMTS ONLY	AB-070-3	HLBO HARSH	DISP	70 M A	
1E51*AOVF025	CONTROL VALVE FISHER CONTROLS	247.491	FCTL,NMCO DBQ, EA180 QUAL FOR LMTS ONLY	AB-070-3	HLBO HARSH	DISP	70 M A	
1E51*AOVF026	CONTROL VALVE FISHER CONTROLS	247.491	FCTL,NMCO DBQ, EA180 QUAL FOR LMTS ONLY	AB-070-3	HLBO HARSH	DISP	70 M A	
1E51*AOVF054	CONTROL VALVE FISHER CONTROLS	247.491	FCTL,NMCO DBQ, EA180 QUAL FOR LMTS ONLY	AB-070-3	HLBO HARSH	DISP	70 M A	
1E51*AOVF065	AIR OPERATED VALVE ATHOOD & HERRILL	228.218	N/R FOR SAFETY FUNCTION	AS-114-2	HARSH		N/R	
1E51*AOVF066	AIR OPERATED VALVE ATHOOD & HERRILL	228.218	N/R FOR SAFETY FUNCTION	DW-4	HARSH		N/R	
1E51*MOV010	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SHB-00-10 N/R FOR SAFETY FUNCTION	AB-070-3	HLBO HARSH	RCIC	N/R A -	
1E51*MOV013	MOTOR OPERATED VALVE VELAN	228.212	LHTQ SHB-0-40	AS-095-3	HLBO HARSH	RCIC	1 HR A -	
1E51*MOV019	MOTOR OPERATED VALVE VELAN	228.214	LHTQ SHB-00-10 N/R FOR SAFETY FUNCTION	AB-095-6	HLBO HARSH	RCIC	N/R A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRG	ENRCON ENVTP	SF01 SF02 SF03	OP TIME OC BASIS	QR01 QR02 QR03

E51 REACTOR CORE ISOLATION COOLING SYSTEM								
1E51*MOV022	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-0-10	AB-070-3	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV031	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-00-10	AB-070-8	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV045	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-0-10	AB-070-3	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV046	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMB-00-5	AB-070-3	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV059	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-0-10	AB-070-3	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV063	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SB-1-60	CT-9	HLBI HARSH	RCIC -	1 HR A -	
1E51*MOV064	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SB-1-60	AB-114-2	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV068	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMD-0-15	AB-095-7	HLBO HARSH	RCIC -	1 HR A -	
1E51*MOV076	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMB-000-2 N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RCIC -	N/R A -	
1E51*MOV077	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMB-000-2	AB-095-G	HLBO HARSH	RCIC -	1 HR A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	ENRGCN ENVTYP	S N1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

FPW FIRE PROTECTION - WATER								
1FPW*MOV122	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-00-10	AB-141-3	HLBO HARSH	CISL	1 HR A	-
FNS FEEDWATER SYSTEM								
1FNS*MOV7A	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-4-200	AB-114-7	HLBO HARSH	MSI	1HR A	-
1FNS*MOV7B	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SMB-4-200	AB-114-7	HLBO HARSH	MSI	1HR A	-
GTS GAS TREATMENT STANDBY								
1GTS*A001A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP	100D A	-
1GTS*A001B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP	100D A	-
1GTS*A0021A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP	100D A	-
1GTS*A0021B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP	100D A	-
1GTS*A0022A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP	100D A	-
1GTS*A0022B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP	100D A	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	NAME/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUCHRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

GTS GAS TREATMENT STANDBY								
1GTS*A0023A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP -	1000 A -	-
1GTS*A0023B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP -	1000 A -	-
1GTS*A003A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP -	1000 A -	-
1GTS*A003B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP -	1000 A -	-
1GTS*A004A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-5	HLBO HARSH	DISP -	1000 A -	-
1GTS*A004B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-6	HLBO HARSH	DISP -	1000 A -	-
1GTS*FE24A	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	AB-141-5	HARSH		1000	
1GTS*FE24B	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	AB-141-6	HARSH		1000	
1GTS*FN1A	FAN MOTOR BUFFALO FORGE	215.400	WEST	AB-141-5	HLBO HARSH	SGTS -	1000 A -	-
1GTS*FN1B	FAN MOTOR BUFFALO FORGE	215.400	WEST	AB-141-6	HLBO HARSH	SGTS -	1000 A -	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUDMRG	ENRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

GTS GAS TREATMENT STANDBY								
1GTS*SOV3A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-5	HARSH		1000	
1GTS*SOV3B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-6	HARSH		1000	
1GTS*SOV4A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-5	HARSH		1000	
1GTS*SOV4B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-6	HARSH		1000	
1GTS*TS35A	TEMPERATURE SWITCH AMERICAN AIR FILTER	225.220		AB-141-5	HARSH		1000	
1GTS*TS35B	TEMPERATURE SWITCH AMERICAN AIR FILTER	225.220		AB-141-6	HARSH		1000	
1GTS*TS5A	TEMPERATURE SWITCH AMERICAN AIR FILTER	225.220		AB-141-5	HARSH		1000	
1GTS*TS5B	TEMPERATURE SWITCH AMERICAN AIR FILTER	225.220		AB-141-6	HARSH		1000	
G33 REACTOR WATER CLEAN-UP								
1G33*HOVF001	MOTOR OPERATED VALVE VELAN	228.212	LMTQ SB-1-25	DH-1	HLBI HARSH	ESA CISL	1 HR A -	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EHRGCM ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

HVF VENTILATION - FUEL BUILDING								
1HVF*FN3A	FAN MOTOR BUFFALO FORGE	215.400	WEST	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FN3B	FAN MOTOR BUFFALO FORGE	215.400	WEST	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FN7A	FAN MOTOR BUFFALO FORGE	215.400	WEST	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FN7B	FAN MOTOR BUFFALO FORGE	215.400	WEST TBFC 143T	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FS109	FLOW SWITCH FLUID COMPONENTS	247.433		FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FS19A	FLOW SWITCH AMERICAN AIR FILTER	225.220	FCI FR72-4R	FB-148-1	HARSH		100D	
1HVF*FS19B	FLOW SWITCH AMERICAN AIR FILTER	225.220		FB-148-1	HARSH		100D	
1HVF*FS32A	FLOW SWITCH FLUID COMPONENTS	247.433	FCI FR72-4R	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*FS32B	FLOW SWITCH FLUID COMPONENTS	247.433	FCI FR72-4R	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*PT30A	PRESSURE TRANSMITTER ROSEMOUNT	247.481	RSMT 1153GB3	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVTP	SFN1 SFN2 SFN3	OP TIME CC BASIS	QRN1 QRN2 QRN3

HVF VENTILATION - FUEL BUILDING								
1HVF*PT38B	PRESSURE TRANSMITTER ROSEMOUNT	247.481	RSMT 1153GB3	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*RTD1A	RTD PYCO	247.461	PYCO 122-4030-04	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*RTD1B	RTD PYCO	247.461	PYCO 122-4030-04	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*RTD30A	RTD PYCO	247.461	PYCO 122-4030-04	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*RTD30B	RTD PYCO	247.461	PYCO 122-4030-04	FB-148-1	FHA HARSH	HVAC -	24 HR A -	-
1HVF*SOV102	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	FB-148-G	HARSH		1 HR	
1HVF*SOV104	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	FB-148-G	HARSH		1 HR	
1HVF*SOV112	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	FB-148-G	HARSH		1 HR	
1HVF*SOV137	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	FB-148-G	HARSH		1 HR	
1HVF*SOV20A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	EMRGCN	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUBGRG	ENV TYP	SFN2	OC BASIS	QRN2
	PANEL/RACK	SPEC. NO	REMARKS		SFN3		QRN3

HV F VENTILATION - FUEL BUILDING							
1HVF*SOV20B	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV3A	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV3B	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV31A	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV31B	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV33A	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*SOV33B	SOLENOID VALVE QUALITY AIR DESIGN	ASCO NP8321A5E	FB-148-1	HARSH		24 HR	
	215.480						
1HVF*TS23A	TEMPERATURE SWITCH AMERICAN AIR FILTER		FB-148-1	HARSH		100D	
	225.220						
1HVF*TS23B	TEMPERATURE SWITCH AMERICAN AIR FILTER		FB-148-1	HARSH		100D	
	225.220						
1HVF*TS5A	TEMPERATURE SWITCH AMERICAN AIR FILTER		FB-148-1	HARSH		100D	
	225.220						

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	MAKE/HANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

HVF VENTILATION - FUEL BUILDING							
1HVF*TS5B	TEMPERATURE SWITCH AMERICAN AIR FILTER 225.220		FB-148-1	HARSH		100D	
1HVF*TT1A	TEMP TRANSMITTER ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
1HVF*TT1B	TEMP TRANSMITTER ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
1HVF*TT30A	TEMP TRANSMITTER ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
1HVF*TT30B	TEMP TRANSMITTER ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
1HVF*TY1A	TEMP RELAY ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
1HVF*TY1B	TEMP RELAY ELECTROMECHANICS 242.444		FB-148-1	HARSH		24 HR	
HVN CHILLED WATER - VENTILATION							
1HVN*HOV102	MOTOR OPERATED VALVE VELAN 228.212	LHTQ SHB-00-15	AN-1	NORM HARSH	HVAC -	1 HR D -	
1HVN*HOV127	MOTOR OPERATED VALVE VELAN 228.212	LHTQ SHB-00-15	AB-141-4	NORM HARSH	HVAC -	1 HR D -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  EHRGCN      SFN1  OP TIME  QRN1
              VENDOR                                MODEL/CATALOG NO.  SUBMRG     ENV TYP     SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC.NO           REMARKS                                           SFN3      QRN3
*****
HVR VENTILATION - REACTOR PLANT

1HVR*A00142  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-6    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480                      REG.G.1.97
1HVR*A00143  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-1    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A00161  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-2    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A00162  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-2    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A00164  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-1    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A0018A  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-2    HLBO        DISP  1000
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A0018B  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-2    HLBO        DISP  1000
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A00214  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-6    HLBO        DISP  1 HR
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480                      REG.G.1.97
1HVR*A0022A  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-3    HLBO        DISP  1000
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
1HVR*A0022B  AIR OPERATED DAMPER                ASCO,NMCO          AB-141-3    HLBO        DISP  1000
              QUALITY AIR DESIGN                NP8321,EA740      HARSH        -    A    -
              215.480
  
```

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENV TYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
HVR VENTILATION - REACTOR PLANT								
1HVR*A0023A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-2	HLBO HARSH	DISP -	1 HR A -	-
1HVR*A0023B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-2	HLBO HARSH	DISP -	1 HR A -	-
1HVR*A00245	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-2	HLBO HARSH	DISP -	1 HR A -	-
1HVR*A00249	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-2	HLBO HARSH	DISP -	1 HR A -	-
1HVR*A00261	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740 REG.C.1.97	AB-141-6	HLBO HARSH	DISP -	1 HR A -	-
1HVR*A00262	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740 REG.G.1.97	AB-141-6	HARSH		1 HR	
1HVR*A00263	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740 REG.G.1.97	AB-141-5	HARSH		1 HR	
1HVR*A00264	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740 REG.G.1.97	AB-141-5	HARSH		1 HR	
1HVR*A0051A	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-1	HLBO HARSH	DISP -	1000 A -	-
1HVR*A0051B	AIR OPERATED DAMPER QUALITY AIR DESIGN	215.480	ASCO,NMCO NP8321,EA740	AB-141-2	HLBO HARSH	DISP -	1000 A -	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC.NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	ENRSCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
HVR VENTILATION - REACTOR PLANT								
1HVR*FE111	FLOW ELEMENT FLUID COMPONENT	247.433	FCI FR72-4R	AB-141-4	HARSH		100D	
1HVR*FE113	FLOW ELEMENT FLUID COMPONENT	247.433	FCI FR72-4R	AB-141-2	HARSH		100D	
1HVR*FE163	FLOW ELEMENT FLUID COMPONENT	247.433	FCI FR72-4R	AB-141-2	HARSH		100D	
1HVR*FE28A	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	CT-G	HARSH		100D	
1HVR*FE28B	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	CT-G	HARSH		100D	
1HVR*FE28C	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	CT-G	HARSH		100D	
1HVR*FE29A	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	AB-170-1	HARSH		100D	
1HVR*FE29B	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI F272-4R	AB-170-1	HARSH		100D	
1HVR*FE56A	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI FR72-4R	AB-141-1	HARSH		100D	
1HVR*FE56B	FLOW ELEMENT FLUID COMPONENTS	247.433	FCI F272-4R	AB-141-1	HARSH		100D	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	EMRGCN	SFN1	OP TIME	QRN1	
	VENDOR	MODEL/CATALOG NO.	SUBMRG	ENVTP	SFN2	OC BASIS	QRN2	
	PANEL/RACK	SPEC. NO	REMARKS		SFN3		QRN3	

HVR VENTILATION - REACTOR PLANT								
1HVR*FN11A	FAN MOTOR BUFFALO FORGE	WEST TBDP 445TS	AB-170-1	HLBO HARSH	HVAC	100D	-	A -
		215.400					-	
1HVR*FN11B	FAN MOTOR BUFFALO FORGE	WEST TBDP 445TS	AB-170-1	HLBO HARSH	HVAC	100D	-	A -
		215.400					-	
1HVR*FS29A	FLOW SWITCH FLUID COMPONENTS	FCI FR72-4R	AB-170-1	HLBO HARSH	ESA	100D	-	A -
		247.433					-	
1HVR*FS29B	FLOW SWITCH FLUID COMPONENTS	FCI FR72-4R	AB-170-1	HLBO HARSH	ESA	100D	-	A -
		247.433					-	
1HVR*FS56A	FLOW SWITCH FLUID COMPONENTS	FCI FR72-4R	AB-141-2	HARSH		100D		
		247.433						
1HVR*FS56B	FLOW SWITCH FLUID COMPONENTS	FCI FR72-4R	AB-141-2	HARSH		100D		
		247.433						
1HVR*PDT60A	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK4	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR	100D	-	A -
		247.481					-	
1HVR*PDT60B	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK3	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR	100D	-	A -
		247.481					-	
1HVR*PDT60C	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK4	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR	100D	-	A -
		247.481					-	
1HVR*PDT60D	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK3	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR	100D	-	A -
		247.481					-	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

 MARK NO EQUIPMENT DESCRIPTION MAKE/MANUFACTURER ENV. ZONE EMRGCN SFN1 OP TIME QRN1
 VENDOR MODEL/CATALOG NO. SUBMRG ENVTP SFN2 OC BASIS QRN2
 PANEL/RACK SPEC.NO REMARKS SFN3 QRN3

HVR VENTILATION - REACTOR PLANT

1HVR*PDT60E	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK4 247.481	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR 100D - A - -
1HVR*PDT60F	DIFF PRESSURE TRANSMITTER ROSEMOUNT 1JPB*RAK3 247.481	RSMT 1153DB3PA	AB-141-2	HLBO HARSH	HVR 100D - A - -
1HVR*SOV10A	SOLENOID VALVE QUALITY AIR DESIGN 215.480	ASCO NP8321A5E	AB-141-2	HARSH	1 HR
1HVR*SOV10B	SOLENOID VALVE QUALITY AIR DESIGN 215.480	ASCO NP8321A5E	AB-141-2	HARSH	1 HR
1HVR*SOV123	SOLENOID VALVE POSI-SEAL 228.241	ASCO HV-206-832-6F	CT-G	HARSH	1 HR
1HVR*SOV125	SOLENOID VALVE POSI-SEAL 228.241	ASCO HV-206-832-6F	CT-G	HARSH	1 HR
1HVR*SOV126	SOLENOID VALVE POSI-SEAL 228.241	ASCO HV-206-832-6F	CT-G	HARSH	1 HR
1HVR*SOV128	SOLENOID VALVE POSI-SEAL 228.241	ASCO HV-206-832-6F	CT-G	HARSH	1 HR
1HVR*SOV142	SOLENOID VALVE QUALITY AIR DESIGN 215.480	ASCO NP8321A5E	AB-141-6	HARSH	1 HR
1HVR*SOV143	SOLENOID VALVE QUALITY AIR DESIGN 215.480	ASCO NP8321A5E	AB-141-1	HARSH	1 HR

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

PBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

HVR VENTILATION - REACTOR PLANT								
1HVR*SOV147	SOLENOID VALVE POSI-SEAL	228.241	ASCO HV-206-832-6F	CT-G	HARSH		1 HR	
1HVR*SOV148	SOLENOID VALVE POSI-SEAL	228.241	ASCO HV-206-832-6F	CT-G	HARSH		1 HR	
1HVR*SOV161	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV162	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV164	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-4	HARSH		1 HR	
1HVR*SOV165	SOLENOID VALVE POSI-SEAL	228.241	ASCO HV-206-832-6F	AB-141-4	HARSH		1 HR	
1HVR*SOV166	SOLENOID VALVE POSI-SEAL	228.241	ASCO HV-206-832-6F	AB-141-3	HARSH		1 HR	
1HVR*SOV18A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1000	
1HVR*SOV18B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1000	
1HVR*SOV214	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-6	HARSH		1 HR	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	ENRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3

HVR VENTILATION - REACTOR PLANT								
1HVR*SOV22A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-3	HARSH		1000	
1HVR*SOV22B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-3	HARSH		1000	
1HVR*SOV23A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV23B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV245	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV249	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-2	HARSH		1 HR	
1HVR*SOV261	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-6	HARSH		1 HR	
1HVR*SOV262	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-6	HARSH		1 HR	
1HVR*SOV263	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-5	HARSH		1 HR	
1HVR*SOV264	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-141-5	HARSH		1 HR	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RDS ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	EHRCEN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
HVR VENTILATION - REACTOR PLANT								
1HVR*SOV51A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	CT-G	HARSH		1000	
1HVR*SOV51B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	CT-G	HARSH		1000	
1HVR*SOV53A	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-170-1	HARSH		1000	
1HVR*SOV53B	SOLENOID VALVE QUALITY AIR DESIGN	215.480	ASCO NP8321A5E	AB-170-1	HARSH		1000	
1HVR*UC1A	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 445TCZ	CT-G	HLBI HARSH	HVAC -	1000 A	-
1HVR*UC1B	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 445TCZ	CT-G	HLBI HARSH	HVAC -	1000 A	-
1HVR*UC10	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 213TCZ	AB-114-3	HLBO HARSH	HVAC -	1000 A	-
1HVR*UC11A	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 405TCZ	AB-141-4	HLBO HARSH	HVAC -	1000 A	-
1HVR*UC11B	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 405TCZ	AB-141-4	HLBO HARSH	HVAC -	1000 A	-
1HVR*UC2	UNIT COOLER MOTOR BUFFALO FORGE	215.252	WEST 213TCZ NO SAFETY FUNCTION	AB-095-G	HLBO HARSH	HVAC -	N/R A	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBDRG     ENVTYP      SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC.NO           REMARKS
*****
  
```

HVR VENTILATION - REACTOR PLANT

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCN	SFN1	OP TIME	QRN1
1HVR*UC3	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 215TCZ	AB-095-8	HLBO HARSH	HVAC	100D A -	
1HVR*UC4	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 215TCZ	AB-095-7	HLBO HARSH	HVAC	100D A -	
1HVR*UC5	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 326TCZ	AB-114-5	HLBO HARSH	HVAC	100D A -	
1HVR*UC6	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 326TCZ	AB-114-8	HLBO HARSH	HVAC	100D A -	
1HVR*UC7	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 256TCZ	AB-114-1	HLBO HARSH	HVAC	100D A -	
1HVR*UC8	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 256TCZ	AB-114-5	HLBO HARSH	HVAC	1 HR A -	
1HVR*UC9	UNIT COOLER MOTOR BUFFALO FORGE 215.252	WEST 324TCZ	AB-114-8	HLBO HARSH	HVAC	100D A -	

IAS INSTRUMENT AIR

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCN	SFN1	OP TIME	QRN1
1IAS*MOV106	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-000-5	AB-114-6	HLBO HARSH	CISL	1HR A -	
1IAS*MOV107	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-000-5	AB-114-6	HLBO HARSH	CISL	1HR A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  EHRGCM      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG     ENV TYP     SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC. NO           REMARKS    SFN3                      QRN3
*****
IAS INSTRUMENT AIR

IIAS*PT39A   PRESSURE TRANSMITTER      RSHT          AB-141-5    HLBO        N/A    1HR
              ROSEMOUNT                  1153GB7       QA CAT II ALARM ONLY
              247.481

IIAS*PT39B   PRESSURE TRANSMITTER      RSHT          AB-141-6    HLBO        N/A    1HR
              ROSEMOUNT                  1153GB7       QA CAT II ALARM ONLY
              247.481

IIAS*PT43A   PRESSURE TRANSMITTER      RSHT          FB-148-G    FHA         N/A    1HR
              ROSEMOUNT                  1153GB7       QA CAT II ALARM ONLY
              247.481

IIAS*PT43B   PRESSURE TRANSMITTER      RSHT          FB-148-G    FHA         N/A    1HR
              ROSEMOUNT                  1153GB7       QA CAT II ALARM ONLY
              247.481

IIAS*PT48A   PRESSURE TRANSMITTER      RSHT          AB-141-5    HLBO        BCNT   1HR
              ROSEMOUNT                  1153GB7       HARSH
              247.481
              -      A      -

IIAS*PT48B   PRESSURE TRANSMITTER      RSHT          AB-141-6    HLBO        BCNT   1HR
              ROSEMOUNT                  1153GB7       HARSH
              247.481
              -      A      -

IIAS*PT49A   PRESSURE TRANSMITTER      RSHT          FB-143-G    FHA         BCNT   1HR
              ROSEMOUNT                  1153GB7       HARSH
              247.481
              -      A      -

IIAS*PT49B   PRESSURE TRANSMITTER      RSHT          FB-148-G    FHA         BCNT   1HR
              ROSEMOUNT                  1153GB7       HARSH
              247.481
              -      A      -

IIAS*SOV41A  SOLENOID VALVE           TRCP          AB-141-1    HLEO        BCNT   1HR
              TARGET ROCK                 77KK-005     HARSH
              247.501
              -      A      -

IIAS*SOV41B  SOLENOID VALVE           TRCP          AB-141-1    HLEO        BCNT   1HR
              TARGET ROCK                 77KK-005     HARSH
              247.501
              -      A      -
  
```


04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```
*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  EHRGCH      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG     ENVTP       SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC.NO           REMARKS    SFN3              QRN3
*****
```

JPB SUPERSTRUCTURE - PRIMARY AUXILIARY BUILDING

```
1JPB*RAK4    INSTRUMENT RACK          MERC              AB-141-1      HLBO          RACK  100D
              MERCURY                  NONE,UNIQUE      HARSH          -            A    -
              247.411
```

JRB SUPERSTRUCTURE - REACTOR BUILDING

```
1JRB*DRA1(JBE) DOOR ACCESS              CT-G              HARSH          100D
              GRAVER                  219.711

1JRB*DRA1(JBF) DOOR ACCESS              CT-G              HARSH          100D
              GRAVER                  219.711

1JRB*DRA2(JBE) DOOR ACCESS              CT-G              HARSH          100D
              GRAVER                  219.711

1JRB*DRA2(JBF) DOOR ACCESS              CT-G              HARSH          100D
              GRAVER                  219.711

1JRB*SOV15    SOLENOID VALVE          AB-170-1          HARSH          1HR
              GRAVER                  219.711

1JRB*SOV25    SOLENOID VALVE          FB-113-G          HARSH          1HR
              GRAVER                  219.711

1JRB*ZS16     POSITION SWITCH           AB-170-1          HARSH          1HR
              GRAVER                  219.711

1JRB*ZS17     POSITION SWITCH           AB-170-1          HARSH          1HR
              GRAVER                  219.711
```


04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVTP	SFN1 SFN2 SFN3	OP TIME CC BASIS	QRN1 QRN2 QRN3
LSV LEAKAGE CONTROL - PENETRATION VALVE								
1LSV*HOV15B	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMC-04-3	AB-141-2	HLBO HARSH	LCS BCNT	30 D A -	-
1LSV*HOV16A	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMC-04-3	AB-095-10	HLBO HARSH	LCS BCNT	30 D A -	-
1LSV*HOV16B	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMC-04-3	AB-141-2	HLBO HARSH	LCS BCNT	30 D A -	-
1LSV*HOV19A	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMS-000-2	AB-141-2	HLBO HARSH	LCS BCNT	30 D A -	-
1LSV*HOV19B	MOTOR OPERATED VALVE VELAN	228.214	LMTQ SMS-000-2	AB-141-2	HLBO HARSH	LCS BCNT	30 D A -	-
1LSV*H2A	MOTOR TO DRIVE COMPRESSOR SUPERPPRESSURE INC. 1LSV*SKD9A	221.512	RELI 254T	AB-141-2	HLBO HARSH	LCS -	1000 A -	-
1LSV*H2B	MOTOR TO DRIVE COMPRESSOR SUPERPPRESSURE INC. 1LSV*SKD9B	221.512	RELI 254T	AB-141-3	HLBO HARSH	LCS -	1000 A -	-
1LSV*PT10A	PRESSURE TRANSHITTER ROSEMOUNT	247.481	RSMT 1153GB7	AB-141-2	HLBO HARSH	LCS -	30 D A -	-
1LSV*PT10B	PRESSURE TRANSHITTER ROSEMOUNT	247.481	RSMT 1153GB7	AB-141-2	HLBO HARSH	LCS -	30 D A -	-
1LSV*PT12A	PRESSURE TRANSHITTER ROSEMOUNT	247.481	RSMT 1153GB7	AB-141-2	HLBO HARSH	LCS -	30 D A -	-

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBDIRG	EMRGCN ENVTYP	SFN1 SF2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
NGP CABLE								
INGP01	600 VOLT CONTROL CABLE OKONITE	241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP02	600 VOLT CONTROL CABLE OKONITE	241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP03	600 VOLT CONTROL CABLE OKONITE	241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP04	600 VOLT CONTROL CABLE OKONITE	241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP06	600 VOLT CONTROL CABLE OKONITE	241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP11	600 VOLT CONTROL CABLE OKONITE	241.240	NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP12	600 VOLT CONTROL CABLE OKONITE	241.240	NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP13	600 VOLT CONTROL CABLE OKONITE	241.240	OKONI NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP14	600 VOLT CONTROL CABLE OKONITE	241.240	OKONI NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP15	600 VOLT CONTROL CABLE OKONITE	241.240	NONE	VARIOUS	N/A HARSH	N/A	1000 A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	CP TIME OC BASIS	QRN1 QRN2 QRN3

NGP CABLE							
INGP16	600 VOLT CONTROL CABLE OKONITE 241.240	NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP22	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP24	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP26	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP27	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP28	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP30	600 VOLT CONTROL CABLE OKONITE 241.240	NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP32	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP33	600 VOLT CONTROL CABLE OKONITE 241.240	OKON NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGP36	600 VOLT CONTROL CABLE OKONITE 241.240		VARIOUS	HARSH		100D	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY HARK NO - HARSH ENVIRONMENT ONLY

HARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBHRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
NGP CABLE								
INGP37	600 VOLT CONTROL CABLE OHONITE	241.240		VARIOUS	HARSH		1000	
INGP42	600 VOLT CONTROL CABLE OHONITE	241.234		VARIOUS	HARSH		1000	
INGP50	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP51	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP52	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP53	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP54	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP55	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP56	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
INGP57	600 VOLT POWER CABLE OHONITE	241.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVYTP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
NGP CABLE								
1NGP58	600 VOLT POWER CABLE OKONITE	291.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
1NGP59	600 VOLT POWER CABLE OKONITE	291.234	OKON NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
1NGP61	ROCKBESTOS	291.242		VARIOUS	HARSH		1000	
1NGP62	ROCKBESTOS	291.242		VARIOUS	HARSH		1000	
1NGP63	SPECIAL INST. CABLE BRAND-REX	291.246		VARIOUS	HARSH		1000	
1NGP67	ROCKBESTOS	291.242		VARIOUS	HARSH		1000	
1NGP70	300 VOLT INSTRUMENTATION CABLE ROCKBESTOS	291.242	ROCK NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
1NGP71	300 VOLT INSTRUMENTATION CABLE ROCKBESTOS	291.242	ROCK NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
1NGP72	300 VOLT INSTRUMENTATION CABLE ROCKBESTOS	291.242	ROCK NONE	VARIOUS	N/A HARSH	N/A	1000 A -	
1NGP73	300 VOLT INSTRUMENTATION CABLE ROCKBESTOS	291.242	ROCK NONE	VARIOUS	N/A HARSH	N/A	1000 A -	

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EMRGCN ENVTYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
NCR CABLE								
INGR11	5KV POWER CABLE ANACONDA	241.232	NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGR12	5KV POWER CABLE ANACONDA	241.232	NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGR30	5KV POWER CABLE ANACONDA	241.232	NONE	VARIOUS	N/A HARSH	N/A	100D A -	
NGS CABLE								
INGS01	THERMOCOUPLE EXT. WIRE CABLE ROCKBESTOS	241.243	ROCK NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGS02	THERMOCOUPLE EXT. WIRE CABLE ROCKBESTOS	241.243	ROCK NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGS03	THERMOCOUPLE EXT. WIRE CABLE ROCKBESTOS	241.243	ROCK NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGS05	THERMOCOUPLE EXT. WIRE CABLE ROCKBESTOS	241.243	ROCK NONE	VARIOUS	N/A HARSH	N/A	100D A -	
INGS06	THERMOCOUPLE EXT. WIRE CABLE ROCKBESTOS	241.243	ROCK NONE	VARIOUS	HARSH		100D	
INGS11	SPECIAL INSTRUMENTATION CABLE BRAND REX	241.246	BNRX NONE	VARIOUS	N/A HARSH	N/A	100D A -	

RCS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

04/23/89
REVISION: 0-D
ISSUE DATE: 04/23/89

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC.NO	REMARKS	MODEL/CATALOG NO.	SUCRPG	ENV. ZONE	EURSCH	ENVTYP	SFNI	OP TIME	CRN1	SFNI	OC BASIS	CRN2	SFNI	OC BASIS	CRN3
INS	EMERGENCY SWV ELECTRICAL SYSTEM																		
INS+SJG5A	SWITCHGEAR	GOULD-BROWN BOVERI		242.521	CAT.II			FB-095-G		HARSH									
INS+SJG5B	SWITCHGEAR	GOULD-BROWN BOVERI		242.521	CAT.II			AD-114-6		HARSH									
RCP	ELECTRICAL PENETRATIONS																		
1RCP+LVC05	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC06	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC10A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC11	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC11A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC13A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				
1RCP+LVC18	ELECTRICAL PENETRATION ASSY	CONAX CORP		241.211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS		CT-G		HLBI HARSH				PNIT	1000				

04/23/84
 REVISION: 8-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	NAME/MANUFACTURER	ENV. ZONE	ENPCDN	SFNI	OP TIME	CRN1
	VENDOR	MODEL/CATALOG NO.	SUBGRS	ENVTP	SFNI	OC BASIS	CRN2
	PANEL/RACK	REMARKS			SFN3		CRN3

RCP ELECTRICAL PENETRATIONS							
1RCP4LVC18A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVC19A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVC20A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVC21	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVC21A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVI05A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVI06A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVI09C	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVI12	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	
1RCP4LVI12A	ELECTRICAL PENETRATION ASSY CONAX CORP	CONAX NONE-UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH		PNIT 1000 A	

RES-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

04/23/84
REVISION: 0-0
ISSUE DATE: 04/23/84

MARK NO	EQUIPMENT DESCRIPTION	NAME/MANUFACTURER	ENV. ZONE	ENGR CN	OP TIME	QTR1
PANEL/RACK	SPEC. NO	MODEL/CATALOG NO.	SUBORG	ENVTYP	DC BASIS	QTR2
		REMARKS				QTR3

PCP ELECTRICAL PENETRATIONS

IRCP-ALVII34	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII4	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII4A	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII5	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII5A	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII7	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX	CT-6	HARSH	1000
IRCP-ALVII7B	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII7C	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII8A	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP-ALVII8D	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE,UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC. NO	REMARKS	NAME, MANUFACTURER	ENV. ZONE	ENVIRON	SFN1	OP TIME	CRN1	SFN2	DC BASIS	CRN2	SFN3	
18CP*LV03	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV03A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV04	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV04A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV07	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV07A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV08	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV08A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV09	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		
18CP*LV09A	ELECTRICAL PENETRATION ASSY	CONAX CORP		241-211		CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT	1000		-	A	-		

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY HSN NO - HARSH ENVIRONMENT ONLY

04/23/84
REVISION: 0-0
ISSUE DATE: 04/23/84

HSN NO	EQUIPMENT DESCRIPTION	MANUFACTURER	ENV. ZONE	EMRGN	SFNI	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUSHRG	ENVTYP	SFNI	OC BASIS	QRN2
	PANEL/RACK	REV/ENS			SFNI		QRN3

RCP ELECTRICAL PENETRATIONS

IRCP+LVP16	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+LVP16A	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+LVP22	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+LVP22A	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MP01	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MP02	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MS10	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MS13	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MS19	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A
IRCP+MS20	ELECTRICAL PENETRATION ASSY CONAX CORP	241.211	CONX NONE, UNIQUE HLBI FOR INBOARD END, REMAINDER TRNS	CT-6	HLBI HARSH	PNIT 1000 A

MARK NO	EQUIPMENT DESCRIPTION	NAME/MAKE/FACTURER	ENV. ZONE	EMRCGN	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUBMRG	ENVTYP	SFN2	OC BASIS	QRN2
	PANEL/RACK	SPEC NO	FINARNS		SFN3		QRN3

RCP ELECTRICAL PENETRATIONS

1RCP*TCA01	TERMINAL CABINET PECP	N/A	AB-114-6	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA02	TERMINAL CABINET PECP	N/A	AB-114-6	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA03	TERMINAL CABINET PECP	N/A	AB-114-6	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA04	TERMINAL CABINET PECP	N/A	AB-114-6	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA05	TERMINAL CABINET PECP	N/A	AB-114-6	HLBO HARSH	RACK	N/R	
	242.491	N/R FOR SAFETY FUNCTION			-	A	-
1RCP*TCA06	TERMINAL CABINET PECP	N/A	AB-114-5	HLBO HARSH	RACK	N/R	
	242.491	N/R FOR SAFETY FUNCTION			-	A	-
1RCP*TCA07	TERMINAL CABINET PECP	N/A	AB-114-5	HLBO HARSH	RACK	N/R	
	242.491	N/R FOR SAFETY FUNCTION			-	A	-
1RCP*TCA08	TERMINAL CABINET PECP	N/A	AB-114-5	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA09	TERMINAL CABINET PECP	N/A	AB-114-5	HLBO HARSH	RACK	1000	
	242.491				-	A	-
1RCP*TCA10	TERMINAL CABINET PECP	N/A	AB-114-5	HLBO HARSH	RACK	1000	
	242.491				-	A	-

09/23/84
 REVISION: 0-D
 ISSUE DATE: 09/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER      ENV. ZONE      ENRGCH      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.      SUBDRG        ENVTYP      SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC.NO                REMARKS
*****
  
```

RCP ELECTRICAL PENETRATIONS

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	ENRGCH	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUBDRG	ENVTYP	SFN2	OC BASIS	QRN2
	PANEL/RACK	SPEC.NO	REMARKS		SFN3		QRN3
1RCP#TCA11	TERMINAL CABINET PECP	N/A	AB-141-4	HLBO HARSH	RACK	N/R	
		242.491	N/R FOR SAFETY FUNCTION		-	A	-
1RCP#TCA12	TERMINAL CABINET PECP	N/A	AB-141-4	HLBO HARSH	RACK	100D	
		242.491			-	A	-
1RCP#TCA13	TERMINAL CABINET PECP	N/A	AB-141-4	HLBO HARSH	RACK	N/R	
		242.491	N/R FOR SAETY FUNCTION		-	A	-
1RCP#TCA14	TERMINAL CABINET PECP	N/A	AB-141-3	HLBO HARSH	RACK	N/R	
		242.491	N/R FOR SAFETY FUNCTION		-	A	-
1RCP#TCA15	TERMINAL CABINET PECP	N/A	AB-141-3	HLBO HARSH	RACK	100D	
		242.491			-	A	-
1RCP#TCA16	TERMINAL CABINET PECP	N/A	FB-113-G	HLBO HARSH	RACK	N/R	
		242.491	N/R FOR SAFETY FUNCTION		-	A	-
1RCP#TCF01	TERMINAL CABINET PECP	N/A	FB-113-G	FHA HARSH	RACK	100D	
		242.491			-	A	-
1RCP#TCF02	TERMINAL CABINET PECP	N/A	FB-113-G	FHA HARSH	RACK	N/R	
		242.491	N/R FOR SAFETY FUNCTION		-	A	-
1RCP#TCF03	TERMINAL CABINET PECP	N/A	FB-113-G	FHA HARSH	RACK	100D	
		242.491			-	A	-
1RCP#TCF04	TERMINAL CABINET PECP	N/A	FB-113-G	FHA HARSH	RACK	100D	
		242.491			-	A	-

MARK NO	EQUIPMENT DESCRIPTION VENDOR PANEL/RACK	SPEC. NO	MAKE/MANUFACTURER MODEL/CATALOG NO. REMARKS	ENV. ZONE SUBMRG	EHRCGN ENV TYP	SFN1 SFN2 SFN3	OP TIME OC BASIS	QRN1 QRN2 QRN3
RCP ELECTRICAL PENETRATIONS								
1RCP*TCR01A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR01F	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR02A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR02F	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR03A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR03F	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR04A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR04F	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR05A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	
1RCP*TCR06A	TERMINAL CABINET PECP	242.491	N/A N/R FOR SAFETY FUNCTION	CT-G	HLBI HARSH	RACK -	N/R A -	

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

04/23/84
REVISION: 0-0
ISSUE DATE: 04/23/84

MARK NO	EQUIPMENT DESCRIPTION	VENDOR	PANEL/RACK	SPEC. NO	REASONS	MODEL/CATALOG NO.	SUBRG	ENV. ZONE	ENVYTR	SFNI OP TIME	QRM1	SFNI OC BASIS	QRM2	SFNI	QRM3
1RCP*TCR07A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR08A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR09A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR10A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR11A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR12A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR13A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR14A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR15A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			
1RCP*TCR16A	TERMINAL CABINET PECP			242.491	N/A	N/R FOR SAFETY FUNCTION	CT-6	MLBI HARSH		RACK	N/R	A			

RCP ELECTRICAL PENETRATIONS

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  EHRGCM      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG    ENVTYP      SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC. NO          REMARKS
*****
  
```

RMS RADIATION MONITORING

MARK NO	EQUIPMENT DESCRIPTION	MAKE/MANUFACTURER	ENV. ZONE	EHRGCM	SFN1	OP TIME	QRN1
	VENDOR	MODEL/CATALOG NO.	SUBMRG	ENVTYP	SFN2	OC BASIS	QRN2
	PANEL/RACK	SPEC. NO	REMARKS		SFN3		QRN3
1RHS*RE112	RADIOACTIVITY ELEMENT G A TECH		CT-4			100 D	
		247.250		HARSH			
1RHS*RE125	RADIOACTIVITY ELEMENT G A TECH		AB-170-1			100D	
		247.250	REG.G.1.97	HARSH			
1RHS*RE15A	RADIOACTIVITY ELEMENT G A TECH		AB-095-6			100D	
		247.250		HARSH			
1RHS*RE15B	RADIOACTIVITY ELEMENT G A TECH		AB-095-6			100D	
		247.250		HARSH			
1RHS*RE16A	RADIOACTIVITY ELEMENT G A TECH		CT-6			100D	
		247.250	REG.G.1.97	HARSH			
1RHS*RE16B	RADIOACTIVITY ELEMENT G A TECH		CT-6			100D	
		247.250	REG.G.1.97	HARSH			
1RHS*RE20A	RADIOACTIVITY ELEMENT G A TECH		DH-1			100D	
		247.250	REG.G.1.97	HARSH			
1RHS*RE20B	RADIOACTIVITY ELEMENT G A TECH		DH-1			100D	
		247.250	REG.G.1.97	HARSH			
1RHS*RE21A	RADIOACTIVITY ELEMENT G A TECH		CT-6			100D	
		247.250		HARSH			
1RHS*RE21B	RADIOACTIVITY ELEMENT G A TECH		CT-6			100D	
		247.250		HARSH			

04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG     ENVTP       SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC. NO           REMARKS     SFN3              QRN3
*****
  
```

RHS RADIATION MONITORING

```

1RMS*RE5A    RADIOACTIVITY ELEMENT          FB-148-G          1000
              G A TECH
              247.250    REG.G.1.97      HARSH

1RMS*RE5B    G A TECH                      FB-148-G          1000
              247.250    REG.G.1.97      HARSH

1RMS*RI21A   RADIOACTIVITY INDICATOR       CT-G              1000
              G A TECH
              247.250

1RMS*RI21B   RADIOACTIVITY INDICATOR       CT-G              1000
              G A TECH
              247.250
  
```

SAS SERVICE AIR

```

1SAS*HOV102  MOTOR OPERATED VALVE          AB-114-6          HLBO          CISL  1HR
              VELAN                      SHB-000-5         HARSH         LCS  A  -
              228.212

1SAS*HOV103  MOTOR OPERATED VALVE          AB-114-6          HLBO          CISL  1HR
              VELAN                      SHB-000-5         HARSH         LCS  A  -
              228.212
  
```

SCV STA CONT BUS (VITAL) - AC SUPPLY INCL TFMR & TRANS SW

```

1SCV*PNL2A1  STDBY DIST PNLBOARD 120 V AC  SQRD          CT-G          HLBO          PANL  1000
              SQUARE D COMPANY          NQOB          HARSH         -    A  -
              242.421

1SCV*PNL2A2  STDBY DIST PNLBOARD 120 V AC  SQRD          AN-3          HLBO          PANL  1000
              SQUARE D COMPANY          NQOB          HARSH         -    A  -
              242.421

1SCV*PNL2B1  STDBY DIST PNLBOARD 120 V AC  SQRD          CT-G          HLBO          PANL  1000
              SQUARE D COMPANY          NQOB          HARSH         -    A  -
              242.421
  
```


04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRQCN  SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG    ENVYTP  SFN2  OC BASIS  QRN2
              PANEL/RACK                SPEC.NO           REMARKS
*****
SVV STEAM VENTS - SAFETY VALVES

1SVV*ZE10E   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10F   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10G   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10H   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10J   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10K   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10L   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10M   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10N   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97

1SVV*ZE10P   PRIMARY POSITION ELEMENT          DH-1          HARSH          1000
              TECH FOR ENERGY CORP
              247.529                REG.G.1.97
  
```


04/23/84
 REVISION: 0-D
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

 MARK NO EQUIPMENT DESCRIPTION MAKE/MANUFACTURER ENV. ZONE ENRGCN SFN1 OP TIME QRN1
 VENDOR MODEL/CATALOG NO. SUBHRG ENVTYP SFN2 OC BASIS QRN2
 PANEL/RACK SPEC. NO REMARKS SFN3 QRN3

SNP SERVICE WATER

1SHP*HOV501B	MOTOR OPERATED VALVE JAHESBURY 228.243	LMTQ SHB-00-10	PT-2	HLBO HARSH	BCNT	100D A -	
1SHP*HOV502A	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-00-10	CT-G	HLBI HARSH	HVR	100D A -	
1SHP*HOV502B	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-00-10	CT-G	HLBI HARSH	HVR	100D A -	
1SHP*HOV503A	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-00-10	CT-G	HLBI HARSH	HVR	100D A -	
1SHP*HOV503B	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-00-10	CT-G	HLBI HARSH	HVR	100D A -	
1SHP*HOV504A	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-0-15	AB-070-8	HLBO HARSH	SH ESA	100D A -	
1SHP*HOV504B	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-0-15	AB-070-7	HLBO HARSH	SH ESA	100D A -	
1SHP*HOV506A	MOTOR OPERATED VALVE JAHESBURY 228.243	LMTQ SHB-000-2	PT-4	ABNO HARSH	ESA	100D D -	
1SHP*HOV506B	MOTOR OPERATED VALVE JAHESBURY 228.243	LMTQ SHB-000-2	PT-4	ABNO HARSH	ESA	100D D -	
1SHP*HOV507A	MOTOR OPERATED VALVE VELAN 228.212	LMTQ SHB-0-15	AB-114-6	HLBO HARSH	CISL	100D A -	

04/23/84
 REVISION: 0-0
 ISSUE DATE: 04/23/84

RBS-ENVIRONMENTAL QUALIFICATION DATA MASTER LIST
 SORTED BY MARK NO - HARSH ENVIRONMENT ONLY

```

*****
MARK NO      EQUIPMENT DESCRIPTION      MAKE/MANUFACTURER  ENV. ZONE  ENRGCN      SFN1  OP TIME  QRN1
              VENDOR                      MODEL/CATALOG NO.  SUBMRG     ENV TYP     SFN2  OC BASIS  QRN2
              PANEL/RACK          SPEC. NO          REMARKS     SFN3              QRN3
*****
SHP SERVICE WATER

1SHP*HOV96B  MOTOR OPERATED VALVE      LMTQ           PT-3        NORM        BCNT  1HR
              JAMESBURY                SMD-00-25      HARSH        -           D      -
              228.243

1SHP*PT21A   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK2          247.481

1SHP*PT21B   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK1          247.481

1SHP*PT21C   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK2          247.481

1SHP*PT21D   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK1          247.481

1SHP*PT21E   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK2          247.481

1SHP*PT21F   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK1          247.481

1SHP*PT21G   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK2          247.481

1SHP*PT21H   PRESSURE TRANSMITTER      RSMT           PT-3        NORM        SW     100D
              ROSEMOUNT                1153GB7        HARSH        BCNT  A      -
              1JPB*RAK1          247.481

1SHP*SOV51A  SOLENOID VALVE           ASCO           AB-141-2    HLBO        SW     100D
              FISHER CONTROLS         DEQ,NP8320     HARSH        BCNT  A      -
              247.491              LCS
  
```


RBS EQD

APPENDIX A.2
SAFETY-RELATED ELECTRICAL EQUIPMENT - NSSS
(LATER)

RBS EQD

APPENDIX A.3
SAFETY-RELATED MECHANICAL EQUIPMENT - BOP
(LATER)

RBS EQD

APPENDIX A.4

SAFETY-RELATED MECHANICAL EQUIPMENT - NSSS

(LATER)

RBS EQD

APPENDIX B
SYSTEM COMPONENT EVALUATION WORK (SCEW) SHEETS.

(LATER)