MEMORANDUM FOR:

James R. Miller, Chief

Operating Reactors Branch No. 3

Division of Licensing

Distribution: Docket File Memo File RIngram

FROM:

John F. Stolz, Chief

Operating Reactors Branch No. 4

Division of Licensing

JVanVliet OThompson

SUBJECT:

REQUEST FOR PUBLICATION IN MONTHLY FR NOTICE-

NOTICE OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING

LICENSE

GPU Nuclear Corporation, et al., Docket No. 50-289, Three Mile Island Nuclear Station, Unit No. 1, Dauphin County, Pennsylvania

Date of application for amendment: April 21, 1982

Brief description of amendment: This amendment changes Section 4.4.1.2 of the Technical Specifications regarding local leakage rate testing of containment isolation valves and resilient seals in penetrations. The amendment adds several valves to the Type C testing program and deletes other valves. The amendment also includes editorial changes.

Date of issuance: May 18, 1984

Effective date: May 18, 1984

Amendment No. 93

Facility Operating License No. DPR-50. Amendment revised the Technical Specifications.

Date of initial notice in Federal Register: November 22, 1983, 48 FR 52816

The Commission's related evaluation of the amendment is contained in a

Safety Evaluation dated May 18, 1984.

No significant hazards consideration comments received: No

Local Public Document Room location: Government Publications Section,
State Library of Pennsylvania, Education Building, Commonwealth and
Walnut Streets, Harrisburg, Pennsylvania 17126

John F. Stolz, Chief Operating Reactors Branch No. 4 Division of Licensing

ORB#4.DL/ RIngram;ef C5/\/84 ORB#4:DL Gold JVanVliet;ef 05/11/84

ORB#4:DL JFSto1z 05/ 1/84 OEVD Julburg 05/4 184

oThompson