

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

May 25, 1984

Director of Nuclear Reactor Regulation
Attention: Ms. E. Adensam, Chief
Licensing Branch No. 4
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

In accordance with 10 CFR Part 50.90, we are enclosing 40 copies of a requested amendment to the operating licenses, DPR-77 and DPR-79, to change the Sequoyah Nuclear Plant units 1 and 2 technical specifications (T/S). The proposed changes are provided in Enclosure 1. These proposed changes revise surveillance requirement (S/R) 4.6.1.3.a to delete the 15-minute time period when performing the pressure decay test for containment air lock door seals. The justification for the proposed T/S changes are provided in Enclosure 2.

In accordance with the provisions of 10 CFR Part 170.22, we have determined the proposed amendment to be Class II for unit 1 and Class I for unit 2. These classifications are based on the facts that the changes involve a single-safety issue and the changes apply to two identical units on the same site. The remittance fee of \$4,400 is being wired to the Nuclear Regulatory Commission, Attention: Licensing Fee Management Branch.

This requested amendment has been evaluated pursuant to 10 CFR Part 50.92 and no significant hazards considerations are involved.

8405310121 840525
PDR ADOCK 05000327
P PDR

Adock


Director of Nuclear Reactor Regulation

May 25, 1984

If you have any questions concerning this matter, please get in touch with Jerry Wills at FTS 858-2683.


Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager
Nuclear Licensing

Sworn to and subscribed before me
this 25th day of May 1984



Notary Public

My Commission Expires 9-5-84

Enclosures

cc: U.S. Nuclear Regulatory Commission (Enclosures)
Region II
Attn: Mr. James P. O'Reilly Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30303

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATIONS
SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2