



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

METROPOLITAN EDISON COMPANY

JERSEY CENTRAL POWER AND LIGHT COMPANY

PENNSYLVANIA ELECTRIC COMPANY

GPU NUCLEAR CORPORATION

DOCKET NO. 50-289

THREE MILE ISLAND NUCLEAR STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 94
License No. DPR-50

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by GPU Nuclear Corporation, et al (the licensees) dated March 9, 1983, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

8405310134 840522
PDR ADOCK 05000289
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.c.(2) of Facility Operating License No. DPR-50 is hereby amended to read as follows:

Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 94, are hereby incorporated in the license. GPU Nuclear Corporation shall operate the facility in accordance with the Technical Specifications.

3. This license amendment becomes effective within 30 days after its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


John F. Stolz, Chief
Operating Reactors Branch No. 4
Division of Licensing

Attachment:
Changes to the Technical
Specifications

Date of Issuance: May 22, 1984

ATTACHMENT TO LICENSE AMENDMENT NO. 94

FACILITY OPERATING LICENSE NO. DPR-50

DOCKET NO. 50-289

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the areas of change.

Remove

3-65
3-66
3-69

Insert

3-65
3-66
3-69

SAFETY RELATED SHOCK SUPPRESSORS (SNUBBERS)

Snubber MK No.	Location	Elevation	Snubber in High Radiation Area During Shutdown*	Snubber Especially Difficult To Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Normal Operation
RC-4	R.B. Inside Sec. Shield N.E. Quad.	355	No	Yes	Yes	No
RC-5	Rx. Bldg. Inside Sec. Shield N.E. Quad. Top of PZR Near RC-V3	355	No	No	Yes	No
RC-15	Rx. Bldg. Inside Sec. Shield N.E. Quad. Top of PZR Near RC-V3	355	No	No	Yes	No
RC-16	Rx. Bldg. Inside Sec. Shield N.E. Quad. Top of PZR Near RC-V3	355	No	No	Yes	No
RC-17	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V1	355	No	No	Yes	No
RC-18	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V1	355	No	No	Yes	No
RC-19	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V1	355	No	No	Yes	No
RC-23	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V1	355	No	No	Yes	No
RC-9	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V31	346	No	No	Yes	No
RC-7	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V31	353	No	No	Yes	No
RC-8	Rx. Bldg. Inside Sec. Shield N.E. Quad. Near RC-V31	353	No	No	Yes	No
RC-6	Rx. Bldg. Inside Sec. Shield N.E. Quad.	353	No	No	Yes	No
RC-10	Rx. Bldg. Inside Sec. Shield N.E. Quad.	346	No	No	Yes	No
RC-11	Rx. Bldg. Inside Sec. Shield N.E. Quad.	328	No	No	Yes	No
RC-12	Rx. Bldg. Inside Sec. Shield N.E. Quad.	328	No	No	Yes	No

TABLE 3.16.1
SAFETY RELATED SHOCK SUPPRESSORS (SNUBBERS)

Snubber MK No.	Location	Eleva- tion	Snubber In High Radiation Area During Shutdown*	Snubber Especially Difficult To Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Normal Operation
RC-13	Rx. Bldg. Inside Sec. Shield N.E. Quad.	321	No	No	Yes	No
RC-14	Rx. Bldg. Inside Sec. Shield N.E. Quad.	321	No	No	Yes	No
HUE-38	Rx. Bldg. Inside Sec. Shield N.E. Quad.	318	No	No	Yes	No
HUE-39	Rx. Bldg. Inside Sec. Shield N.E. Quad.	318	No	No	Yes	No
PR-23	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1A Disch. Line	340	No	No	Yes	No
PR-24	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1A Disch. Line	340	No	No	Yes	No
PR-25	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1B Disch. Line	340	No	No	Yes	No
PR-26	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1B Disch. Line	340	No	No	Yes	No
PR-34	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1A Disch. Line	345	No	No	Yes	No
PR-36	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1A Disch. Line	345	No	No	Yes	No
PR-35	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1B Disch. Line	345	No	No	Yes	No
PR-37	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1B Disch. Line	345	No	No	Yes	No
PR-47	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-2 Disch. Line	355	No	No	Yes	No
PR-48	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-2 Disch. Line	355	No	No	Yes	No
PR-52	Rx. Bldg. Inside Sec. Shield N.E. Quad. RC-RV-1 Disch. Line	345	No	No	Yes	No

TABLE 3.16.1
SAFETY RELATED SHOCK SUPPRESSORS (SNUBBERS)

Snubber MK No.	Location	Eleva- tion	Snubber In High Radiation Area During Shutdown*	Snubber Especially Difficult To Remove	Snubbers Inaccessible During Normal Operation	Snubbers Accessible During Normal Operation
DH-34	Rx. Bldg. Inside Sec. Shield S.W. Quad. at DH-VI	305	No	No	Yes	No
FW-114	Rx. Bldg. Inside Sec. Shield S. W. Quad.	325	No	No	Yes	No
FW-115	Rx. Bldg. Inside Sec. Shield S. W. Quad.	325	No	No	Yes	No
EF-113	Rx. Bldg. Inside Sec. Shield S.W. Quad.	320	No	Yes	Yes	No
DH-4	Rx. Bldg. Inside Sec. Shield S.W. Quad.	302	No	Yes	Yes	No
DH-5	Rx. Bldg. Inside Sec. Shield S.W. Quad.	302	No	Yes	Yes	No
CF-6	Rx. Bldg. Inside Sec. Shield S.W. Quad.	316	No	No	Yes	No
DH-32	Rx. Bldg. Outside Sec. Shield N. E. Quad.	340	No	No	No	Yes
MS-202	Rx. Bldg. Outside Sec. Shield N.E. Quad.	337	No	Yes **	No	No
MS-203	Rx. Bldg. Outside Sec. Shield N.E. Quad.	337	No	Yes **	No	No
MS-206	Rx. Bldg. Outside Sec. Shield N.E. Quad.	337	No	Yes **	No	No
MS-207	Rx. Bldg. Outside Sec. Shield N.E. Quad.	337	No	Yes **	No	No
RC-154	Rx. Bldg. Outside Sec. Shield N.E. Quad.	301	No	Yes	No	No
RC-160A&B	Rx. Bldg. Outside Sec. Shield N.E. Quad.	336	No	Yes	No	No

Amendment No. 57, 94

3-69