VIRGINIA ÉLECTRIC AND POWER COMPANY RICHMOND, VIRGINIA 20261

April 3, 1992

U. S. Nuclear Regulatory Commission Attn.: Document Control Desk Washington, D.C. 20555 Serial No. 92-222 NL&P/TAH: R0 Docket No. 50-339 Licanse No. NPF-7

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT NO. 2
WITHDRAWAL OF ASME SECTION XI RELIEF REQUEST
TEMPORARY NON-CODE REPAIR TO A CLASS 2 COMPONENT

On December 21, 1990, Virginia Electric and Power Company submitted a ASME Section XI relief request, pursuant to 10 CFR 50.55a(g)(5), associated with a temporary non-code repair of a 3/4-inch vent line on the "A" main steam line for North Anna Unit 2. A pin-hole leak had developed between the main steam trip valve and the non-return valve outside of containment. The relief request described that the flaw was discovered during power operation and that the Unit would have had to be shut down in order to perform a Code repair.

The relief request also described that the temporary repair was an engineered, mechanical enclosure filled with a hardened liquid sealant that is fabricated from safety related materials and designed for the pressure and temperature rating of the main steam system. The request further stated that the engineered, temporary repair enclosure was intended for use until the first opportunity for completion of a Code repair.

On September 23, 1991, the temporary repair enclosure was removed and the flawed section of piping was replaced in accordance with ASME Section XI requirements. As a result of this repair activity, our December 21, 1990 relief request is no longer needed and is withdrawn.

If you have any questions, please contact us.

Very truly yours,

W. L. Stewart

Senior Vice President - Nuclear

A047 1/0

9204100120 920403 PDR ADOCK 05000339 PDR

Docket No. 50-339 Serial No. 92-222

cc: U.S. Nuclear Regulatory Commission Region II 101 Marietta Street, N.W. Suite 2900 Atlanta, Georgia 30323

> Mr. M. S. Lesser NRC Senior Resident Inspector North Anna Power Station