


1901 Chouteau Avenue  
Post Office Box 149  
St. Louis, Missouri 63166  
314-621-3222



April 6, 1992

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, D.C. 20555

Gentlemen:

ULNRC-2610

DOCKET NUMBER 50-483  
CALLAWAY PLANT  
AMENDMENT NUMBER 64

This is to inform the Commission of the implementation of Amendment No. 64 to the Callaway Facility Operating License No. NPF-30. Amendment No. 64 approved Technical Specification changes to extend the allowable out-of-service times (AOTs) and the surveillance test intervals (STIs) for the analog channels of the Engineered Safety Features Actuation System (ESFAS). These changes also included extended AOTs for the ESFAS actuation logic and actuation relays of the solid state protection system (SSPS). The changes have been issued to all controlled Technical Specification holders and became effective on October 22, 1991.

Very truly yours,

*David Shafer*  
for A. C. Passwater  
Manager, Licensing and Fuels

600040

GGY/kea

9204100162 920406  
PDR ADOCK 05000483  
P PDR

ADD 1/0

cc: T. A. Baxter, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N. Street, N.W.  
Washington, D.C. 20037

Dr. J. O. Cermak  
CFA, Inc.  
18225-A Flower Hill Way  
Gaithersburg, MD 20879-5334

R. C. Knop  
Chief, Reactor Project Branch 1  
U.S. Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Bruce Bartlett  
Callaway Resident Office  
U.S. Nuclear Regulatory Commission  
RR#1  
Steedman, Missouri 65077

L. R. Wharton (2)  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
1 White Flint, North, Mail Stop 13E21  
11555 Rockville Pike  
Rockville, MD 20852

Manager, Electric Department  
Missouri Public Service Commission  
P.O. Box 360  
Jefferson City, MO 65102

Ron Kucera  
Department of Natural Resources  
P.O. Box 176  
Jefferson City, MO 65102