## BEFORE THE

## UNITED STATES NUCLEAR REGULATORY COMMISSION

In the Matter of the Facility Operating License)
of

PUBLIC SERVICE COMPANY OF COLORADO

Application for Amendment to Appendix A of Facility Operating License License No. DPR-34

OF THE

PUBLIC SERVICE COMPANY OF COLORADO

FOR THE

FORT ST. VRAIN NUCLEAR GENERATING STATION

This application for Amendment to Appendix A of Facility Operating License, License No. DPR-34, is submitted for NRC review and approval.

Respectfully submitted,

PUBLIC SERVICE COMPANY OF COLORADO

By A. Clegg Crawford Vice President Nuclear Operations

KELLY, STANSFIELD & O'DONNELL
James K. Tarpey
Mark A. Davidson
Public Service Company Building
Denver, Colorado 80202

Attorneys for Applicant

9110290010 911011 PDR ADOCK 05000267 PDR ATTACHMENT 1

70 P-91298

SUMMARY OF PROPOSED CHANGES

## Summary of Proposed Changes

Specification

Changes

LCO 4.2.15

The maximum outlet water temperature of the PCRV liner cooling water system in part b) has been reduced from 120 degrees F to 105 degrees F. The minimum average of the inlet and outlet PCRV liner cooling water temperatures in part e) has been recooling water temperatures from 100 degrees F to 85 degrees F. The base or LCO 4.2.15 has been revised to include the justification for the reduced allowable PCRV liner cooling water temperatures.