

# The Light company

Houston Lighting & Power

South Texas Project Electric Generating Station P. O. Box 289 Wadsworth, Texas 77483

April 10, 1992  
ST-HL-AE-4061  
File No.: G02  
10CFR50.71

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, DC 20555

South Texas Project  
Units 1 & 2  
Docket Nos. STN 50-498 & 50-499  
Monthly Operating Reports for March, 1992

Pursuant to 10CFR50.71(a) and South Texas Project Electric  
Generating Station (STPEGS) Technical Specification 6.9.1.5,  
attached are the Monthly Operating Reports for March, 1992.

If you should have any questions on this matter, please  
contact Mr. C. A. Ayala at (512) 972-8628.

*William J. Jump*  
William J. Jump  
Manager  
Nuclear Licensing

MKJ/lf

- Attachments: 1) STPEGS Unit 1 Monthly Operating Report -  
March, 1992  
2) STPEGS Unit 2 Monthly Operating Report -  
March, 1992

9204130283 920331  
PDR ADDCK 05000498  
R PDR

RREP\92098002.162

A Subsidiary of Houston Industries Incorporated

IS24  
||

Houston Lighting & Power Company  
South Texas Project Electric Generating Station

ST-HL-AL- 4061  
File No.: G02  
Page 2

cc:

Regional Administrator, Region IV  
Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 400  
Arlington, TX 76011

George Dick, Project Manager  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

J. I. Tapia  
Senior Resident Inspector  
c/o U. S. Nuclear Regulatory  
Commission  
P. O. Box 910  
Bay City, TX 77414

J. R. Newman, Esquire  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, DC 20036

D. E. Ward/T. M. Puckett  
Central Power and Light Company  
P. O. Box 2121  
Corpus Christi, TX 78403

J. C. Lanier/M. B. Lee  
City of Austin  
Electric Utility Department  
P.O. Box 1088  
Austin, TX 78767

K. J. Fiedler/M. T. Hardt  
City Public Service Board  
P. O. Box 1771  
San Antonio, TX 78296

Rufus S. Scott  
Associate General Counsel  
Houston Lighting & Power Company  
P. O. Box 61867  
Houston, TX 77208

INPO  
Records Center  
1100 Circle 75 Parkway  
Atlanta, GA 30339-3064

Dr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, NY 11713

D. K. Lacker  
Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, TX 78756-3189

Revised 10/11/91

L4/NRC/

SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION  
UNIT 1  
MONTHLY OPERATING REPORT  
MARCH 1992  
HOUSTON LIGHTING AND POWER CO.  
NRC DOCKET NO. 50-498  
LICENSE NO. NPF-76

Reviewed By: <u><i>[Signature]</i></u>	<u>4-7-92</u>
Supervisor	Date
Reviewed By: <u><i>[Signature]</i></u>	<u>4-7-92</u>
Plant Engineering Manager	Date
Approved By: <u><i>[Signature]</i></u>	<u>4/8/92</u>
Plant Manager	Date

Monthly Summary

STPEGS Unit 1 began the reporting period at 100% reactor power.

On 3/14/92 at 1109 a reactor trip occurred due to a momentary false reactor coolant flow trip signal. Maintenance was being performed to calibrate a LOOP 2 Reactor Coolant Flow, Protection Set flow transmitter. Following calibration, when returning the transmitter to service, the high pressure side of the transmitter was opened first instead of the low pressure side to pressurize the transmitter. This caused a momentary low (below setpoint) differential pressure to be detected by two adjacent flow transmitters which initiated a reactor trip caused by a reactor coolant low flow indication.

The cause of the trip was attributed to failure to follow procedures. The unit was returned to service on 3/17/92 at 2359 and concluded the reporting period at full power.

OPERATING DATA REPORT

DOCKET NO. 50-498  
 UNIT 1  
 DATE Apr. 2, 1992  
 COMPLETED BY A.P. Kent  
 TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 03/01-03/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3800  
 MAX. DEPEND. CAPACITY (MWe-Net): 1250.6  
 DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>668.6</u>	<u>2108.6</u>	<u>22128.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>659.2</u>	<u>2099.2</u>	<u>21311.4</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWt)....	<u>2470851</u>	<u>7960369</u>	<u>78114691</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)..	<u>834460</u>	<u>2718120</u>	<u>26426120</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>798605</u>	<u>2606156</u>	<u>24934525</u>
12. REACTOR SERVICE FACTOR.....	<u>89.9%</u>	<u>96.5%</u>	<u>70.1%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>89.9%</u>	<u>96.5%</u>	<u>70.1%</u>
14. UNIT SERVICE FACTOR.....	<u>88.6%</u>	<u>96.1%</u>	<u>67.5%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>88.6%</u>	<u>96.1%</u>	<u>67.5%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>85.8%</u>	<u>95.4%</u>	<u>63.2%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>85.8%</u>	<u>95.4%</u>	<u>63.2%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>11.4%</u>	<u>3.9%</u>	<u>13.4%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH):	<p>Scheduled 8 day maintenance outage to begin April 6, 1992. Refueling and scheduled maintenance outage to begin September 19, 1992.</p>		
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP:	<u>N/A</u>		

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-498  
UNIT 1  
DATE Apr. 2, 1992  
COMPLETED BY A. P. Kent  
TELEPHONE 512/972-7786

MONTH MARCH

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>1258</u>
2	<u>1257</u>
3	<u>1258</u>
4	<u>1258</u>
5	<u>1258</u>
6	<u>1255</u>
7	<u>1253</u>
8	<u>1252</u>
9	<u>1254</u>
10	<u>1256</u>
11	<u>1255</u>
12	<u>1258</u>
13	<u>1256</u>
14	<u>555</u>
15	<u>0</u>
16	<u>0</u>

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	<u>0</u>
18	<u>652</u>
19	<u>1215</u>
20	<u>1217</u>
21	<u>1217</u>
22	<u>1219</u>
23	<u>1221</u>
24	<u>1221</u>
25	<u>1221</u>
26	<u>1219</u>
27	<u>1207</u>
28	<u>1131</u>
29	<u>1216</u>
30	<u>1219</u>
31	<u>1218</u>

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-4  
 UNIT 1  
 DATE APR 1  
 COMPLETED BY A.P.  
 TELEPHONE 512/9

REPORT MONTH MARCH

No.	Date	Type	Duration (Hours)	Reason	Method of Shutting Down Reactor	Licensee Event Report #	System Code	Component Code	Cause & Corrective Action to Prevent Recurrence
92-01	920314	F	84.8	G	3	1-92-003	AB	FI1	A reactor trip occurred due to a momentary false reactor coolant flow trip signal. Maintenance was being performed to calibrate a LOOP 2 Reactor Coolant Flow Protection Set flow transmitter. Following calibration, when returning the transmitter to service, the high side of the transmitter was opened first instead of the low pressure side to pressurize the transmitter. This caused a momentary low (below setpoint) differential pressure to be detected by two adjacent flow transmitters which initiated a reactor trip caused by a reactor coolant low flow indication.  Corrective actions to prevent recurrence will be addressed in the LER.

1 F: Forced  
 S: Scheduled

2 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Exam  
 F-Administrative  
 G-Operational Error (Explain)

3 Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Cont. of Existing  
 5-Reduction  
 9-Other

4 IEEE 805-1983

5 IEEE 803A-1983

PORVs and Safety Valves Summary

There were no PORV or Safety Valves challenged during the reporting period.

SOUTH TEXAS PROJECT  
ELECTRIC GENERATING STATION  
UNIT 2  
MONTHLY OPERATING REPORT  
MARCH 1992  
HOUSTON LIGHTING AND POWER CO.  
NRC DOCKET NO. 50-499  
LICENSE NO. NPF-80

Reviewed By: *[Signature]* 4-7-92  
Supervisor Date  
Reviewed By: *[Signature]* 4-7-92  
Plant Engineering Manager Date  
Approved By: *[Signature]* 4/2/92  
Plant Manager Date

Monthly Summary

STPEGS Unit 2 began the reporting period at 100% reactor power.

On 3/9/92 Steam Generator Feedwater Pump Turbine 23 was tripped due to an electro-hydraulic control fluid leak on the line to the low pressure stop valve. The fluid leak caused the stop valve to stick in the open position. A weld had cracked causing a leak to develop. The weld and a portion of the line was replaced. Two hydraulic actuators were replaced to allow the stop valve to return to service. During the loss of the feedwater pump turbine, the Master Controller was responding erratically. Reactor power was reduced to 49% to minimize the possibility of a unit trip during troubleshooting. A spike was detected on an auxiliary relay card in the 7300 cabinet. The card was replaced and the unit was returned to full power on 3/12/92.

On 3/30/92 Steam Generator Feedwater Pump Turbine 27 tripped on low oil pressure when a main oil pump tripped due to a fault in the cabling. Reactor power was reduced to 48% while investigating the cause of the pump trip. The cable at the oil pump was repaired. The unit completed the reporting period with the unit approaching full power.

OPERATING DATA REPORT

DOCKET NO. 50-499  
 UNIT 2  
 DATE Apr 2, 1992  
 COMPLETED BY A.P. Kent  
 TELEPHONE 512/972-7786

OPERATING STATUS

1. REPORTING PERIOD: 03/01-03/31 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 3800  
 MAX. DEPEND. CAPACITY (MWe-Net): 1250.6  
 DESIGN ELECTRICAL RATING (MWe-Net): 1250.6
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL.....	<u>744.0</u>	<u>2035.6</u>	<u>17458.2</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>1998.3</u>	<u>16480.5</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWt)....	<u>2663411</u>	<u>7366291</u>	<u>59759562</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)..	<u>408680</u>	<u>2513490</u>	<u>20180850</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>870309</u>	<u>2407855</u>	<u>19111858</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>93.2%</u>	<u>71.5%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>93.2%</u>	<u>71.5%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>91.5%</u>	<u>67.5%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>91.5%</u>	<u>67.5%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>93.5%</u>	<u>88.2%</u>	<u>62.6%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)...	<u>93.5%</u>	<u>88.2%</u>	<u>62.6%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>8.5%</u>	<u>15.5%</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE AND DURATION OF EACH): N/A			
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: <u>N/A</u>			

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-499  
UNIT 2  
DATE Apr. 2, 1992  
COMPLETED BY A. P. Kent  
TELEPHONE 512/972-7786

MONTH MARCH

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	1251
2	1254
3	1255
4	1256
5	1255
6	1254
7	1255
8	1255
9	976
10	543
11	545
12	962
13	1252
14	1251
15	1249
16	1249

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	1252
18	1255
19	1257
20	1255
21	1256
22	1256
23	1252
24	1250
25	1250
26	1255
27	1256
28	1253
29	1256
30	1252
31	649

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499  
 UNIT 2  
 DATE Apr. 2, 1992  
 COMPLETED BY A.P. Kent  
 TELEPHONE 512/972-7786

REPORT MONTH MARCH

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
92-03	920309	F	0.0	B	5	N/A	JC	P	Steam Generator Feedwater Pump Turbine 23 was tripped due to an electro-hydraulic control fluid leak on the line to the low pressure stop valve. The fluid leak caused the stop valve to stick in the open position. A weld had cracked causing a leak to develop. The weld and a portion of the line was replaced. Two hydraulic actuators were replaced to allow the stop valve to return to service. During the loss of the feedwater pump turbine, the Master Controller was responding erratically. The reactor was reduced to 49% to minimize the possibility of a unit trip during troubleshooting. A spike was detected on an auxiliary relay card in the 7300 cabinet. The card was replaced.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup> Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Exam  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup> Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Cont. of Existing Outage  
 5-Reduction  
 9-Other

<sup>4</sup> IEEE 805-1983

<sup>5</sup> IEEE 803A-1983

ATTACHMENT 2  
 ST-11-AE-4061  
 PAGE 5 OF 7

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-499  
 UNIT 2  
 DATE Apr. 2, 1992  
 COMPLETED BY A. P. Kent  
 TELEPHONE 512/972-7786

REPORT MONTH MARCH

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
92-04	920330	F	0.0	B	5	N/A	SJ	P	Steam Generator Feedwater Pump Turbine 22 tripped on low oil pressure when a main oil pump tripped due to a fault in the cabling. Reactor power was reduced to 48% while investigating the cause of the pump trip. The cable at the oil pump was repaired.

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup> Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance or Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Exaa  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup> Method:  
 1-Manual  
 2-Manual Scram  
 3-Automatic Scram  
 4-Cont. of Existing Outage  
 5-Reduction  
 9-Other

<sup>4</sup> IEEE 805-1983

<sup>5</sup> IEEE 803A-1983

ATTACHMENT 2  
 ST-HI-AE-4061  
 PAGE 6 OF 7

PORVs and Safety Valves Summary

There were no PORV or Safety Valves challenged during the reporting period.