



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-454

BYRON STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 45
License No. NPF-37


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated October 26, 1990, as supplemented April 23, 1991, November 18, 1991 and February 6, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-37 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 45 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



for

Richard J. Barrett, Director
Project Directorate III-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 25, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 45

FACILITY OPERATING LICENSE NO. NPF-37

DOCKET NO. STN 50-454

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the attached pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

Remove Pages

Insert Pages

2-5

2-5

3/4 3-26

3/4 3-26

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

<u>FUNCTIONAL UNIT</u>	<u>TOTAL ALLOWANCE (TA)</u>	<u>Z</u>	<u>SENSOR ERROR (SE)</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
12. Reactor Coolant Flow-Low	2.5	1.77	0.6	>90% of loop minimum measured flow*	>89.2% of loop minimum measured flow*
13. Steam Generator Water Level Low-Low					
a. Unit 1	N.A.	N.A.	N.A.	>33.0% of narrow range instrument span	>31.0% of narrow range instrument span
b. Unit 2	N.A.	N.A.	N.A.	>36.3% of narrow range instrument span	>35.4% of narrow range instrument span
14. Undervoltage - Reactor Coolant Pumps	12.0	0.7	0	>5268 volts - each bus	>4728 volts - each bus
15. Underfrequency - Reactor Coolant Pumps	14.4	13.3	0	>57.0 Hz	>56.5 Hz
16. Turbine Trip					
a. Emergency Trip Header Pressure	N.A.	N.A.	N.A.	>540 psig	>520 psig
b. Turbine Throttle Valve Closure	N.A.	N.A.	N.A.	>1% open	>1% open
17. Safety Injection Input from ESF	N.A.	N.A.	N.A.	N.A.	N.A.
18. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.	N.A.	N.A.	N.A.

*Minimum measured flow = 97,600 gpm

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (SE)	TRIP SETPOINT	ALLOWABLE VALUE
5. Turbine Trip and Feedwater Isolation (continued)					
c. Safety Injection	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.				
6. Auxiliary Feedwater					
a. Manual Initiation	N.A.	N.A.	N.A.	N.A.	N.A.
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.	N.A.
c. Steam Generator Water Level-Low-Low-Start Motor-Driven Pump and Diesel-Driven Pump					
1) Unit 1	N.A.	N.A.	N.A.	>33.0% of narrow range instrument span	>31.0% of narrow range instrument span
2) Unit 2	N.A.	N.A.	N.A.	>36.3% of narrow range instrument span	>35.4% of narrow range instrument span
d. Undervoltage-RCP Bus-Start Motor Driven Pump and Diesel-Driven Pump	N.A.	N.A.	N.A.	>5268 volts	>4728 volts
e. Safety Injection-Start Motor-Driven Pump and Diesel-Driven Pump	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.				

BYRON - UNITS 1 & 2

3/4 3-26

Amendment No. 45



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. STN 50-456

BRAIDWOOD STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 34
License No. NPF-72

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Commonwealth Edison Company (the licensee) dated October 26, 1990, as supplemented April 23, 1991, November 18, 1991 and February 6, 1992, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-72 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A as revised through Amendment No. 34 and the Environmental Protection Plan contained in Appendix B, both of which are attached hereto, are hereby incorporated into this license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



for

Richard J. Barrett, Director
Project Directorate III-2
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: March 25, 1992

ATTACHMENT TO LICENSE AMENDMENT NO. 34

FACILITY OPERATING LICENSE NO. N.F-72

DOCKET NO. STN 50-456

Replace the following pages of the Appendix "A" Technical Specifications with the attached pages. The revised pages are identified by amendment number and contain vertical lines indicating the area of change.

Remove Pages

Insert Pages

2-5

2-5

3/4 3-26

3/4 3-26

3/4 3-26a

-

BRAIDWOOD - UNITS 1 & 2

2-5

Amendment No. 34

TABLE 2.2-1 (Continued)

REACTOR TRIP SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA)	Z	SENSOR ERROR (SE)	TRIP SETPOINT	ALLOWABLE VALUE
12. Reactor Coolant Flow-Low	2.5	1.77	0.6	>90% of loop minimum measured flow*	>89.2% of loop minimum measured flow*
13. Steam Generator Water Level Low-Low					
a. Unit 1	N.A.	N.A.	N.A.	>33.0% of narrow range instrument span	>31.0% of narrow range instrument span
b. Unit 2	17.0 (Cycle 3) N.A. (Cycle 4 and after)	14.78 (Cycle 3) N.A. (Cycle 4 and after)	1.5 (Cycle 3) N.A. (Cycle 4 and after)	>17% (Cycle 3); >36.3% (Cycle 4 and after) of narrow range instrument span	>15.3% (Cycle 3); >35.4% (Cycle 4 and after) of narrow range instrument span
14. Undervoltage - Reactor Coolant Pumps	12.0	0.7	0	>5268 volts - each bus	>4728 volts - each bus
15. Underfrequency - Reactor Coolant Pumps	14.4	13.3	0	>57.0 Hz	>56.5 Hz
16. Turbine Trip					
a. Emergency Trip Header Pressure	N.A.	N.A.	N.A.	>540 psig	>520 psig
b. Turbine Throttle Valve Closure	N.A.	N.A.	N.A.	>1% open	>1% open
17. Safety Injection Input from ESF	N.A.	N.A.	N.A.	N.A.	N.A.
18. Reactor Coolant Pump Breaker Position Trip	N.A.	N.A.	N.A.	N.A.	N.A.

*Minimum measured flow = 97,600 gpm

TABLE 3.3-4 (Continued)

ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION TRIP SETPOINTS

FUNCTIONAL UNIT	TOTAL ALLOWANCE (TA) Z	SENSOR ERROR (SE)	TRIP SETPOINT	ALLOWABLE VALUE
5. Turbine Trip and Feedwater Isolation (continued)				
c. Safety Injection	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.			
6. Auxiliary Feedwater				
a. Manual Initiation	N.A.	N.A.	N.A.	N.A.
b. Automatic Actuation Logic and Actuation Relays	N.A.	N.A.	N.A.	N.A.
c. Steam Generator Water Level-Low-Low-Start Motor-Driven Pump and Diesel-Driven Pump				
1) Unit 1	N.A.	N.A.	N.A.	>33.0% of narrow range instrument span >31.0% of narrow range instrument span
2) Unit 2	17.0 (Cycle 3) N.A. (Cycle 4 and after)	14.78 (Cycle 3) N.A. (Cycle 4 and after)	1.5 (Cycle 3) N.A. (Cycle 4 and after)	>17% (Cycle 3); >36.3% (Cycle 4 and after) of narrow range instrument span >15.3% (Cycle 3); >35.4% (Cycle 4 and after) of narrow range instrument span
d. Undervoltage-RCP Bus-Start Motor Driven Pump and Diesel-Driven Pump	N.A.	N.A.	N.A.	>5268 volts >4728 volts
e. Safety Injection-Start Motor-Driven Pump and Diesel-Driven Pump	See Item 1. above for all Safety Injection Trip Setpoints and Allowable Values.			

BRAIDWOOD - UNITS 1 & 2

3/4 3-26

Amendment No. 34