

NUCLEAR REGULATORY COMMISSION

101 MARIETTA ST., N.W. SUITE 3100
ATLANTA, GEORGIA 30303December 4, 1981
GM-29

TO: C. Burger, Section Chief, Division of Resident and Reactor Project Inspection

FROM: G. F. Maxwell, SRI Harris site

SUBJECT: Allegations concerning QA welding inspector

On the afternoon of November 24, 1981, I was approached by a construction inspector, who will remain anonymous, who had concerns about welds which had been inspected and accepted by a CP&L inspector named [redacted] has been assigned to the QA welding inspection organization at the Harris site for approximately [redacted]. He was hired in to assist in the hanger re-inspection program which commenced approximately [redacted] 1980 and ended near [redacted] 1981.

Prior to my conversation with the complainant, I had been approached by a welder and one other CP&L QA welding inspector concerning the performance of [redacted] inspections. During the conversation on November 24, I was informed that [redacted] had been inspecting and accepting welds which should not have been accepted. For example, I was told by the complainant that if the weld was in a difficult location, [redacted] would not acquire the appropriate scaffolding to allow him to have access to the weld to be inspected.

I informed the complainant that I can not perform an investigation into [redacted] performance based on hearsay, that I would need specific unsatisfactory welds to aid me in making the determination. The complainant assured me that within two weeks I would be provided with a list of five to ten welds which [redacted] had inspected and accepted which otherwise should be rejected.

He further stated that the welds which he would provide me with were non-safety related pipe welds. Upon return to the site (after Thanksgiving) on November 30, I was approached by a CP&L QA welding inspector who asked me what I was going to do about [redacted] unsatisfactory performance. I made an attempt to inform Region II staff of this concern, however, I was not able to do so that day. Subsequently I decided to commence gathering information concerning the three allegations I have received concerning [redacted]

At about 11 a.m. November 30, I informed the CP&L QA welding supervisor of the potential concerns which the NRC may have with [redacted]. The supervisor indicated that he needed time to look into this matter.

Later in the day during my routine inspections in the field, I encountered a welder who complained that [redacted] had inspected and accepted unsatisfactory

8406010132 840403
PDR FOIA
VADEN83-413 PDR

92 94

welds which were made on a seismic I pipe hanger which is numbered [redacted] I obtained the inspection package late in the afternoon for the pipe hanger in question.

During the morning of December 1, I contacted the QA welding supervisor and asked him to assist me during an inspection of the hanger in question. During the inspection no flagrant rejectable conditions were observed either by me or the supervisor on the aforementioned hanger. However, I observed a rejectable condition on a hanger located just adjacent to the aforementioned hanger and was advised by both the QA welding supervisor and the responsible welding foreman that the hanger which contained the rejectable condition had never been inspected and accepted by QA welding.

Later in the day I made an independent review of the records and found both of them to be incorrect, that in fact the hanger had been inspected and accepted by [redacted] on December 22, 1980.

On December 2 the QA welding supervisor and the CP&L project manager selected ten additional hangers which had been inspected and accepted by [redacted] both of them reinspected the ten hangers and found all welds to be acceptable. After work hours on December 3 I selected 3 pipe hangers which were located in very inaccessible areas and conducted an inspection of the welds which were still clean enough to inspect. No rejectable conditions were noted.

During the morning of December 4 I interviewed the site QA/QC director who informed me that he plans to require in the future supervisory audits to be conducted on each individual QA welding inspector to ascertain their satisfactory performance. However, he denies any QA program problem exists with the performance of his current inspectors.

Currently, I plan to give CP&L a violation contrary to 10CFR 50.55a(a)(1). The citation will be failure to inspect to the quality standards required by the applicable AWS-D.1.1-1975 requirements for new bridges.

If I receive additional information to substantiate the concerns made known to me, this violation could be made against 10CFR 50 Appendix B criterion 9 or 10.

In my opinion CP&L has not conducted sufficient audits of in-process welding activities nor have they conducted sufficient in-process monitoring of welding activities, including inspection of welds commensurate with the activities being performed.

This opinion has been voiced also by other Region II inspectors such as Ed Girard and most recently by Jim Coley during their visits to the site. If Region II decides to conduct an extensive audit of CP&L's audit program or monitoring program, as they relate to ongoing activities, I suggest that the necessary technical IE inspection personnel be made a part of the assigned team.

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

December 4, 1981
GM-29

R. C. Lewis
A. R. Herdt
C. E. Alderson

TO: C. Burger, Section Chief, Division of Resident and Reactor Project Inspection

FROM: G. F. Maxwell, SRI Harris site

SUBJECT: Allegations concerning QA welding inspector

12/9/81
G. W. B...

On the afternoon of November 24, 1981, I was approached by a construction inspector, who will remain anonymous, who had concerns about welds which had been inspected and accepted by a CP&L inspector named [redacted] has been assigned to the QA welding inspection organization at the Harris site for approximately one year. He was hired in to assist in the hanger re-inspection program which commenced approximately November 1980 and ended near June 1981.

Prior to my conversation with the complainant, I had been approached by a welder and one other CP&L QA welding inspector concerning the performance of [redacted] inspections. During the conversation on November 24, I was informed that [redacted] had been inspecting and accepting welds which should not have been accepted. For example, I was told by the complainant that if the weld was in a difficult location, [redacted] would not acquire the appropriate scaffolding to allow him to have access to the weld to be inspected.

I informed the complainant that I can not perform an investigation into performance based on hearsay, that I would need specific unsatisfactory welds to aid me in making the determination. The complainant assured me that within two weeks I would be provided with a list of five to ten welds which [redacted] had inspected and accepted which otherwise should be rejected.

He further stated that the welds which he would provide me with were non-safety related pipe welds. Upon return to the site (after Thanksgiving) on November 30, I was approached by a CP&L QA welding inspector who asked me what I was going to do about [redacted] unsatisfactory performance. I made an attempt to inform Region II supervision of this concern, however, I was not able to on that day. Subsequently I decided to commence gathering information concerning the three allegations I have received concerning [redacted]

At about 11 a.m. November 30, I informed the CP&L QA welding supervisor of the potential concerns which the NRC may have with [redacted]. The supervisor indicated that he needed time to look into this matter.

Later in the day during my routine inspections in the field, I encountered a welder who complained that [redacted] had inspected and accepted unsatisfactory

welds which were made on a seismic pipe hanger which is numbered [redacted]. I obtained the inspection package late in the afternoon for the pipe hanger in question.

During the morning of December 1, I contacted the QA welding supervisor and asked him to assist me during an inspection of the hanger in question. During the inspection no flagrant rejectable conditions were observed either by me or the supervisor on the aforementioned hanger. However, I observed a rejectable condition on a hanger located just adjacent to the aforementioned hanger and was advised by both the QA welding supervisor and the responsible welding foreman that the hanger which contained the rejectable condition had never been inspected and accepted by QA welding.

Later in the day I made an independent review of the records and found both of them to be incorrect, that in fact the hanger had been inspected and accepted by [redacted] on December 22, 1980.

On December 2 the QA welding supervisor and the CP&L project manager selected ten additional hangers which had been inspected and accepted by [redacted]. Both of them reinspected the ten hangers and found all welds to be acceptable. After work hours on December 3, I selected 3 pipe hangers which were located in very inaccessible areas and conducted an inspection of the welds which were still clean enough to inspect. No rejectable conditions were noted.

During the morning of December 4, I interviewed the site QA/QC director who informed me that he plans to require in the future supervisory audits to be conducted on each individual QA welding inspector to ascertain their satisfactory performance. However, he denies any QA program problem exists with the performance of his current inspectors.

Currently, I plan to give CP&L a violation contrary to 10CFR 50.53(a)(1). The citation will be failure to inspect to the quality standards required by the applicable AWS-D.1.1-1975 requirements for new bridges.

If I receive additional information to substantiate the concerns made known to me, this violation could be made against 10CFR 50 Appendix B criterion 9 or 10.

In my opinion CP&L has not conducted sufficient audits of in-process welding activities nor have they conducted sufficient in-process monitoring of welding activities, including inspection of welds commensurate with the activities being performed.

This opinion has been voiced also by other Region II inspectors such as Ed Girard and most recently by Jim Coley during their visits to the site. If Region II decides to conduct an extensive audit of CP&L's audit program or monitoring program, as they relate to welding activities, I suggest that the necessary technical inspection personnel be made a part of the assigned team.

1.4 Definitions

The following definitions are provided to ensure a uniform understanding of selected terms as they are used in this standard.

Certification (Personnel)—The action of determining, verifying, or attesting in writing to the qualifications of personnel.

Construction Phase—A period which commences with receipt of items at the construction site and ends when the components and systems are ready for turnover to operations personnel.

Contractor—Any individual or organization entering into a contract to furnish items or services to a purchaser. The term contractor includes the terms Vendor, Supplier, and Subcontractor or sub-tier levels of these where appropriate.

Examination—A critical investigation of items by nondestructive methods.

Inspection—A phase of quality control which by means of examination, observation or measurement determines the conformance of materials, supplies, components, parts, appurtenances, systems, processes or structures to predetermined quality requirements.

Item—Any level of unit assembly, including structures, system, subsystem, subassembly, component, part or material.

Owner—The person, group, company, or corporation who has or will have title to the facility or installation under construction.

Project—A planned series of activities including all actions necessary to provide, utilize and maintain a facility or a portion thereof.

Qualifications—The characteristics or abilities gained through training or experience or both that enable an individual to perform a required function.

Quality Assurance—All those planned and systematic actions necessary to provide adequate confidence that an item or a facility will perform satisfactorily in service.

Quality Control—Those quality assurance actions which provide a means of control and measure the characteristics of an item, process or facility to established requirements.

Testing—The determination or verification of the capability of an item to meet specified require-

ments by subjecting the item to a set of physical, chemical, environmental or operating conditions.

Other terms and their definitions are contained in ANSI N45.2.10, Quality Assurance Terms and Definitions.

1.5 Referenced Documents

Other documents that are required to be included as a part of this standard are either identified at the point of reference or described in Paragraph 6 of this standard. The issue or edition of the referenced document that is required will be specified either at the point of reference or in Paragraph 6 of this standard.

2. GENERAL REQUIREMENTS

2.1 Planning

Plans shall be developed for assigning or staffing and training an adequate number of personnel to perform the required inspections, examinations, and tests and shall reflect the schedule of project activity so as to allow adequate time for assignment or selection and training of the required personnel. The need for formal training programs shall be determined, and such training activities shall be conducted as required to qualify personnel responsible for inspection, examination, and testing; and other appropriate technical support personnel whose work can directly or indirectly affect the quality or reliability of those items delineated in the scope of this standard.

2.2 Certification

Each person who verifies conformance of work activities to quality requirements shall be certified by his employer as being qualified to perform his assigned work. This certification shall be supported by appropriate measures such as education or training, testing, evaluation, and periodic review to assure the initial and continued proficiency of each person. The effective period of certification shall be established and at the end of the effective period of certification, each individual shall be recertified in accordance with the requirements of this standard. Personnel involved in the performance, evaluation and supervision of non-destructive examinations need only be certified in accordance with the requirements specified in SNT-TC-1A¹ and supplements.

2.2.1 Training. When training programs are required they shall include indoctrination of personnel with the technical objectives of the project; the codes

¹SNT-TC-1A and Supplements, "Recommended Practice for Nondestructive Testing Personnel Qualification and Certification", issued by the Society for Nondestructive Testing, 914 Chicago Avenue, Evanston, Illinois 60201.

and standards that are to be used; and the quality assurance elements that are to be employed, with guidance regarding their limitations and capabilities. On-the-job participation shall also be included in the program, with emphasis on firsthand experience gained through actual performance of processes, tests, examinations, and inspections.

2.2.2 Proficiency Testing. In accordance with the requirements of SNT-TC-1A and supplements, tests shall be devised for determining the capability and proficiency of personnel who perform nondestructive examinations; and each person who performs these examinations shall be tested to demonstrate his capability. The results of these tests shall be documented and placed in the personnel file (see paragraph 5) and shall be considered in the evaluation described in paragraph 2.2.3.

2.2.3 Evaluation of Performance. The job performance of inspection, examination and testing personnel shall be evaluated initially and at periodic intervals not to exceed two years, and the results of each evaluation shall be reviewed to determine the capability of the individual. If it is determined that the capabilities of an individual are not in accordance with the qualifications specified for the job, that person shall be removed from operations until such time as he has been trained in the needed skill and has been re-certified as being qualified to perform the work.

2.2.4 Certificate of Qualification. The qualifications of personnel shall be documented in an appropriate form. The certificate shall include the following information:

- (1) Employer's name
- (2) Person being certified
- (3) Activity qualified to perform
- (4) Level of capability
- (5) Effective period of certification
- (6) Signature of Employer's Designated Representative
- (7) Basis used for certification

3. QUALIFICATIONS

The requirements contained within this section are intended to define the minimum capabilities that qualify personnel to perform quality assurance functions that are within the scope of this standard. The capability requirements of nondestructive examination personnel shall be as specified in SNT-TC-1A and supplements. The capability requirements of other personnel covered by this standard shall be as specified in the following paragraphs.

The qualifications have been defined in terms of three levels of capability. The categorization of requirements that are defined are not intended to be limiting with regard to company position or professional status, but are merely a convenient method of defining functional activities.

3.1 Levels of Capability

Three levels of capability for persons who perform inspections and tests, or who participate in the approval of procedures, the handling of data or test results, or the control of reports and records are delineated below. The education and experience requirements specified for the various levels should not be treated as absolute when other factors provide reasonable assurance that a person can competently perform a particular task. Other factors may be demonstrated capability in a given job through previous performance of a particular function or completion of proficiency testing.

3.1.1 Level I. To be considered for certification, a candidate must satisfy the following requirements:

High school graduate, plus one year of experience in quality assurance, including testing or inspection (or both) of equivalent construction and installation activities.

3.1.2 Level II. To be considered for certification, a candidate must satisfy one of the following requirements:

- (1) Graduate of a four-year accredited engineering or science college or university, plus two years of experience in quality assurance including testing or inspection (or both) of equivalent construction and installation activities.
- (2) High school graduate, plus four years of experience in testing or inspection (or both) of power plant, nuclear plant, heavy industrial, or other similar equipment or facilities.

3.1.3 Level III. To be considered for certification, a candidate must satisfy one of the following requirements:

- (1) Graduate of a four-year accredited engineering or science college or university, plus five years of experience in quality assurance, including testing or inspection (or both) of equivalent manufacturing, construction and installation activities. At least two years of this experience should be associated with nuclear facilities, or if not, the individual

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT
ENGINEERING & CONSTRUCTION QUALITY ASSURANCE/
QUALITY CONTROL SECTION

NUMBER

QQA-1

REVISION

4

TITLE: PERSONNEL TRAINING AND QUALIFICATION

5.4 Prior experience may be applied to the experience level requirements for more than one inspection/testing activity provided the requirements of 5.3 above are met.

6.0 PHYSICAL QUALIFICATION

6.1 QA/QC inspection personnel shall meet the physical requirements for the particular CP&L classification involved at initial hiring.

6.2 Contracted personnel employed to augment CP&L QA/QC inspectors shall meet the physical requirements of their employers.

6.3 QA/QC and augmented inspection personnel shall be tested to assure:

1. Natural or corrected near distance acuity such as being capable of reading the J-1 letters on a standard Jaeger's test-type chart or equivalent test type.

2. The capability for distinguishing and differentiating contrast between colors as demonstrated by practical demonstration or test performance.

6.4 Personnel that fail the near distance acuity or color sense testing may be evaluated and, through satisfactory demonstration of capability to perform the required inspections, found acceptable for certification for a sub-category of inspection. The personnel records shall reflect the evaluation process used and any inspection limitations imposed.

6.5 The tests specified in 6.3 (or as allowed by 6.4) shall be conducted on an annual basis.

7.0 INDOCTRINATION AND TRAINING

7.1 Newly assigned personnel CP&L and augments will be trained in the performance of their intended assignment. Training shall be accomplished through a program consisting of indoctrination and on the job training (OJT) under the direct supervision of qualified personnel. The degree of training will depend on the amount of previous experience and training.

GENERAL BUILDING & LIGHT CONSTRUCTION
CORPORATE QUALITY ASSURANCE DEPARTMENT
ENGINEERING & CONSTRUCTION QUALITY ASSURANCE/
QUALITY CONTROL SECTION

NUMBER
CQA-1

REVISION
4

TITLE: PERSONNEL TRAINING AND QUALIFICATION

7.1 (cont.)

Emphasis will be on firsthand experience gained through actual performance of processes, tests, examinations and inspections. As the inspector in training develops proficiency, he may be allowed to perform certain functions with minimal supervision; however, he will not be permitted to "sign-off" hold points in verification of quality requirements for work activities.

7.2 Personnel performing QA/QC activities shall be indoctrinated in those project informational areas necessary for effective coordination and accomplishment of their assigned activities and responsibilities. Indoctrination shall be documented on QA/QC Personnel Indoctrination Check-Off (Form QA-47) and consist of, but not be limited to:

1. Organization and Organizational Relationships
2. Introduction to appropriate site personnel
3. Duties and Responsibilities
4. CP&L - CQA/CQC procedures, instructions, reports, records and filing system.
5. Technical objectives of construction site CQA/CQC procedures
6. Codes and Standards to be employed

7.3 Appendix A to this procedure specifies the training time required for the individual inspection/testing activities. Where the inspector in training has been previously certified for the inspection/testing activity by another organization, the classroom# hours may be reduced by one-half and the OJT** hours may be reduced by two-thirds.

Notes: *Classroom training includes lectures, discussions, and demonstrations of the uses of documents, tools and equipment related to the inspection/testing activity; and the administration of appropriate examinations and tests.

**Where equally applicable to more than one inspection/testing activity, OJT time may be applied to each of the appropriate activities.

7.4 Formal training administered by the Discipline QA/QC Specialists to develop or maintain the proficiency of inspection personnel shall be documented. These training records shall include the following information:

1. Name of Instructor
2. Subject matter
3. Date
4. Time spent
5. List of attendees

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT
ENGINEERING & CONSTRUCTION QUALITY ASSURANCE/
QUALITY CONTROL SECTION

NUMBER	REVISION
QQC-19	2

TITLE: WELD CONTROL

6.3.7 (cont.)

Any problems noted with items a or b will be handled as an "in-process" conditions unless it involves a pipe hanger in "Phase II" of the installation process, as described in Reference 2p, in which case it will be handled as a nonconformance in accordance with Reference 1d.

6.3.9 The QC Inspector shall monitor welding activities within his assigned area(s). Activities monitored will include, but not be limited to the following:

- a. Fitup of non-full penetration joints (configuration, gap cleanliness). Enter on appropriate QA-34 Form.
- b. Correct welding procedure utilized.
- c. Qualification of welder to procedure and position.
- d. Specified filler metal being used.
- e. Preheat technique and temperature satisfactory. (Use temperature indicating crayon or contact pyrometer.)

Deficiencies noted with items b, c or d and any other deficiencies which cannot be corrected by routine rework shall be handled as nonconformances in accordance with Reference 1d.

6.3.10 The QC Inspector shall perform the required visual inspections in accordance with Reference 1h and initiate the NDE Requests when the specified NDE holdpoints are reached.

6.3.11 Minor surface defects detected by visual inspection will be identified on the item by marking the defective areas with black marking ink and indicating the nature of the defects. The QC Inspector will enter the weld identification/description and check the appropriate "reject" box on both the QA and craft foreman's copies of the QA-34 Form. These are in-process defects and not reported as nonconformances.

6.3.12 When a weld is found rejectable by NDE, the QA Inspector will enter the weld identification/description and check the appropriate "reject" box on both the QC and craft foreman's copies of the QA-34 Form. He will forward a copy of the NDE report of the craft foreman.

- a. If the defect is in the weldment, rework is considered "in-process" and not reported as a nonconformance.

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT
ENGINEERING & CONSTRUCTION QUALITY ASSURANCE
QUALITY CONTROL SECTION

NUMBER

QQA-1

REVISION

4

TITLE: PERSONNEL TRAINING AND QUALIFICATION

8.0 QUALIFICATION PRIOR TO CERTIFICATION

Prior to assignment to perform specific inspection/testing functions, QA/QC personnel shall meet the minimum requirements for the assignment as delineated in Appendix A. Classroom, self-study and practical demonstrations shall be performed and documented in accordance with Reference 3.

9.0 CERTIFICATION

9.1 QA/QC Specialists (Supervisors)

9.1.1 Discipline QA/QC Specialists (supervisors) are assigned supervisory and technical responsibilities based on combinations of formal education, training, previous work experience, completion of indoctrination and demonstration of ability and knowledge to satisfactorily perform their assignments. Discipline QA/QC Specialists are considered qualified to perform the following functions as applicable to the activities within their assignments:

1. Train, qualify and supervise QA/QC personnel in inspection, monitoring and testing assignments.
2. Develop and administer oral and written qualification examinations.
3. Evaluate capabilities and performance of QA/QC personnel.
4. Evaluate results of examinations, inspections and tests.
5. Develop and prepare new QA/QC procedures and instructions.
6. Review QA/QC and Construction procedures and instructions for appropriate commitments and requirements.
7. Technical review of site generated documents which furnish documentary evidence of the quality of nuclear safety related items and of activities affecting quality.

QA/QC PERSONNEL EXPERIENCE & TRAINING REQUIREMENTS

INSPECTION/TESTING ACTIVITIES	NOS. EXPERIENCE REQUIRED			HRS. TRAINING	
	HIGH SCHOOL	2-YR ENGR/TECH 4-YR NON-ENGR	4-YR ENGR	CLASS- ROOM	TOT
WELDING					
ASME Code Weld Inspector	6	3	1-1/2	9	80
Non-Code Pipe Weld Inspector	4	2	1	9	40
Structural Weld Inspector	4	2	1	9	80
Seismic Hanger Weld Inspector	4	2	1	9	80
Pool Liner Weld Inspector	4	2	1	9	40
Containment Liner Erection Welding Monitor	4	2	1	9	40
Stud Welding Inspector	4	2	1	4	40
Post Weld Heat Treatment Inspector	2	1	1/2	4	40
Weld Control Surveillance	2	1	1/2	9	80
MISCELLANEOUS (Non-inspection/testing activities)					
QA/QC Specialist (supervisor)	72	48	24	N/A	N/A
1. Civil					
2. Electrical & Instru.					
3. Material Control					
4. Mechanical					
5. Records					
6. Welding					
QA Records Clerk	2	N/A	N/A	8	40

SS No. _____

Inspection/Test Activity: Seismic Hanger Weld Inspector

Prerequisite Certifications: None

Function	Hours	Date	Rating	Certified Inspector
<ol style="list-style-type: none"> 1. Verify fit-up of full penetration welds. 2. Verify pre-heat of weld joints with base material greater than 1½" thick. 3. Review applicable installation drawings FCR's, PW's, DCN's, etc. for correctness and requirements. 4. Identify missing, incorrect and confusing weld symbols. 5. Verify weld type and configuration agree with the drawing. Verify that the welder is qualified. 6. Verify that the items to be welded are in the accept status. 8. Inspect weld at it's completion is in accordance with applicable procedure and initiate request for NDE required. 9. Verify that specific items checked are entered on a weld inspection checklist and attached to the QA-34 Form. 10. Submit completed QA-34 and associated documents to the Welding QA/QC Specialist. 				
Knowledge & use of procedures & specs				
Ability to use drawings/diagrams				
Knowledge of DCN's, FCR's, PW's & RCI's				
Application of inspection/testing techniques				
e of inspection tools/aids				

Reviewed By: _____ Date: _____
 QA/QC Specialist

Name _____ SS No. _____

Inspection/Test Activity: Seismic Hanger Weld Inspector

Required Reading	Rev.	Date Completed	Initials
<u>Procedures</u> CQA-1 CQA-4 CQC-1 CQC-2 CQC-21 QCI-19.1 NDEP-10 NDEP-601 MP-03 MP-05 MP-06 MP-07 MP-08 MP-09 MP-10 MP-13 P-18 P-30 WP-110			
<u>Specifications</u> Site Specifications 031 033 034			
<u>Codes & Standards</u> AWS D1.1			
<u>Other</u> None			

Reviewed By: _____ Date _____

The SNPP Project complies with Regulatory Guide 1.58 (8-73) with the following clarifications to ANSI N45.2.6-1973:

CP&L Power Plant Engineering and Site Construction Activities

Section 2.2.4: Certification of Qualifications

CP&L will provide certification of inspection, examination and testing personnel qualifications. However, it is CP&L's intent that certification of qualification will not distinguish levels of capability for other than non-destructive examination (NDE-IT,PT,UT,RT) personnel.

41

52,55

Section 3.1: Qualifications

With the exception of NDE, CP&L does not intend to qualify and certify inspection personnel to levels of capability as described in this paragraph.

42

Section 3.2.1: Physical

CP&L requires potential employees to complete a medical examination to assure satisfactory medical condition. In addition, CP&L requires that site inspection, examination, and testing personnel be checked annually to assure that they possess the physical characteristics necessary to satisfactorily perform their assigned tasks. These physical characteristics are normal color vision and near vision acuity. These characteristics are checked by means of a color perception test utilizing pseudiosochromatic plates and the standard Jaeger test, respectively, administered by qualified personnel.

Section 3.2.2: Technical

CP&L inspection personnel will meet the appropriate requirements of this paragraph; however, other than NDE, personnel will not be classified by levels of capability.

For NSSS Suppliers, AE, and Vendor Personnel

For other than NDE personnel, it will be the responsibility of the organization employing such inspection, examination, and testing personnel to assure the physical and technical capability of these personnel to perform their assigned tasks in accordance with the organization's standard procedures.

41,43

1.59 Design Basis Floods for Nuclear Power Plants (8-73)

The SNPP Project complies with Regulatory Guide 1.59.

39

1.60 Design Response Spectra for Seismic Design of Nuclear Power Plants (Revision 1, 12-73)

The SNPP project complies with Regulatory Guide 1.60 (Revision 1, 12-73) with the following clarifications and exceptions:

54

0

130.

12

For the Seismic Category I Main Dam, Auxiliary Dam and Auxiliary Dike the seismic stability analysis is presented in Appendices 2E and 5E.

The SNRP Project complies with Regulatory Guide 1.58 (6-73) with the following clarifications to ANSI N45.2.6-1973:

CP&L Power Plant Engineering and Site Construction Activities

Section 2.2.4: Certification of Qualifications

CP&L will provide certification of inspection, examination and testing personnel qualifications. However, it is CP&L's intent that certification of qualification will not distinguish levels of capability for other than non-destructive examination (NDE-UT,PT,UT,RT) personnel.

Section 3.1: Qualifications

with the exception of NDE, CP&L does not intend to qualify and certify inspection personnel to levels of capability as described in this paragraph.

Section 3.2.1: Physical

CP&L requires potential employees to complete a medical examination to assure satisfactory medical condition. In addition, CP&L requires that site inspection, examination, and testing personnel be checked annually to assure that they possess the physical characteristics necessary to satisfactorily perform their assigned tasks. These physical characteristics are normal color vision and near vision acuity. These characteristics are checked by means of a color perception test utilizing pseudiosochromatic plates and the standard Jaeger test, respectively, administered by qualified personnel.

Section 3.2.2: Technical

CP&L inspection personnel will meet the appropriate requirements of this paragraph; however, other than NDE, personnel will not be classified by levels of capability.

For NSSS Suppliers, AE, and Vendor Personnel

For other than NDE personnel, it will be the responsibility of the organization employing such inspection, examination, and testing personnel to assure the physical and technical capability of these personnel to perform their assigned tasks in accordance with the organization's standard procedures.

1.59 Design Basis Floods for Nuclear Power Plants (8-73)

The SNRP Project complies with Regulatory Guide 1.59.

1.60 Design Response Spectra for Seismic Design of Nuclear Power Plants (Revision 1, 12-73)

The SNRP project complies with Regulatory Guide 1.60 (Revision 1, 12-73) with the following clarifications and exceptions:

For the Seismic Category I Main Dam, Auxiliary Dam and Auxiliary Dike the seismic stability analysis is presented in Appendices 2E and 5E.

WELDER: Jim SYM: _____

INSPECTION REQUIREMENTS: CLEAN FIT UP FINAL

NO. DESTRUCTIVE TEST FOREMAN: _____ LOCATION: _____ ELEV: _____

INSPECTION REQUEST # _____

WELDER: _____ SYMBOL: _____ DWG./ISO: _____ SHEET: _____

CLEAN FIT UP FINAL

DETAIL

NONDESTRUCTIVE TEST INSPECTION REQUEST #		FOREMAN	LOCATION	ELEV.	TIME	DATE
		<u>Jim</u>	<u>RAB-1</u>	<u>256</u>	<u>2pm</u>	<u>7/25/81</u>
WELDER:	<u>Jim</u>	SYMBOL <u>S1-5</u>	DWG./ISO. # <u>A-6-256-1</u>	SHEET	JOINT NUMBER <u>20-H-175</u>	
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input type="checkbox"/>				DETAIL	
	VISUAL <input checked="" type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>					
REWORK <input type="checkbox"/>		NEW <input checked="" type="checkbox"/>				
COMMENTS: <u>Rev. 0/2-</u> PC _____ TO PC _____						
<u>pc 6 to Embed one stud underneath</u>						
<u>pc 1 to pc 6</u>						
INSPECTOR	<u>Timan</u>		ACCEPT <input type="checkbox"/>	REJECT <input checked="" type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>7/25/81</u>

*This form for Information Only-NOT A QA RECORD.

96
95

86

1
PROCEDURE CLC
3. COMPONENT/HANGER ID.

DATE 1/17

1
FOR ADDITIONAL INSTRUCTIONS FOR FULL PENETRATION
FOR ADDITIONAL INSTRUCTIONS ON JOINTS INVOLVING ENGINEERED FLANGE
FOR ADDITIONAL INSTRUCTIONS ON JOINTS NOT REQUIRING ADDITIONAL INSTRUCTIONS
FOR HOLD POINTS (H) & FINAL WELD INSPECTION

FOREMAN: NCLEY

DATE 6/11/12

DATE

DATE

QA/QC INSPECTION

QA/QC INSPECTION

NCR/DDR

3. MAT'L STATUS

ROOT NDE

FITUP

PREHEAT

WELDER SYMBOL(S)

WELDER(S) QUALIFICATION

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

DESCRIPTION OF DEFICIENCY, REPAIR OR REWORK NCR/DDR, ETC.

DATE

INSP. INITIALS

PWT

VAC BOX

FINAL NDE

VT

MT/PT

VT

MT/PT

H

TEMP

H

A

R

A

R

A

R

REMARKS:

QA/QC INSPECTION & NI AND/OR VERIFIED BY.

LEGEND: H = HOLDPOINT

A = ACCEPT

R = REJECT

T = TEMP. GREATER THAN LISTED

DATE

QA/QC SPECIALIST / DESIGNEE

* USE OA - 34A TO LIST ADDITIONAL WELDS


Federal Agencies & CP&L To Investigate Charges

By James Hamilton
 In a letter to the Federal Bureau of Investigation, CP&L has requested that the FBI investigate the charges against the four workers at the Mission Harris Nuclear Construction site in New Hill, Four Damsel workers listed numerous charges in last week's Western Week Herald.

Another worker, interviewed since the charges were first made public, reported that the four workers are making attempts to contact safety and welfare officials. Supervisors and management level people have been "battered all over the job site" since the charges appeared in your paper.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.



Two federal agencies and CP&L are investigating charges of poor workmanship, inadequate safety procedures, and on the job drug use at the Mission Harris Nuclear Construction site in New Hill. Four Damsel workers listed numerous charges in last week's Western Week Herald.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.

Workmen Charges Under Investigation By CP&L

Continued from page 1
 A worker who works near the construction unit stated the methods used to pour concrete because no pockets often prevent concrete from filling the entire area. Welds in critical areas for (Damsel) are being a hard time getting the welds done right so it's taking more time. Often they have to grind out and redo the welds in critical areas. If they had more experienced welders they would not get a done state job.

Another worker, interviewed since the charges were first made public, reported that the four workers are making attempts to contact safety and welfare officials. Supervisors and management level people have been "battered all over the job site" since the charges appeared in your paper.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.

OSHA inspectors who spent two days at the job site, the worker said, pointing out safety violations.

100 99

Letter To Editor:

Daniel Employee Praises Accuracy Of Construction Story

To the Editor:
As an employee of Daniel Construction Co. in the field (New York) I was very surprised at the information contained in your recent article. As most employees there were not supposed to know the site was accurate this is an error in your reporting.
Your readership should be aware the article created quite a stir among management of both Daniel & CP&L. Numerous members of which expressed their concern over the accuracy of your reporting. I was surprised to find your stand was completely and much to the point. One would feel as if you were an employee of the site.

My Jackson Ward, OSHA safety officer a communication individual leads a lengthy inspection on the site with particular attention to the concrete area. Various all employees in that area have since been notified the safety problems related there.
To be fair to CP&L and Daniel it is clear they are rapidly and sincerely trying to correct their errors and generally meet their ways in both safety (most noticeable) and quality craftsmanship and speed the group meetings!

With regard to the issue of craftsmanship generally and welding in particular it would be inaccurate to claim these men don't do quality work as most construction workers can do as well as is expected of them. This is the problem. Maximum safety, efficiency, and rock hauling equipment, be

then regard for the safety and well being of the craftsmen building that structure is manifestly evident before he even picks up his tools.

The above described conditions and other related safety concerns, and supply about coming about like an air beam in the dirt are not of a calculated plan, but of pure indifference.

You, here, as responsible news reporters should, looked the proverbial burner's nose and saw they swam - for the time being.

A Daniel employee

Editor's Note: Writers, state factual info, submit names and address from the individual writing a letter to the Editor. The workman submitting this letter provided proper information, but requested that the newspaper withhold his name from publication. The request will be honored since the workman interviewed in last week's article was also unidentified.

Letter To Editor:

Subscriber Charges Sensationalism

Unbiased reporting seeks of the National Enquirer, which also cannot be found in my home.

To bear an entire story on 4 of 4000 workers' remarks leaves much to be desired in terms of accurate reporting. I am sure that in a group of 4000 construction workers as with any other

cross section of society, opinions vary on any subject by advanced on any subject.

Published in your paper, I assure the students of Spruill High School that you will donate directly to the school.

C. S. Hinnant

CHARGE IS TRUE!

On May 12, 1981, an article containing a number of allegations against the construction of the Strategic Fuel Nuclear Power Plant in common thread which run through the allegations is that the job is unsafe. Danie claims wages and job conditions for craftsmen, welders and industrial electricians have been cut down and the quality poor. These allegations are irresponsible, untrue and unfair to both CP&I and Danie.

You point out that the men noted in the Hamill manipulation situation were I take the good safety record which Danie has achieved. The statistics are a matter of record. The accident rate is substantially below one-half the national average and there has been no draft or disabling injury. It is alleged that if a worker is injured the company tries to blame him so that it will not have to pay workmen's compensation claims. We need to point out that the company pays their health and accident and state tax, whatever is a law.

I stand in statement that many workers fail to follow safety procedures. According to a National Safety Council study, unsafe acts are a contributing factor in over 90% of the accident cases. I think we can relate this situation somewhat to vehicle accidents; rarely is the vehicle at fault, it is usually the driver.

One of the workers is quoted as saying "on-the-job training should be done at a nuclear facility." The emphasis is that all should be experienced journeymen. This worker is out of touch with reality. How does a worker reach journeyman status if he cannot train under other experienced workers? This is an accepted process throughout the construction industry and any other workplace where skilled work must be accomplished.

So the Danie work force is composed of some less experienced workers training under a group of highly skilled long-term employees. This combined with multiple training programs at the site has produced craftsmen and construction which we are justly proud. CP&I is also quite proud of the fact that local people can be trained to the necessary skills level allowing them long-term employment without having to leave the area. These training programs allow Danie to hire more women and minorities.

Your article alleges that numerous skilled people leave the job because they are not paid enough. The facts do not bear out this allegation. The primary common reasons given by these employees would be:

1. Lack of pay for the time spent finding housing in the April area. This is a gross injustice and should be paid.

2. There is a great deal of work at the Danie site should be something that makes people think about or some other area of the country. Many nuclear power plants have been constructed in the southeast and with southern location an excellent area to live in. You say that the men Hamill should work for whenever Danie trained workers will get hired a

few days. The production is not going to be any slower because a large number of workers from Columbia are available to simply take the job. We are proud of the high quality displayed by our workers.

You also point out that the reinforcement workers will not rebar and another that will come in on the reinforcement and put in pipe or welding plates. This does a great job of accommodating a change in design. As often times is done on purpose, fast site construction and it works within prescribed tolerances. The point is that even if the rates of cash these changes are made prior to putting the concrete around the entire assembly and this is when changes are easily made. Since the decisions for changes are made by engineering personnel the field craftsmen at times may not show the reasons.

You also cited a situation where some defective welds were detected in parts of the condenser steel. It was not made clear that our inspection process worked as it should have. We detected the situation and the manufacturer and CP&I is bearing the cost of repairs. As previously mentioned the welder is not expected to know he needs to know what is paying for the cost of changes or corrections.

You cited a case where a welder continued to weld after flanking a test. The point which was not made clear was that there are numerous weld procedures or are required to the different job requirements. It is perfectly appropriate that a welder continue to weld under a procedure for which he has qualified but he is not allowed to weld under a procedure which he has not qualified.

Insofar as the allegation concerning drug use on the site let me repeat what you were told prior to your writing the article. Drug and alcohol use are absolutely forbidden on the site. Any employee caught using either at the site is immediately terminated.

As for the implication we should have an undercover drug agent on site let me remind you that is a police decision. We cooperate fully with local law enforcement agencies. However if we had one working we wouldn't let you since he would immediately lose part of his protection if we did.

I hope I have set forth the facts about the Hamill plant construction. I believe that had you interviewed a representative cross section of the workers instead of only a few dissidents, the story would have been substantially different and much fairer.

To assure the quality necessary in construction of a nuclear power plant, there is a comprehensive system of checks and balances built into all of the construction and inspection process, particularly welding. We have an on-site quality control and control another individual for you to assure yourself with the thoroughness I have enough confidence in the system to let the you make the change you wish to.

Sincerely,
Burt J. McEwen
General Manager
Strategic Fuel

WINDSTOCK

Carl
m 3/20

VOL. 21 NO. 11

APEX, NORTH CAROLINA

Nuclear Power Workers Charge

Dominic Building A "Bomb"

THE WEDDAY, MARCH 20, 1980

15 PER COPY

Reasons for Power Plant

By Janet H. Davis

Large construction workers at CP&I's Shearon Harris
Fast Fission Unit Construction Company of hiring
and training experienced welders who are building a
nuclear power plant. The workers believe the
plant will be completed.

Nuclear Regulatory Commission (NRC) officials, who
inspect the site every other week, acknowledge they inspect
the site about 80 percent of the work. But lately we
are seeing more and more workers.

CP&I employees and the site claims CP&I inspectors
inspect about 10 percent of the work. He also said "We
are seeing the same thing in other parts of the country."

The union disagrees. They believe a nuclear power
plant is a very complex, technical, and difficult job that
should be done by the best.

Unemployed workers who work only in experienced
workers who are the best, for example, and during their
career with the CP&I construction site, the men with the
best skills.

The union says it will pay more to take experienced
workers who are the best. For a nuclear
power plant, it is a very complex job. The plant is built by
experienced workers. When you're getting into the
industry, you're getting into the best. They are
the best workers in the industry.

failed

test, but they still let me work as a welder in the construction
unit," an experienced welder said.

"I can get any kind of job, and I can get these jobs
continuing to receive. The men here, for example, let me
take their stuff and then let me go to work. They don't
immediately say."

"If I had had 100% of the site, and if the
inspectors came out right now, they'd see the job done
to the same number of men. They'd see the same
men," welder said.

"Anyone can do it, but you need the right equipment
and the right kind of training. The site is a very
complex job."

The two men, however, are not the only ones who
are not experienced welders. CP&I's site is
a very complex construction job. They believe the
plant will be completed in the next few years.
The union says it will pay more to take experienced
workers who are the best.

Two of the four men were experienced welders
and men who have worked in the industry for
many years. They believe the plant will be
completed in the next few years. The union
says it will pay more to take experienced
workers who are the best.

The union says it will pay more to take experienced
workers who are the best. They are the best
workers in the industry. They are the best
workers in the industry. They are the best
workers in the industry.

...to the ...
...the ...
...the ...
...the ...
...the ...
...the ...

↑
B

...the ...
...the ...
...the ...
...the ...
...the ...
...the ...

THE ...



...the ...

Catell...

List of

INITIALS OF SITE QA/QC INSPECTION PERSONNEL

W...
12-9-81
move to file

<u>Name</u>	<u>Initials</u>
Andy Bartrom	AB
Ed Betz	EB
James Brown	JB
Emma Jean Burton	EB
Richard Bussey	RB
James Cagle	JWC
Herb Casanova	HXC
Jerry Cates	JC
Robert Cates	RC
Pete Cook	PC
Don Crispino	DC
Gina Cullins	GC
George Daniel	GD
Rick Demling	RD
Ken Douglas	KD
Bud Driggers	BD
Tommy Gilbert	TG
Bruce Giles	BG
Bill Godbold	BG
Glenda Goodman	GG
Robin Groves	RG
Iyanne Harcy	IH
Jenn Holland	JH
David Holter	DH
Bobby Miller	BM

↙

Name

Barbara Howe

Don Hudson

D.H.

Rhett Hunt

RH

Margaret Hundley

Eric Hunter

Dudley Jacobs

Sandy Jenkins

SJ

Gene Kelly

GK

Kendel Kirks

KK

Jay Kremer

JK

John Langdon

JD

Tom Lee

TL

Walt Leggett

WJ

Pam McCurdy

Judi McDonnell

JM

Ward Mercer

WM

Lil Meyer

LM

Cheryl Miller

Glenn Milner

GM

Dale Mize

Rich Moore

DM

Steve Mountcastle

SM

David Myers

Carl Osman

CO

Jean Parker

JP

Bill Pere

BP

Nguyen Van Phung

NV

Don Prince

DP





















Al Ralston

AR

Sunny Richbough

Ann Richards

Marc Davis
John Harrell
Reginald Faulkner
Gil DeBarros
Alan Kinsey
Mark Tallon
James Hampton
Eugene Martin
Rose Briere
John Swindell
Alan Lowe
Dwight Estes
Ian Simpson
David Jarvis
Robert Steele
John Scoates —
John R. Bain
Wayne Martin
Jim Storey
Douglas Sudduth

James East Robert St. Pierre

Judy Sauerbier

David Shockley Bobby Smith

Ricky Strickland

Don Sugg

Cyndi Talbott

Frank Taylor

Pete Tingen

Cynthia Turner

Vernon Veglia

Terry Wait

Richard Warren

Paul West
Tom West

David Whitehead

Additions:

Robert L. St. Pierre

John Barber

Sheila Freeman

Mark Hale

Margaret Hundley

Rich Moore

Clay Rhodes

Don Sands

Bobby Smith

Don Smith

Ken Stanley

Janice Weeber

Tony West

James Williams

RS

JS

DS

RS

Don Sugg

Cyndi

Frank

Pete

Cynthia

RW

Paul West

Tom West

RS

John Barber

Sheila Freeman

Mark Hale

Margaret Hundley

Rich Moore

Clay Rhodes

Don Sands

Bobby Smith

Don Smith

Ken Stanley

Janice Weeber

Tony West

INITIALS OF SITE QA/QC INSPECTION PERSONNEL

<u>Name</u>	<u>Initials</u>
Andy Bartrom	AB
Ed Betz	EB
James Brown	JB
Emma Jean Burton	EB
Richard Bussey	RB
James Cagle	JWC
Herb Casanova	H/C
Jerry Cates	JC
Robert Cates	RC
Pete Cook	PC
Don Crispino	DC
Gina Cullins	GC
George Daniel	GD
Rick Demling	RD
Ken Douglas	KD
Bud Driggers	
Tommy Gilbert	TG
Bruce Giles	
Bill Godbold	
Glenda Goodman	GG
Robin Groves	RG
Dyanne Hardy	DH
John Holland	JH
David Holler	DH
Becky Holter	BH

3.11.8
2000



Barbara Howe

Hunt

Don Hudson

DAD

Phett Hunt

H

Margaret Hundley

Eric Hunter

Dudley Jacobs

Sandy Jenkins

SJ

Gene Kelly

GK

Kendel Kirks

KK

Jay Kremer

JK

John Langdon

JD

Tom Lee

TOL

Walt Leggett

WLG

Pam McCurdy

Judi McDonnell

JM

Ward Merc...

WM

Lil Meyer

LM

Cheryl Miller

Glenn Milner

GM

Dale Mize

DM

Rich Moore

Steve Mountcastle

SM

David Myers

Carl Osman

C.O.

Jean Parker

JP

Bill Pere

BP

Nguyen Van Phung

N.V. Phung

Don Prince

D.P.

Al Pullian

A.P.

Cathy Rohrbaugh

Clay Tinkles

James Root Robert St. Pierre
 Judy Sauerbier
 David Shockley Bobby Smith
 Ricky Strickland
 Don Sugg
 Cyndi Talbott
 Frank Taylor
 Pete Tingen
 Cynthia Turner
 Vernon Veglia
 Terry Wait
 Richard Warren
 Paul West
 Tom West
 David Whitehead

[Handwritten initials]
[Handwritten initials]
 DS
 RS
 Don Sugg
 Cyndi
 Frank Taylor
 Pete
 Cynthia

Additions:

Robert L. St. Pierre
 John Barber
 Sheila Freeman
 Mark Hale
 Margaret Hundley
 Rich Moore
 Clay Rhodes
 Don Sands
 Bobby Smith
 Don Smith
 Ken Stanley
 Janie Weeder
 Tony West
 Patricia Williams

RW
 DEW
 David Whitehead
 RLS
 JB
 JMF
 MH
 MH
 RKM
 CR
 SD
 BS
 DS
 JW
 TW
 PW

Hangers

3-31-82

	Rev. No.	QA Inspector	Welder's Name	Weld Symbol Missing/Minor	Weld Symbol Unclear	Weld Orientation (Front)	Weld Orientation (Side)	Weld Type as Drawn	Extra Valid	Missing Valid	Remarks
A-2-261-1-CW-H-162	0/A	JR	B 16		A	C	C	e	P	T	
A-2-261-1-CW-H-272	0/A	JR	B 16		A	C	C	e	P	T	
A-2-261-1-CW-H-273	0/A	JR	B 16		A	C	C	e	P	T	
A-2-261-1-CW-H-277	0/A	JR	SI 98		A	C	C	e	P	T	
A-2-261-1-CX-H-1637	0/A	SES	SI 66		A	C	C	e	P	T	
A-2-261-1-CW-H-193	0/A	JES	SI 5		A	C	C	e	P	T	
A-2-261-1-FW-H-89	0/A	JES	SI 66		A	C	C	e	P	T	
A-2-261-1-CX-H-1532	0/A	JES	SH 73		A	C	C	E	P	T	
A-2-261-1-CW-H-188	0/A	JES	SH 71		A	C	C	E	P	T	
A-2-261-1-CW-H-182	0/A	JES	D 30		A	C	C	E	P	T	
A-2-261-1-CH-H-1538	1/0	JES	SI 73		A	C	C	E	P	T	
A-2-261-1-SW-H-2144	5/1	JES	SH 95	-	A	C	C	E	P	T	
A-2-261-1-FW-H-88	1/1A	JES	SH 93		A	C	C	E	P	T	
A-2-261-1-CW-H-276	0/A	JR	D 91		A	C	C	e	P	T	
A-2-261-1-CW-H-458	3/0	JR	SB 74		A	C	C	e	P	T	
A-2-261-1-CX-H-1635	1/0	JR	SI 16					✓			REJECT
A-2-261-1-PM-H-232	3/0	JR	C 45		A	C	C	e	P	T	
A-2-236-1-PM-H-278	2/3	6A D	D 11		A	C	C	e	P	T	
A-2-236-1-CX-H-236	3/0	6A D	D 69		A	C	C	e	P	T	
A-2-236-1-SW-H-1233	1/52	6A D	SI 3		A	C	C	e	P	T	

Wingard
4/1/82

	Rev. No.	QA Inspector	Welder's	Weld Symbol Missing/Correct	Weld Symbol Unclear	Weld Overlay (greater than 1/8")	Weld Underline	Weld Type Not as Drawing	Extra Metal	Missing	Remarks
U-5-236-1-WG-H-510	3	JR	C 93				✓				Reject
U-5-236-1-WG-H-511	151	JR	C 93		A	C	C	e	P	T	
U-6-236-1-WG-H-736	4/E	JR	C 93		A	C	C	e	P	T	
U-6-236-1-WG-H-1767	4/A	JR	C 93		A	C	C	e	P	T	
3-1-216-1-RH-H-28	5/C	JE S	SI 5		A	C	C	e	P	T	
A-1-216-1-PD-H-941	152	JE S	D 61		A	C	C	e	P	T	
A-1-216-1-PD-H-943	152	JE S	P 61		A	C	C	e	P	T	
A-1-216-1-PD-H-678	4/B	JE S	D 71		A	C	C	e	P	T	
U-5-236-1-WG-H-518	25	JR	C 93				✓				Reject
F-2-236-1-PD-H-278	0/A	JR	C 43				✓				Reject
T-1-261-1-FW-H-74	45	JE S	SI 86								Reject
A-1-236-1-WL-H-2326	151	JE S	D 30	-	A	C	C	e	P	T	
A-2-281-1-CX-H-1562	0/A	JE S	SI 98		A	C	C	e	P	T	
A-2-261-1-CX-H-											
U-6-236-1-CS-H-1083	05	JE S	SI 71		A	C	C	e	P	T	
F-2-236-1-CC-H-1411	2/C	JR	C 43		A	C	C	e	P	T	
F-1-236-1-SF-H-1154	05	JR	D 54		A	C	C	e	P	T	
A-4-236-1-CX-H-509	4/E	JR	D 51		A	C	C	e	P	T	

1-2-80

	Rev. No.	QA Inspector	Welder's Symbol	Weld Symbol Missing/Drawn	Weld Symbol Unclear	Weld Oversize (greater than 1)	Weld Undersize	Weld Type as Drawn	Extra Material	Missing Weld	Remarks
A-3-236-1-FP-H-603	3/D	RS	S3		A	C	C	E	P	T	
A-3-236-1-CH-H-398	1/B	RS	C		A	C	C	E	P	T	
A-2-236-1-SW-H-1238	2/C	RS	S13		A	C	C	E	P	T	
A-2-236-1-CC-H-1325	0/S1	RS	C13		A	C	C	E	P	T	
A-3-236-1-MSH-197	2/B	RS	D11		A	C	C	E	P	T	
A-1-216-1-PD-H-686	5/2	RS	D27		A	C	C	E	P	T	
A-1-216-1-PD-H-959	1/S2	RS	D61		A	C	C	E	P	T	
A-7-236-1-BR-H-1251	3/0	SR	D61		A	C	C	E	P	T	
A-5-236-1-CC-H-1056	1/B	SR	D69		A	C	C	E	P	T	
A-2-236-1-CH-H-187	0/4	RS	S15		A	C	C	E	P	T	
A-2-236-1-SW-H-279	0/A	RS	D91		A	C	C	E	P	T	
A-5-236-1-CC-H-358	2/C	SR	D69	-	A	C	C	E	P	T	
A-5-236-1-CC-H-353	3/0	SR	C91		A	C	C	E	P	T	
A-4-236-1-CC-H-423	3/C	SR	D51		A	C	C	E	P	T	
A-4-236-1-CC-H-426	3/C	SR	SH71		A	C	C	E	P	T	
A-1-236-1-CH-H-1215	0/S1	SR	D78		A	C	C	E	P	T	
A-4-236-1-BR-H-1575	1/S1	SR	C13		A	C	C	E	P	T	
A-4-236-1-CS-H-2816	0/S1	SR	SH95		A	C	C	E	P	T	
A-4-236-1-CH-H-767	0/S1	SR	D78		A	C	C	E	P	T	
A-6-236-1-CS-H-3181	0/A	SR	D69		A	C	C	E	P	T	

4/3/82

	Rev. No.	QA Inspector	Welder's Symbol	Weld Symbol Missing/Drone	Weld Symbol Unclear	Weld Overlap (greater than)	Weld Underlap	Weld Type as Drawn	Extra Welds	Missing Weld	
2-2-261-1-PD-H-4201	10/A	JR	D 62		A	C	C	e	P	T	
2-2-261-1-PD-H-4221	0/A	JR	SH 71		A	C	C	e	P	T	
2-2-261-1-SW-H-2136	0/A	JR	SI 98		A	C	C	e	P	T	
2-2-261-1-CS-H-224	0/A	JR	SI 5		A	C	C	e	P	T	
2-7-236-1-BR-H-1252	2/C	JR	D 61		A	C	C	e	P	T	
2-7-236-1-BR-H-1174	0/S	JR	C 81		A	C	C	e	P	T	
2-5-236-1-FP-H-654	2/C	JR	C 13		A	C	C	e	P	T	
2-5-236-1-CS-H-2647	1/S	JR	SB 73		A	C	C	e	P	T	
2-5-236-1-CS-H-499	2/C	JR	C 81		A	C	C	e	P	T	
2-6-236-1-PP-H-1673	0/S	JR	SB 73		A	C	C	e	P	T	
2-5-236-1-CX-H-490	2/B	JR	D 69	✓							Rejct
				-							

Waugus
3-30-82

	Rev. No.	QA Inspector	Welder's Symbol	Weld Symbol Missing/Incorrect	Weld Symbol Unclear	Weld Overlay (greater than)	Weld Ripples	Weld Tack on Drawing	Extra Welds	Missing Weld	Remarks
A-1-236-1-BD-H-126	✓ 2/C	JR	D 51		A	C	C	e	P	T	
A-7-236-1-BR-H-1213	✓ 45/2	JR	D 27		A	C	C	e	P	T	
A-6-236-1-BR-H-1508	✓ 1/B	JR	C 84		A	C	C	e	P	T	
A-1-216-1-BR-H-10	✓ RCI 244	JR	D 27		A	C	C	e	P	T	
A-3-236-1-CC-H-344	✓ 75/1	GA D	SI 3		A	C	C	e	P	T	
A-1-236-1-CH-H-595	✓ 0/A	JR	C 43		A	C	C	e	P	T	
A-3-236-1-CS-H-1459	✓ 2/C	GA D	C 95		A	C	C	e	P	T	
A-4-236-1-CT-H-509	✓ 4/E	JR	D 51				✓				Reject
A-2-261-1-CW-H-194	✓ 0/A	J E S	SI 5		A	C	C	e	P	T	
A-2-261-1-CW-H-195	✓ 0/A	J E S	SI 5		A	C	C	e	P	T	
A-2-261-1-CW-H-183	✓ 0/A	J E S	SI 66		A	C	C	C	P	T	
A-2-261-1-CW-H-187	✓ 0/A	J E S	SI 5	-	R	e	j	e	C	T	Reject
A-2-261-1-CW-H-184	✓ 0/A	J E S	SI 5		A	C	C	e	P	T	
A-1-236-1-FF-H-830	✓ 1/B	JR	C 43		A	C	C	e	P	T	
A-1-216-1-PD-H-989	✓ 15/1	JR	D 61		A	C	C	e	P	T	
A-1-216-1-PD-H-2078	✓ 15/1	JR	D 27		A	C	C	e	P	T	
A-1-216-1-RH-H-88	✓ 4/B	JR	D 27		A	C	C	e	P	T	
A-3-236-1-SW-H-1508	✓ 2/C	GA D	SI 59		A	C	C	e	P	T	
A-2-236-1-SW-H-1534	✓ 5/F	GA D	C 43		A	C	C	e	P	T	
A-3-236-1-SW-H-2649	✓ 0/A	GA D	D 62		A	C	C	e	P	T	

JUN 19 1980

TD

In Reply Refer To:
CBA716

Dear

This refers to our conversation of April 14, 1980, during which you expressed concerns regarding the speed with which craft personnel are promoted from trainee to journeyman level at Carolina Power and Light's Sharon Harris construction site. Although you expressed this concern, you also indicated that you knew of no cases where welders were performing work they were not certified to do.

You also expressed concern about numerous defective welds in the main condenser supplied by Westinghouse. We concur with our technical staff's determination that this condenser is not a safety-related assembly and, therefore, is outside NRC's regulatory authority. CVL is aware of the quality problems associated with this equipment and is pursuing the matter.

We appreciate you informing us of your concerns in that the Nuclear Regulatory Commission is committed to assure that safety-related work is properly performed in the construction of nuclear power plants. We feel our actions have been responsive to your concerns; however, please contact us if you have any further questions.

Sincerely,

C. E. Alderson
Senior Regional Investigator

cc: W. Ward, MOE

CERTIFIED MAIL NO.

103

OFFICE ▶	RII:INV	RII:INV			
SURNAME ▶	RJMarsh:hem	CEAlderson			
DATE ▶	6/ /80	6/ /80			

Personal Tools

Hi-Low gauge - Hand S.S

Hi-Low gauge - wire

Feet Gauge

Cambridge Gauge

Gap Gauge

Bevel Gauge

Pen file

Mirrors - Large - Small

Gap Pins

Flask light

Flask light holder

Ruler

Ruler Holder

Scale

Soap Stone & Holder

Walt in Glass

MEMORANDUM TO CASE FILE

TYPE ACTION <input checked="" type="checkbox"/> RECORD OF CONVERSATION <input type="checkbox"/> CASE REVIEW / STATUS <input type="checkbox"/> OTHER	PARTICIPANTS Vorse	FILE NO 26010
		DATE 01-28-82
		TIME 8:20A
CONFIDENTIALITY REQUESTED		YES NO

SUMMARY

called and told me that she could be reached at home after 5:15 PM. I told her I would call her tonight. She also told me that her office phone is

PREPARED BY	PAGE OF
ACTION REQUIRED	DATE
REVIEWED BY	DATE

OFFICIAL USE ONLY — DO NOT DISCLOSE

Carolina Power & Light Company

Company Correspondence

December 9, 1981

MEMORANDUM TO: File

FROM: R. M. Parsons

SUBJECT: Allegation of Inadequate Hanger Inspection

On Tuesday, December 1, 1981, the writer became aware of an allegation related as coming from one or more welders in the field who were working on pipe hangers. The summary of the allegation was that some of the welders were saying one or more inspectors were not doing a thorough job in inspecting the hanger welds. It was alleged that if a hanger was located in an inconvenient location, hard to get to, then the inspectors did not go to the trouble of doing a thorough job of inspection. It was established that the inspector being challenged was

The writer walked through the field that afternoon and randomly examined a number of hangers but was unable to draw any conclusions. The writer then discussed the possibility of inadequate weld inspection with Ashleigh Lucas, Senior Resident Engineer. The only thing that had surfaced recently was a speed memo from John Brinckel to Ray Hanford calling his attention to an accepted weld on a 3/4" stainless steel line. The weld was accepted on June 18, 1981 by [redacted] with a small amount of undercut in violation of the acceptance standards. The line is a Category 7 line. The problem had subsequently been documented on a NCR and will be repaired.

Later on the same day after quitting time the writer further discussed the allegation with Ashleigh Lucas and Ray Hanford, Principal Welding Engineer. Ray related that on November 19 in a meeting with the welding superintendents some opinions were voiced about the QA welding inspectors. The complaints were general and ran along the vein that "they are not welders - they make mistakes". Ray Hanford asked for specifics not generalities. The request precipitated the speed memo from Brinckel. It is significant to note that work as long ago as June 18, 1981 had to be examined to come up with an example.

On Wednesday, December 2, 1981, Alex Fuller researched the records and found hanger inspection packages for 10 hangers that had been previously inspected and accepted by [redacted]

The writer also learned that the NRC Resident Inspector knew of example(s) which could be challenged as having being accepted but not fully meeting the acceptance criteria.

111
W

At 1:00 p.m. [Terry Wain] and the writer went into the reactor auxiliary building to inspect ten hangers that had previously been inspected and accepted. [Terry Wain] is the CP&L supervisor of the quality assurance welding inspection subunit and is a qualified inspector. The writer watched the qualified inspector recheck six of the subject hangers, and in addition, examined the welds that [Terry Wain] had inspected. The remaining four hangers of the group were checked by [Terry Wain] but not by the writer. Including three other hangers inspected during the investigation, a total of 13 hangers had been reinspected with the results as follows:

- SW-H-1333 - Acceptable
 - CC-H-503 - Acceptable
 - FP-H-513 - Acceptable
 - CC-H-332 - Acceptable
 - SF-H-470 - Acceptable
 - CC-H-945 - Acceptable
 - PD-H-458 - Acceptable
 - PD-H-1143 - Acceptable
 - PD-H-463 - Acceptable
 - CC-H-1040 - Acceptable
 - CC-H-1514 - Acceptable
 - * CC-H-342 - Allegation of porosity - too conical to be porosity - could be interpreted otherwise. Did find 1/4 inch of overlap - will repair - welded 12/22/80.
 - * CC-H-469 - Allegation of arc strike - judged not to be an arc strike. Found small porosity that could be judged unacceptable - welded 4/8/81.
- * Brought to our attention by NRC

If the above welds are considered, along with the one pipe weld originally inspected in June, 1981, the pattern suggests that an allegator has to go back almost one year to find three welds inspected by [] that can be challenged as unacceptable AND only one of these has a small defect (1/4 inch of overlap) that requires repair. Based on the above, the writer feels comfortable with [] work. It will be further confirmed when the supervisors monthly evaluation system, proposed below, is implemented.

On Wednesday after work, [George Forehand and Roland Parsons] discussed the potential of the welders trying to discredit []. We also discussed the risk involved if craftsmen are successful in opening an avenue for getting back at inspectors for being too tough by using the NRC. It was felt that we needed to be in a position to defend our inspectors from this brand of what might be called reverse intimidation.

We then called [N. J. Chiangi, Manager of Engineering & Construction QA]. The three of us discussed an approach for ensuring we are in a position to protect inspectors. Given the reality that in any visual inspection, no matter how carefully the English language is used to define acceptance criteria, some judgement exists; and therefore, an opportunity is provided to challenge inspectors.

A concept was generally discussed for enhancing the system for evaluating an inspector's work periodically. The evaluation would also protect the inspector by providing documented backup of his competence. The evaluation procedure was

discussed previously and a method evolved: (1) the welding supervisor shall be behind each welding inspector once a month and shall check a representative 100 lineal inches per month; (2) if no pattern develops to accepted challengeable defects; (3) if no safety significance to any challenged interpretation of criteria exists; (4) and the ones found are repaired; (5) no more than 2 lineal inches could be challenged as inadvertently overlooked. If the above is satisfied then the inspector's performance is judged satisfactory. If the inspector's performance is not adequate based on the criteria above, he shall be retrained and all welds inspected by him during the past month will be reinspected.

On Thursday the writer engaged in discussions with a knowledgeable individual who is in a position to comment on the job pulse. Admittedly the information obtained was second hand and could not be substantiated, however, two significant items surfaced that are worthy of comment: (1) one of the welding superintendents had been complaining to the personnel department that he felt he should be working overtime to straighten out all the welding problems on the job. He suggested that he be transferred to another job where he would get 20 hours per week overtime; (2) some indication was picked up that one or more of the welders had a disagreement with a QA inspector about a week ago. The inspector had irritated the welders for being too tough. Again, the information was second hand and could not be substantiated, however, the writer could not overlook the possibility that certain individuals may be trying to get back at an inspector by making allegations of poor inspection.

Conclusions

1. With one exception, no challenged inspector work was such that it could not have been subjected to different interpretations.
2. No accepted work contained challengeable defects that would have been detrimental to a safety related installation.
3. It could not be definitely established that anyone was trying to use the NRC to discredit QA inspectors, although prudent management must be alert to the possibility.
4. An over reaction against an inspector could come across as lack of support and thereby inhibit his effectiveness.
5. A definite method of judging an inspectors work is needed in order to insulate them from being harassed by unwarranted allegations.

Proposed Corrective Action

1. Increase the frequency and formality of the method for checking an inspector's work by developing a criteria that provides for a reinspection of at least 100 lineal inches of his work each month.
2. Institute the evaluation check on each inspector once per month in a positive way that protects the inspector and helps in his professional development.

3. Continually follow-up on individual allegations to ensure our system is not allowing significant items to go undetected.

Handwritten signature

RJP/bc
cc: Mr. N. J. Chiangi
Mr. G. L. Forehand
Mr. A. M. Lucas

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

FOR INFORMATION ONLY

VISUAL EXAMINATION OF WELDS (SHNPP)

ASME
SECTION III

NUMBER:

NDEP-601

INITIAL ISSUE DATE:

APR 27 1981

Nondestructive Examination
Procedure

RECOMMENDED FOR APPROVAL
BY:

NDE LEVEL III

APPROVED BY:

MANAGER - E&C D/QCC

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

1.0 PURPOSE

The purpose of this procedure is to delineate the visual welding examinations to be performed on fabrication welds and field welds.

2.0 SCOPE

This procedure applies to welds related to ASME Code Section III, Nuclear Safety Related and Seismic Category I Items. This procedure may be utilized, when deemed appropriate, for visual examination of welds related to other code, specification, safety or seismic category items.

3.0 REFERENCES

3.1 ASME B & PV Code, Section V, Article 9, 1974 Edition, with addenda through Winter, 1976.

3.2 CP&L Corporate QA Department Nondestructive Examination Procedures Manual.

3.3 SHNPP Site Specification 034.

3.4 SHNPP Site Specification 030.

3.5 SHNPP Site Specification 031.

3.6 SHNPP Site Specification 033.

3.7 SHNPP Site Specification 040.

3.8 SHNPP Site Specification 041.

3.9 SHNPP Site Specification 036.

3.10 SHNPP MP's 01, 02, 05, 06, 07, 08, 10.

3.11 SHNPP TP-04.

4.0 PROCEDURE QUALIFICATION

4.1 Procedure Qualification Record, No. PQR-601 describes the actual qualification activity for this procedure.

5.0 PERSONNEL QUALIFICATION

Personnel performing visual examinations in accordance with this procedure shall meet qualification requirements as specified in Carolina Power & Light Company Corporate QA procedure NDEP-10.

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

6.0 EQUIPMENT

FOR INFORMATION ONLY

6.1 The following equipment may be used to aid the visual inspector in his evaluation of items being inspected:

- 6.1.1 Flashlight or other illuminating device that provides adequate lighting as described in 6.2.
- 6.1.2 Cambridge Weld Gauge
- 6.1.3 6" Ruled Scale
- 6.1.4 Magnifying Glass
- 6.1.5 Boroscope and Fiber Optics
- 6.1.6 Fillet Weld Gauges
- 6.1.7 Mirrors
- 6.1.8 Optical Comparators
- 6.1.9 Micrometers
- 6.1.10 Depth Gauges
- 6.1.11 Other equipment may be used as necessary, but will be required to meet the conditions of 6.2 and 6.3.

6.2 Illumination

Visual examination shall be performed in an area illuminated with flashlight or other auxiliary lighting to attain a minimum of 15 foot candles (160 Lux) for general examination and a minimum of 50 foot candles (540 Lux) for the detection or study of small anomalies, unless otherwise specified.

6.3 Optical Aids

- 6.3.1 When optical aids such as boroscope, magnifying glass, mirror, etc., are used for remote examination, the system shall have a resolution capability equivalent to or better than that obtained by direct observation.
- 6.3.2 When specified, optical aids shall have a minimum power of magnification called out in the specification or code.

CONTROL

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

NDEF-601

REVISION

0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

6.4 Mechanical Aids and Instruments

FOR INFORMATION ONLY

- 6.4.1 Mechanical aids to inspection shall have scales in useable increments that are easily discernable.
- 6.4.2 Dial depth gauges, micrometers, optical comparators and other mechanical measuring devices used for final acceptance inspection shall be calibrated in accordance with Reference 3.11.
- 6.4.3 Rules, scales, and other measuring devices used to aid inspectors shall be reasonable accurate but do not require calibration such as 6" scale (metal), cambridge gauge and fillet weld gauge.

7.0 EXAMINATION

7.1 General

- 7.1.1 Visual examinations shall normally be performed without magnification. The examination shall be such that the surface to be examined is within 24" of the eye, and at an angle not less than 30° to the surface to be examined.
- 7.1.2 Visual examination performed using optical equipment shall be performed only when required by specification or code, using equipment that conforms to 6.3.

7.2 Time of Inspection

Visual Inspections shall be performed when required by codes, specifications, appropriate site procedures and when appropriate hold points are reached on Weld Data Reports (WDR's), Repair WDR's and prior to all NDE examinations of welds.

7.3 Inspection Points

Items to be inspected at a particular stage of manufacture are listed in Attachment "A".

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER
NDEP-601

REVISION
0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

8.0 EVALUATION

8.1 All welds prior to inspection at any hold point from initial cleanliness inspection to final NDE examinations shall be clean, dry, and free of deteriorious surface matter and surface indications such as:

- a. Paint
- b. Oil, Grease
- c. Moisture
- d. Scale
- e. Oxide and Rust
- f. Nicks, gouges, and irregularities including weld spatter
- g. Zinc or Galvanizing
- h. Slag
- i. Other foreign material (dirt, sand, shavings, grinding dust, etc.)

8.2 Joint Preparation

Piping butt joint and preparation dimensions shall be in accordance with approved drawings and specifications. The preparation of weld joints for matching ends of pipe and correction for out of roundness (counter bore) shall be in accordance with approved drawings, specifications and welding procedures.

8.3 Butt Joint Fitup

Butt Joint fitup shall be in accordance with approved drawings, specifications and welding procedures. Inspectors shall measure and record the amount of counter bore on ISI joints. Counter bore shall be at least 2T on SW Fabrication piping and 1-1/2T on Westinghouse supplied piping.

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-601

0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

8.4 Socket Joint Fitup

FOR INFORMATION ONLY

Socket type joints shall have an end gap of 1/16" minimum between the bottom of the socket and the end of the pipe prior to welding. The minimum engagement length of the pipe into the socket is maintained in accordance with the following requirements:

Minimum Engagement of Socket Welds

<u>Pipe Size</u>	<u>Minimum Engagement</u>
1/8" to 1/2"	1/4"
3/4" to 1-1/2"	3/8"
2" to 3"	1/2"

This shall be accomplished by measuring, using an appropriate measuring device, to determine that the depth of the socket is of adequate depth for the minimum engagement, as listed above, plus the allowed 1/8" pull back requirement, as described below. If the fitting does not have enough socket depth to accommodate the minimum engagement + 1/8" shall be rejected.

The end gap shall be accomplished by scribing a line 1/2" back from the end of the socket fitting; inserting, and bottoming the pipe into the fitting, then scribing a line on the pipe 1" from the face of the fitting. Then pipe is withdrawn at least 1/16". The distance between the two scribe lines shall be between 1-9/16" and 1-11/16".

8.5 Cold Spring

Cold Spring shall be no more than allowed by specification, drawings, and installation instructions. Inspectors shall check for cold spring by looking along the pipe for chains, come alongs, chain falls, hydraulic jacks or blocking devices used to force the pipe or appertenance horizontally or downward into place prior to fitup and welding. When these devices are present, they should be only for support. When the visual inspector has reason to believe that cold spring has been introduced into the pipe system, the visual inspector shall request Mechanical Engineering to measure the amount of cold spring. The measurements shall be recorded on the WDR. When cold spring is in excess of specified limits, the fit-up shall be rejected.

8.6 Appearance of Welds

- 8.6.1 Welds not requiring In-Service Inspection (ISI) shall be free of abrupt ridges, valleys, excessive under cut, cracks, fusion defects, slag or porosity, but need not be ground smooth. Welds requiring surface NDE shall have a surface finish that will not interfere with the interpretation of the NDE.

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NPQP-601

0

FOR INFORMATION ONLY

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

8.6.2 Butt welds requiring In-Service Inspection (ISI) shall have a surface finish that conforms to the ISI surface finish required in NP-06, Appendix "O". Reinforcement shall be 1/32" to 1/16" high, be flat topped and slope 10° to 14° to the base metal - no undercut is allowed.

8.6.3 Reinforcement of Welds

8.6.3.1 Thickness of weld reinforcement for vessels, pumps, and valves

The surface of the reinforcement of all butt welded joints in vessels, pumps, and valves may be flush with the base material or may have uniform crowns. The height of reinforcement on each face of the weld shall not exceed the value listed for the thickness in the following table:

<u>Nominal Thickness in.</u>	<u>Maximum Reinforcement in.</u>
Up to 1, inclusive	3/32
Over 1 to 2 inclusive	1/8
Over 2 to 3 inclusive	5/32
Over 3 to 4 inclusive	7/32
Over 4 to 5 inclusive	1/4
Over 5	5/16

8.6.3.2 Thickness of weld reinforcement for piping

For double welded butt joints, the limitation on the reinforcement given in Column 1 of the following tabulation shall apply separately to both inside and outside surfaces of the joint. For single welded butt joints, the reinforcement given in Column 2 shall apply to the inside surface and the reinforcement given in Column 1 shall apply to the outside surface. The reinforcement shall be determined from the higher of the abutting surfaces involved.

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

Material Nominal Thickness in.	Maximum Reinforcement Thickness, in.	
	Column 1	Column 2
Up to 1/8 inclusive	3/32	3/32
Over 1/8 to 3/16 inclusive	1/8	3/32
Over 3/16 to 1/2 inclusive	5/32	1/8
Over 1/2 to 1 inclusive	3/16	5/32
Over 1 to 2 inclusive	1/4	5/32
Over 2	*	5/32

* Greater of 1/4" or 1/8 time the wide of the weld in inches.

8.6.4 Socket Weld Surface

The weld edges of fillets in socket welds shall have a pipe to weld reentrant angle of not more than 90° and shall be free from cracks, excessive porosity, fusion defects, slag, crater pits (as defined in 9.4), tungsten and undercut.

The leg length for socket welds shall be 1.09T (1.25T for ANSI B31.1 Welds) for pipe to fittings and 1.4T for pipe to flanges. In no case shall the leg length be less than 1/8".

8.7 Internal Diameter Surface of Fused Root Layer

8.7.1 When accessible the internal ID surface of the pipe or appertenance shall be checked to assure that the root on the ID surface is properly fused and is free of cracks, crater pits, excessive porosity, tungsten, oxidation (sugaring), excessive convexity or concavity.

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

NDEP-601

REVISION

0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

9.0 INTERPRETATION OF DISCONTINUITIES

- 9.1 Porosity requirements will be found in the applicable code section.
- 9.2 The welded rounded depressions on the internal surface of piping butt welds made using consumable insert or open butt are acceptable provided the following conditions are met:
- Depression shall not exceed 1/16" deep
 - Depressions shall have a width that is at least three times the depth
 - The resulting weld metal thickness under the depression is not less than the minimum pipe wall thickness of the thinnest member.

Note: Weld reinforcement up to maximum of 1/32" thickness may be considered as pipe wall thickness in such cases. The concavity may extend for the entire periphery of the weld.

- 9.3 Convexity shall be considered reinforcement and shall be judged using the requirements of 8.6.3.2 above.

9.4 Crater Pits

Internal crater pits shall be considered acceptable provided the area contains no cracks and the weld metal thickness under the pit is not less than the thinner adjacent base metal thickness.

9.5 Butt Joint Burn Through and Melt Through

Internal surfaces of butt joints (insert and open butt) shall be free of burn through. Melt through and repaired burn through areas are acceptable provided the areas do not contain cracks, crevices, globules, or unacceptable oxidation and provided the root reinforcement and root concavity limits are not exceeded.

9.6 Butt Weld Overlap

The weld edges of butt welds shall be free of overlap which forms a re-entrant angle of less than 90°.

CORPORATE QUALITY ASSURANCE DEPARTMENT
CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER
NDEP-601

REVISION
0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

9.7 Internal Oxidation

The internal surfaces of piping butt welds after completion of welding shall be free of rough oxide scale accompanied by wrinkling or crystalline surface appearance (sugaring). Thin, tightly adhering iridescent temper films shall be considered acceptable.

9.8 External of Internal Undercut

External or internal undercut which does not exceed 1/32" is acceptable provided the bottom of the undercut is clearly visible, does not provide a liquid penetrant or magnetic particle indication, and does not encroach on the required section thickness.

9.9 Cracks

All welds and adjacent base metal surfaces shall be free of cracks.

9.10 Incomplete Fusion

All welds shall be free of incomplete fusion.

9.11 Arc Strikes, Weld Spatter, and Mishandling Marks

Weld and adjacent base metal shall be free of visible arc strikes, weld spatter and mishandling marks. Arc strikes and mishandling marks, which penetrate the base metal surface outside the weld area shall be found to the bottom of the depression (with care not to violate minimum wall) and liquid penetrant or magnetic particle inspected. The depression made by grinding shall be rounded (not straight-cut).

9.12 Weld Undercut

Weld undercut which does not exceed 1/32" or 10% of the adjacent base metal thickness, whichever is less, is acceptable provided the bottom of the undercut is clearly visible or does not provide a liquid penetrant or magnetic particle indication as applicable.

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENTNUMBER

NDEP-601

REVISION

0

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

10.0 MARKING OF INDICATIONS**FOP INFORMATION ONLY**

All rejectable discontinuities shall be marked up on the weld using approved marking material.

11.0 DOCUMENTATION11.1 Sketches

All excavations on Code Class 1, 2, and 3 shall be sketched on Form QA-3 showing location and depth. This is to include indications found by all NDE methods including visual.

11.2 Welds Requiring A Weld Data Report (WDR)

Document performance of visual examination on the WDR for the particular weld. Check off the appropriate status, date, and initial for the applicable inspection activity.

11.3 Welds Not Requiring a WDR

Document performance of visual examination using the Visual Examination Report for QA VT-1. A single visual examination report form may be used to document visual examination(s) of one or more welds (such as some or all welds in a particular piping line). However, each weld examined must be identified on the report form.

11.4 Welds Requiring Seismic I Weld Data Report (Form QA-34)

Document performance of visual examination on the Seismic I Weld Data Report (Form QA-34). Check off appropriate status, date, and initial.

TITLE: VISUAL EXAMINATION OF WELDS (SHNPP)

FOR INFORMATION ONLY

ATTACHMENT A - INSPECTION POINTS

	BUTT WELDS	SOCKET WELDS	PIPING ATTACHMENTS	STRUCTURAL JOINTS		
1.0 <u>Prior to Fit-up</u>	X	X				
Joint scarf/bevel cleanliness (oxides, rust, dirt, etc.)	X	X	X	X		
Cleanliness of internal surfaces	X	X				
Cleanliness of external surface(s) adjacent to weld	X	X	X	X		
Cleanliness of consumable insert	X					
Joint end prep dimensional configuration and finish	X	X				
Freedom from joint surface defects	X	X	X			
Cold spring for closure joints	X	X				
Marking applied for control of socket engagement		X				
2.0 <u>After fit-up and prior to welding</u>	X	X	X	X		
Joint cleanliness	X	X	X	X		
Fit-up dimensions (i.e., root opening, clearance, etc.)	X	X	X	X		
Joint alignment and offset	X	X	X	X		
Material identification	X	X	X	X		
Purge Dam	X					
O ₂ analysis (if applicable)	X					
3.0 <u>After completion of root layer - when required</u>	X					
Weld shall be hand wire brushed and inspected for freedom from cracks, crater pits, tungsten contamination, lack of fusion and porosity and slag in excess of specified limits.	X					

CAROLINA POWER & LIGHT COMPANY
CORPORATE QUALITY ASSURANCE DEPARTMENT

NUMBER

REVISION

NDEP-601

C

TITLE: VISUAL EXAMINATION OF WELDS (SHNPF)

ATTACHMENT A - INSPECTION POINTS (Continued)

FOR INFORMATION ONLY

	BUTT WELDS	SOCKET WELDS	PIPING ATTACHMENTS	STRUCTURAL JOINTS		
4.0 <u>External surface after completion of weld</u>	X	X	X	X		
Reinforcement (crown) height in a W I SSI Requirements when applicable	X	X	X	X		
Undercut or overgrind	X	X	X	X		
Suitability of surface for required NDT (i.e., removal of weld spatter, arc strikes, etc.)	X	X	X	X		
Removal of temporary attachments	X	X	X	X		
Joint identification	X	X				
Fillet size		X	X	X		
Check socket engagement and pullback		X				
Blending with base metal	X	X	X	X		
Freedom from cracks, incomplete fusion, porosity and slag in excess of specified limits	X	X	X	X		
Welder Symbol	X	X	X	X		
5.0 <u>Internal surface after completion of weld (when accessible)</u>	X					
Cleanliness	X					
Reinforcement - Concavity and Convexity	X					
Incomplete fusion or incomplete melting of consumable inert	X					
Oxidation (sugaring)	X					
Crater Pits	X					
Blending with Base Metal	X					
Burn or melt through	X					

SECTION NO. _____

WELDER: [Signature] SYMBOL 151

INSPECTION REQUIREMENTS: CLEAN FIT UP FINAL DATE 11/11/01

VISUAL LP MP

REWORK NEW

COMMENTS: PC _____ TO PC _____

QA on Rev 9/11

INSPECTOR: [Signature] ACCEPT REJECT HOLD DATE 11/11/01

OVERLAY

*This form for information only-NOT A QA RECORD.

NONDESTRUCTIVE TEST INSPECTION REQUEST *	FOREMAN	LOCATION	ELEV	TIME	DATE
	<u>[Signature]</u>	<u>11/11/01</u>	<u>24</u>		<u>11/11/01</u>
WELDER: <u>[Signature]</u>	SYMBOL <u>151</u>	DWG/ISO	SHEET		
INSPECTION REQUIREMENTS: CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>		<u>11-2-24</u>	<u>23</u>		<u>11/11/01</u>
VISUAL <input checked="" type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>					DETAIL
REWORK <input checked="" type="checkbox"/> NEW <input type="checkbox"/>					
COMMENTS: PC _____ TO PC _____					
					<i>1 pilot weld</i>
INSPECTOR: <u>[Signature]</u>					DATE <u>11/11/01</u>

*This form for information only-NOT A QA RECORD.

True copy handwriting

ET

11/11/01

QA/QC file

NONDESTRUCTIVE TEST FOREMAN		LOCATION	ELEV	TIME	DATE
INSPECTION REQUEST *					
WELDER: _____		SYMBOL _____		DWG/ISO.*	SHEET _____
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>		
	VISUAL <input type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>	DETAIL _____	
REWORK <input type="checkbox"/>		NEW <input type="checkbox"/>			
COMMENTS:		PC _____	TO PC _____		
		<i>1 fileted weld</i>			
INSPECTOR: <u>[Signature]</u>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>[Date]</u>	

This form for Information Only - NOT A QA RECORD.
To be made for each weld

NONDESTRUCTIVE TEST FOREMAN		LOCATION	ELEV	TIME	DATE
INSPECTION REQUEST *					
WELDER: _____		SYMBOL _____		DWG/ISO.*	SHEET _____
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>		
	VISUAL <input type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>	DETAIL _____	
REWORK <input type="checkbox"/>		NEW <input type="checkbox"/>			
COMMENTS:		PC _____	TO PC _____		
		<i>over 1/2</i>			
INSPECTOR: <u>[Signature]</u>	ACCEPT <input type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>[Date]</u>	

This form for Information Only - NOT A QA RECORD.

File
NA 1/31

INDIANA POWER & LIGHT COMPANY
 WASHINGTON HARRIS NUCLEAR POWER PL.

HEISING HANGER INSTALLATION & INSPECTION

HANGER NUMBER 11-1431 REV NO _____

LOCATION OF SPECIAL REQUIREMENTS: P-3-236-1

ACTIVITY	RESPONSIBILITY	SIGN-OFF	
		PHASE I INITIAL	DATE
1. PROVIDE HANGER WITH PACKAGE	MECH ENGR.	JO CA	5/22/81
2. PREPARE HANGER MEMBERS	HANGER SUPT.		
3. BRACE HANGER			
4. IDENTIFY CAP ON PER PACKAGE	CI	3/2/81	5/24/81
5. POSITION & ORIENTATION	CI	3/2/81	5/24/81
6. WELD JOINT FIT UP FULL PEN WELDS	QA		
7. WELD JOINT PER STRESS ISO	CI		
8. CLEANUP PER SPEC	CI		
9. WELD JOINT MEMBERS	HANGER SUPT.	JO CA	5-23-81
10. BRACE	HANGER SUPT.		
11. INSPECT COMPLETED WELDS	QA	JO CA	5/25/81
12. RETURN COPY OF TRAVELER	QA		
13. RETURN PACKAGE TO MECH ENGR	HANGER SUPT.	JO CA	5-28-81
14. SUBMIT PACKAGE TO CI	MECH ENGR.		
15. SUBMIT PACKAGE TO QA	CI		

ENDED THICKNESS = $1\frac{1}{2}$ " 42915/

ENDED THICKNESS = 1 1

PREHEAT VERIFIED BY QA 1 1

COMMENTS

11-1431 (5/22/81) JO CA 5/22/81

CEISMIC

INSTALLATION & INSPECTION

ORDER NUMBER

PD H-1444

REV

DATE

1 PD 3/4 - 1/1

PROJECT OR SITE

EQUIPMENTS:

A-3-2361

ACTIVITY	RESPONSIBILITY	SIGN OFF	
		DATE	FORCE
1. PREPARE HANGER WELD	WAGE MECH ENGR	5/10	9/16/81
2. WELD HANGER NEAR	HANGER SUPT		
3. CHECK HANGER			
4. IDENTIFICATION PER	WAGE CI	9/16	6/28/81
5. PERFORM IDENTIFICATION			
6. PERFORM IDENTIFICATION			
7. WELD HANGER	WELD CI		
8. IDENTIFICATION PER			
9. IDENTIFICATION PER			
10. IDENTIFICATION PER			
11. IDENTIFICATION PER			
12. IDENTIFICATION PER			
13. IDENTIFICATION PER			
14. IDENTIFICATION PER			
15. IDENTIFICATION PER			
16. IDENTIFICATION PER			
17. IDENTIFICATION PER			
18. IDENTIFICATION PER			
19. IDENTIFICATION PER			
20. IDENTIFICATION PER			
21. IDENTIFICATION PER			
22. IDENTIFICATION PER			
23. IDENTIFICATION PER			
24. IDENTIFICATION PER			
25. IDENTIFICATION PER			
26. IDENTIFICATION PER			
27. IDENTIFICATION PER			
28. IDENTIFICATION PER			
29. IDENTIFICATION PER			
30. IDENTIFICATION PER			
31. IDENTIFICATION PER			
32. IDENTIFICATION PER			
33. IDENTIFICATION PER			
34. IDENTIFICATION PER			
35. IDENTIFICATION PER			
36. IDENTIFICATION PER			
37. IDENTIFICATION PER			
38. IDENTIFICATION PER			
39. IDENTIFICATION PER			
40. IDENTIFICATION PER			
41. IDENTIFICATION PER			
42. IDENTIFICATION PER			
43. IDENTIFICATION PER			
44. IDENTIFICATION PER			
45. IDENTIFICATION PER			
46. IDENTIFICATION PER			
47. IDENTIFICATION PER			
48. IDENTIFICATION PER			
49. IDENTIFICATION PER			
50. IDENTIFICATION PER			
51. IDENTIFICATION PER			
52. IDENTIFICATION PER			
53. IDENTIFICATION PER			
54. IDENTIFICATION PER			
55. IDENTIFICATION PER			
56. IDENTIFICATION PER			
57. IDENTIFICATION PER			
58. IDENTIFICATION PER			
59. IDENTIFICATION PER			
60. IDENTIFICATION PER			
61. IDENTIFICATION PER			
62. IDENTIFICATION PER			
63. IDENTIFICATION PER			
64. IDENTIFICATION PER			
65. IDENTIFICATION PER			
66. IDENTIFICATION PER			
67. IDENTIFICATION PER			
68. IDENTIFICATION PER			
69. IDENTIFICATION PER			
70. IDENTIFICATION PER			
71. IDENTIFICATION PER			
72. IDENTIFICATION PER			
73. IDENTIFICATION PER			
74. IDENTIFICATION PER			
75. IDENTIFICATION PER			
76. IDENTIFICATION PER			
77. IDENTIFICATION PER			
78. IDENTIFICATION PER			
79. IDENTIFICATION PER			
80. IDENTIFICATION PER			
81. IDENTIFICATION PER			
82. IDENTIFICATION PER			
83. IDENTIFICATION PER			
84. IDENTIFICATION PER			
85. IDENTIFICATION PER			
86. IDENTIFICATION PER			
87. IDENTIFICATION PER			
88. IDENTIFICATION PER			
89. IDENTIFICATION PER			
90. IDENTIFICATION PER			
91. IDENTIFICATION PER			
92. IDENTIFICATION PER			
93. IDENTIFICATION PER			
94. IDENTIFICATION PER			
95. IDENTIFICATION PER			
96. IDENTIFICATION PER			
97. IDENTIFICATION PER			
98. IDENTIFICATION PER			
99. IDENTIFICATION PER			
100. IDENTIFICATION PER			

EMBED THICKNESS 5/14/81

EMBED THICKNESS 1/1

PREHEAT VERIFIED 1/1

COMMENTS

[Handwritten notes]

NONDESTRUCTIVE TEST FOREMAN	LOCATION	ELEV.	TIME	DATE
INSPECTION REQUEST * <u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>
WELDER: <u>[Signature]</u> BY: <u>[Signature]</u> DL: <u>1-13</u>	DWG / ISO. #	SHEET		
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>	<u>4-3221 2</u>		<u>[Signature]</u>
	VISUAL <input checked="" type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>			DETAIL
	REWORK <input type="checkbox"/> NEW <input checked="" type="checkbox"/>			
COMMENTS: <u>QA ON Rev of A</u>	PC _____	TO PC _____		
INSPECTOR: <u>[Signature]</u>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/> HOLD <input type="checkbox"/>	DATE: <u>[Signature]</u>		

This form for information only - NOT A QA RECORD.

This is my handwriting 2/6/12

NONDESTRUCTIVE TEST FOREMAN	LOCATION	ELEV.	TIME	DATE
INSPECTION REQUEST * <u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>	<u>[Signature]</u>
WELDER: <u>[Signature]</u> BY: <u>[Signature]</u> DL: <u>1-13</u>	DWG / ISO. #	SHEET		
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>	<u>4-3221 2</u>		<u>[Signature]</u>
	VISUAL <input type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>			DETAIL
	REWORK <input type="checkbox"/> NEW <input checked="" type="checkbox"/>			
COMMENTS: <u>QA ON Rev of A</u>	PC _____	TO PC _____		
INSPECTOR: <u>[Signature]</u>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/> HOLD <input type="checkbox"/>	DATE: <u>[Signature]</u>		

This form for information only - NOT A QA RECORD.

[Signature]

SEISMIC HANGER INSTALLATION & INSPECTION

DRAWING NO. PA-11-1470
 LINE NO. 2034-1-1
 LOCATION OR PROJECT REQUIREMENTS: 3-236-1

ACTIVITY	RESPONSIBILITY	SIGN OFF	
		PHASE I INITIAL	DATE
1. PROVIDE HANGER WITH PACKAGE	MECH ENGR	JD	6-2-51
2. SET UP HANGER WITH RIG	HANGER SUPT		
3. INSPECT HANGER			
4. IDENTIFICATION PER PACKAGE	CI	JCH	6-2-51
5. LOCATION & ORIENTATION PER PACKAGE & HANGER	CI	JCH	6-2-51
6. WELD JNT. FIT UP & PEN WELD			
7. LOCATION PER SPEC & ISO	CI		
8. GEOMETRY PER SPEC	CI		
9. WELD OUT MEMBERS	HANGER SUPT	SSA	6-2-51
10. SECONDARY	HANGER SUPT	PT	6/2/51
11. INSPECT COMPLETE WELDS	QA		
12. FILE COPY OF TESTS			
13. RETURN PACKAGE TO MECH ENGR	HANGER SUPT	SSA	6-2-51
14. SUBMIT PACKAGE TO CI	MECH ENGR		
15. SUBMIT PACKAGE TO QA	CI		

EMBED THICKNESS = $1\frac{1}{2}$ " See 5/14/51
 LIMBED THICKNESS = 1/1
 PREHEAT VERIFIED BY QA 1/1

COMMENTS

[Handwritten signature]

NONDESTRUCTIVE TEST INSPECTION REQUEST *		FOREMAN	LOCATION	ELEV.	TIME	DATE
		<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>
Welder: <i>[Handwritten]</i> SYMBOL <i>[Handwritten]</i>		DWG./ISO.*	SHEET	NON INSURER*		
SECTION	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>		
REQUIREMENTS	VISUAL <input checked="" type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>			DETAIL		
REWORK <input type="checkbox"/> NEW <input checked="" type="checkbox"/>						
REMARKS:		PC _____	TO PC _____			
<i>[Handwritten Signature]</i>						
FOR	<i>[Handwritten]</i>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <i>[Handwritten]</i>	
*This form for information only-NOT A GA RECORD.						
<i>[Handwritten]</i>						

NONDESTRUCTIVE TEST INSPECTION REQUEST *		FOREMAN	LOCATION	ELEV.	TIME	DATE
		<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>
Welder: <i>[Handwritten]</i> SYMBOL <i>[Handwritten]</i>		DWG./ISO.*	SHEET	NON INSURER*		
SECTION	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>	<i>[Handwritten]</i>	<i>[Handwritten]</i>	<i>[Handwritten]</i>		
REQUIREMENTS	VISUAL <input checked="" type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>			DETAIL		
REWORK <input type="checkbox"/> NEW <input checked="" type="checkbox"/>						
REMARKS:		PC _____	TO PC _____			
<i>[Handwritten Signature]</i>						
FOR	<i>[Handwritten]</i>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <i>[Handwritten]</i>	
*This form for information only-NOT A GA RECORD.						
<i>[Handwritten]</i>						

SEISMIC HANGER INSTALLATION & INSPECTION

HANGER NUMBER: PD 11451 REV. NO. 1
 LINE NO. 9 PD 3/4 - 1-1
 LOCATION OF SPECIAL REQUIREMENTS: A-3-23

ACTIVITY	RESPONSIBILITY	SIGN OFF	
		PHASE 1 INITIAL DATE	PHASE 2 INITIAL DATE
1 PROVIDE HANGER WORK PACKAGE	MECH ENGR	J.D. 6/2/81	
2 REVIEW HANGER MEMBERS	HANGER SUPT.		
3 INSPECT HANGER			
A IDENTIFICATION PER PACKAGE	CI	J.D. 6/2/81	
B LOCATOR & ORIENTATION PER PACKAGE & PROCEDURE	CI	J.D. 6/2/81	
C WELDMENT FIT UP (FULL PEN WELD)	QA		
D LOCATION PER STRESS ISO	CI		
E GEOMETRY PER SYSTEM	CI		
F WELD OUT MEMBERS	HANGER SUPT.	J.D. 6/2/81	
G PRIMARY			
H SECONDARY	HANGER SUPT.	J.D. 6/2/81	
I INSPECT COMPLETED WELDS	QA		
J GET COPY OF TRAVEL	QA		
K RETURN PACKAGE TO MECH ENGR	HANGER SUPT.	J.D. 6/2/81	
L SUBMIT PACKAGE TO CI	MECH ENGR		
M SUBMIT PACKAGE TO QA	CI		

EMBED THICKNESS $\leq 1\frac{1}{2}$ " 5114101
 EMBED THICKNESS = 1 1
 PREHEAT VERIFIED BY QA 1 1

COMMENTS

CI /




NONDESTRUCTIVE TEST		CREWAN	LOCATION	ELEV	TIME	DATE
INSPECTION REQUEST						
WELDER		SYMBOL	DWG / ISO	SHEET	JOIN NUMBER	
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	UP <input type="checkbox"/>	FINAL <input type="checkbox"/>			
	VISUAL <input checked="" type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>			
REWORK <input type="checkbox"/>		NEW <input type="checkbox"/>				
COMMENTS:		PC _____	TO PC _____			
INSPECTOR		<u>[PT]</u>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>6/10/01</u>

This form for information only - NOT A QA RECORD.

Handwritten: 11-7 check file
 JD H 1151

Handwritten: [no marks above]
 [3] marks

NUMERICAL VE TEST	FOREMAN	LOCAL	DATE
DEFECT OR REQUEST	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
WELDER	SYMBOL	ENGINEER	
	<i>[Signature]</i>	<i>[Signature]</i>	
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT <input type="checkbox"/>	FINAL <input checked="" type="checkbox"/>
	VISUAL <input checked="" type="checkbox"/>	LP <input checked="" type="checkbox"/>	MP <input type="checkbox"/>
	REWORK <input type="checkbox"/>	NEW <input checked="" type="checkbox"/>	
COMMENTS	PC _____	TO PC _____	
<i>QA ON Rev 9/A</i>			
INSPECTOR	<i>[Signature]</i>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/> HOLD <input type="checkbox"/> DATE <i>5/1/51</i>
<small>This Form for Information Only - NOT A QA RECORD.</small>			



Oxford Pendarley

STOCK No. 7521/3

MADE IN U.S.A.

2-1-51

1951

[Signature]

TEST #		FILE #		DATE	
REMARKS		36		30/1/01	
MATERIAL		A-6-200-1		DDH 1610	
INSPECTOR	REWORK	FIT UP	TEST	DETAIL	
REQUIREMENTS	VISUAL	LP	MP		
REWORK		NEW			
COMMENTS:		PC		TO TC	
SPECIFIED		ACCEPT	REJECT	HOLD	DATE
7/25/01					7/25/01

This form for Information Only - NOT A QA RECORD




Oxford Reading
STOCK No. 7521/5

MADE IN U.S.A.


Handwritten notes:

7/25/01

7/25/01

NONDESTRUCTIVE TEST INSPECTION REQUEST #		FOREMAN	LOCATION	ELEV.	TIME	DATE
WELDER:		SYMBOL	DWG/ISO #	SHEET	WELDER	
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>	DETAIL		
	VISUAL <input type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>			
REWORK <input type="checkbox"/>		NEW <input type="checkbox"/>				
COMMENTS: _____ PC _____ TO PC _____						
INSPECTOR: 		ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE 7/25/11	
*This form for information only - NOT A CA RECORD.						

M. G. C. 16-53

 7/25/11

(PROCEDURE CQC-19)

1. UNIT	2. BUILDING	3. ELEV.	4. LOCA.	5. COMPONENT/HANGER ID.	6. DRAWINGS, REV. & SHL #	7. WELD PROC.	9. WELD POSITION
DATE		WELDING ENG / FOREMAN			DATE		8. WELD MET.

- 1. NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS FOR FULL PENETRATION
 - 2. NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS ON JOINTS INVOLVING ENGINEERED PLATES
 - 3. COMPLETE WELDOUT OF JOINTS NOT REQUIRING ADDITIONAL INSTRUCTIONS
 - 4. INFORM QA/QC FOR HOLD POINTS (H) & FINAL WELD INSPECTION
- FOREMAN: GARZELL

WELDER(S) QUALIFICATION A R 3. MAT'L STATUS A T B-RECORD # INSPECTOR DATE 7/25/87

JOINT ID OR DESCIP NO. OF WELDS	WELDER SYMBOL(S)	PREHEAT		FITUP		ROOT NO.				FINAL NO.				WELD	INSP INITIALS	DATE	DESCRIPTION OF DEFECT OR REWORK NO. OF WELDS				
		H	TEMP	H	A	R	H	A	R	H	A	R	H					A	R	UT	VAC BOX
SH87	SH87																				

LEGEND: H = HOLDPOINT
A = ACCEPT
R = REJECT
T = TEMP GREATER THAN LISTED

QA/QC INSPECTION & NDE HOLDPOINT ASSIGNED AND/OR VERIFIED BY INITIALS DATE

QA/QC SPECIALIST / DESIGNEE DATE

REMARKS

*Responsible handovering
6/2/87*

* USE QA-35A TO LIST ADDITIONAL WELDS

SHEARON HARRIS NUCLEAR POWER PLANT

SEISMIC HANGER INSTALLATION & INSPECTION TRAVELER

HANGER NUMBER 121-H-1678 REV NO. 1/1

LINE NO. 9-11-2-1

LOCATION OR SPECIAL REQUIREMENTS: A-226-1

ACTIVITY	RESPONSIBILITY	SIGN OFF			
		PHASE I		PHASE II	
		INITIAL	DATE	INITIAL	DATE
1 PROVIDE HANGER WORK PACKAGE	MECH ENGR	J.D. GH	7-13-81		
2 FIT UP HANGER MEMBERS	HANGER SUPT.				
3 INSPECT HANGER IDENTIFICATION PER PACKAGE	CI	F.E. CIA	7-16-81		
4 LOCATION & ORIENTATION PER PACKAGE & PROCEDURE	CI	RDS CIA	7-16-81		
5 WELDMENT FIT UP (FULL PEN WELD)	QA				
6 LOCATION PER STRESS ISO	CI				
7 GEOMETRY PER SKETCH	CI				
8 WELD OUT MEMBERS	HANGER SUPT.	OCS, OTR	7/26/81		
9 PRIMARY	HANGER SUPT.				
10 SECONDARY	HANGER SUPT.				
11 INSPECT COMPLETED WELDS	QA	[Signature]	7/25/81		
12 PULL COPY OF TRAVELER	QA				
13 RETURN PACKAGE TO MECH ENGR	HANGER SUPT.	[Signature]	7/25/81		
14 SUBMIT PACKAGE TO CI	MECH ENGR				
15 SUBMIT PACKAGE TO QA	CI				

EMBED THICKNESS $\leq 1\frac{1}{2}$ " WPC 16/12/81

EMBED THICKNESS -


PREHEAT VERIFIED BY QA

COMMENTS

CI / F.E. - PLOG NOT INSTALLED


CAI

[]

NONDESTRUCTIVE TEST		FOREMAN	LOCATION	E. EV	TIME	DATE
DEFECTS - REQUEST *						
WELDER:		SYMBOL		CWG / ISO *	SHEET	JOINT
INSPECTION REQUIREMENTS	CLEAR <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>			
	VISUAL <input type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>			DETAIL
REWORK <input type="checkbox"/>		NEW <input type="checkbox"/>				
COMMENTS:		PC _____	TO PC _____			
INSPECTOR		ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE	7/25/97

This form for Information Only-NOT A QA RECORD.

FROM Mark Fl
 PD 41678



NONDESTRUCTIVE TEST FOREMAN		LOCATION	ELEV.	TIME	DATE
INSPECTION REQUEST # <i>5716-104</i>		<i>W-13-1</i>	<i>2.56</i>	<i>2:00</i>	<i>7/25/81</i>
WELDER: <i>Reambl</i>	WBCL <i>3H-7</i>	DWG/ISO. # <i>44-2367</i>	SHEET	JOINT NUMBER	<i>25-167</i>
INSPECTION REQUIREMENTS:	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input checked="" type="checkbox"/>			DETAIL	
		VISUAL <input checked="" type="checkbox"/>	MP <input type="checkbox"/>		
REWORK <input type="checkbox"/>		NEW <input checked="" type="checkbox"/>			
COMMENTS: <i>has g</i> PC _____ TO PC _____					
INSPECTOR: <i>[Signature]</i>	ACCEPT <input checked="" type="checkbox"/> REJECT <input type="checkbox"/> HOLD <input type="checkbox"/>		DATE <i>7/25/81</i>		

This form for Information Only-NOT A QA RECORD.

25-167P

QA/QC file

1. UNIT	2. BUILDING	3. ELEV	4. LOCA	5. COMPONENT/HANGER ID.	6. DRAWINGS, REV & SHE #	7. WELD PROC.	8. WELD INSPECTION
DISCIPLINE ENG.		DATE	WELDING ENG./FOREMAN		DATE	8. WELD ML. TY.	

- I. NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS FOR FULL PENETRATION
 II. NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS ON JOINTS INVOLVING ENGINEERED PLATES
 3. COMPLETE WELDOUT OF JOINTS NOT REQUIRING ADDITIONAL INSTRUCTIONS
 4. INFORM QA/QC FOR HOLD POINTS (H) & FINAL WELD INSPECTION

FOREMAN: Ray M. Seal DATE: _____

1. WELD TYPE & CONFIGURATION CHECKED WITH DWG(S) & COMPONENT/HANGER CONFIGURATION CHECKED WITH DWG(S) A [] R []

2. WELDER(S) QUALIFICATION A [] R [] 3. MAT'L STATUS A [] R []

NCR/DDR # _____ QA/QC INSPECTION _____ DATE _____

# JOINT ID OR DESCIP. B QTY OF WELDS	WELDER SYMBOL(S)	PREHEAT		FITUP		ROOT NDE				FINAL NDE				PWHT	INSP INITIALS	DATE	DESCRIPTION OF DEF OR REWORK NEEDED		
		H	TEMP	H	A	H	A	H	A	H	A	H	A					H	A
14024	SN71																		

LEGEND: H = HOLDPOINT
 A = ACCEPT
 R = REJECT
 T = TEMP. GREATER THAN LISTED

This is my handwriting
 [Signature]

QA/QC INSPECTION & NDE HOLDPOINT ASSIGNED AND/OR VERIFIED BY _____ INITIALS _____ DATE _____

QA/QC SPECIALIST / DESIGNEE _____ DATE _____

REMARKS: _____

[Handwritten notes]

* USE QA-34A TO LIST ADDITIONAL WELDS

ORIGINAL FILE COPY (FIELD COPY)

(PROCEDURE CQC-19)

1 UNIT	2 BUILDING	3 ELEV	4 LOCA	5 COMPONENT/HANGER ID.	6 DRAWINGS, REV. & SHT #	7 WELD PROC.	9 WELD INST.
DISCIPLINE ENG. DATE WELDING ENG./FOREMAN DATE					8 WELD ML. TY.		
Y. ... 6-18-81					17-236-PA-117E 1A440		ETC18

- 1 NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS FOR FULL PENETRATION
- 2 NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS ON JOINTS INVOLVING ENGINEERED PLATES
- 3 COMPLETE WELDOUT OF JOINTS NOT REQUIRING ADDITIONAL INSTRUCTIONS
- 4 PERFORM QA/QC FOR HOLD POINTS (H) & FINAL WELD INSPECTION

FOREMAN: _____ DATE _____

WELD TYPE & CONFIGURATION CHECKED WITH DWG(S) & COMPONENT/HANGER CONFIGURATION CHECKED WITH DWG(S) AS SET

WELDER(S) QUALIFICATION A [] R [] 3. MAT'L STATUS A [] R []

* JOINT ID. OR DESCRIP. QTY OF WELDS	WELDER SYMBOL(S)	PREHEAT		FITUP		ROOT NDE				FINAL NDE				PWHT	WSP INITIALS	DATE	DEFECTS OR REWORK		
		H	TEMP	H	A	H	A	H	A	H	A	H	A					H	A
1/2" PA	0/A	SH-71																	

LEGEND: H = HOLDPOINT
A = ACCEPT
R = REJECT
T = TEMP GREATER THAN LISTED

QA/QC INSPECTION & NDE HOLDPOINT ASSIGNED AND/OR VERIFIED BY _____ INITIALS _____ DATE _____

REMARKS:

QA/QC SPECIALIST / DESIGNEE _____ DATE _____

* USE QA-34A TO LIST ADDITIONAL WELDS

INA POWER & LIGHT COMPANY
 SECTION HARRIS NUCLEAR POWER PLANT

SEISMIC HANGER INSTALLATION & INSPECTION TR

HANGER NUMBER
 LINE NO

FD-H-11-2
 FD-2-1-1

REV. NO. 1/1

LOCATION OR SPECIAL REQUIREMENTS:

A-236-1

ACTIVITY	RESPONSIBILITY	SIGN-OFF			
		PHASE I		PHASE II	
		INITIAL	DATE	INITIAL	DATE
1 PROVIDE HANGER WORK PACKAGE	MECH ENGR				
2 REVIEW HANGER VERIFICATION	HANGER Supt	JDC/2	7-15-81		
3 INSPECT HANGER					
4 IDENTIFICATION PER PACKAGE	CI	F.E. 0/15			
5 LOCATION & ORIENTATION PER PACKAGE & PROCEDURE	CI	RDC	7-16-81		
6 WELDMENT FIT UP / FULL PEN WELDS	QA	F.E. 0/16	7-16-81		
7 LOCATION PER STRENGTH	CI				
8 DIMENSIONS PER SKETCH	CI				
9 WELD OUT MEMBERS: PRIMARY	HANGER Supt				
10 SECONDARY	HANGER Supt				
11 INSPECT COMPLETED WELDS	QA				
12 FILE COPY OF TRAVELER	QA				
13 RETURN PACKAGE TO MECH ENGR	HANGER Supt				
14 SUBMIT PACKAGE TO	MECH ENGR				
15 SUBMIT PACKAGE TO	CI				

BEHEED THICKNESS 5/16" WPC 6/12/81

BEHEED THICKNESS = 1/1

POSITION VERIFIED BY QA. 1/1

COMMENTS

011 F.E. - PIPG NOT INSTALLED

NONDESTRUCTIVE TEST FOREMAN		LOCATION	ELEV	TIME	DATE
INSPECTION REQUEST * <u>Inter-lead</u>		<u>QA-1</u>	<u>736</u>	<u>3:11</u>	<u>7/5/81</u>
WELDER <u>Frank</u>		SYMBOL <u>SH-11</u>	OWNSHIP * <u>AL-206</u>	REJECT	<u>PC-11-1682</u>
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>	DETAIL	
	VISUAL <input checked="" type="checkbox"/>	LP <input type="checkbox"/>	MP <input type="checkbox"/>		
REWORK <input type="checkbox"/>		NEW <input checked="" type="checkbox"/>			
COMMENTS: <u>Rev. 0/1</u> PC _____ TO PC _____					
INSPECTOR <u>D. [Signature]</u>		ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>7/5/81</u>

This form for information only - NOT A QA RECORD.


SDH 1682
from QC/QA file

[This is my handwriting]
5/2/10/20

From Mech File
PDH 1682

NONDESTRUCTIVE TEST INSPECTION REQUEST *		FOREMAN	LOCATION	ELEV	TIME	DATE
WELDER:		SYMBOL	DWG./ISO *	SHEET	JOINT MANAGER	
SECTION:	CLEAN <input type="checkbox"/> FIT UP <input type="checkbox"/> FINAL <input type="checkbox"/>				DETAIL	
REQUIREMENTS	VISUAL <input type="checkbox"/> LP <input type="checkbox"/> MP <input type="checkbox"/>					
	REWORK <input type="checkbox"/> NEW <input type="checkbox"/>					
COMMENTS:	PC _____ TO PC _____					
ENTER	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE	7/5/10	
This form is for Information Only - NOT A QA RECORD.						

log reflect [Krispin] inspected the weld



from Mark file

NONDESTRUCTIVE TEST INSPECTION REQUEST *		FOREMAN	LOCATION	ELEV	TIME	DATE
WELDER:		SYMBOL	DWG./ISO *	SHEET		
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	FIT UP <input type="checkbox"/>	FINAL <input type="checkbox"/>			
	VISUAL <input type="checkbox"/>	LP <input type="checkbox"/>	WP <input type="checkbox"/>			DETAIL
COMMENTS:		REWORK <input type="checkbox"/>	NEY <input type="checkbox"/>			
		TC	TC	PC		
INSPECTOR [Signature]		ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE	

File: RA/QC File

NONDESTRUCTIVE TEST INSPECTION REQUEST *		FOREMAN	LOCATION	ELEV.	TIME	DATE
WELDER <u>Markins</u>		<u>Michael RAB</u>	<u>236</u>	<u>3pm</u>	<u>7/25/81</u>	
SYMBOLS <u>5</u>		DWG./ISO.# <u>RL-236-1</u>	SHEET	JOINT NUMBER <u>PO # 1695</u>		
INSPECTION REQUIREMENTS	CLEAN <input type="checkbox"/>	UP <input type="checkbox"/>	FINAL <input type="checkbox"/>	DETAIL		
	VISUAL <input checked="" type="checkbox"/>	HP <input type="checkbox"/>				
REWORK <input type="checkbox"/>		NEW <input checked="" type="checkbox"/>				
COMMENTS: <u>Rev. 9/2</u>		PC _____	TO PC _____			
INSPECTOR <u>[Signature]</u>	ACCEPT <input checked="" type="checkbox"/>	REJECT <input type="checkbox"/>	HOLD <input type="checkbox"/>	DATE <u>7/25/81</u>		

*This form for Information Only-NOT A QA RECORD.

(PROCEDURE CQC-19)

1. BUILDING	2. FLEV	3. LOCA	4. COMPONENT/HANGER ID	5. DRAWINGS, REV. & SHE. #	6. WELD PROC.
DISCIPLINE ENG. / DATE	WELDING ENG. / FOREMAN	DATE			

NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS FOR FULL PENETRATION
 NOTIFY DISCIPLINE ENGINEER FOR ADDITIONAL INSTRUCTIONS ON JOINTS INVOLVING ENGINEERED PLATES
 COMPLETE WELDOUT OF JOINTS NOT REQUIRING ADDITIONAL INSTRUCTIONS
 INFORM QA/QC FOR HOLD POINTS (H) & FINAL WELD INSPECTION

WELD TYPE & CONFIGURATION CHECKED WITH DWG(S) & COMPONENT/HANGER CONFIGURATION CHECKED WITH DWG(S) & ACTED UPON BY: [Signature] DATE: 1/25/51

WELDER(S) QUALIFICATION A R STATE STATUS A R WELDER: [Signature] DATE: 1/25/51

JOINT ID. OR DESCIP. NO. OF WELDS	WELDER SYMBOL(S)	PREHEAT		FITUP		ROOT NDE				FINAL NDE				VAL BOX	INITIALS	DATE	DESCRIPTION OR REWORK		
		H	TEMP	H	R	VT	MT/PT	VT	MT/PT	RT	UT	H	A					H	A
11/10/51 0/A	SI-S																		

LEGEND
 H = HOLDPOINT
 A = ACCEPT
 R = REJECT
 T = TEMP GREATER THAN LISTED

QA/QC INSPECTION & NDE HOLDPOINT ASSIGNED AND/OR VERIFIED BY: [Signature] INITIALS: [Signature] DATE: [Signature]

QA/QC SPECIALIST / DESIGNEE: _____ DATE: _____

REMARKS

* USE QA-34A TO LIST ADDITIONAL WELDS

IX

Marc Davis
John Harrall
Reginald Faulkner
Gil DeBarros
Alan Kinsey
Mark Tallon
James Hampton
Eugene Martin
Rose Briere
John Swindell
Alan Lowe
Dwight Estes
Ian Simpson
David Jarvis
Robert Steele
John Scoates
John R. Bain
Wayne Martin
Jim Storey
Douglas Sudduth

← another name under
white-out, but illegible

~~MD~~
~~12L~~
~~R.S.~~
~~GAO~~
~~BR~~
~~TD~~
~~JFH~~
~~JEM~~
~~R.S.~~
~~J.S.~~
~~JDL~~
~~J.S.~~
~~J.S.~~
~~J.S.~~
~~R.S.~~
~~J.S.~~
~~RB~~
~~WOM~~
~~J.S.~~
~~J.S.~~

James Root

• Robert St. Pierre (printed)

Judy Sauerbier

David Shackley

• Bobby Smith (printed)

Ricky Strickland

Don Sugg

Cyndi Talbott

Frank Taylor

Pete Tingen

Cynthia Turner

• Vernon Veglia (typed)

• Terry Wait (typed)

Richard Warren

Paul West

• Tom West (printed)

David Whitehead

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

~~Handwritten initials~~

• Additions: ← name under white out, but illegible)

Robert L. St. Pierre

~~Handwritten initials~~

John Barber

~~Handwritten initials~~

Sheila Freeman

~~Handwritten initials~~

Mark Hale

~~Handwritten initials~~

Margaret Hundley

~~Handwritten initials~~

Rich Moore

~~Handwritten initials~~

Clay Rhodes

~~Handwritten initials~~

Don Sands

~~Handwritten initials~~

Bobby Smith

~~Handwritten initials~~

Don Smith

~~Handwritten initials~~

• Ken Stanley (typed)

Janie Weeder

~~Handwritten initials~~

Tony West

~~Handwritten initials~~

Raymond Williams

~~Handwritten initials~~

Barbara Howe

Don Hudson

Rhett Hunt

• Eric Hunter (typed)

• Dudley Jacobs (typed)

Sandy Jenkins

Gene Kelly

Kendel Kirks

Jay Kremer

John Langdon

Tom Lee

Walt Leggett

• Pam McCurdy (typed)

Judi McDonnell

Ward Mercer

Lil Meyer

• Cheryl Miller (typed)

Glenn Milner

Dale Mize

• Rich Moore (printed)

Steve Mountcastle

• David Myers (typed)

Carl Osman

Jean Parker

Bill Pere

Nguyen Van Phung

Don Prince

Al Pulliam

• Cathy Rehrbough (typed)

• Clay Rhodes (printed)

Handwritten initials

D.M.H.

H

[Handwritten initials]

[Handwritten initials]

K.K.

[Handwritten initials]

[Handwritten initials]

T.W.L.

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]

[Handwritten initials]


[Handwritten initials]

INITIALS OF SITE QA/QC INSPECTION PERSONNEL

<u>Name</u>	<u>Initials</u>
Andy Barstrom	A.B.
Ed Betz	EB
James Brown	JB
Emma Jean Burton	EB
Richard Bussey	RB.
James Cagle	JWC
Herb Casanova	H/C
Jerry Cates	JC
Robert Cates	RC
Pete Cook	PC
• Don Crispino (typed)	DC
Gina Cullins	GC
George Daniel	GD
Rick Demling	RD
Ken Douglas	KD
• Bud Driggers (typed)	BD
Tommy Gilbert	TG
• Bruce Giles (typed)	BG
• Bill Godbold (typed)	BG
Glenda Goodman	GG
Robin Groves	RG
• Mike Hale (printed, w/no initials)	
Dyanne Hardy	DH
John Holland	JH
• David Holler (typed)	DH
Teddy Holter	TH

Marc Davis
 John Harrell
 Reginald Faulkner
 Gil DeBarros
 Alan Kinsey
 Mark Tallon
 James Hampton
 Eugene Martin
 Rose Briere
 John Swindell
 Alan Lowe
 Dwight Estes
 Ian Simpson
 David Jarvis
 Robert Steele
 John Scoates
 John R. Bain
 Wayne Martin
 Jim Storey
 Douglas Sudduth

~~MD~~
~~JRH~~
~~R.F.~~
~~G.D.~~
~~AK~~
~~MT~~
~~JFH~~
~~JEM~~
~~R.B.~~
~~JS~~
~~AL~~
~~DES~~
~~IS~~
~~DJ~~
~~RS~~
~~JSP~~
~~JB~~
~~WDM~~
~~JST~~
~~DS~~



James Root
Judy Sauerbier
David Snockley
Ricky Strickland
Don Sugg
Cyndi Talbott
Frank Taylor
Pete Tingen
Cynthia Turner

Richard Warren
Paul West
David Whitehead

Additions:

Robert L. St. Pierre
John Barber
Sheila Freeman
Mark Hale
Margaret Hundley
Rich Moore
Clay Rhodes
Don Sands
Bobby Smith
Don Smith

Janie Needer
Tom West

INITIALS OF SITE CAVCO INSPECTION PERSONNEL

<u>Name</u>	<u>Initials</u>
Andy Bartram	AB
Ed Betz	EB
Jares Brown	JB
Emma Jean Burton	EB
Richard Bussey	RB
James Cagle	JWC
Herb Casanova	H/C
Jerry Cates	JC
Robert Cates	RC
Pete Cook	PC
Gina Cullins	GC
George Daniel	GD
Rick Depling	RD
Ken Douglas	KD
Tommy Gilbert	TG
Glenda Goodman	GG
Robin Groves	RG
Dyanne Hardy	DH
John Holland	JH
Becky Holter	BH



and periodic evaluations, and certification of the qualifications of each person.

6. REVISION OF ANSI STANDARDS REFERRED TO IN THIS DOCUMENT

When the following standards referred to in this document are superseded by a revision approved by the American National Standards Institute, the revision shall apply.

N45.2, Quality Assurance Program Requirements for Nuclear Power Plants

N45.2.10,³ Quality Assurance Terms and Definitions.

³This Standard is being approved by the American National Standards Institute and it should be available early in 1973.

Table 1
 Minimum Levels of Capability for Project Functions

Project Function	Level		
	L-I	L-II	L-III
Approve inspection and test procedures			X
Implement inspection and test procedures	X		
Evaluate inspection and test results		X	
Reporting of inspection and test results		X	

RECEIVING OFFICE

1. Facility(ies) Involved:
(If more than 3, or if generic, write GENERIC)

(Name) SHEARON HARRIS

Docket Number (if applicable)

050 00400

2. Functional Area(s) Involved:
(Check appropriate box(es))

operations onsite health and safety
 construction offsite health and safety
 safeguards emergency preparedness
 other (Specify) _____

3. Description:
(Limit to 100 characters)

ALLEGED FAILURE TO REPAIR
DEFECTIVE HANGER WELDS

4. Source of Allegation:
(Check appropriate box)

contractor employee security guard
 licensee employee news media
 NRC employee private citizen
 organization (Specify) _____
 other (Specify) _____

5. Date Allegation Received:

MM DD YY
08 03 83

6. Name of Individual Receiving Allegation:

(First two initials and last name) B. JONES

7. Office:

RII

ACTION OFFICE

8. Action Office Contact:

(First two initials and last name) GA TODD

9. FTS Telephone Number:

242-4193

10. Status:
(Check one)

Open, if followup actions are pending or in progress
 Closed, if followup actions are completed

11. Date Closed:

MM DD YY

117
3032

12. Remarks:
(Limit to 50 characters)

FOLLOWUP AS REACTIVE INSP
ACTION

13. Allegation Number:

Office Year Number
RII - 83 - A - 0066

INSTRUCTIONS

The following are specific instructions for completing each of the required items on the Allegation Data Form.

The first part of the form (items 1 - 7) should be completed by the Office receiving the allegation. The remainder of the form (items 8 - 13) should be completed by the Office responsible for reviewing and taking action on the allegation.

1. Facility(ies) Involved: Give the name of the facility(ies) or company(ies) about whom the allegation is made. Write the docket number, if appropriate, in the boxes to the right.
If the allegation is made about a specific individual or if the information in this item is otherwise sensitive, write SENSITIVE.
If more than three facilities or companies are involved write GENERIC.
2. Functional Area(s) Involved: Check all applicable boxes.
3. Description: Briefly describe the allegation (1 or 2 sentences). Be concise. If an allegation includes several instances of wrong doing list the assertions separately or group them by type.
NOTE: if the description of the allegation is sensitive, write only SENSITIVE.
4. Source of Allegation: Check the box that most clearly describes the affiliation or occupation of the person making the allegation. DO NOT include the name of the individual making the allegation.
5. Date Allegation Received: Show the month, day, and year on which the allegation was reported to NRC.
6. Name of Individual Receiving Allegation: Give the NRC staff member's first and middle initials and last name.
7. Office: Use official NRC abbreviations to indicate the NRC Office receiving the allegation.
8. Action Office Contact: Write the first and middle initials and last name of the NRC staff member responsible for follow-up action on the allegation.
9. FTS Telephone Number: Write the seven-digit FTS telephone number at which the Action Office Contact (see item 8) can be reached.
10. Status: Check the appropriate box.
11. Date Closed: Show the month, day, and year on which the follow-up action was completed.
12. Remarks: Include additional information as appropriate.
EXAMPLES: list other allegations related to this allegation;
list other NRC offices responsible for follow-up activities on this allegation.
13. Allegation Number: Fill in the boxes to uniquely identify this allegation:
OFFICE -- official NRC office abbreviation for the Office responsible for follow-up activities.
YEAR -- last two digits of the calendar year in which the allegation was reported to NRC.
A -- identifies this number as an allegation number.
NUMBER -- sequential number assigned by the Office responsible for the follow-up activities.
EXAMPLE: The 24th allegation received by IE in 1982 would be shown as IE-82-A-0024