

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) Joseph M. Farley - Unit 1 DOCKET NUMBER (2) 0 5 0 0 0 3 4 8 1 OF 0 2

TITLE (4)
Inoperable Service Water Battery

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)			
MONTH	DAY	YEAR	YEAR	SEQUENTIAL NUMBER	REVISION NUMBER	MONTH	DAY	YEAR	FACILITY NAMES	DOCKET NUMBER(S)		
05	01	84	84	011	00	05	25	84	J. M. Farley - Unit 2	0 5 0 0 0 3 6 4		
										0 5 0 0 0		

THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR 5. (Check one or more of the following) (11)

OPERATING MODE (9) 1	20.402(b)	20.408(e)	90.73(a)(2)(iv)	73.71(b)
POWER LEVEL (10) 047	20.408(a)(1)(i)	90.38(a)(1)	90.73(a)(2)(v)	73.71(e)
	20.408(a)(1)(ii)	90.38(a)(2)	90.73(a)(2)(vi)	OTHER (Specify in Abstract below and in Text, NRC Form 365A)
	20.408(a)(1)(iii)	90.73(a)(2)(i)	90.73(a)(2)(vii)(A)	
	20.408(a)(1)(iv)	90.73(a)(2)(ii)	90.73(a)(2)(vii)(B)	
	20.408(a)(1)(v)	90.73(a)(2)(iii)	90.73(a)(2)(viii)	

LICENSEE CONTACT FOR THIS LER (12)

NAME	TELEPHONE NUMBER
W. G. Hairston, III	2 0 5 8 9 9 - 5 1 5 6

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)

CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NPRDS

SUPPLEMENTAL REPORT EXPECTED (14)

YES (If yes, complete EXPECTED SUBMISSION DATE) NO

EXPECTED SUBMISSION DATE (15)

MONTH	DAY	YEAR

ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

At 1035 on 5-1-84, during performance of FNP-0-STP-606.2 (Service Water Building Battery Weekly Verification), the B train service water battery was declared inoperable due to cell number 42 (EJ, BTRY) having a specific gravity of 1.182 corrected to 77 degrees Fahrenheit versus 1.190 required. The affected cell and the two neighboring cells (3 cell unit) were replaced. Health/safety of the public was not affected.

8406010235 840525
PDR ADOCK 05000348
S PDR

LICENSEE EVENT REPORT (LER) TEXT CONTINUATION

FACILITY NAME (1) Joseph M. Farley Nuclear Plant - Unit 1	DOCKET NUMBER (2) 0500034884	LER NUMBER (6)			PAGE (3)	
		YEAR 84	SEQUENTIAL NUMBER 011	REVISION NUMBER 00	02	OF 02

TEXT (If more space is required, use additional NRC Form 386A's) (17)

On 05-01-84, FNP-0-STP-606.2 (Service Water Building Battery Weekly Verification) was performed on the B train battery. At 1035, the battery was declared inoperable due to cell number 42 (EJ, BTRY) having a specific gravity of 1.182 corrected to 77 degrees Fahrenheit versus 1.190 required by technical specification 4.8.2.4.2.a.2. It is noted that the specific gravity of this cell and of the other cells was still sufficient to fulfill the FSAR load requirements with margin.

It is suspected that the low specific gravity was caused by current tracking across the battery case between the cell terminals. This tracking may result from contaminants introduced during battery operation and may be compounded by the close terminal spacing of the service water battery. Such tracking could shunt the float charge in a manner as to slowly deplete the cell specific gravity. Since similar occurrences have been reported (see LERs 78-026/03L-0 [Unit 1], 80-056/03L-0 [Unit 1], 80-067/03L-0 [Unit 1], 80-070/03L-0 [Unit 1], 83-017/03L-0 [Unit 1], and 83-041/03L-0 [Unit 1]), this is believed to be a potentially generic problem rather than a random problem.

The affected cell and two neighboring cells (3 cell unit) were replaced restoring the B train battery to operable status at 1225 on 05-01-84. An engineering evaluation is in progress to determine a means to prevent recurrence.

Mailing Address
Alabama Power Company
600 North 18th Street
Post Office Box 2641
Telephone 205 783-6090

R. P. McDonald
Senior Vice President
Nuclear Generation
Flintridge Building



Alabama Power
the southern electric system

May 25, 1984

Docket Nos. 50-348

Document Control Desk
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dear Sir:

Joseph M. Farley Nuclear Plant - Unit 1, Licensee Event Report No. LER 84-011-00 is forwarded in accordance with 10CFR50.73 to provide 30 days written notification of this occurrence.

If you have any questions, please advise.

Yours very truly,

R. P. McDonald

RPM/CJS:1sh-D16
Enclosure
cc: IE, Region II

IERZ
//