

APPENDIX A

NOTICE OF VIOLATION

Omaha Public Power District
Fort Calhoun Nuclear Station

Docket: 50-285/84-07
License: DPR-40

Based on the results of an NRC inspection conducted during the period of March 1-31, 1984, and in accordance with the NRC Enforcement Policy (10 CFR Part 2, Appendix C), 47 FR 9987, dated March 9, 1982, the following violation was identified:

Failure to Follow Procedures

Technical Specification 5.8.1 requires that "written procedures . . . be established, implemented, and maintained that meet or exceed the minimum requirements of Section 5.1 and 5.3 of ANSI N18.7-1972, and Appendix A of USNRC Regulatory Guide 1.33"

Standing Order G-7 establishes the Operating Manual and states in Section 1.3 that "adherence to the Operating Manual is mandatory."

Procedure CMP-4.5, "Containment Purge Release Permit," contains the instructions for initiating and conducting a containment purge release. Section VIII.6(c) states that, "during the use of the containment purge system, the release must be terminated if the X/Q value becomes greater than ___ E-___ Sec/M³ (the limiting X/Q) based on ___ CFM."

Contrary to the above, on March 6, 1984, during the conduct of Containment Purge 84013, the licensee failed to terminate the containment purge when the 8:00 a.m. X/Q reading was greater than the limiting X/Q for the established flow rate.

This is a Severity Level IV Violation. (Supplement I.D.3) (285/8407-01)

Pursuant to the provisions of 10 CFR 2.201, Omaha Public Power District is hereby required to submit to this office, within 30 days of the date of this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

Dated: APR 27 1984

8406010337 840427
PDR ADOCK 05000285
Q PDR