

UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555

April 9, 1992

Docket No. 50-352

Mr. George J. Beck Manager-Licensing, MC 52A-5 Philadelphia Electric Company Nuclear Group Headquarters Correspondence Control Desk P.O. Box No. 195 Wayne, Pennsylvania 19087-0195

Dear Mr. Beck:

INDICATION IN REACTOR VESSEL RECIRCULATION RISER NOZZLE TO SAFE END WELD, LIMERICK GENERATING STATION, UNIT 1, (TAC NO. M83078)

Your letter of April 3, 1992 requested approval for the application of the Mechanical Stress Improvement Process (MSIP) to the N2H recirculation riser nozzle to safe end weld at Limerick Generating Station, Unit 1. Approval is hereby granted subject to the following commitments described in your letter and confirmed in discussions with your staff:

- 1. An ultrasonic testing (UT) examination will be performed following the application of the MSIP, prior to startup from the current (fourth) refueling outage. The results of this examination will be used as the baseline for future examinations of the N2H nozzle to safe end weld. Also, prior to startup from the current outage, the post-MSIP UT results will be provided to the NRC.
- 2. Future examinations of the N2H nozzle to safe end weld will be performed in accordance with the requirements of the Limerick Technical Specifications (TSs). Section 4.0.5.f of the TSs requires that "the Inservice Inspection (ISI) Program for piping identified in NRC Generic Letter 88-01 shall be performed in accordance with the staff positions on schedules, methods and personnel, and sample expansion included in the Generic Letter". As confirmed with your staff, this TS section requires that the weld be reinspected at each of the next four Unit 1 refueling outages to meet the staff position on inspection schedules in Generic Letter 88-01 and NUREG-0313. Revision 2.
- The performance of the Limerick chemistry staff in maintaining high quality reactor water chemistry during the past operating cycle minimized the potential for intergranular stress corrosion cracking of stainless steel piping in Units 1 and 2. You will continue to strive to maintain reactor water chemistry within the EPRI guidelines and will continue with implementation of the Condensate Filter Demineralizer Optimization Program at Limerick. You will complete installation of the deep bed demineralizers in the condensate system during the current outage and, following testing, the units will be placed in service during the early part of the next operating cycle.

4. The ability to continue monitoring the N2H nozzle to safe end weld with the Crack Advance Verification System (CAVS) during the fifth operating cycle will be evaluated. A final decision regarding this continued CAVS monitoring will be reached prior to startup from the current refueling outage and discussed with the NRC at that time.

Sincerely,

Original signed by
Richard J. Clark
Richard J. Clark, Senior Project Manager
Project Directorate I-2
Division of Reactor Projects - 1/II
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:
Docket File
NRC & Local PDRs
PDI-2 Reading
SVarga
JCalvo
CMiller
MO'Brien(2)
RClark
JShea
OGC
JWiggins
ACRS(10)
RBlough, RGN-1
LDoerflein, RGN-1

OFFICE	Annual Control of the	PDI-2/PM		PD1-2/D /	
NAME	MO Brien	RCFark tlo	Wiggins Com	CMPTTer)	
DATE	A.19/92	04/09/92	+ 19/92	04/04/92	1 1

OFFICIAL RECORD COPY FILENAME: A:\L1183078.GEN 4. The ability to continue monitoring the N2H nozzle to safe end weld with the Crack Advance Verification System (CAVS) during the fifth operating cycle will be evaluated. A final decision regarding this continued CAVS monitoring will be reached prior to startup from the current refueling outage and discussed with the NRC at that time.

Sincerely,

(Richard J. Clark, Senior Project Manager

Project Directorate I-2

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

.cc: See next page

Mr. George J. Beck Philadelphia Electric Company

001

J. W. Durham, Sr., Esquire Sr. V.P. & General Counsel Philadelphia Electric Company 2301 Market Street Philadelphia, Pennsylvania 19101

M: And Krich 52A-5
Philadelphia Electric Company
955 Chesterbrook Boulevard
Wayne, Pennsylvania 19087-5691

Mr. Graham M. Leitch, Vice President Limerick Generating Station Post Office Box A Sanatoga, Pennsylvania 19464

Mr. John Doering Plant Manager Limerick Generating Station P.U. Box A Sanatoga, Pennsylvania 19464

Regiona! Administrator U.S. Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Mr. Thomas Kenny Senior Resident Inspector US Nuclear Regulatory Commission P. O. Box 596 Pottstown, Pennsylvania 19464

Mr. Richard W. Dubiel
Superintendent - Services
Limerick Generating Station
P.O. Box A
Sanatoga, Pennsylvania 19464

Limerick Generating Station, Units 1 à 2

Mr. William P. Dornsife, Director Bureau of Radiation Protection PA Dept. of Environmental Resources P. O. Box 2063 Harrisburg, Pennsylvania 17120

Mr. James A. Muntz Superintendent-Technical Limerick Generating Station P. O. Box A Sanatoga, Pennsylvania 19464

Mr. Gil J. Madsen Regulato Engineer Limerick Generating Station P. O. Box A Sanatoga, Pennsylvania 19464

Library US Nuclear Regulatory Commission Region I 475 Allendale Road King of Prussia, PA 19406

Mr. George A. Hunger Project Manager Limerick Generating Station P. O. Box A Sanatoga, Pennsylvania 19464

Mr. Larry Hopkins Superintendent-Operations Limerick Generating Station P. O. Box A Sanatoga, Pennsylvania 19464