



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

MAY 13 1983

MEMORANDUM FOR: D. G. Eisenhut, Director, Division of Licensing, NRR  
FROM: R. F. Warnick, Director, Office of Special Cases  
SUBJECT: RECOMMENDATION FOR NOTIFICATION OF LICENSING BOARD

In accordance with present NRC procedures regarding Board Notifications, the following information is being provided as constituting new information relevant and material to the Midland OM/OL proceedings. This information deals with the licensee's May 9, 1983 decision to stop Remedial Soils work due to violations of applied Hold Tag requirements.

The pertinent facts that relate to the stop work are as follows:

1. On May 6, 1983, MPQAD issued a nonconformance report (NCR) to document drift set deficiencies identified on previous Remedial Soils installations. As a result of the NCR, Hold Tags were applied.
2. On May 7, 1983, MPQAD issued an NCR to document drift set deficiencies identified during installation of pier KC-2 (East). As a result of the NCR, Hold Tags were applied.
3. On May 9, 1983, the licensee determined that work had continued on pier KC-2 (East) despite the presence of the Hold Tags. An additional NCR was issued to document the Hold Tag violations. At noon on May 9, 1983, the Field Soils Organization (FSO) stopped Remedial Soils work activities due to the Hold Tag violations. Although a formal Stop Work Order was not issued, 53 workers were sent home.
4. At 8:00 a.m. on May 10, 1983, the licensee resumed Remedial Soils work activities. The resumption of work was allowed after a resolution of differences between MPQAD and FSO pertaining to the significance of NCR's and Hold Tags. The NRC was informed of the Remedial Soils stop work by Stone and Webster (S&W) personnel during their meeting with the Midland Resident Inspectors to discuss the monthly S&W report of Remedial Soils work activities.

D. G. Eisenhut

- 2 -

MAY 13 1953

If you have any questions or desire further information regarding this matter, please call me.

*J. J. Harrison*  
for

R. F. Warnick, Director  
Office of Special Cases

cc: A. B. Davis  
J. J. Harrison  
R. N. Gardner  
R. B. Landsman  
R. J. Cook

Warrick

MIDLAND NUCLEAR SITE  
FACILITY DATA

Facility Description

1. Location	Midland, MI (Within City Limits)
2. Electric Reliability Council	NA
3. Type of Reactor	PWR
4. Power Level (MWT)	2552
5. Design Electrical Rating (MWE Net)	Unit 1 - 492, Unit 2 - 818
6. Date of Initial Criticality	NA
7. Date of Commercial Operation	NA
8. Condenser Cooling Method	Cooling Pond
9. Condenser Cooling Water Source	Tittabawasee River

Utility & Contractor Information

10. Licensee	Consumers Power Company
11. Corporate Contact	James W. Cook, Vice President Midland Project (517) 788-0453
12. Corporate Address	1945 W. Parnall Rd., Jackson, MI 49201
13. Architect/Engineer	Bechtel (517) 788-0453
14. Nuclear Steam Supply System	Babcock & Wilcox
15. Constructor	Bechtel

Plant Contacts

D. L. Quamme, Site Manager	(517) 839-6458
R. Wells, Executive Manager, MPQAD	(517) 839-6389
Switchboard	(517) 839-6000

Plant Address

3500 Miller Road  
Midland, MI 48640

Regulatory Information

16. IE Region responsible	III
17. IE Branch Chief	R. F. Warnick, Chief, Projects Branch 1 (312) 790-5575
18. Section Chief	J. J. Harrison (312) 790-5635
19. IE Project Manager	R. N. Gardner (312) 790-5524
20. IE Senior Resident Inspector	R. J. Cook (517) 631-7807 (Res.) (517) 631-8150 (Office)
21. IE Resident Inspector	Bruce L. Burgess (517) 835-3537 (Res.) (517) 631-8150 (Office)
22. IE Resident Inspector	Patrick L. Hiland (517) 695-9308 (Res.) (517) 631-8150 (Office)
23. Licensing Project Manager	Darl Hood (301) 492-8402
24. Docket Number	50-329; 50-330
25. License Number/Date of Issue	CPPR-81; CPPR-82 12/15/72
26. Public Document Room	Grace A. Dow Memorial Library 1710 W. St. Andrews Road Midland, MI 48640

I have a copy ~~①~~  
② Warnick



**Consumers  
Power  
Company**

Dean L Quamme  
Site Manager  
Midland Project

Midland Project: PO Box 1963, Midland, MI 48640 • (517) 831-8650

File: 16.0, 0460.3, 0505.2  
Serial: CSM-0746  
UFI: 73\*10\*03

March 13, 1984

Mr J J Harrison  
US Nuclear Regulatory Commission  
Region III  
799 Roosevelt Road  
Glen Ellyn, IL 60137

PRINCIPAL STAFF		
✓ EA	WWS	OPRP
✓ D/RA		DE
✓ W/RA		DRMSP
✓		DRMA
✓ AD		SCS
✓ EA		REL
✓		File WWS

✓ 6-16-84 +3

MIDLAND ENERGY CENTER PROJECT -  
REQUEST FOR APPROVAL OF RELEASE OF INSPECTION ACTIVITY ASSOCIATED WITH  
VERIFICATION OF NCR REWORK

Per our discussion of 3/7/84, this letter documents our request to obtain approval for release of inspection associated with verification of rework as a result of an NCR rework disposition regardless of what module the action item is in. There are approximately 750 nonconformance reports for which rework had previously been accomplished per the NCR disposition, but the verification inspection had not been accomplished prior to the general halt of inspection activities. Any such inspections are completely controlled by the existing MPQAD procedures.

Your concurrence to this request will be appreciated.

*Dean L Quamme*

WRB/DLQ/jkd

CC JGKepler, Administrator, Region III  
RJCook, NRC Resident Inspector, Midland  
DSHood, USNRC

8403230031

MAR 22 1984

OC0384-0001A-QL03



OM/OL SERVICE LIST

Mr Frank J Kelley  
Attorney General of the  
State of Michigan  
Ms Carole Steinberg  
Assistant Attorney General  
Environmental Protection Division  
720 Law Building  
Lansing, MI 48913

Mr Myron M Cherry, Esq  
Suite 3700  
Three First National Plaza  
Chicago, IL 60602

Mr Wendell H Marshall  
RFD 10  
Midland, MI 48640

Mr Charles Bechhoefer, Esq  
Atomic Safety & Licensing  
Board Panel  
U S Nuclear Regulatory Commission  
East-West Towers, Room E-413  
Bethesda, MD 20014

Dr Frederick P Cowan  
6152 N Verde Trail  
Apt B-125  
Boca Raton, FL 33433

Mr Fred C Williams  
Isham, Lincoln & Beale  
1120 Connecticut Ave, NW, Suite 840  
Washington, DC 20036

Mr James E Brunner, Esq  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, MI 49201

Mr D F Judd  
Babcock & Wilcox  
PO Box 1260  
Lynchburg, VA 24505

Mr Steve Gadler, Esq  
2120 Carter Avenue  
St Paul, MN 55108

Atomic Safety & Licensing  
Appeal Board  
U S Nuclear Regulatory Commission  
Washington, DC 20555

Mr C R Stephens (3)  
Chief, Docketing & Services  
U S Nuclear Regulatory Commission  
Office of the Secretary  
Washington, DC 20555

Ms Mary Sinclair  
5711 Summerset Street  
Midland, MI 48640

Mr William D Paton, Esq  
Counsel for the NRC Staff  
U S Nuclear Regulatory Commission  
Washington, DC 20555

Atomic Safety & Licensing  
Board Panel  
U S Nuclear Regulatory Commission  
Washington, DC 20555

Ms Barbara Stamaris  
5795 North River Road  
Rt 3  
Freeland, MI 48623

Dr Jerry Harbour  
Atomic Safety & Licensing  
Board Panel  
U S Nuclear Regulatory Commission  
East-West Towers, Room E-454  
Bethesda, MD 20014

Mr M I Miller, Esq  
Isham, Lincoln & Beale  
Three First National Plaza  
52nd Floor  
Chicago, IL 60602

Mr John DeMeester, Esq  
Dow Chemical Building  
Michigan Division  
Midland MI 48640

Ms Lynne Bernabei  
Government Accountability Project  
1901 Q Street, NW  
Washington, DC 20009

3/8/84