

December 2, 1991

DISTRIBUTION
See attached page

Docket No. 50-395

Mr. John L. Skolds
Vice President, Nuclear Operations
South Carolina Electric & Gas Company
Virgil C. Summer Nuclear Station
P.O. Box 88
Jenkinsville, South Carolina, 29065

Dear Mr. Skolds:

SUBJECT: REQUEST FOR 1ST VALVE TEST RELIEF, VIRGIL C. SUMMER
NUCLEAR STATION, UNIT 1 (TAC NO. M82150)

By letter dated November 21, 1991, South Carolina Electric & Gas Company (SCE&G) requested relief from Section XI, Subsection IWV-3200, of the American Society of Mechanical Engineers Code. Specifically, SCE&G requested relief from performing a stroke test of the "B" feedwater isolation valve following maintenance on a shuttle valve related to the isolation valve's actuator.

Subsequent to issuing this relief request, SCE&G reconsidered its position and elected to perform the stroke test. SCE&G's new position was made known to me in a telephone conversation with Mr. Ken Nettles and other members of your staff on the afternoon of November 21, 1991. It is our understanding that the subject relief is no longer necessary; therefore, we consider your relief request to be withdrawn. No further submittal on this subject is required of you. If you have any questions, please contact me.

Sincerely,

George F. Wunder, Project Manager
Project Directorate II-1
Division of Reactor Projects I/II
Office of Nuclear Reactor Regulation

cc: See next page

9112100300 911202
PDR ADOCK 05000395
P PDR

NRC FILE CENTER COPY

OFF	:LA:FRD:SRPE	:PM:PD21:DRPE	:D:PD21:DRPE	:	:
NAME	:PAnderson	:GWunder:dt	:EAden:am	:	:
DATE	:11/21/91	:11/27/91	:11/29/91	:	:

OFFICIAL RECORD COPY
Document Name: SUMMER RELIEF M82150

DF01 1/0

DISTRIBUTION

Docket File

NRC PDR

Local PDR

S. Varga 14-E-4

G. Laines 14-H-3

L. Reyes R11

E. Adensam 14-B-20

P. Anderson 14-B-20

G. Wunder 14-B-20

OGC 15-B-18

E. Jordan MNBB-3701

ACRS (10) P-315

PD21 Plant File Summer

cc: Plant Service list