

Omaha Public Power District  
444 South 16th Street Mall  
Omaha, Nebraska 68102-2247  
402/636-2000

June 26, 1995  
LIC-95-0112

U. S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Mail Station P1-137  
Washington, DC 20555

Reference: Docket No. 50-285

SUBJECT: Application for Amendment of Operating License

Enclosed please find Omaha Public Power District's (OPPD) "Application for Amendment of Operating License" which seeks to amend Technical Specification 2.3 extending the allowed outage time (AOT) from 24 hours to seven (7) days for an inoperable low pressure safety injection pump. This amendment request is a collaborative effort of participating Combustion Engineering Owners Group members based on an integrated assessment of plant operations and deterministic and probabilistic analyses.

Attachment A contains a markup reflecting the requested changes of the Technical Specifications. Attachment B provides the "Discussion, Justification and No Significant Hazards Consideration." Attachment C contains a copy of Combustion Engineering Report CE NPSD-995, titled "Joint Applications Report for Low Pressure Safety Injection System AOT Extension," dated May 1995.


100001

A001  
1/37

U. S. Nuclear Regulatory Commission  
LIC-95-0112  
Page 2

If you have additional questions, or require further information, please do not hesitate to contact me or members of my staff.

Sincerely,



W. G. Gates  
Vice President

WGG/mle

Attachments

c: Winston & Strawn  
L. J. Callan, NRC Regional Administrator, Region IV  
T. Y. Liu, NRC Acting Project Manager  
W. C. Walker, NRC Senior Resident Inspector  
P. J. Hijeck, CEOG Assistant Project Manager  
B. E. Casari, Director, Environmental Health Division,  
State of Nebraska, Department of Health

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
Omaha Public Power District ) Docket No. 50-285  
(Fort Calhoun Station )  
Unit No. 1) )

AFFIDAVIT

W. G. Gates, being duly sworn, hereby deposes and says that he is the Vice President in charge of all nuclear activities of the Omaha Public Power District; that as such he is duly authorized to sign and file with the Nuclear Regulatory Commission the attached information concerning the Application for Amendment dated June 26, 1995 concerning revisions to Technical Specification 2.3 to extend the allowed outage time from 24 hours to seven (7) days for an inoperable low pressure safety injection pump; that he is familiar with the content thereof; and that the matters set forth therein are true and correct to the best of his knowledge, information, and belief.

W. G. Gates  
W. G. Gates  
Vice President

STATE OF NEBRASKA)  
 ) ss  
COUNTY OF DOUGLAS)

Subscribed and sworn to before me, a Notary Public in and for the State of Nebraska on this 27<sup>th</sup> day of June, 1995.

Theresa Petersen  
Notary Public

