

*Southern California Edison Company*



SAN ONOFRE NUCLEAR GENERATING STATION  
P.O. BOX 128  
SAN CLEMENTE, CALIFORNIA 92672

J. G. HAYNES  
STATION MANAGER

TELEPHONE  
(714) 492-7700

May 29, 1984

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Docket No. 50-361 and 50-362  
30-Day Report  
Licensee Event Report No. 84-030  
San Onofre Nuclear Generating Station, Units 2 and 3

References: (1) Letter, J. G. Haynes (SCE) to J. B. Martin (NRC)  
dated April 25, 1984, Licensee Event Report 84-024  
  
(2) Letter, K. P. Baskin (SCE) to H. R. Denton (NRC),  
dated March 19, 1984, "FHA Update Consistent  
with 10 CFR 50.71(e)"

Pursuant to 10 CFR 50.73 and License Condition 2.G to Facility Operating Licenses NPF-10 and NPF-15 for Units 2 and 3, respectively, this submittal provides the 24-hour telephone report, 14-day Follow-up report, and Licensee Event Report (LER) Number 84-030 (Docket No. 50-361) for apparent fire protection program discrepancies. Since these occurrences involved shared systems between Units 2 and 3, a single LER for Unit 2 is enclosed in accordance with NUREG-1022.

As indicated in Reference 1, discrepancies have been discovered during our continuing review (see LER 84-001, Docket No. 50-361) associated with the preparation of the updated Fire Hazards Analysis (FHA) (Reference 2). These conditions have been documented in three Nonconformance Reports (NCR's). Two NCR's represent additional examples of deficiencies reported previously in Reference 1 and corrective actions, described in Reference 1, will be implemented for these two NCRs. The third NCR documents deficient conditions involving the storage of combustible materials. Compensatory fire watches have been established in the affected areas.

The health and safety of plant personnel and the public were not affected by these discrepancies.

8406040239 840529  
PDR ADOCK 05000361  
S PDR

IERL  
1/1

May 29, 1984

If you require any additional information, please so advise.

Sincerely,

*JG Haynes/sem*

Enclosure: LER No. 84-030

cc: A. E. Chaffee (USNRC Resident Inspector, Units 1, 2 and 3)  
J. P. Stewart (USNRC Resident Inspector, Units 2 and 3)

J. B. Martin (Regional Administrator, NRC Region V)

Institute of Nuclear Power Operations (INPO)