

LICENSEE EVENT REPORT (LER)

FACILITY NAME (1) SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 2	DOCKET NUMBER (2) 0 5 0 0 0 3 6 1	PAGE (3) 1 OF 0 1
---	---	-----------------------------

TITLE (4)
FIRE PROTECTION PROGRAM DISCREPANCIES

EVENT DATE (5)			LER NUMBER (6)			REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)		
MONTH	DAY	YEAR	YEAR	SEQ. NUMBER	REV. NUMBER	MONTH	DAY	YEAR	FACILITY NAMES		DOCKET NUMBER(S)
									UNIT 3		0 5 0 0 0 3 6 2
0 5	2 5	8 4	8 4	0 3 0	0 0	0 5	2 9	8 4			0 5 0 0 0 1 1

OPERATING MODE (9) 1	THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10 CFR §: (Check one or more of the following) (11)									
POWER LEVEL (10) 1 0 0	<input type="checkbox"/> 20.402(b)	<input type="checkbox"/> 20.405(c)	<input type="checkbox"/> 50.73(a)(2)(iv)	<input type="checkbox"/> 73.71(b)						
	<input type="checkbox"/> 20.405(a)(1)(i)	<input type="checkbox"/> 50.36(c)(1)	<input type="checkbox"/> 50.73(a)(2)(v)	<input type="checkbox"/> 73.71(c)						
	<input type="checkbox"/> 20.405(a)(1)(ii)	<input type="checkbox"/> 50.36(c)(2)	<input type="checkbox"/> 50.73(a)(2)(vii)	<input checked="" type="checkbox"/> OTHER (Specify in Abstract below and in Text, NRC Form 366A)						
	<input type="checkbox"/> 20.405(a)(1)(iii)	<input type="checkbox"/> 50.73(a)(2)(i)	<input type="checkbox"/> 50.73(a)(2)(viii)(A)	License Condition 2.G						
	<input type="checkbox"/> 20.405(a)(1)(iv)	<input checked="" type="checkbox"/> 50.73(a)(2)(ii)	<input type="checkbox"/> 50.73(a)(2)(viii)(B)							
<input type="checkbox"/> 20.405(a)(1)(v)	<input type="checkbox"/> 50.73(a)(2)(iii)	<input type="checkbox"/> 50.73(a)(2)(x)								

LICENSEE CONTACT FOR THIS LER (12)		TELEPHONE NUMBER	
NAME J. G. HAYNES, STATION MANAGER	AREA CODE 7 1 1 4	NUMBER 4 9 2 1	EXTENSION - 7 7 0 0

COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)									
CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRPDS	CAUSE	SYSTEM	COMPONENT	MANUFACTURER	REPORTABLE TO NRPDS

SUPPLEMENTAL REPORT EXPECTED (14)			EXPECTED SUBMISSION DATE (15)		
YES (If yes, complete EXPECTED SUBMISSION DATE)	<input checked="" type="checkbox"/> NO		MONTH	DAY	YEAR

Abstract (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)

As reported on May 25, 1984, pursuant to 10 CFR 50.36 and 50.72(b)(1)(ii)(B) and License Condition 2.G., discrepancies have been discovered during our continuing review (see LER 84-001, Docket No. 50-361) associated with the preparation of the updated Fire Hazards Analysis (FHA). These conditions have been documented in three Nonconformance Reports (NCR's). Two NCR's represent additional examples of deficiencies reported previously in LER 84-024 and corrective actions, described in LER 84-024, will be implemented for these two NCRs. The third NCR documents deficient conditions involving the storage of combustible materials. Compensatory fire watches have been established in the affected areas.

This report is also submitted to fulfill the requirements of License Condition 2.G. relating to License Conditions 2.C.(14)a and 2.C.(12)a of Operating Licenses NPF-10 and NPF-15 for Units 2 and 3, respectively.

8406040240 840529
PDR ADOCK 05000361
S PDR