



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

May 24, 1984

Docket Nos: 50-329 OM, OL  
and 50-330 OM, OL

Mr. J. W. Cook  
Vice President  
Consumers Power Company  
1945 West Parnall Road  
Jackson, Michigan 49201

Dear Mr. Cook:

Subject: Request for Additional Information Regarding  
Seismic Margin Review for the Midland Auxiliary  
Building, Service Water Pump Structure, and  
Diesel Generator Building

Sections 1.8 and 3.7.2.2 of Supplement 2 to the SER identified seismic margin studies as a confirmatory issue for Midland Plant, Units 1 and 2. Your letters of July 22, September 2, and August 2, 1983, forwarded Volumes III, IV and V of the Seismic Margin Reviews by Structural Mechanics Associates for NRC review. The NRC staff has reviewed these three volumes and finds that additional information identified by Enclosure 1 is needed to complete structural engineering aspects of this review.

The reporting and/or recordkeeping requirements contained in this letter affect fewer than ten respondents; therefore, OMB clearance is not required under P.L. 96-511.

Should you have questions regarding Enclosure 1, contact our Licensing Project Manager, Darl Hood, at (301) 492-8474. Your response within 30 days of receipt of this letter is requested.

Sincerely,

Elinor G. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing

Enclosure:  
As stated

cc: See next page

DESIGNATED ORIGINAL  
Certified By

MIDLAND

Mr. J. W. Cook  
Vice President  
Consumers Power Company  
1945 West Parnall Road  
Jackson, Michigan 49201

cc: Michael I. Miller, Esq.  
Ronald G. Zamarin, Esq.  
Alan S. Farnell, Esq.  
Isham, Lincoln & Beale  
Three First National Plaza,  
51st floor  
Chicago, Illinois 60602

James E. Brunner, Esq.  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Ms. Mary Sinclair  
5711 Summerset Drive  
Midland, Michigan 48640

Stewart H. Freeman  
Assistant Attorney General  
State of Michigan Environmental  
Protection Division  
720 Law Building  
Lansing, Michigan 48913

Mr. Wendell Marshall  
Route 10  
Midland, Michigan 48640

Mr. R. B. Borsum  
Nuclear Power Generation Division  
Babcock & Wilcox  
7910 Woodmont Avenue, Suite 220  
Bethesda, Maryland 20814

Cherry & Flynn  
Suite 3700  
Three First National Plaza  
Chicago, Illinois 60602

Mr. Don van Farrowe, Chief  
Division of Radiological Health  
Department of Public Health  
P. O. Box 33035  
Lansing, Michigan 48909

Mr. Steve Gadler  
2120 Carter Avenue  
St. Paul, Minnesota 55108

U.S. Nuclear Regulatory Commission  
Resident Inspector's Office  
Route 7  
Midland, Michigan 48640

Ms. Barbara Stamiris  
5795 N. River  
Freeland, Michigan 48623

Mr. Paul A. Perry, Secretary  
Consumers Power Company  
212 W. Michigan Avenue  
Jackson, Michigan 49201

Mr. Walt Apley  
c/o Mr. Max Clausen  
Battelle Pacific North West Labs  
(PNWL)  
SIGMA IV Building  
Battelle Blvd.  
Richland, Washington 99352

Mr. I. Charak, Manager  
NRC Assistance Project  
Argonne National Laboratory  
9700 South Cass Avenue  
Argonne, Illinois 60439

James G. Keppler, Regional Admin.  
U.S. Nuclear Regulatory Commission,  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

Mr. J. W. Cook

- 2 -

cc: Mr. Ron Callen  
Michigan Public Service Commission  
6545 Mercantile Way  
P. O. Box C J221  
Lansing, Michigan 48909

Ms. Julie Morrison  
Midland Daily News  
124 McDonald Street  
Midland, Michigan 48640

Billie Pirner Garde  
Director, Citizens Clinic  
for Accountable Government  
Government Accountability Project  
Institute for Policy Studies  
1901 Que Street, N.W.  
Washington, D. C. 20009

Mr. Howard Levin, Project Manager  
TERA Corporation  
7101 Wisconsin Avenue  
Bethesda, Maryland 20814

Ms. Lynne Bernabei  
Government Accountability Project  
1901 Q Street, N.W.  
Washington, D. C. 20009

Supplemental page to the Midland OM, OL Service List

Mr. J. W. Cook

- 3 -

cc: Commander, Naval Surface Weapons Center  
ATTN: P. C. Huang  
White Oak  
Silver Spring, Maryland 20910

Mr. L. J. Auge, Manager  
Facility Design Engineering  
Energy Technology Engineering Center  
P. O. Box 1449  
Canoga Park, California 91304

Mr. Neil Gehring  
U.S. Corps of Engineers  
NCEED - T  
7th Floor  
477 Michigan Avenue  
Detroit, Michigan 48226

Charles Bechhoefer, Esq.  
Atomic Safety & Licensing Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. Frederick P. Cowan  
Apt. B-125  
6125 N. Verde Trail  
Boca Raton, Florida 33433

Jerry Harbour, Esq.  
Atomic Safety and Licensing Board  
U.S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Geotechnical Engineers, Inc.  
ATTN: Dr. Steve J. Paulos  
1017 Main Street  
Winchester, Massachusetts 01890

ATTN: Clyde Herrick  
Franklin Research Center  
20th & Race Streets  
Philadelphia, Pennsylvania 19103

Mr. Patrick Bassett  
Energy Division  
Norwest Bank Minneapolis, N.A.  
8th and Marquette  
Minneapolis, Minnesota 55479

ENCLOSURE 1

REQUEST FOR ADDITIONAL INFORMATION REGARDING  
SEISMIC MARGIN REVIEW FOR AUXILIARY BUILDING (VOL. III),  
SERVICE WATER PUMP STRUCTURE (VOL. IV), AND  
DIESEL GENERATOR BUILDING (VOL. V)

130.0 STRUCTURAL ENGINEERING SECTION B, OF THE STRUCTURAL AND GEOTECHNICAL  
ENGINEERING BRANCH

130.31 Provide the following additional information and clarifications with  
respect to Volume III of the seismic margin report for the Midland  
Auxiliary Building:

1. Page III-2-13 states that the results of the parametric study are presented in Appendix B of this report. Clarify how the figures provided in Appendix III-B apply to the contents of the first paragraph on page III-2-13.
2. North-South cracks have been observed in several floors of the control tower. You have selected the slab at elevation 685' to assess vertical seismic amplifications in the floors. Discuss how the reduction in bending stiffness due to the cracks affects the results of these analyses. Also, discuss whether or not Elevation 685' is still considered to be a representative location for this structure for the effects of vertical seismic amplification.
3. Page III-3-9 states that Seismic Margins Earthquake (SME) values exceed the design values, as noted. However, page III-6-6 states that the SME values would have to be increased by a factor of 1.2 before code capacity would be reached for any auxiliary building structural element. Explain this apparent inconsistency.
4. We assume that the diaphragm forces discussed on page III-3-15 refer to the interface between the Electrical Penetration Areas (EPA) and the Control Tower (CT). Confirm or correct our assumption. Also, clarify whether these diaphragm forces are obtained at the finite element nodal points or at their center points. Explain how the location of these forces can effect the results for evaluation of local load transfer. Special consideration should be given at wall and slab off-sets.
5. Discuss how you selected and/or determined the temporary and permanent jacking loads identified on pages III-3-15 and III-3-16. This discussion should include how all tributary areas of the structure are included in the determination of the permanent jacking loads at lock-off. Also, address the effects on the results if these loads were to be exceeded by 20%.

6. Discuss how the increased stiffness resulting from the final modification proposed for the slab at elevation 659' would effect the code margins stated on page III-6-5.
7. A note on Figure III-2-4 states that "horizontal members shown are rigid except between lines G and H". Clarify this figure by providing a legend for the model and state whether this note applies only to the slabs and walls.

130.32 Provide the following additional information and clarifications with respect to Volume IV of the seismic margin report for the Midland Service Water Pump Structure:

1. Seismic Margin Report Vol. IV includes a discussion of "Dynamic Soil Decrement." Why was this concept not applied to the evaluation of the auxiliary building?
2. Page IV-3-11 addresses Bechtel's dynamic soil decrement. Provide additional clarifying discussion for this proposed concept. Include a list of applicable references with related discussion as to their contents and applicability to the seismic margin earthquake analysis for the Service Water Pump Structure.

130.33 Provide the following additional information with respect to Volume V of the seismic margin report for the Midland Diesel Generator Building: The settlement loads identified on page V-3-11 refer to Bechtel's calculated settlement-load values. These values have not been accepted by the staff. Identify the sensitivity of this parameter on the seismic margin earthquake (SME) results provided in Volume V. Provide documentation addressing changes in the settlement load values resulting from different analyses, and the effects on the SME results.

Docket Nos. 50-329/330 OM, OL

NRC PDR

Local PDR

PRC System

NSIC