

Duquesne Light Company

Beaver Valley Power Station
P.O. Box 4
Shippingport, PA 15077-0004
(412) 393-5206
(412) 643-8089 FAX

GEORGE S. THOMAS
Division Vice President
Nuclear Services
Nuclear Power Division

June 29, 1995

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001


Subject: Beaver Valley Power Station, Unit No. 1 and No. 2
BV-1 Docket No. 50-334, License No. DPR-66
BV-2 Docket No. 50-412, License No. NPF-73
Typed Pages for Technical Specification Change Nos. 199 and 66, Revision 1

Attached are the typed final technical specification pages for issuance of amendments in response to the Duquesne Light Company request for Technical Specification Change Nos. 199 and 66, Revision 1. The following non-intent editorial changes have been incorporated to ensure consistency with current format and content:

<u>UNIT</u>	<u>PAGE</u>	<u>CHANGE DESCRIPTION</u>
1	B 3/4 6-4	Replaced the sentence which states, "At no time should the OPERABLE door be opened if it cannot be demonstrated that the inoperable door is sufficiently closed/latched such that it could inadvertently open while the OPERABLE door is opened." with the following two sentences: "At no time should the OPERABLE door be opened if it cannot be demonstrated that the inoperable door is sufficiently closed/latched. This verification is necessary to preclude an inadvertent opening of the inoperable door while the OPERABLE door is open."
2	B 3/4 6-3	(Same as Unit 1)

If you have any questions regarding the attached information, please contact Mr. G. S. Sovick at (412) 393-5211.

Sincerely,


George S. Thomas

110025

Attachment

c: Mr. L. W. Rossbach, Sr. Resident Inspector
Mr. T. T. Martin, NRC Region I Administrator
Mr. D. S. Brinkman, Sr. Project Manager

9507100418 950629
PDR ADOCK 05000334
PDR

Adol
11/11

