



South Carolina Electric & Gas Company  
Virgil C. Summer Nuclear Station  
P. O. Box 88  
Jenkinsville, SC 29065  
(803) 345-5209

July 11, 1995  
RC-95-0185

Mr. S. Dembek  
Project Directorate II-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation  
Mail Stop 14B20 (OWFN)  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Dembek:

Subject: VIRGIL C. SUMMER NUCLEAR STATION  
DOCKET NO. 50/395  
OPERATING LICENSE NO. NPF-12  
AMENDMENT 95-02  
FINAL SAFETY ANALYSIS REPORT (FSAR)

Per your phone conversation with Ms. Berley indicating that the previously transmitted FSAR Amendment 95-02 was destroyed prior to reaching your office, enclosed is a replacement set of FSAR Amendment 95-02 to the Final Safety Analysis Report (FSAR) for the Virgil C. Summer Nuclear Station. The remaining ten sets will be forwarded by copy of this letter to the Document Control Desk.

This FSAR Amendment is updated as of March 27, 1995; it constitutes the second update to the FSAR for 1995, including the required information in accordance with 10CFR50.71(e).

Please note that pages which are submitted as amendment numbers other than 95-02 are administrative in nature and do not constitute any technical changes.

If there are any questions, please contact Ms. Janis Berley at (803) 345-4248.

Very truly yours:

R. M. Fowlkes

jlb  
Enclosure

c: Document Control Desk w/ATTACHMENTS  
RTS (REM 8000-95-02) WO/ATTACHMENTS  
Central File System "  
File (813 12) "

A05B  
1/10

9507140099 950711  
PDR ADOCK 05000395  
K PDR

143086




NUCLEAR EXCELLENCE - A SUMMER TRADITION!

VIRGIL C. SUMMER NUCLEAR STATION  
FINAL SAFETY ANALYSIS REPORT - AMENDMENT 95-02  
INSTRUCTION SHEET

This Instruction Sheet functions as a guide and checklist for inserting Amendment 95-02 into the Virgil C. Summer Final Safety Analysis Report. Please note that pages which are submitted as amendment numbers other than 95-02 are pages which have received corrections which are administrative in nature.

The following listed pages and figures of South Carolina Electric & Gas Company's Final Safety Analysis Report for the Virgil C. Summer Nuclear Station are to be removed and replaced as indicated

<u>REMOVE</u> (Front/Back)	<u>INSERT</u> (Front/Back)
<u>Volume I</u>	<u>Volume I</u>
Page 1-v/1-vi Fig. 1.2-6 Fig. 1.2-15	Page 1-v/1-vi Fig. 1.2-6 Fig. 1.2-15
<u>Volume VI</u>	<u>Volume VI</u>
Page 5-xi/5-xii Page 5-xiii/5-xiv Page 5.5-53/5.5-54	Page 5-xi/5-xii Page 5-xiii/5-xiv Page 5.5-53/5.5-54
<u>Volume VII</u>	<u>Volume VII</u>
Page 6-xxi/6-xxii Page 6-xxv/6-xxvi Fig. 6.2-46	Page 6-xxi/6-xxii Page 6-xxv/6-xxvi Fig. 6.2-46
<u>Volume VIII</u>	<u>Volume VIII</u>
Page 7-ix/7-x Page 7-xi/7-xii Page 7.7-25/7.7-26 Page 7.7-27/7.7-28 Page 7.7-29/7.7-30 Page 8-viia/8-viii Fig. 8.2-3 Fig. 8.2-4	Page 7-ix/7-x Page 7-xi/7-xii Page 7.7-25/7.7-26 Page 7.7-27/7.7-28 Page 7.7-29/7.7-30 Page 8-viia/8-viii Fig. 8.2-3 Fig. 8.2-4







LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 1 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-10 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 1-i	0	Aug. 1984	Fig. 1.2-13	4	Aug. 1988
1-ii	0	Aug. 1984	1.2-14	0	Aug. 1984
1-iii	0	Aug. 1984	1.2-15	95-02	Apr. 1995
1-iv	3	Aug. 1987	1.2-16	5	Aug. 1989
1-v	3	Aug. 1987	1.2-17	0	Aug. 1984
1-vi	94-10	Dec. 1994	1.2-18	94-10	Dec. 1994
1-vii	94-01	Jan. 1994	1.2-19	94-10	Dec. 1994
1-viii	2	Aug. 1986	1.2-20	93-06	Jul. 1993
1.1-1	0	Aug. 1984	1.2-21	93-06	Jul. 1993
1.1-2	0	Aug. 1984	1.2-22	94-10	Dec. 1994
1.2-1	0	Aug. 1984	1.2-23	0	Aug. 1984
1.2-2	0	Aug. 1984	1.2-24	4	Aug. 1988
1.2-3	0	Aug. 1984	1.2-25	93-10	Dec. 1993
1.2-4	0	Aug. 1984	1.2-26	4	Aug. 1988
1.2-5	0	Aug. 1984	1.2-27	94-10	Dec. 1994
1.2-6	0	Aug. 1984	1.2-28	7	Aug. 1991
1.2-7	0	Aug. 1984	1.2-28a	94-10	Dec. 1994
1.2-8	0	Aug. 1984	1.2-29	0	Aug. 1984
1.2-9	0	Aug. 1984	Page 1.3-1	0	Aug. 1984
1.2-10	0	Aug. 1984	1.3-2	0	Aug. 1984
1.2-11	0	Aug. 1984	1.3-3	0	Aug. 1984
1.2-12	3	Aug. 1987	1.3-4	0	Aug. 1984
1.2-13	0	Aug. 1984	1.3-5	0	Aug. 1984
1.2-14	0	Aug. 1984	1.3-6	0	Aug. 1984
1.2-15	0	Aug. 1984	1.3-7	0	Aug. 1984
1.2-16	0	Aug. 1984	1.3-8	0	Aug. 1984
1.2-17	0	Aug. 1984	1.3-9	0	Aug. 1984
1.2-18	0	Aug. 1984	1.3-10	0	Aug. 1984
1.2-19	0	Aug. 1984	1.3-11	0	Aug. 1984
1.2-20	0	Aug. 1984	1.3-12	0	Aug. 1984
Fig. 1.2-1	94-04	Apr. 1994	1.3-13	0	Aug. 1984
1.2-2	2	Aug. 1986	1.3-14	5	Aug. 1989
1.2-3	3	Aug. 1987	1.4-1	0	Aug. 1984
1.2-4	4	Aug. 1988	1.4-2	0	Aug. 1984
1.2-5	93-10	Dec. 1993	1.4-3	0	Aug. 1984
1.2-6	95-02	Apr. 1995	1.4-4	0	Aug. 1984
1.2-7	0	Aug. 1984	1.4-5	0	Aug. 1984
1.2-8	3	Aug. 1987	1.4-6	0	Aug. 1984
1.2-9	2	Aug. 1986	1.4-7	0	Aug. 1984
1.2-10	5	Aug. 1989	1.4-8	0	Aug. 1984
1.2-11	7	Aug. 1991	1.4-9	0	Aug. 1984
1.2-12	93-10	Dec. 1993	1.4-10	0	Aug. 1984

LIST OF FIGURES (Continued)

<u>Figure No.</u>	<u>Title</u>
1.2-18	Turbine Building Basement Floor Plan Above Elevation 412'-0"
1.2-19	Turbine Building Mezzanine Floor Plan Above Elevation 436'-0"
1.2-20	Turbine Building Operating Floor Plan Above Elevation 463'-0"
1.2-21	Turbine Room General Cross Section
1.2-22	Longitudinal Section Through Turbine Room
1.2-23	Condenser Circulating Water Intake Screen and Pump House
1.2-24	Service Water Intake Screen and Pump House
1.2-25	Drumming Station and Hot Machine Shop Plan at Elevation 436'-0" and 447'-0"
1.2-26	Roof Plan Unit 1
1.2-27	Westinghouse Flow Diagram Legend
1.2-28	Diagram Symbols and Schedule; System Instrument Identification
1.2-28a	Equipment List
1.2-29	Simplified Diagram of the Nuclear Steam Supply System
1.4-1	Organization Chart Gilbert/Commonwealth Companies
1.4-2	Organization Chart Gilbert Project Engineering
1.5-1	Schematic of G-Loop Test Facility
1.5-2	Schematic of J-Loop Test Facility

---

REMOVE  
(Front/Back)

Volume IX

Page 9-xiii/9-xiv  
 Page 9-xv/9-xvi  
 Page 9-xvii  
 Fig. 9.2-1  
 Fig. 9.2-2  
 Fig. 9.2-4  
 Fig. 9.2-7  
 Fig. 9.3-3A  
 Fig. 9.3-4  
 Fig. 9.3-16 SHT. 1C

Volume X

Page 9.4-53/9.4-54  
 Page 9.4-55/9.5-55a  
 Page 9.4-77/9.4-78  
 Fig. 9.4-5  
 Fig. 9.4-26c  
 Fig. 9.4-33  
 Fig. 9.5-1  
 Fig. 9.5-2  
 Fig. 9.5-11  
 Page 10-v//10-vi  
 Page 10-vii  
 Fig. 10.4-14  
 Fig. 10.4-16

Volume XI

Page 11-ix/11-x  
 Page 11-xi  
 Page 11.5-11/11.5-12  
 Fig. 11.2-2 SHT. 2 of 5  
 Fig. 11.2-2 SHT. 3 of 5  
 Page 12-ix/12-x  
 Page 12-xi  
 Page 12.2-5/12.2-6  
 Fig. 12.1-19  
 Fig. 12A.4-7

---

INSERT  
(Front/Back)

Volume IX



Page 9-xiii/9-xiv  
 Page 9-xv/9-xvi  
 Page 9-xvii  
 Fig. 9.2-1  
 Fig. 9.2-2  
 Fig. 9.2-4  
 Fig. 9.2-7  
 Fig. 9.3-3A  
 Fig. 9.3-4  
 Fig. 9.3-16 SHT. 1C

Volume X

Page 9.4-53/9.4-54  
 Page 9.4-55/9.5-55a  
 Page 9.4-77/9.4-78  
 Fig. 9.4-5  
 Fig. 9.4-26c  
 Fig. 9.4-33  
 Fig. 9.5-1  
 Fig. 9.5-2  
 Fig. 9.5-11  
 Page 10-v//10-vi  
 Page 10-vii  
 Fig. 10.4-14  
 Fig. 10.4-16

Volume XI

Page 11-ix/11-x  
 Page 11-xi  
 Page 11.5-11/11.5-12  
 Fig. 11.2-2 SHT. 2 of 5  
 Fig. 11.2-2 SHT. 3 of 5  
 Page 12-ix/12-x  
 Page 12-xi  
 Page 12.2-5/12.2-6  
 Fig. 12.1-19  
 Fig. 12A.4-7



- TECHNICAL SUPPORT CENTER  
COMMUNICATIONS SYSTEMS**
- ① THREE DEDICATED LINE WITH SPEAKERS
  - ② PLANT PHONE
  - ③ PLANT PHONE WITH PRGMS
  - ④ TWO WAY RADIO
  - ⑤ ALL DEDICATED LINES WITH SPEAKERS
  - ⑥ PRIVATE BELL LINES
  - ⑦ INTERCOM CONTROL ROOM TO TECH SUPPORT CENTER
  - ⑧ INTERCOM OPERATIONAL SUPPORT CENTER TO TECH SUPPORT CENTER
  - ⑨ INTERCOM CONTROL ROOM TO OPERATIONAL SUPPORT CENTER
  - ⑩ PRIVATE BELL LINES WITH SPEAKER
  - ⑪ ALL DEDICATED LINES

**CONTROL ROOM EQUIPMENT LIST**

NO.	GROUP NO.	TYPE	DESCRIPTION
1	SP 705B	MS	COMPUTER OPERATOR CONSOLE
2	SP 704A	MS	CONSOLE WITH MICRO TLU MAPPING SYS
3	SP 610C	MS	MAIN CONTROL BOARD
4	SP 610C	MS	TIME SERVICE PANEL
5	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 5
6	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 6
7	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 7
8	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 8
9	SP 620C	MS	REARVIEW MONITORING SYSTEM PANEL
10	SP 620C	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 9
11	SP 620C	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 10
12	SP 620C	MS	TEMP MEASUREMENT SYS CONTROL PANEL


**CONTROL ROOM EQUIPMENT LIST**

NO.	GROUP NO.	TYPE	DESCRIPTION
1	SP 705B	MS	COMPUTER OPERATOR CONSOLE
2	SP 704A	MS	CONSOLE WITH MICRO TLU MAPPING SYS
3	SP 610C	MS	MAIN CONTROL BOARD
4	SP 610C	MS	TIME SERVICE PANEL
5	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 5
6	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 6
7	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 7
8	SP 707A	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 8
9	SP 620C	MS	REARVIEW MONITORING SYSTEM PANEL
10	SP 620C	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 9
11	SP 620C	MS	NUCLEAR INSTRUMENT SYS CONSOLE CHAN 10
12	SP 620C	MS	TEMP MEASUREMENT SYS CONTROL PANEL



# ANSTEC APERTURE CARD

Also Available on Aperture Card



AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C SUMMER NUCLEAR STATION

PLANT LAYOUT CONTROL COMPLEX

PLAN AT ELEVATIONS 412'-0", 436'-0",  
463'-0" & 482'-0"

E-005-001 REV. 38

Figure 1.2-15

9506160376-02

LIST OF FIGURES (Cont'd)

<u>Figure</u>	<u>Title</u>
5.5-13	Schematic Flow Diagram of the Reactor Vessel Head Vent System
5.5-14	Clamp to Head Lifting Leg
5.5-15	Reactor Vessel Head Vent System Pipe Support Clamp to CRDM Seismic Support Platform
5.5-16	RCP Cooling Supplies
5.5-17	Reactor Coolant Pump
5.5-18	Seal Flow Diagram
5.5-19	Reactor Coolant Pump Motor
5.5-20	RCP Motor Bearing Heatup Data for Loss of CCW
5.5-21	RCP Motor Bearing Heatup Data for Loss of CCW - Details
5.5-22	Motor Upper Thrust Bearing Temperatures After Termination of Cooling Water Flow
5.7-1	Tool Details (Vessel Scanner)
5.7-2	Tool Details (Nozzle and Flange Scanner)
5.7-3	Sample Weld Data (2 Sheets)

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 5 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-09 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 5-i	7	Aug. 1991	Page 5.2-11	0	Aug. 1984
5-ii	7	Aug. 1991	5.2-12	0	Aug. 1984
5-iii	7	Aug. 1991	5.2-13	0	Aug. 1984
5-iv	7	Aug. 1991	5.2-14	0	Aug. 1984
5-v	0	Aug. 1984	5.2-15	0	Aug. 1984
5-vi	0	Aug. 1984	5.2-16	0	Aug. 1984
5-vii	0	Aug. 1984	5.2-17	0	Aug. 1984
5-viii	0	Aug. 1984	5.2-18	0	Aug. 1984
5-ix	94-02	Feb. 1994	5.2-19	0	Aug. 1984
5-x	0	Aug. 1984	5.2-20	0	Aug. 1984
5-xi	0	Aug. 1984	5.2-21	0	Aug. 1984
5-xii	95-02	Apr. 1995	5.2-22	0	Aug. 1984
5-xiii	94-09	Nov. 1994	5.2-23	0	Aug. 1984
5-xiv	95-02	Apr. 1995	5.2-24	7	Aug. 1991
5-xv	94-09	Nov. 1994	5.2-25	0	Aug. 1984
5.1-1	0	Aug. 1984	5.2-26	0	Aug. 1984
5.1-2	0	Aug. 1984	5.2-27	0	Aug. 1984
5.1-3	0	Aug. 1984	5.2-28	0	Aug. 1984
5.1-4	0	Aug. 1984	5.2-29	0	Aug. 1984
5.1-5	0	Aug. 1984	5.2-30	0	Aug. 1984
5.1-6	0	Aug. 1984	5.2-31	0	Aug. 1984
5.1-7	6	Aug. 1990	5.2-32	0	Aug. 1984
5.1-8	6	Aug. 1990	5.2-33	0	Aug. 1984
Fig. 5.1-1(1 of 3)	7	Aug. 1991	5.2-34	94-09	Nov. 1994
5.1-1(2 of 3)	94-08	Oct. 1994	5.2-35	2	Aug. 1986
5.1-1(Sht. 3a)	7	Aug. 1991	5.2-36	94-08	Oct. 1994
5.1-1(Sht. 3b)	7	Aug. 1991	5.2-37	1	Aug. 1985
5.1-1(Sht. 3c)	7	Aug. 1991	5.2-38	0	Aug. 1984
5.1-2	0	Aug. 1984	5.2-39	0	Aug. 1984
5.1-3(1 of 3)	7	Aug. 1991	5.2-40	0	Aug. 1984
5.1-3(2 of 3)	0	Aug. 1984	5.2-41	0	Aug. 1984
5.1-3(3 of 3)	0	Aug. 1984	5.2-42	0	Aug. 1984
Page 5.2-1	0	Aug. 1984	5.2-43	94-02	Feb. 1994
5.2-2	0	Aug. 1984	5.2-44	91-03	Nov. 1991
5.2-3	0	Aug. 1984	5.2.44a	91-03	Nov. 1991
5.2-4	7	Aug. 1991	5.2-45	0	Aug. 1984
5.2-5	91-03	Nov. 1991	5.2-46	0	Aug. 1984
5.2-6	0	Aug. 1984	5.2-47	0	Aug. 1984
5.2-7	0	Aug. 1984	5.2-48	0	Aug. 1984
5.2.7a	91-03	Nov. 1991	5.2-49	0	Aug. 1984
5.2-8	0	Aug. 1984	5.2-50	0	Aug. 1984
5.2-9	0	Aug. 1984	5.2-51	0	Aug. 1984
5.2-10	0	Aug. 1984	5.2-52	0	Aug. 1984

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 5.2-53	92-09	Sep. 1992	Fig. 5.2-11	0	Aug. 1984
5.2-54	3	Aug. 1987	5.2-12	0	Aug. 1984
5.2-55	0	Aug. 1984	5.2-15	0	Aug. 1984
5.2-56	1	Aug. 1985	5.2-16	0	Aug. 1984
5.2-57	0	Aug. 1984	5.2-17	0	Aug. 1984
5.2-58	0	Aug. 1984	5.2-18	0	Aug. 1984
5.2-59	0	Aug. 1984	5.2-19	0	Aug. 1984
5.2-60	94-04	Apr. 1994	5.2-20	0	Aug. 1984
5.2-61	0	Aug. 1984	5.2-21	0	Aug. 1984
5.2-62	0	Aug. 1984	5.2-22	0	Aug. 1984
5.2-63	0	Aug. 1984	5.2-23	0	Aug. 1984
5.2-64	0	Aug. 1984	Page 5.3-1	0	Aug. 1984
5.2-65	0	Aug. 1984	Fig. 5.3-1	0	Aug. 1984
5.2-66	0	Aug. 1984	Page 5.4-1	0	Aug. 1984
5.2-67	0	Aug. 1984	5.4-2	0	Aug. 1984
5.2-68	6	Aug. 1990	5.4-3	0	Aug. 1984
5.2-69	2	Aug. 1986	5.4-4	0	Aug. 1984
5.2-70	0	Aug. 1984	5.4-5	0	Aug. 1984
5.2-71	0	Aug. 1984	5.4-6	0	Aug. 1984
5.2-72	7	Aug. 1991	5.4-7	94-02	Feb. 1994
5.2-73	0	Aug. 1984	5.4-8	94-02	Feb. 1994
5.2-74	0	Aug. 1984	5.4-9	0	Aug. 1984
5.2-75	0	Aug. 1984	5.4-10	0	Aug. 1984
5.2-76	94-07	Aug. 1994	5.4-11	0	Aug. 1984
5.2-77	0	Aug. 1984	5.4-12	94-09	Nov. 1994
5.2-78	0	Aug. 1984	5.4-13	0	Aug. 1984
5.2-79	0	Aug. 1984	5.4-14	0	Aug. 1984
5.2-80	0	Aug. 1984	5.4-15	0	Aug. 1984
5.2-81	0	Aug. 1984	5.4-16	0	Aug. 1984
5.2-82	0	Aug. 1984	5.4-17	0	Aug. 1984
5.2-83	0	Aug. 1984	5.4-18	0	Aug. 1984
5.2-84	0	Aug. 1984	Fig. 5.4-1	0	Aug. 1984
5.2-85	0	Aug. 1984	Page 5.5-1	0	Aug. 1984
5.2-86	0	Aug. 1984	5.5-2	0	Aug. 1984
5.2-87	0	Aug. 1984	5.5-3	0	Aug. 1984
5.2-88	0	Aug. 1984	5.5-4	0	Aug. 1984
5.2-89	0	Aug. 1984	5.5-5	0	Aug. 1984
5.2-90	0	Aug. 1984	5.5-6	0	Aug. 1984
5.2-91	0	Aug. 1984	5.5-7	0	Aug. 1984
Fig. 5.2-1	0	Aug. 1984	5.5-8	0	Aug. 1984
5.2-2	0	Aug. 1984	5.5-9	0	Aug. 1984
5.2-3	0	Aug. 1984	5.5-10	0	Aug. 1984
5.2-4	0	Aug. 1984	5.5-11	0	Aug. 1984
5.2-5	0	Aug. 1984	5.5-12	0	Aug. 1984
--- 5.2-6	0	Aug. 1984	5.5-13	0	Aug. 1984
5.2-7	0	Aug. 1984	5.5-14	0	Aug. 1984
5.2-8	94-02	Feb. 1994	5.5-15	0	Aug. 1984
5.2-8a	94-03	Mar. 1994	5.5-16	0	Aug. 1984
5.2-9	0	Aug. 1984	5.5-17	0	Aug. 1984
5.2-10	0	Aug. 1984	5.5-18	0	Aug. 1984



LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 5.5-19	0	Aug. 1984	Page 5.5-70	0	Aug. 1984
5.5-20	0	Aug. 1984	5.5-71	0	Aug. 1984
5.5-21	0	Aug. 1984	5.5-72	0	Aug. 1984
5.5-22	0	Aug. 1984	5.5-73	0	Aug. 1984
5.5-23	7	Aug. 1991	5.5-74	0	Aug. 1984
5.5-24	0	Aug. 1984	5.5-75	0	Aug. 1984
5.5-25	7	Aug. 1991	5.5-76	0	Aug. 1984
5.5-26	7	Aug. 1991	5.5-77	0	Aug. 1984
5.5-27	94-07	Aug. 1994	5.5-78	0	Aug. 1984
5.5-28	7	Aug. 1991	5.5-79	0	Aug. 1984
5.5-29	0	Aug. 1984	5.5-80	0	Aug. 1984
5.5-30	0	Aug. 1984	5.5-81	0	Aug. 1984
5.5-31	94-07	Aug. 1994	5.5-82	0	Aug. 1984
5.5-32	94-07	Aug. 1994	5.5-83	0	Aug. 1984
5.5-33	94-07	Aug. 1994	5.5-84	0	Aug. 1984
5.5-34	94-07	Aug. 1994	5.5-85	0	Aug. 1984
5.5-35	94-07	Aug. 1994	5.5-86	0	Aug. 1984
5.5-36	94-07	Aug. 1994	5.5-87	0	Aug. 1984
5.5-37	94-07	Aug. 1994	5.5-88	0	Aug. 1984
5.5-38	94-07	Aug. 1994	5.5-89	0	Aug. 1984
5.5-39	94-07	Aug. 1994	5.5-90	0	Aug. 1984
5.5-40	94-07	Aug. 1994	5.5-91	0	Aug. 1984
5.5-41	94-07	Aug. 1994	5.5-92	0	Aug. 1984
5.5-42	94-07 (Corr)	Aug. 1994	5.5-93	0	Aug. 1984
5.5-43	94-07	Aug. 1994	5.5-94	0	Aug. 1984
5.5-44	94-07	Aug. 1994	5.5-95	0	Aug. 1984
5.5-45	0	Aug. 1984	5.5-96	0	Aug. 1984
5.5-46	5	Aug. 1989	Fig. 5.5-1	0	Aug. 1984
5.5-47	0	Aug. 1984	5.5-2	0	Aug. 1984
5.5-48	0	Aug. 1984	5.5-3	0	Aug. 1984
5.5-49	0	Aug. 1984	5.5-4	94-08	Oct. 1994
5.5-50	6	Aug. 1990	5.5-5	0	Aug. 1984
5.5-51	1	Aug. 1985	5.5-6	0	Aug. 1984
5.5-52	1	Aug. 1985	5.5-7	0	Aug. 1984
5.5-53	95-02	Apr. 1995	5.5-8	0	Aug. 1984
5.5-54	6	Aug. 1990	5.5-9	0	Aug. 1984
5.5-55	0	Aug. 1984	5.5-10	0	Aug. 1984
5.5-56	0	Aug. 1984	5.5-11	0	Aug. 1984
5.5-57	0	Aug. 1984	5.5-12	0	Aug. 1984
5.5-58	4	Aug. 1988	5.5-13	4	Aug. 1988
5.5-59	0	Aug. 1984	5.5-14	0	Aug. 1984
5.5-60	0	Aug. 1984	5.5-15	0	Aug. 1984
5.5-61	0	Aug. 1984	5.5-16	0	Aug. 1984
5.5-62	0	Aug. 1984	5.5-17	0	Aug. 1984
5.5-63	0	Aug. 1984	5.5-18	0	Aug. 1984
5.5-64	7	Aug. 1991	5.5-19	0	Aug. 1984
5.5-65	5	Aug. 1989	5.5-20	0	Aug. 1984
5.5-66	0	Aug. 1984	5.5-21	0	Aug. 1984
5.5-67	0	Aug. 1984	5.5-22	0	Aug. 1984
5.5-68	0	Aug. 1984	Page 5.6-1	0	Aug. 1984
5.5-69	0	Aug. 1984	5.6-2	7	Aug. 1991

### 5.5.7.3.3 Overpressurization Protection

Each inlet line to the RHRS is equipped with a pressure relief valve which protects the system from inadvertent overpressurization during plant cooldown or startup. Each valve has a relief flow capacity of 900 gpm at a set pressure of 450 psig. Analyses have been conducted to confirm the capability of the RHRS relief valve to prevent overpressurization of the RHRS. All credible events were examined for their potential to overpressurize the RHRS. These events included normal operating conditions, infrequency transients, and abnormal occurrences. The analyses confirmed that one relief valve has the capability to keep the RHRS maximum pressure within 10CFR50 Appendix G limits.

Each discharge line from the RHRS to the RCS is equipped with a pressure relief valve to relieve the maximum possible back-leakage through the valves separating the RHRS from the RCS. Each valve has a relief flow capacity of 20 gpm at a set pressure of 600 psig. These relief valves are located in the ECCS (see Figure 6.3-1).

The fluid discharged by the suction side relief valves is collected in the pressurizer relief tank. The fluid discharged by the discharge side relief valves is collected in the recycle holdup tanks of the boron recycle system.

### 5.5.7.3.4 Prevention of Exposure of the RHRS to Normal RCS Operating Pressure

The design of the RHRS includes two motor-operated gate isolation valves in series on each inlet line between the high pressure RCS and the lower pressure RHRS. They are closed during normal operation and are only opened for residual heat removal and RCS cold overpressure protection during a plant cooldown after the RCS pressure is reduced to approximately 425 psig or lower and the RCS temperature is reduced to approximately 350°F. During a plant startup the inlet isolation valves are shut after drawing a bubble in the pressurizer and prior to increasing RCS pressure above 425 psig. Power to the isolation valves is manually locked out during normal operation.

The two inlet isolation valves in each residual heat removal subsystem are independently and diversely interlocked with pressure signals to prevent their being opened whenever the RCS pressure is greater than approximately 425 psig. The autoclosure interlock of these valves has been removed as per WCAP-11835. An alarm has been added to alert the operator if the valves are not closed when the RCS pressure increases above the alarm 520 psig setpoint.

The use of two independently powered motor-operated valves in each of the two inlet lines, along with an independent and diverse pressure interlock to prevent them from being opened, and a RCS pressure high with RHR suction. Valves not closed alarm assures a design which meets applicable single failure criteria. Not only more than one single failure, but also different failure mechanisms, must be postulated to defeat the function of preventing possible exposure of the RHR system to normal RCS operating pressure. This protective interlock design, in combination with alarm, administrative controls and plant operating procedures, provide the means for accomplishing the protective function. For further information on the instrumentation and control features, see Section 7.6.2.

The RHR inlet isolation valves are provided with red-green position indicator lights on the main control board and a ESF monitor light for proper valve position. ESF monitor light is independent and diverse from valve position indication.

Isolation of the low pressure RHRS from the high pressure RCS is provided on the discharge side by two check valves in series. These check valves are located in the ECCS and their testing is described in Section 5.2.2.4.

#### 5.5.7.3.5 Shared Function

The safety function performed by the RHRS is not compromised by its normal function which is normal plant cooldown. The valves associated with the RHRS are normally aligned to allow immediate use of this system in its engineered safety features mode of operation. The system has been designed in such a manner that two redundant flow circuits are available, assuring the availability of at least one train for safety purposes.

The normal plant cooldown function of the RHRS is accomplished through a suction line arrangement which is independent of any safety function. The cold leg cooldown return lines are arranged in parallel redundant circuits and are utilized also as the low head injection lines to the RCS. Utilization of the same return circuits for cold leg cooldown lends assurance to the proper functioning of these lines for engineered safety features purposes.

#### 5.5.7.3.6 Radiological Consideration

The highest radiation levels experienced by the RHRS are those which would result from a loss of coolant accident. Following a loss of coolant accident, the RHRS is used as part of the ECCS. During the recirculation phase of emergency core cooling, the RHRS is designed to operate for up to a year pumping water from the reactor building sump, cooling it, and returning it to the reactor building to cool the core.

Since, except for some valves and piping, the RHRS is located outside the reactor building, most of the system is not subjected to the high levels of radioactivity in the reactor building post-accident environment.

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 6 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-09 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 6-i	7	Aug. 1991	Page 6.2-14	0	Aug. 1984
6-ii	0	Aug. 1984	6.2-15	0	Aug. 1984
6-iii	0	Aug. 1984	6.2-16	0	Aug. 1984
6-iv	0	Aug. 1984	6.2-17	3	Aug. 1987
6-v	0	Aug. 1984	6.2-18	0	Aug. 1984
6-vi	0	Aug. 1984	6.2-19	0	Aug. 1984
6-vii	0	Aug. 1984	6.2-20	94-01	Jan. 1994
6-viii	5	Aug. 1989	6.2-21	0	Aug. 1984
6-ix	0	Aug. 1984	6.2-22	0	Aug. 1984
6-x	0	Aug. 1984	6.2-23	5	Aug. 1989
6-xi	3	Aug. 1987	6.2-24	0	Aug. 1984
6-xii	3	Aug. 1987	6.2-25	0	Aug. 1984
6-xiii	0	Aug. 1984	6.2-26	0	Aug. 1984
6-xiv	0	Aug. 1984	6.2-27	0	Aug. 1984
6-xv	0	Aug. 1984	6.2-28	5	Aug. 1989
6-xvi	0	Aug. 1984	6.2-29	3	Aug. 1987
6-xvii	0	Aug. 1984	6.2-30	3	Aug. 1987
6-xviii	0	Aug. 1984	6.2-30a	3	Aug. 1987
6-xix	0	Aug. 1984	6.2-31	0	Aug. 1984
6-xx	0	Aug. 1984	6.2-32	0	Aug. 1984
6-xxi	94-09	Nov. 1994	6.2-33	2	Aug. 1986
6-xxii	94-09	Nov. 1994	6.2-34	2	Aug. 1986
6-xxiii	94-09	Nov. 1994	6.2-35	2	Aug. 1986
6-xxiv	94-09	Nov. 1994	6.2-36	2	Aug. 1986
6-xxv	95-02	Apr. 1995	6.2-36a	6	Aug. 1990
6-xxvi	94-09	Nov. 1994	6.2-37	0	Aug. 1984
6-xxvii	1	Aug. 1985	6.2-38	6	Aug. 1990
6.1-1	0	Aug. 1984	6.2-39	4	Aug. 1988
6.1-2	0	Aug. 1984	6.2-40	0	Aug. 1984
6.2-1	3	Aug. 1987	6.2-41	0	Aug. 1984
6.2-2	94-01	Jan. 1994	6.2-42	0	Aug. 1984
6.2-3	0	Aug. 1984	6.2-43	0	Aug. 1984
6.2-4	0	Aug. 1984	6.2-44	5	Aug. 1989
6.2-5	3	Aug. 1987	6.2-44a	5	Aug. 1989
6.2-6	3	Aug. 1987	6.2-45	6	Aug. 1990
6.2-7	3	Aug. 1987	6.2-46	6	Aug. 1990
6.2-8	3	Aug. 1987	6.2-47	6	Aug. 1990
6.2-9	0	Aug. 1984	6.2-48	3	Aug. 1987
6.2-10	0	Aug. 1984	6.2-49	0	Aug. 1984
6.2-11	0	Aug. 1984	6.2-50	5	Aug. 1989
6.2-12	3	Aug. 1987	6.2-51	0	Aug. 1984
6.2-13	0	Aug. 1984	6.2-52	0	Aug. 1984



LIST OF EFFECTIVE PAGES (Cont'd)


<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 6.2-53	0	Aug. 1984	Page 6.2-103	3	Aug. 1987
6.2-54	0	Aug. 1984	6.2-104	3	Aug. 1987
6.2-55	0	Aug. 1984	6.2-105	3	Aug. 1987
6.2-56	0	Aug. 1984	6.2-106	3	Aug. 1987
6.2-57	3	Aug. 1987	6.2-107	3	Aug. 1987
6.2-58	0	Aug. 1984	6.2-108	0	Aug. 1984
6.2-59	0	Aug. 1984	6.2-109	0	Aug. 1984
6.2-60	5	Aug. 1989	6.2-110	0	Aug. 1984
6.2-61	1	Aug. 1985	6.2-111	0	Aug. 1984
6.2-62	1	Aug. 1985	6.2-112	0	Aug. 1984
6.2-63	0	Aug. 1984	6.2-113	0	Aug. 1984
6.2-64	0	Aug. 1984	6.2-114	0	Aug. 1984
6.2-65	0	Aug. 1984	6.2-115	0	Aug. 1984
6.2-66	0	Aug. 1984	6.2-116	0	Aug. 1984
6.2-67	6	Aug. 1990	6.2-117	0	Aug. 1984
6.2-68	6	Aug. 1990	6.2-118	0	Aug. 1984
6.2-69	6	Aug. 1990	6.2-119	0	Aug. 1984
6.2-70	0	Aug. 1984	6.2-120	0	Aug. 1984
6.2-71	0	Aug. 1984	6.2-121	0	Aug. 1984
6.2-72	94-09	Nov. 1994	6.2-122	0	Aug. 1984
6.2-73	94-09	Nov. 1994	6.2-123	94-01	Jan. 1994
6.2-74	94-09	Nov. 1994	6.2-124	0	Aug. 1984
6.2-75	94-09	Nov. 1994	6.2-125	0	Aug. 1984
6.2-76	0	Aug. 1984	6.2-126	0	Aug. 1984
6.2-77	0	Aug. 1984	6.2-127	0	Aug. 1984
6.2-78	0	Aug. 1984	6.2-128	0	Aug. 1984
6.2-79	0	Aug. 1984	6.2-129	0	Aug. 1984
6.2-80	94-09	Nov. 1994	6.2-130	0	Aug. 1984
6.2-81	0	Aug. 1984	6.2-131	0	Aug. 1984
6.2-82	0	Aug. 1984	6.2-132	0	Aug. 1984
6.2-83	0	Aug. 1984	6.2-133	0	Aug. 1984
6.2-84	3	Aug. 1987	6.2-134	0	Aug. 1984
6.2-85	0	Aug. 1984	6.2-135	0	Aug. 1984
6.2-86	0	Aug. 1984	6.2-136	0	Aug. 1984
6.2-87	0	Aug. 1984	6.2-137	0	Aug. 1984
6.2-88	0	Aug. 1984	6.2-138	0	Aug. 1984
6.2-89	93-01	Jan. 1993	6.2-139	0	Aug. 1984
6.2-90	0	Aug. 1984	6.2-140	0	Aug. 1984
6.2-91	0	Aug. 1984	6.2-141	0	Aug. 1984
6.2-92	0	Aug. 1984	6.2-142	0	Aug. 1984
6.2-93	0	Aug. 1984	6.2-143	0	Aug. 1984
6.2-94	0	Aug. 1984	6.2-144	0	Aug. 1984
6.2-95	0	Aug. 1984	6.2-145	0	Aug. 1984
6.2-96	3	Aug. 1987	6.2-146	0	Aug. 1984
6.2-97	5	Aug. 1989	6.2-147	0	Aug. 1984
6.2-98	0	Aug. 1984	6.2-1	0	Aug. 1984
6.2-99	3	Aug. 1987	6.2-149	0	Aug. 1984
6.2-100	3	Aug. 1987	6.2-150	0	Aug. 1984
6.2-101	3	Aug. 1987	6.2-151	0	Aug. 1984
6.2-102	3	Aug. 1987	6.2-152	0	Aug. 1984

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Fig. 6.2-33e	5	Aug. 1989	Fig. 6.2-51aa	6	Aug. 1990
6.2-34	5	Aug. 1989	6.2-51bb	6	Aug. 1990
6.2-34a	5	Aug. 1989	6.2-51cc	0	Aug. 1984
6.2-34b	5	Aug. 1989	6.2-51dd	0	Aug. 1984
6.2-35	5	Aug. 1989	6.2-51ee	0	Aug. 1984
6.2-35a	5	Aug. 1989	6.2-51ff	0	Aug. 1984
6.2-36	0	Aug. 1984	6.2-52	94-01	Jan. 1994
6.2-37	0	Aug. 1984	6.2-53	0	Aug. 1984
6.2-38	0	Aug. 1984	6.2-54	0	Aug. 1984
6.2-39	0	Aug. 1984	6.2-55(Deleted)	0	Aug. 1984
6.2-40	0	Aug. 1984	6.2-56(Deleted)	0	Aug. 1984
6.2-41	0	Aug. 1984	6.2-57(Deleted)	0	Aug. 1984
6.2-42	0	Aug. 1984	6.2-58	93-09	Nov. 1993
6.2-43	0	Aug. 1984	6.2-59	0	Aug. 1984
6.2-44	0	Aug. 1984	6.2-60	0	Aug. 1984
6.2-45	0	Aug. 1984	6.2-60a	0	Aug. 1984
6.2-46	95-02	Apr. 1995	6.2-61(Deleted)	0	Aug. 1984
6.2-47	0	Aug. 1984	6.2-62	5	Aug. 1989
6.2-48	0	Aug. 1984	6.2-63	0	Aug. 1984
6.2-49	0	Aug. 1984	6.2-64	0	Aug. 1984
6.2-50	5	Aug. 1989	6.2-65	0	Aug. 1984
6.2-51	0	Aug. 1984	6.2-66	0	Aug. 1984
6.2-51a	0	Aug. 1984	6.2-67	0	Aug. 1984
6.2-51b	0	Aug. 1984	6.2-68	0	Aug. 1984
6.2-51c	0	Aug. 1984	6.2-69	1	Aug. 1985
6.2-51d	0	Aug. 1984	6.2-70	0	Aug. 1984
6.2-51e	0	Aug. 1984	6.2-71	0	Aug. 1984
6.2-51f	0	Aug. 1984	6.2-72	0	Aug. 1984
6.2-51g	0	Aug. 1984	6.2-73	0	Aug. 1984
6.2-51h	0	Aug. 1984	6.2-74	0	Aug. 1984
6.2-51i	0	Aug. 1984	6.2-75	0	Aug. 1984
6.2-51j	0	Aug. 1984	6.2-76	0	Aug. 1984
6.2-51k	0	Aug. 1984	6.2-77	0	Aug. 1984
6.2-51l	0	Aug. 1984	6.2-78	0	Aug. 1984
6.2-51m	6	Aug. 1990	6.2-79	0	Aug. 1984
6.2-51n	6	Aug. 1990	6.2-80	0	Aug. 1984
6.2-51o	6	Aug. 1990	6.2-81	0	Aug. 1984
6.2-51p	6	Aug. 1990	6.2-82	0	Aug. 1984
6.2-51q	6	Aug. 1990	6.2-83	0	Aug. 1984
6.2-51r	6	Aug. 1990	6.2-84	0	Aug. 1984
6.2-51s	6	Aug. 1990	Page 6.3-1	3	Aug. 1987
6.2-51t	6	Aug. 1990	6.3-2	0	Aug. 1984
6.2-51u	6	Aug. 1990	6.3-3	3	Aug. 1987
6.2-51v	6	Aug. 1990	6.3-4	3	Aug. 1987
6.2-51w	6	Aug. 1990	6.3-5	5	Aug. 1989
6.2-51x	6	Aug. 1990	6.3-6	0	Aug. 1984
6.2-51y	6	Aug. 1990	6.3-7	0	Aug. 1984
6.2-51z	6	Aug. 1990	6.3-8	0	Aug. 1984

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 6.3-9	3	Aug. 1987	Page 6.3-57	0	Aug. 1984
6.3-10	0	Aug. 1984	6.3-58	3	Aug. 1987
6.3-11	3	Aug. 1987	6.3-59	0	Aug. 1984
6.3-12	3	Aug. 1987	6.3-60	5	Aug. 1989
6.3-13	0	Aug. 1984	6.3-61	3	Aug. 1987
6.3-14	2	Aug. 1986	6.3-62	0	Aug. 1984
6.3-15	4	Aug. 1988	6.3-63	0	Aug. 1984
6.3-16	0	Aug. 1984	6.3-64	0	Aug. 1984
6.3-17	0	Aug. 1984	6.3-65	0	Aug. 1984
6.3-18	0	Aug. 1984	6.3-66	0	Aug. 1984
6.3-19	0	Aug. 1984	Fig. 6.3-1(1 of 3)	3	Aug. 1987
6.3-20	0	Aug. 1984	6.3-1(2 of 3)	94-03	Mar. 1994
6.3-21	0	Aug. 1984	6.3-1(3 of 3)	94-03	Mar. 1994
6.3-22	2	Aug. 1986	6.3-2(1 of 3)	3	Aug. 1987
6.3-23	0	Aug. 1984	6.3-2(2 of 3)	0	Aug. 1984
6.3-24	3	Aug. 1987	6.3-2(3 of 3)	0	Aug. 1984
6.3-24a	3	Aug. 1987	Notes to		
6.3-25	0	Aug. 1984	Fig. 6.3-2(1 of 4)	0	Aug. 1984
6.3-26	0	Aug. 1984	6.3-2(2 of 4)	0	Aug. 1984
6.3-27	0	Aug. 1984	6.3-2(3 of 4)	0	Aug. 1984
6.3-28	0	Aug. 1984	6.3-2(4 of 4)	3	Aug. 1987
6.3-29	0	Aug. 1984	6.3-3	0	Aug. 1984
6.3-30	0	Aug. 1984	6.3-4	0	Aug. 1984
6.3-31	0	Aug. 1984	6.3-5	0	Aug. 1984
6.3-32	0	Aug. 1984	6.3-6	0	Aug. 1984
6.3-33	0	Aug. 1984	6.3-7	0	Aug. 1984
6.3-34	0	Aug. 1984	Page 6.4-1	0	Aug. 1984
6.3-35	0	Aug. 1984	6.4-2	0	Aug. 1984
6.3-36	0	Aug. 1984	6.4-3	0	Aug. 1984
6.3-37	0	Aug. 1984	6.4-4	3	Aug. 1987
6.3-38	0	Aug. 1984	6.4-5	0	Aug. 1984
6.3-39	0	Aug. 1984	6.4-6	0	Aug. 1984
6.3-40	3	Aug. 1987	6.4-7	0	Aug. 1984
6.3-41	3	Aug. 1987	6.4-8	0	Aug. 1984
6.3-42	0	Aug. 1984	6.4-9	0	Aug. 1984
6.3-43	0	Aug. 1984	6.4-10	0	Aug. 1984
6.3-44	0	Aug. 1984	6.4-11	0	Aug. 1984
6.3-45	0	Aug. 1984	6.4-12	0	Aug. 1984
6.3-46	3	Aug. 1987	6.4-13	0	Aug. 1984
6.3-47	3	Aug. 1987	6.4-14	0	Aug. 1984
6.3-48	3	Aug. 1987	6.5-1	0	Aug. 1984
6.3-49	0	Aug. 1984	6.5-2	0	Aug. 1984
6.3-50	4	Aug. 1988	6.5-3	0	Aug. 1984
6.3-51	3	Aug. 1987	6.5-4	0	Aug. 1984
6.3-52	3	Aug. 1987	6.5-5	0	Aug. 1984
6.3-53	7	Aug. 1991	6.5-6	0	Aug. 1984
6.3-54	3	Aug. 1987	6.5-7	0	Aug. 1984
6.3-55	94-09	Nov. 1994	6.5-8	0	Aug. 1984
6.3-56	94-09	Nov. 1994	6.5-9	0	Aug. 1984



**SYSTEM DATA**

NO.	PSIG	°F	BY	REMARKS
1	1500	24	120	INAC
2	1500	31	120	INAC
3	1500	44	120	INAC INJECTION
4	1500	48	120	INAC INAC INAC
5	1500	50	120	INAC INAC INAC
6	1500	57	120	INAC INAC INAC
7	1500	57	120	INAC INAC INAC
8	1500	57	120	INAC INAC INAC
9	1500	57	120	INAC INAC INAC
10	1500	57	120	INAC INAC INAC
11	100	7	100	
12	100	42	100	
13	100	75	100	
14	100	80	100	

- NOTES:**
- FOR PUMP CASING DRAINING FOR BOTH PUMPS SEE DETAIL 'A'
  - SPECTACLE GAINED PLATES FOR TESTING ISOLATION CHECK VALVES.
  - THE FLANGE HAS BEEN DRILLED AND TAPPED TO ACCEPT A 1/2" COMPRESSION FITTING TO FACILITATE LIFT WORK. THE FITTING SHOULD BE CARRIED AT OTHER TIMES.
  - ROBERTA BASED WITH SOME MORE FLOW DISTRIBUTION FOR R.E. BEARS AND P.S.E.

CONTAINMENT SPRAY ACTUATION  
TRAIN "A"  
REF. 145-41-01-B (W/ DMS 100 D 881 516)

CONTAINMENT SPRAY ACTUATION  
TRAIN "B"  
REF. 145-41-01-B (W/ DMS 100 D 881 516)

- (2 PLACES) (A)
- (2 PLACES) (B)
- (2 PLACES) (C) ALARM DEPART INTERLOCKED WITH PUMP BREAKER CIRCUIT.
- (4 PLACES) (D) PHASE "X" CONTAINMENT ISOLATION SIGNAL (OPEN VALVES)

MAXIMUM FLOW WITH BOTH PUMPS OPERATING  
BY MAXIMUM FLOW WITH ONE PUMP OPERATING

**SAFETY CLASS VERIFICATION**  
ORIGINATED BY  
REVIEWED BY

**NOTE:**  
A. TEMPORARY STRAPS FOR SYS. CLEAN UP TO BE REMOVED AFTER FINAL FLUSH.

**NOTE:**  
WHEN APPLICABLE, THE NORMAL DESIGN PRESSURES & TEMPERATURES (ESPECIALLY TEST CONDITIONS) ARE THE WORST CONDITIONS THAT EXIST DURING INJECTION PHASE OF SAFETY INJECTION. THE OPPOSITE CONDITIONS ARE THE WORST CONDITIONS FOR RECIRCULATION.

**DESIGN DATA**

14	100	100	110	150	145	
15	100	100	110	150	145	
16	100	100	110	150	145	
17	100	100	110	150	145	
18	100	100	110	150	145	
19	100	100	110	150	145	
20	100	100	110	150	145	
21	100	100	110	150	145	
22	100	100	110	150	145	
23	100	100	110	150	145	
24	100	100	110	150	145	
25	100	100	110	150	145	
26	100	100	110	150	145	
27	100	100	110	150	145	
28	100	100	110	150	145	
29	100	100	110	150	145	
30	100	100	110	150	145	
31	100	100	110	150	145	
32	100	100	110	150	145	
33	100	100	110	150	145	
34	100	100	110	150	145	
35	100	100	110	150	145	
36	100	100	110	150	145	
37	100	100	110	150	145	
38	100	100	110	150	145	
39	100	100	110	150	145	
40	100	100	110	150	145	
41	100	100	110	150	145	
42	100	100	110	150	145	
43	100	100	110	150	145	
44	100	100	110	150	145	
45	100	100	110	150	145	
46	100	100	110	150	145	
47	100	100	110	150	145	
48	100	100	110	150	145	
49	100	100	110	150	145	
50	100	100	110	150	145	

**NOTE:**  
FLAG & 'NORMAL' REPRESENTS THE DESIGN IN SERVICE PRESSURE. EMERGENCY 1 FOR THIS FLAG REPRESENTS AN ISOLATED CONDITION FROM PUMP DISCHARGE PRESSURE.

**NOTE:**  
HYDROTEST TEMP TO BE AT OR ABOVE 60°F FOR CARBON STEEL SUBSYSTEM AND AT OR ABOVE 40°F FOR STAINLESS STEEL SUBSYSTEMS. HYDROSTATIC TESTING OF TUBING HEADERS & NOZZLES TO BE ACCOMPLISHED PER CODE N-58, PAR. 614





LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 7 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-08 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 7-i	7	Aug. 1991	Page 7.1-30	0	Aug. 1984
7-ii	94-08	Oct. 1994	7.1-31	0	Aug. 1984
7-iii	7	Aug. 1991	7.1-32	0	Aug. 1984
7-iiiia	5	Aug. 1989	7.1-33	0	Aug. 1984
7-iv	94-08	Oct. 1994	7.1-34	0	Aug. 1984
7-v	94-08	Oct. 1994	7.1-35	0	Aug. 1984
7-vi	1	Aug. 1985	7.1-36	0	Aug. 1984
7-vii	0	Aug. 1984	7.1-37	0	Aug. 1984
7-viii	5	Aug. 1989	7.1-38	94-08	Oct. 1994
7-ix	94-08	Oct. 1994	7.1-39	94-08	Oct. 1994
7-x	94-08	Oct. 1994	7.1-40	0	Aug. 1984
7-xi	94-08	Oct. 1994	7.1-41	0	Aug. 1984
7-xii	95-02	Apr. 1995	7.1-42	0	Aug. 1984
7.1-1	0	Aug. 1984	7.1-43	0	Aug. 1984
7.1-2	0	Aug. 1984	Fig. 7.1-1	2	Aug. 1986
7.1-3	0	Aug. 1984	Page 7.2-1	2	Aug. 1986
7.1-4	0	Aug. 1984	7.2-2	2	Aug. 1986
7.1-5	94-08	Oct. 1984	7.2-3	0	Aug. 1984
7.1-6	6	Aug. 1990	7.2-4	0	Aug. 1984
7.1-7	0	Aug. 1984	7.2-5	0	Aug. 1984
7.1-8	0	Aug. 1984	7.2-6	0	Aug. 1984
7.1-9	0	Aug. 1984	7.2-7	0	Aug. 1984
7.1-10	0	Aug. 1984	7.2-8	1	Aug. 1985
7.1-11	0	Aug. 1984	7.2-9	0	Aug. 1984
7.1-12	0	Aug. 1984	7.2-10	4	Aug. 1988
7.1-13	0	Aug. 1984	7.2-11	7	Aug. 1991
7.1-14	0	Aug. 1984	7.2-12	4	Aug. 1988
7.1-15	0	Aug. 1984	7.2-12a	6	Aug. 1990
7.1-16	7	Aug. 1991	7.2-13	6	Aug. 1990
7.1-17	0	Aug. 1984	7.2-14	6	Aug. 1990
7.1-18	0	Aug. 1984	7.2-15	6	Aug. 1990
7.1-19	0	Aug. 1984	7.2-16	6	Aug. 1990
7.1-20	0	Aug. 1984	7.2-17	6	Aug. 1990
7.1-21	7	Aug. 1991	7.2-18	0	Aug. 1984
7.1-21a	7	Aug. 1991	7.2-19	0	Aug. 1984
7.1-22	0	Aug. 1984	7.2-20	0	Aug. 1984
7.1-23	92-01	Jan. 1992	7.2-21	0	Aug. 1984
7.1-24	0	Aug. 1984	7.2-22	0	Aug. 1984
7.1-25	0	Aug. 1984	7.2-23	0	Aug. 1984
7.1-26	0	Aug. 1984	7.2-24	2	Aug. 1986
7.1-27	0	Aug. 1984	7.2-25	2	Aug. 1986
7.1-28	0	Aug. 1984	7.2-26	2	Aug. 1986
7.1-29	0	Aug. 1984			

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 7.2-26a	2	Aug. 1986	Page 7.3-14	0	Aug. 1984
7.2-27	0	Aug. 1984	7.3-15	0	Aug. 1984
7.2-28	0	Aug. 1984	7.3-16	0	Aug. 1984
7.2-29	7	Aug. 1991	7.3-17	7	Aug. 1991
7.2-30	7	Aug. 1991	7.3-17a	7	Aug. 1991
7.2-31	0	Aug. 1984	7.3-18	0	Aug. 1984
7.2-32	0	Aug. 1984	7.3-19	94-08	Oct. 1994
7.2-33	0	Aug. 1984	7.3-20	0	Aug. 1984
7.2-34	4	Aug. 1988	7.3-21	0	Aug. 1984
7.2-35	0	Aug. 1984	7.3-22	0	Aug. 1984
7.2-36	1	Aug. 1985	7.3-23	5	Aug. 1989
7.2-37	0	Aug. 1984	7.3-24	0	Aug. 1984
7.2-38	1	Aug. 1985	7.3-25	3	Aug. 1987
7.2-39	7	Aug. 1991	7.3-26	0	Aug. 1984
7.2-40	7	Aug. 1991	7.3-27	0	Aug. 1984
7.2-41	7	Aug. 1991	7.3-28	0	Aug. 1984
7.2-42	0	Aug. 1984	7.3-29	0	Aug. 1984
7.2-43	0	Aug. 1984	7.3-30	0	Aug. 1984
7.2-44	6	Aug. 1990	7.3-31	0	Aug. 1984
7.2-45	6	Aug. 1990	7.3-32	0	Aug. 1984
7.2-46	6	Aug. 1990	7.3-33	0	Aug. 1984
Fig. 7.2-1(1 of 15)	0	Aug. 1984	7.3-34	7	Aug. 1991
7.2-1(2 of 15)	2	Aug. 1986	7.3-35	0	Aug. 1984
7.2-1(3 of 15)	4	Aug. 1988	7.3-36	0	Aug. 1984
7.2-1(4 of 15)	1	Aug. 1985	7.3-37	0	Aug. 1984
7.2-1(5 of 15)	0	Aug. 1984	7.3-38	0	Aug. 1984
7.2-1(6 of 15)	0	Aug. 1984	7.3-39	3	Aug. 1987
7.2-1(7 of 15)	0	Aug. 1984	7.3-40	3	Aug. 1987
7.2-1(8 of 15)	0	Aug. 1984	7.3-41	3	Aug. 1987
7.2-1(9 of 15)	7	Aug. 1991	7.3-42	0	Aug. 1984
7.2-1(10 of 15)	7	Aug. 1991	7.3-43	0	Aug. 1984
7.2-1(11 of 15)	7	Aug. 1991	7.3-44	0	Aug. 1984
7.2-1(12 of 15)	0	Aug. 1984	7.3-45	0	Aug. 1984
7.2-1(13 of 15)	0	Aug. 1984	7.3-46	0	Aug. 1984
7.2-1(14 of 15)	0	Aug. 1984	7.3-47	0	Aug. 1984
7.2-1(15 of 15)	1	Aug. 1985	Fig. 7.3-1	93-05	May 1993
7.2-2	0	Aug. 1984	7.3-2	0	Aug. 1984
7.2-3	2	Aug. 1986	7.3-3	0	Aug. 1984
Page 7.3-1	0	Aug. 1984	Page 7.4-1	0	Aug. 1984
7.3-2	0	Aug. 1984	7.4-2	0	Aug. 1984
7.3-3	0	Aug. 1984	7.4-3	0	Aug. 1984
7.3-4	0	Aug. 1984	7.4-4	4	Aug. 1988
7.3-5	0	Aug. 1984	7.4-5	4	Aug. 1988
7.3-6	0	Aug. 1984	7.4-6	0	Aug. 1984
7.3-7	0	Aug. 1984	7.4-7	1	Aug. 1985
7.3-8	94-08	Oct. 1994	7.4-8	1	Aug. 1985
7.3-9	0	Aug. 1984	7.4-9	0	Aug. 1984
7.3-10	0	Aug. 1984	7.4-10	0	Aug. 1984
7.3-11	0	Aug. 1984	7.4-11	0	Aug. 1984
7.3-12	7	Aug. 1991	7.4-12	0	Aug. 1984
7.3-13	0	Aug. 1984			

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 7.4-13	0	Aug. 1984	Page 7.5-31	Deleted	
7.4-14	0	Aug. 1984	7.5-32	Deleted	
7.4-15	0	Aug. 1984	7.5-33	Deleted	
7.4-16	0	Aug. 1984	7.5-34	Deleted	
7.4-17	0	Aug. 1984	7.5-35	Deleted	
7.4-18	0	Aug. 1984	7.5-36	Deleted	
7.4-19	0	Aug. 1984	7.5-37	Deleted	
7.4-20	0	Aug. 1984	7.5-38	Deleted	
7.4-21	0	Aug. 1984	7.5-39	Deleted	
7.4-22	0	Aug. 1984	7.5-40	Deleted	
7.4-23	0	Aug. 1984	7.5-41	Deleted	
7.4-24	0	Aug. 1984	7.5-42	Deleted	
7.4-25	0	Aug. 1984	7.5-43	Deleted	
Fig. 7.4-1	4	Aug. 1988	7.5-44	Deleted	
Notes to			7.5-45	Deleted	
Fig. 7.4-1(1 of 3)	4	Aug. 1988	7.5-46	Deleted	
7.4-1(2 of 3)	0	Aug. 1984	7.5-47	Deleted	
7.4-1(3 of 3)	0	Aug. 1984	7.5-48	Deleted	
Fig. 7.4-2	0	Aug. 1984	7.5-49	Deleted	
Page 7.5-1	94-08	Oct. 1994	7.5-50	94-08	Oct. 1994
7.5-2	Deleted		7.5-51	94-08	Oct. 1994
7.5-3	Deleted		7.5-52	94-08	Oct. 1994
7.5-4	Deleted		7.5-53	94-08	Oct. 1994
7.5-5	Deleted		7.5-54	94-08	Oct. 1994
7.5-6	Deleted		7.5-55	94-08	Oct. 1994
7.5-7	Deleted		7.5-56	94-08	Oct. 1994
7.5-8	Deleted		7.5-57	94-08	Oct. 1994
7.5-9	Deleted		7.5-58	94-08	Oct. 1994
7.5-10	Deleted		Fig. 7.5-1	94-02	Feb. 1994
7.5-11	Deleted		7.5-2	0	Aug. 1984
7.5-12	Deleted		7.5-3	6	Aug. 1990
7.5-13	Deleted		7.5-4	0	Aug. 1984
7.5-14	94-08	Oct. 1994	7.5-5	3	Aug. 1987
7.5-15	Deleted		Page 7.6-1	92-02	Feb. 1992
7.5-16	Deleted		7.6-2	92-02	Feb. 1992
7.5-17	Deleted		7.6-3	6	Aug. 1990
7.5-18	Deleted		7.6-4	0	Aug. 1984
7.5-19	Deleted		7.6-5	0	Aug. 1984
7.5-20	Deleted		7.6-6	1	Aug. 1985
7.5-21	Deleted		7.6-7	1	Aug. 1985
7.5-22	Deleted		7.6-8	1	Aug. 1985
7.5-23	Deleted		7.6-9	1	Aug. 1985
7.5-24	Deleted		7.6-10	1	Aug. 1985
7.5-25	Deleted		7.6-11	3	Aug. 1987
7.5-26	Deleted		7.6-12	1	Aug. 1985
7.5-27	Deleted		7.6-13	1	Aug. 1985
7.5-28	Deleted		Fig. 7.6-1	6	Aug. 1990
7.5-29	Deleted		7.6-1a	6	Aug. 1990
7.5-30	Deleted		7.6-1b	6	Aug. 1990
			7.6-2	0	Aug. 1984



LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Fig. 7.6-3(Deleted)	1	Aug. 1985	Fig. 7.7-9	0	Aug. 1984
7.6-3a	0	Aug. 1984	7.7-10	0	Aug. 1984
7.6-4	0	Aug. 1984	7.7-11	0	Aug. 1984
7.6-5	0	Aug. 1984	7.7-12	0	Aug. 1984
7.6-6	0	Aug. 1984	7.7-13	0	Aug. 1984
7.6-7	0	Aug. 1984	7.7-14	0	Aug. 1984
7.6-8	0	Aug. 1984	7.7-15	0	Aug. 1984
7.6-9	0	Aug. 1984	Page 7.8-1	5	Aug. 1989
7.6-10	0	Aug. 1984	7.8-2	5	Aug. 1989
Page 7.7-1	2	Aug. 1986	7.8-3	5	Aug. 1989
7.7-2	0	Aug. 1984	7.8-4	5	Aug. 1989
7.7-3	7	Aug. 1991	7.8-5	5	Aug. 1989
7.7-4	0	Aug. 1984	7.8-6	5	Aug. 1989
7.7-5	0	Aug. 1984	7.8-7	5	Aug. 1989
7.7-6	0	Aug. 1984	7.8-8	5	Aug. 1989
7.7-7	0	Aug. 1984	7.8-9	5	Aug. 1989
7.7-8	7	Aug. 1991	Fig. 7.8-1	5	Aug. 1989
7.7-9	0	Aug. 1984			
7.7-10	0	Aug. 1984			
7.7-11	6	Aug. 1990			
7.7-12	0	Aug. 1984			
7.7-13	7	Aug. 1991			
7.7-14	1	Aug. 1985			
7.7-15	0	Aug. 1984			
7.7-16	0	Aug. 1984			
7.7-17	0	Aug. 1984			
7.7-18	0	Aug. 1984			
7.7-19	0	Aug. 1984			
7.7-20	7	Aug. 1991			
7.7-20a	7	Aug. 1991			
7.7-21	0	Aug. 1984			
7.7-22	0	Aug. 1984			
7.7-23	0	Aug. 1984			
7.7-24	0	Aug. 1984			
7.7-25	95-02	Apr. 1995			
7.7-26	95-02	Apr. 1995			
7.7-27	95-02	Apr. 1995			
7.7-28	95-02	Apr. 1995			
7.7-29	4	Aug. 1988			
7.7-30	95-02	Apr. 1995			
7.7-31	0	Aug. 1984			
7.7-32	0	Aug. 1984			
7.7-33	0	Aug. 1984			
Fig. 7.7-1	7	Aug. 1991			
7.7-2	7	Aug. 1991			
7.7-3	0	Aug. 1984			
7.7-4	6	Aug. 1990			
7.7-5	7	Aug. 1991			
7.7-6	0	Aug. 1984			
7.7-7	0	Aug. 1984			
7.7-8	7	Aug. 1991			



### 7.7.3 TECHNICAL SUPPORT COMPLEX (TSC)

#### 7.7.3.1 Description

In response to the recommendations issued post-TMI (e.g., NUREG-0578, NUREG-0585), South Carolina Gas and Electric will incorporate into the Virgil Summer Nuclear Power Plant a Technical Support Complex (TSC). This complex will improve the information available to operating and technical personnel. The 3 elements of the TSC are:

1. ON-SITE Technical Support Center (OSTS).
2. Bypass and Inoperable Status Indication (BISI)
3. Safety Parameter Display System (SPDS)

The ON-SITE Technical Support Center is at a location adjacent to but separate from the control room. Key plant information can be displayed in and transmitted from the OSTS to those technical personnel who are responsible for engineering support during post accident recovery. The center has the capability to receive, process, and display analog and digital signals from both the NSSS and BOP parts of the plant.

Bypass and Inoperable Status Indication provides the operator with a clear indication of the availability of plant safety systems. It provides the operator and OTSC personnel with a continuous systems level indication of bypasses or inoperable status of the systems comprising the Engineered Safety Features.

The purpose of the safety parameter display system (SPDS) is to assist operating personnel in evaluating the safety status of the plant. The SPDS provides a continuous indication of plant parameters or derived variables which are representative of the safety status of the plant during both normal and emergency use. The primary function of the SPDS is to aid in the rapid detection of abnormal operating conditions. Secondary functions include analyzing and diagnosing the abnormality, and providing an informational basis for corrective action execution.

The TSC is located in the Control Building, elevation 463'0", separate from but next to, the control room and is capable of accommodating a minimum of 25 persons (see Figure 1.2-15). Access to the control room is available through connecting doors between the TSC and the control room. Print storage and plant information will be available in the TSC. The TSC contains the following areas:

1. Data Display Room - This contains the communications and monitoring equipment necessary to provide the engineering and management support functions during an accident condition. The Communications, monitoring, and display equipment in this area includes:
  - a. Communications Network including plant telephones, dedicated lines to external parties, and radio systems.

PAGE INTENTIONALLY LEFT BLANK

2. SCE&G Co. Technical Area - Office and communications facilities for SCE&G assigned personnel.
3. NRC Office - Office and communications for five (5) NRC assigned personnel.
4. Operations Conference Room - Conference Room facilities.
5. Westinghouse Office - Office and communications facilities for plant personnel to communicate with Westinghouse.
6. GAI Office - Office and communications facilities for plant personnel to communicate with GAI.

The TSC is habitable to the same environmental conditions as the control room for postulated accident conditions. (The TSC has the same air supply and exhaust system as the control room, (see Section 9.4.1).

Installed radiation monitors (RM-G1 and RM-A1) will detect direct radiation and airborne radioactive contaminants for both the control room and the TSC. The monitors will alarm when high radiation levels are being approached. SCE&G Co. has established in the plant's emergency procedures the necessary precautionary protective measures to be taken for high levels of radiation.

#### 7.7.3.2 Analysis

1. The TSC is located on elevation 463'0" of the Control Building, which is a Seismic Category I structure.
2. The environmental conditions within the TSC are the same as those in the control room.
3. Installed radiation monitors (RM-G1 and RM-A1) will detect direct radiation and airborne radioactive contaminants for both the control room and the TSC. The monitors will alarm when high radiation levels are being approached.
4. Equipment within the TSC is designed to assure reliability in the recovery of data.
5. The TSC and equipment located in the TSC are not required to initiate actuation of safety related systems. Loss of the TSC or any equipment within the TSC will not prevent safe shutdown of the plant.

### 7.7.4 CRITICAL SYSTEMS LEAK MONITORING SYSTEM

#### 7.7.4.1 Description

An acoustical type leak monitoring system is provided to detect through the wall and valve seat leakage. Sensors for this system are located in the following locations:

- a. Downstream of the pressurizer safety valves

- b. Downstream of the reactor vessel head vent valves
- c. On the feedwater lines to the steam generator
- d. On the emergency feedwater lines to the steam generator.

The sensors for the system are located inside the reactor building, with all conditioning components located outside.

A leak through a valve seat generates metal borne acoustic waves which are detected by acoustic transducers mounted on the piping adjacent to the valves. The transducers convert the acoustic waves into electrical signals which are amplified and then transmitted to the leak detection system.

The control room is provided with indication which relates to the size of the leak and an alarm which alerts the operator of the occurrence of a leak. The system is provided with multiple sensors to enable the plant operator to determine which pressurizer safety valve or reactor vessel head vent valve is open. Multiple sensors also aide in determining the approximate location of a through wall leak in the feedwater or emergency feedwater lines to the steam generators.

#### 7.7.4.2 Analysis

The critical systems leak monitoring system is powered from a vital instrument bus. The system will be qualified to IEEE 323 and IEEE 344. Seismic and environmental qualification is discussed in Section 3.10 and 3.11, respectively.

#### 7.7.5 REACTOR VESSEL LEVEL INSTRUMENTATION SYSTEM

This section deleted by Amendment 4.



## 7.7.6 CORE SUBCOOLING MONITOR

This section deleted by Amendment 1, August 1985.

## 7.7.7 REFERENCES

1. Lipchak, J. B. and Stokes, R. A., "Nuclear Instrumentation System," WCAP-8255, January, 1974.
2. "Calculation of Distance Factors for Power and Test Reactor Sites," J. J. Dinunno, et. al, U. S. Atomic Energy Commission, Washington, D. C., March, 1962.


LIST OF FIGURES (Cont.)

<u>Figure</u>	<u>Title</u>
8G-1	Containment Penetration Conductor Overcurrent Protection Devices
8G-2	Containment Penetration Conductor Overcurrent Protection Devices
8G-3	Containment Penetration Conductor Overcurrent Protection Devices
8G-4	Containment Penetration Conductor Overcurrent Protection Devices
8G-5	Containment Penetration Conductor Overcurrent Protection Devices
8G-6	Containment Penetration Conductor Overcurrent Protection Devices
8G-7	Containment Penetration Conductor Overcurrent Protection Devices
8G-8	Containment Penetration Conductor Overcurrent Protection Devices
8G-9	Containment Penetration Conductor Overcurrent Protection Devices
8G-10	Containment Penetration Conductor Overcurrent Protection Devices

LIST OF EFFECTIVE PAGES (LEP)


The following list delineates pages to Chapter 8 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-05 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 8-i	7	Aug. 1991	8.2-4	95-02	Apr. 1995
8-ii	3	Aug. 1987	Fig. 8.2-5(Deleted)	0	Aug. 1984
8-iii	5	Aug. 1989	8.2-6(Deleted)	0	Aug. 1984
8-iv	0	Aug. 1984	8.2-7(Deleted)	0	Aug. 1984
8-v	5	Aug. 1989	Page 8.3-1	0	Aug. 1984
8-vi	0	Aug. 1984	8.3-2	93-05	May 1993
8-vii	0	Aug. 1984	8.3-3	94-05	June 1993
8-viia	3	Aug. 1987	8.3-4	2	Aug. 1986
8-viii	95-02	Apr. 1995	8.3-5	93-05	May 1993
8-ix	93-10	Dec. 1993	8.3-6	93-05	May 1993
8-x	93-06	Jul. 1993	8.3-7	6	Aug. 1990
8.1-1	0	Aug. 1984	8.3-8	93-05	May 1993
8.1-2	4	Aug. 1988	8.3-9	93-05	May 1993
8.1-3	5	Aug. 1989	8.3-10	0	Aug. 1984
8.1-4	0	Aug. 1984	8.3-11	6	Aug. 1990
8.1-5	0	Aug. 1984	8.3-12	0	Aug. 1984
8.1-6	0	Aug. 1984	8.3-13	92-02	Feb. 1992
8.1-7	0	Aug. 1984	8.3-14	5	Aug. 1989
8.1-8	0	Aug. 1984	8.3-15	0	Aug. 1984
8.1-9	0	Aug. 1984	8.3-16	0	Aug. 1984
Fig. 8.1-1	5	Aug. 1989	8.3-17	0	Aug. 1984
Page 8.2-1	93-05	May 1993	8.3-18	1	Aug. 1985
8.2-2	93-05	May 1993	8.3-19	0	Aug. 1984
8.2-3	93-05	May 1993	8.3-20	0	Aug. 1984
8.2-3a	93-05	May 1993	8.3-21	2	Aug. 1986
8.2-4	0	Aug. 1984	8.3-21a	2	Aug. 1986
8.2-5	0	Aug. 1984	8.3-22	0	Aug. 1984
8.2-6	5	Aug. 1989	8.3-23	0	Aug. 1984
8.2-7	93-05	May 1993	8.3-24	0	Aug. 1984
8.2-8	93-05	May 1993	8.3-25	0	Aug. 1984
8.2-9	93-05	May 1993	8.3-26	0	Aug. 1984
8.2-10	93-05	May 1993	8.3-27	92-11	Nov. 1992
8.2-11	5	Aug. 1989	8.3-27a	92-11	Nov. 1992
8.2-12	93-05	May 1993	8.3-27b	7	Aug. 1991
Fig. 8.2-1	5	Aug. 1989	8.3-28	7	Aug. 1991
8.2-2	5	Aug. 1989	8.3-29	92-11	Nov. 1992
8.2-2a	93-05	May 1993	8.3-30	92-11	Nov. 1992
8.2-2b	93-05	May 1993	8.3-31	92-02	Feb. 1992
8.2-2c	5	Aug. 1989	8.3-32	92-02	Feb. 1992
8.2-2d	0	Aug. 1984	8.3-33	92-02	Feb. 1992
8.2-3	95-02	Apr. 1995	8.3-34	3	Aug. 1987



ANSTEC  
APERTURE  
CARD

Also Available on  
Aperture Card



NOTES  
1. ITEMS WITH NO LIGHTEN ARE BY THE 1/2 IN. OF 600V BREAKERS  
2. 200V SCALE RELAYS  
3. 400V/600V BREAKING CT'S EXTERNALLY DETALLED  
4. BUS - INDICATES WHEN ARE LOCALLY OPERATED BREAKERS ARE IN DISCONNECT SWITCHES  
5. 600V BUS  
6. TRANSFORMER TAPPED DRAWING ARE CORRECT, THE MOTOR TAPS AND TRENDS: 1 1/2 IN. 2 IN. 3 IN. 4 IN. 5 IN. 6 IN. 7 IN. 8 IN. 9 IN. 10 IN. 11 IN. 12 IN. 13 IN. 14 IN. 15 IN. 16 IN. 17 IN. 18 IN. 19 IN. 20 IN. 21 IN. 22 IN. 23 IN. 24 IN. 25 IN. 26 IN. 27 IN. 28 IN. 29 IN. 30 IN. 31 IN. 32 IN. 33 IN. 34 IN. 35 IN. 36 IN. 37 IN. 38 IN. 39 IN. 40 IN. 41 IN. 42 IN. 43 IN. 44 IN. 45 IN. 46 IN. 47 IN. 48 IN. 49 IN. 50 IN. 51 IN. 52 IN. 53 IN. 54 IN. 55 IN. 56 IN. 57 IN. 58 IN. 59 IN. 60 IN. 61 IN. 62 IN. 63 IN. 64 IN. 65 IN. 66 IN. 67 IN. 68 IN. 69 IN. 70 IN. 71 IN. 72 IN. 73 IN. 74 IN. 75 IN. 76 IN. 77 IN. 78 IN. 79 IN. 80 IN. 81 IN. 82 IN. 83 IN. 84 IN. 85 IN. 86 IN. 87 IN. 88 IN. 89 IN. 90 IN. 91 IN. 92 IN. 93 IN. 94 IN. 95 IN. 96 IN. 97 IN. 98 IN. 99 IN. 100 IN.


REFERENCES  
AMENDMENT 95-02  
APRIL, 1995  
SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGINIA C. SUMNER NUCLEAR STATION  
  
ELECTRICAL  
ONE LINE AND RELAY DIAGRAM  
BALANCE OF PLANT POWER SYSTEM  
E-206-011 REV. 15  
Figure 8.2-3


44022851 9506160376-04

9506160376-04




A  
B  
C  
D  
E  
F  
G  
H  
J  
K





ANSTEC  
APERTURE  
CARD

Also Available on  
Aperture Card



- NOTES:
1. A & B INDICATES THESE ARE LOGICALLY OPERATED BREAKERS USED AS DISCONNECT DEVICES.
  2. ○ INDICATES INTERLOCK IN THE SWM POWER SYSTEM WHICH IS TRANSFERRED TO THE INTERLOCK FROM THE NEAREST PROTECTIVE DEVICE. ALL RELAYS ARE ASSIGNED SA OF SD.
  3. △ INDICATES INTERLOCK RELAYING IN THE SWM POWER SYSTEM WHICH IS CLASSIFIED AS ASSIGNED SA OF SD.
  4. NOT USED.
  5. SERVICE WATER PUMP SPEED CHANGE SWITCHES ARE LOCKED IN HIGH SPEED OPERATING POSITION PERMANENTLY.
  6. A CORRECT TRANSFORMER RATIO NOTED WITH 'C' RELAY AND THE SECONDARY WINDING.
  7. △ THE RELAY IS WIRING AND FED TO ITS COIL, BUT THE CONTROL CIRCUIT CONTACTS ARE WIRING ASSIGNED TO THE RELAY SERVED AS SAFETY FUNCTION.
  8. ○ THE RELAY IS WIRING ASSIGNED FROM THE NEAREST PROTECTIVE DEVICE TO ITS COIL AND THE CONTROL CIRCUIT CONTACTS ARE WIRING AND FED, BUT SERVED AS SAFETY FUNCTION.
  9. VOLTAGE REGULATOR IS FED RELAYING, G RESISTANCE OPERATED THROUGH COILED VOLTAGE RESISTOR.
  10. TRANSFORMER VOLTAGE TAPPER ARE WIRING, THE ACTION TAPS USED ARE LISTED AND IN THE 1.000V/1.25V.

REFERENCES:  
E-206-012 LINE AND RELAY DIAGRAMS  
WATER SYSTEMS ARE REFERENCED.

AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

ELECTRICAL  
ONE LINE AND RELAY DIAGRAM  
ENGINEERED SAFETY FEATURES POWER SYSTEM  
E-206-012 REV. 26  
Figure 8.2-4

9506160376-05

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 9 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-10 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 9-i	7	Aug. 1991	Page 9.1-25	0	Aug. 1984
9-ii	7	Aug. 1991	9.1-26	0	Aug. 1984
9-iii	7	Aug. 1991	9.1-27	7	Aug. 1991
9-iv	2	Aug. 1986	9.1-28	2	Aug. 1986
9-v	2	Aug. 1986	9.1-29	2	Aug. 1986
9-vi	0	Aug. 1984	Fig. 9.1-1	2	Aug. 1986
9-vii	2	Aug. 1986	9.1-2	2	Aug. 1986
9-viii	0	Aug. 1984	9.1-2a	2	Aug. 1986
9-ix	0	Aug. 1984	9.1-2b	2	Aug. 1986
9-x	0	Aug. 1984	9.1-3	94-03	Mar. 1994
9-xi	94-10	Dec. 1994	9.1-4	0	Aug. 1984
9-xii	0	Aug. 1984	9.1-5	0	Aug. 1984
9-xiii	94-10	Dec. 1994	9.1-6	0	Aug. 1984
9-xiv	95-02	Apr. 1995	9.1-7	0	Aug. 1984
9-xv	95-02	Apr. 1995	9.1-8	0	Aug. 1984
9-xvi	95-02	Apr. 1995	9.1-9	0	Aug. 1984
9-xvii	95-02	Apr. 1995	9.1-10	0	Aug. 1984
9.1-1	2	Aug. 1986	9.1-11	0	Aug. 1984
9.1-2	2	Aug. 1986	9.1-12	0	Aug. 1984
9.1-3	2	Aug. 1986	Page 9.2-1	5	Aug. 1989
9.1-4	2	Aug. 1986	9.2-2	92-10	Oct. 1992
9.1-5	7	Aug. 1991	9.2-3	92-10	Oct. 1992
9.1-5a	7	Aug. 1991	9.2-4	5	Aug. 1989
9.1-6	2	Aug. 1986	9.2-5	92-10	Oct. 1992
9.1-7	2	Aug. 1986	9.2-5a	4	Aug. 1988
9.1-8	0	Aug. 1984	9.2-6	92-10	Oct. 1992
9.1-9	0	Aug. 1984	9.2-7	92-10	Oct. 1992
9.1-10	0	Aug. 1984	9.2-8	92-10	Oct. 1992
9.1-11	0	Aug. 1984	9.2-9	0	Aug. 1984
9.1-12	0	Aug. 1984	9.2-10	0	Aug. 1984
9.1-13	0	Aug. 1984	9.2-11	0	Aug. 1984
9.1-14	0	Aug. 1984	9.2-12	0	Aug. 1984
9.1-15	0	Aug. 1984	9.2-13	3	Aug. 1987
9.1-16	0	Aug. 1984	9.2-14	4	Aug. 1988
9.1-17	0	Aug. 1984	9.2-15	4	Aug. 1988
9.1-18	0	Aug. 1984	9.2-16	0	Aug. 1984
9.1-19	0	Aug. 1984	9.2-17	3	Aug. 1987
9.1-20	0	Aug. 1984	9.2-18	0	Aug. 1984
9.1-21	4	Aug. 1988	9.2-19	0	Aug. 1984
9.1-22	4	Aug. 1988	9.2-20	7	Aug. 1991
9.1-23	0	Aug. 1984	9.2-21	0	Aug. 1984
9.1-24	0	Aug. 1984	9.2-22	0	Aug. 1984

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 9.2-23	2	Aug. 1986	Fig. 9.2-10	0	Aug. 1984
9.2-24	0	Aug. 1984	9.2-11	0	Aug. 1984
9.2-25	0	Aug. 1984	9.2-12	0	Aug. 1984
9.2-26	0	Aug. 1984	9.2-13	0	Aug. 1984
9.2-27	0	Aug. 1984	9.2-14	0	Aug. 1984
9.2-28	0	Aug. 1984	9.2-15	0	Aug. 1984
9.2-29	4	Aug. 1988	9.2-16	0	Aug. 1984
9.2-30	0	Aug. 1984	9.2-17	0	Aug. 1984
9.2-31	5	Aug. 1989	9.2-18	0	Aug. 1984
9.2-32	1	Aug. 1985	9.2-19	0	Aug. 1984
9.2-33	1	Aug. 1985	9.2-20	0	Aug. 1984
9.2-34	0	Aug. 1984	9.2-21	0	Aug. 1984
9.2-35	4	Aug. 1988	9.2-22	0	Aug. 1984
9.2-36	0	Aug. 1984	9.2-23	0	Aug. 1984
9.2-37	0	Aug. 1984	9.2-24	94-05	June 1994
9.2-38	7	Aug. 1991	Page 9.3-1	4	Aug. 1988
9.2-39	7	Aug. 1991	9.3-2	0	Aug. 1984
9.2-40	7	Aug. 1991	9.3-3	7	Aug. 1991
9.2-41	7	Aug. 1991	9.3-4	0	Aug. 1984
9.2-42	7	Aug. 1991	9.3-5	0	Aug. 1984
9.2-43	7	Aug. 1991	9.3-6	7	Aug. 1991
9.2-44	7	Aug. 1991	9.3-7	7	Aug. 1991
9.2-45	7	Aug. 1991	9.3-8	94-10	Dec. 1994
9.2-46	7	Aug. 1991	9.3-9	0	Aug. 1984
9.2-47	7	Aug. 1991	9.3-10	1	Aug. 1985
9.2-48	7	Aug. 1991	9.3-11	1	Aug. 1985
9.2-49	7	Aug. 1991	9.3-12	3	Aug. 1987
9.2-50	7	Aug. 1991	9.3-13	0	Aug. 1984
9.2-51	7	Aug. 1984	9.3-14	0	Aug. 1984
9.2-52	7	Aug. 1984	9.3-15	0	Aug. 1984
9.2-53	7	Aug. 1984	9.3-16	0	Aug. 1984
9.2-54	0	Aug. 1984	9.3-17	0	Aug. 1984
9.2-55	0	Aug. 1984	9.3-18	0	Aug. 1984
9.2-56	0	Aug. 1984	9.3-19	0	Aug. 1984
9.2-57	0	Aug. 1984	9.3-20	0	Aug. 1984
9.2-58	0	Aug. 1984	9.3-21	0	Aug. 1984
9.2-59	0	Aug. 1984	9.3-22	0	Aug. 1984
9.2-60	0	Aug. 1984	9.3-23	0	Aug. 1984
9.2-61	0	Aug. 1984	9.3-24	5	Aug. 1989
Fig. 9.2-1	95-02	Apr. 1995	9.3-25	0	Aug. 1984
9.2-2	95-02	Apr. 1995	9.3-26	0	Aug. 1984
9.2-3	93-11	Dec. 1993	9.3-27	0	Aug. 1984
9.2-4	95-02	Apr. 1995	9.3-28	0	Aug. 1984
9.2-5	6	Aug. 1990	9.3-29	0	Aug. 1984
9.2-6	7	Aug. 1991	9.3-30	0	Aug. 1984
9.2-7	95-02	Apr. 1995	9.3-31	0	Aug. 1984
9.2-8	7	Aug. 1991	9.3-32	0	Aug. 1984
9.2-9	94-02	Feb. 1994	9.3-33	0	Aug. 1984
9.2-9A	94-10	Dec. 1994	9.3-34	0	Aug. 1984
9.2-9B	94-10	Dec. 1994	9.3-35	0	Aug. 1984
9.2-9C	91-1	Sep. 1991	9.3-36	0	Aug. 1984



LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 9.3-37	0	Aug. 1984	Fig. 9.3-16(2 of 5)	93-03	Mar. 1993
9.3-38	0	Aug. 1984	9.3-16(3 of 5)	94-03	Mar. 1994
9.3-39	0	Aug. 1984	9.3-16(4 of 5)	5	Aug. 1989
9.3-40	0	Aug. 1984	9.3-16(5 of 5)	3	Aug. 1987
9.4-41	0	Aug. 1984	9.3-17 (Deleted)	0	Aug. 1984
9.3-42	0	Aug. 1984	9.3-18	94-05	June 1994
9.3-43	0	Aug. 1984	9.3-19 (Deleted)	0	Aug. 1984
9.3-44	0	Aug. 1984	9.3-20	7	Aug. 1991
9.3-45	0	Aug. 1984	9.3-21	7	Aug. 1991
9.3-46	2	Aug. 1986	Page 9.4-1	0	Aug. 1984
9.3-47	0	Aug. 1984	9.4-2	7	Aug. 1991
9.3-48	0	Aug. 1984	9.4-3	0	Aug. 1984
9.3-49	0	Aug. 1984	9.4-4	0	Aug. 1984
9.3-50	0	Aug. 1984	9.4-5	94-10	Dec. 1994
9.3-51	0	Aug. 1984	9.4-6	94-10	Dec. 1994
9.3-52	0	Aug. 1984	9.4-7	94-10	Dec. 1994
9.3-53	0	Aug. 1984	9.4-8	94-10	Dec. 1994
9.3-54	0	Aug. 1984	9.4-9	94-10	Dec. 1994
9.3-55	0	Aug. 1984	9.4-10	4	Aug. 1988
9.3-56	0	Aug. 1984	9.4-10a	4	Aug. 1988
9.3-57	0	Aug. 1984	9.4-11	0	Aug. 1984
9.3-58	0	Aug. 1984	9.4-12	0	Aug. 1984
9.3-59	0	Aug. 1984	9.4-13	4	Aug. 1988
9.3-60	0	Aug. 1984	9.4-14	0	Aug. 1984
9.3-61	0	Aug. 1984	9.4-15	3	Aug. 1987
9.3-62	0	Aug. 1984	9.4-16	0	Aug. 1984
9.3-63	0	Aug. 1984	9.4-17	92-09	Sep. 1992
9.3-64	7	Aug. 1991	9.4-18	0	Aug. 1984
9.3-65	7	Aug. 1991	9.4-19	0	Aug. 1984
9.3-66	0	Aug. 1984	9.4-20	0	Aug. 1984
9.3-67	7	Aug. 1991	9.4-21	4	Aug. 1988
Fig. 9.3-1	93-02	Feb. 1993	9.4-22	4	Aug. 1988
9.3-2	93-03	Mar. 1993	9.4-22a	4	Aug. 1988
9.3-3	6	Aug. 1990	9.4-23	0	Aug. 1984
9.3-3a	95-02	Apr. 1995	9.4-24	0	Aug. 1984
9.3-4	95-02	Apr. 1995	9.4-25	0	Aug. 1984
9.3-5	0	Aug. 1984	9.4-26	0	Aug. 1984
9.3-6	5	Aug. 1989	9.4-27	0	Aug. 1984
9.3-7	3	Aug. 1987	9.4-28	0	Aug. 1984
9.3-8	0	Aug. 1984	9.4-29	0	Aug. 1984
9.3-9	1	Aug. 1985	9.4-30	0	Aug. 1984
9.3-10	7	Aug. 1991	9.4-31	0	Aug. 1984
9.3-11	93-06	Jul. 1993	9.4-32	0	Aug. 1984
9.3-12	93-09	Nov. 1993	9.4-33	0	Aug. 1984
9.3-13	93-06	Jul. 1993	9.4-34	0	Aug. 1984
9.3-13a	0	Aug. 1984	9.4-35	94-10	Dec. 1994
9.3-14	7	Aug. 1991	9.4-36	94-10	Dec. 1994
9.3-15	7	Aug. 1991	9.4-37	94-10	Dec. 1994
9.3-16	93-03	Mar. 1993	9.4-38	94-10	Dec. 1994
9.3-16(1a of 5)	91-02	Oct. 1991	9.4-39	94-10	Dec. 1994
9.3-16(1b of 5)	91-02	Oct. 1991	9.4-39a	94-10	Dec. 1994
9.3-16(1c of 5)	95-02	Apr. 1995	9.4-40	0	Aug. 1984


LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 9.4-41	0	Aug. 1984	Fig. 9.4-14	94-10	Dec. 1994
9.4-42	94-10	Dec. 1994	9.4-15	4	Aug. 1988
9.4-43	0	Aug. 1984	9.4-16	94-10	Dec. 1994
9.4-44	0	Aug. 1984	9.4-17	93-11	Dec. 1993
9.4-45	93-05	May 1993	9.4-18	5	Aug. 1989
9.4-46	93-05	May 1993	9.4-19	94-05	June 1994
9.4-47	94-10	Dec. 1994	9.4-20	6	Aug. 1990
9.4-48	94-10	Dec. 1994	9.4-21	0	Aug. 1984
9.4-49	94-10	Dec. 1994	9.4-22	93-09	Nov. 1993
9.4-50	0	Aug. 1984	9.4-23	94-10	Dec. 1994
9.4-51	0	Aug. 1984	9.4-24	93-09	Nov. 1993
9.4-52	0	Aug. 1984	9.4-25	94-08	Oct. 1994
9.4-53	95-02	Apr. 1995	9.4-26	0	Aug. 1984
9.4-54	0	Aug. 1984	9.4-26a	93-09	Nov. 1993
9.4-55	94-10 (Corr)	Dec. 1994	9.4-26b	0	Aug. 1984
9.4-55a	94-10	Dec. 1994	9.4-26c	95-02	Apr. 1995
9.4-55b	94-10	Dec. 1994	9.4-27(Deleted)	0	Aug. 1984
9.4-56	0	Aug. 1984	9.4-28	7	Aug. 1991
9.4-57	0	Aug. 1984	9.4-29	6	Aug. 1990
9.4-58	0	Aug. 1984	9.4-30	7	Aug. 1991
9.4-59	0	Aug. 1984	9.4-31	1	Aug. 1985
9.4-60	0	Aug. 1984	9.4-32	7	Aug. 1991
9.4-61	0	Aug. 1984	9.4-33	95-02	Apr. 1995
9.4-62	0	Aug. 1984	9.4-34	94-10	Dec. 1994
9.4-63	0	Aug. 1984	Page 9.5-1	4	Aug. 1988
9.4-64	0	Aug. 1984	9.5-2	2	Aug. 1986
9.4-65	0	Aug. 1984	9.5-3	5	Aug. 1989
9.4-66	0	Aug. 1984	9.5-4	5	Aug. 1989
9.4-67	0	Aug. 1984	9.5-5	4	Aug. 1988
9.4-68	0	Aug. 1984	9.5-6	2	Aug. 1986
9.4-69	0	Aug. 1984	9.5-7	3	Aug. 1987
9.4-70	0	Aug. 1984	9.5-7a	2	Aug. 1986
9.4-71	0	Aug. 1984	9.5-8	5	Aug. 1989
9.4-72	0	Aug. 1984	9.5-9	0	Aug. 1984
9.4-73	0	Aug. 1984	9.5-10	0	Aug. 1984
9.4-74	0	Aug. 1984	9.5-11	0	Aug. 1984
9.4-75	0	Aug. 1984	9.5-12	6	Aug. 1990
9.4-76	0	Aug. 1984	9.5-13	6	Aug. 1990
9.4-77	94-10	Dec. 1994	9.5-14	6	Aug. 1990
9.4-78	0 (Corr)	Aug. 1984	9.5-15	0	Aug. 1984
Fig. 9.4-1	6	Aug. 1990	9.5-16	0	Aug. 1984
9.4-2	94-10	Dec. 1994	9.5-17	93-10	Dec. 1993
9.4-3	94-10	Dec. 1994	9.5-18	0	Aug. 1984
9.4-4	7	Aug. 1991	9.5-19	0	Aug. 1984
9.4-5	94-10 (Corr)	Dec. 1994	9.5-20	0	Aug. 1984
9.4-6	93-09	Nov. 1993	9.5-21	2	Aug. 1986
9.4-7	93-09	Nov. 1993	9.5-22	0	Aug. 1984
9.4-8	93-09	Nov. 1993	9.5-23	6	Aug. 1990
9.4-9	93-09	Nov. 1993	9.5-24	0	Aug. 1984
9.4-10	93-09	Nov. 1993	9.5-25	0	Aug. 1984
9.4-10a	93-03	Mar. 1993	9.5-26	0	Aug. 1984
9.4-11	7	Aug. 1991	9.5-27	0	Aug. 1984
9.4-12	0	Aug. 1984	9.5-28	0	Aug. 1984
9.4-13	0	Aug. 1984			





LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 9.5-29	0	Aug. 1984			
9.5-30	0	Aug. 1984			
9.5-31	0	Aug. 1984			
Fig. 9.5-1	95-02	Apr. 1995			
9.5-1a	5	Aug. 1989			
9.5-1b	93-10	Dec. 1993			
9.5-1c	93-10	Dec. 1993			
9.5-1d	93-10	Dec. 1993			
9.5-1e	0	Aug. 1984			
9.5-1f	5	Aug. 1989			
9.5-1g	5	Aug. 1989			
9.5-1h	0	Aug. 1984			
9.5-2	95-02	Apr. 1995			
9.5-2a	0	Aug. 1984			
9.5-3	0	Aug. 1984			
9.5-4	0	Aug. 1984			
9.5-5	0	Aug. 1984			
9.5-6	0	Aug. 1984			
9.5-7	0	Aug. 1984			
9.5-8	0	Aug. 1984			
9.5-9	0	Aug. 1984			
9.5-10	0	Aug. 1984			
9.5-11	95-02	Apr. 1995			

SYSTEM DATA					
NO.	GPM	PSIG	%	BY	REMARKS
1	400	40	50	G.C.S.	NORMAL
2	400	40	50	G.C.S.	POST ACC'D
3	400	40	50	G.C.S.	POST ACC'D
4	400	40	50	G.C.S.	POST ACC'D
5	400	40	50	G.C.S.	POST ACC'D
6	400	40	50	G.C.S.	POST ACC'D
7	400	40	50	F.J.S.	NORMAL
8	400	40	50	F.J.S.	NORMAL




SAFETY CLASS VERIFICATIONS	
ORIGINATED BY	P. G. ...
REVIEWED BY	P. G. ...




MOTOR BEARING COOLING					
NO.	TEMP.	INLET	OUTLET	MARK.	NOTE
1	75	95	85	10	NOTE 1
2	75	95	85	10	NOTE 1
3	75	95	85	10	NOTE 1
4	75	95	85	10	NOTE 1
5	75	95	85	10	NOTE 1

DESIGN DATA



# ANSTEC APERTURE CARD

Also Available on Aperture Card



AMENDMENT 95-02  
APRIL, 1995


THE 3rd PUMP WITH THE THIRD CONSIDERED AS AN INSTALLED SPARE. I.E. NO AUTOSTART CAPABILITIES EXIST FOR A STANDBY PUMP DUE TO ADMINISTRATIVE PROCEDURES.

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

PIPING SYSTEM FLOW DIAGRAM  
SERVICE WATER COOLING  
(D-302-221 REV.16)  
Figure 9.2-1

9506160376-06





SYSTEM DATA

OP	GPH	PSIG	°F	BY	REMARKS
1	35	50	85	JJV	NORMAL
2	13,750	35	124		NORMAL
3	1850	35	116		NORMAL
4	1880	35	105		NORMAL
5	990	50	187		POST ACCID
6	2580	180	95		BLACK OUT
7	28	35	95	JJV	NORMAL
8	28	50	95	JJV	POST ACCID

SERVICE WATER TO DIESEL GENERATOR 'A' START AIR COMPRESSOR AFTERCOOLER

SERVICE WATER TO DIESEL GENERATOR 'A' START AIR COMPRESSOR AFTERCOOLER

DC 'A' MI LUBE OIL/MI WATER JACKET TEMPERATURE LOGIC SEE GAI DNG D-862-814, SHT 5

DC 'B' MI LUBE OIL/MI WATER JACKET TEMPERATURE LOGIC SEE GAI DNG D-862-814, SHT 5

STATION DRAINAGE LOC. D-8

COOLING WATER TO DRPPI COOLING UNIT COIL


HYDROSTATIC TEST TEMP. DEG	13	45	124	85	124	78
12	128	95	188	214	111	236
18	129	95	185	95	111	214
9	14	158	20	198	111	21
8	16	95	20	214	111	21
7	16	124	20	124	111	21
6	85	124	85	124	111	82
5	85	95	85	85	111	82
4	128	95	188	214	111	236
2	168	95	181	95	111	236

DESIGN DATA

- NOTES:
1. ALL PIPING TO BE LINE SPEC 152N, EXCEPT AS NOTED.
  2. CHECK VALVE 'N' CONTROLLABLE DASH POTS.
  3. TEMP CORRESPONDING TO PERTINENT HEAT EXCHANGER OUTLET.
  4. CEP CONTROL ROOM EXHAUSTION PANEL.
  5. ALL STATUS LIGHT INDICATE BOTH OPEN AND CLOSED POSITIONS.
  6. \* DENOTES MISSION CRIT CHECK OR EQUAL.
  7. \*\* INDICATES SWITCHES, ALARMS AND INDICATING LIGHTS ARE LOCATED ON THE HVAC CONTROL BOARD (EPC-4278-865-1) THE MACH CONTROL ROOM.
  8. RECORDER SHARED WITH REACTOR BULK SHIP PUMP FLOW INSTRUMENTATION.
  9. FLOW VENTS AND DRAINS ON RAG-1A, 1B, 2A & 2B-4A SEE DETAIL 'M' ON DNG D-362-321.

# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

SYSTEM FLOW DIAGRAM  
SERVICE WATER COOLING  
(D-302-222 REV. 29)

Figure 9.2-2


9506160376-07

SYSTEM DATA				
SP	MAX V.P.W.	PSIG	WT	REMARKS
1	1000	30	100	100
2	1000	30	100	100
3	1000	30	100	100
4	1000	30	100	100
5	1000	30	100	100
6	1000	30	100	100
7	1000	30	100	100
8	1000	30	100	100
9	1000	30	100	100
10	1000	30	100	100

\* THIS TEMPERATURE IS A MAXIMUM EXPECTED FOR 90°F SERVICE WATER TEMPERATURE & LOSS OF ONE COMPONENT COOLING WATER HEAT EXCHANGER DURING PLANT COLD-DOWN MODE.

**SAFETY CLASS VERIFICATION**  
 ORIGINATED BY: [Signature]  
 REVIEWED BY: [Signature]

HYDRO TEMP - COLD WATER										
SP	120	140	160	180	200	220	240	260	280	300
1										
2										
3										
4										
5										
6										
7										
8										
9										
10										



\* CONDITION AT TOP OF SURGE TANK





14 13 12 11 10

SYSTEM DATA

NO	SIZE	TYPE	DATE	BY	REMARKS
1	40	100	120	AC/C	
2	15	70	130	AC/C	
3	5	70	140	AC/C	
4	40	85	150	AC/C	

\* THIS TEMPERATURE IS A MAXIMUM EXPECTED FOR 40° SERVICE WATER TEMPERATURE & LOSS OF ONE EQUIPMENT COOLING WATER HEAT EXCHANGER SURFACE COOLING MODE

SAFETY CLASS VERIFICATION

ORIGINATED BY: PTE/Edg  
 REVIEWED BY: J. P. [Signature]

CC	19500	19615
CC	19500	19615
SYSTEM(S)	FIRST NO	LAST NO

VALVE NUMBERING

W-1-W-1 Dwg. 1-01-88

HYDRO TEMP. COLD WATER


NO	SIZE	TYPE	DATE	BY	REMARKS
1	10	100	120	AC/C	
2	15	70	130	AC/C	
3	5	70	140	AC/C	
4	40	85	150	AC/C	

SEALING



# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



- NOTES**
1. ALL NUCLEAR SAFETY CLASS PIPING TO BE LINE SPEC 152N.
  2. ALL HIGH-NUCLEAR SAFETY CLASS PIPING TO BE LINE SPEC 152A.
  3. ALL PIPING TO BE 300 SAFETY CLASS 2B EXCEPT AS NOTED.

AMENDMENT 95-02  
APRIL, 1995

FIG. 9.2-7  
NUCLEAR SAFETY RELATED  
EQUIPMENT IS SHOWN ONLY. SEE  
REVISIONS TO DRAWINGS UNDER DRAWING  
REVISIONS FROM THE APERTURE CARD.

**SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION**


**PIPING SYSTEM FLOW DIAGRAM  
COMPONENT COOLING SYSTEM TO NSSS PUMPS  
(D-302-614 REV.10)  
Figure 9.2-7**

9506160376-09

Hardcopy 1995 anstec/answ/answ Wed Jun 21 13:45 EDT 1995

SYSTEM DATA


ID	SCFM	PSIG	IN	BY	REMARKS
1	480	120	100	JL	



SAFETY CLASS VERIFICATION  
 ORIGINATED BY *JDG/1-16*  
 REVIEWED BY *STK/1-16*

VALVE NUMBERING


VALVE NO.	FIRST NO.	LAST NO.
1A	22670	22671
1A	22672	22673



ID	SCFM	PSIG	IN	BY	REMARKS
1	480	120	100	JL	

# ANSTEC APERTURE CARD

Also Available on Aperture Card




AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

PIPING SYSTEM FLOW DIAGRAM  
INSTRUMENT AIR BACKUP  
(D-302-274 REV. 7)

Figure 9.3-3A

9506160376-10




**SYSTEM DATA**

LINE NO.	ITEM	QTY	REV.	REMARKS
1	1.0	1	1	INITIAL
2	1.0	1	1	INITIAL
3	1.0	1	1	INITIAL
4	1.0	1	1	INITIAL
5	1.0	1	1	INITIAL
6	1.0	1	1	INITIAL
7	1.0	1	1	INITIAL
8	1.0	1	1	INITIAL
9	1.0	1	1	INITIAL
10	1.0	1	1	INITIAL
11	1.0	1	1	INITIAL
12	1.0	1	1	INITIAL
13	1.0	1	1	INITIAL
14	1.0	1	1	INITIAL
15	1.0	1	1	INITIAL
16	1.0	1	1	INITIAL
17	1.0	1	1	INITIAL
18	1.0	1	1	INITIAL
19	1.0	1	1	INITIAL
20	1.0	1	1	INITIAL
21	1.0	1	1	INITIAL
22	1.0	1	1	INITIAL
23	1.0	1	1	INITIAL
24	1.0	1	1	INITIAL


Ⓞ NEXT LETTER

**SAFETY CLASS VERIFICATION**  
 DESIGNATED BY: [ ]  
 REVIEWED BY: [ ]



**NOTES CONT.**

- SYSTEMS AND COMPONENTS SHOWN AS NOT BEING USED DECLASSIFIED TO NOT BE OPERATED.
- PHASE 'W' CONTAINMENT ISOLATION SIGNAL.



**HYDRO TEST TEMP. 40°F MIN.**

LINE NO.	ITEM	QTY	REV.	REMARKS
1	1.0	1	1	INITIAL
2	1.0	1	1	INITIAL
3	1.0	1	1	INITIAL
4	1.0	1	1	INITIAL
5	1.0	1	1	INITIAL
6	1.0	1	1	INITIAL
7	1.0	1	1	INITIAL
8	1.0	1	1	INITIAL
9	1.0	1	1	INITIAL
10	1.0	1	1	INITIAL
11	1.0	1	1	INITIAL
12	1.0	1	1	INITIAL
13	1.0	1	1	INITIAL
14	1.0	1	1	INITIAL
15	1.0	1	1	INITIAL
16	1.0	1	1	INITIAL
17	1.0	1	1	INITIAL
18	1.0	1	1	INITIAL
19	1.0	1	1	INITIAL
20	1.0	1	1	INITIAL
21	1.0	1	1	INITIAL
22	1.0	1	1	INITIAL
23	1.0	1	1	INITIAL
24	1.0	1	1	INITIAL


**DESIGN DATA**

**STANDIC WATER HYDROTEST**  
 \*\* AT NORMAL LINE POWER  
 \*\*\* HYDROTEST TEMP. 80°F MIN.

THE VALVES AT THESE LOCATIONS ARE PART OF THE SAMPLE COOLERS AND WILL NOT HAVE THE NUMBERS.

ANSTEC  
APERTURE  
CARD

Also Available on  
Aperture Card



AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
V.C. SUMMER NUCLEAR STATION

D-302-771 REV. 29  
NUCLEAR SAMPLING  
Figure 9.3-4

9506160376-11


100777; rev 02/21; 01/19/95; msource@stetco.com; West Coast 26 13-44-28 EDTT 1995





# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



- NOTES
- THIS DRAWING IS BASED UPON THE 1948073, SHEET 1 OF 5, REVISION NO. 1, WHICH IS PART OF THE ANSTEC SYSTEM OPERATING MANUAL. SYSTEMS ATTACHED TO THIS DRAWING ARE THE RESPONSIBILITY OF THE DESIGN ORGANIZATION SET FORTH IN THE SAID DRAWING.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.
  - NOTE FLOW RESTRICTIONS ARE TO BE MAINTAINED AT ALL TIMES.
  - OPERATIONAL PROCEDURES SHOULD BE FOLLOWED.
  - OPERATIONAL PROCEDURES SHOULD BE FOLLOWED.
  - FOR CONTINGENCY SEE NOTE 13 OF DRAWING E-302-673.
  - FOR CONTINGENCY PROCEDURES, SEE AN OPERATIONAL PLAN WHICH IS ATTACHED TO THIS DRAWING UNDER THE TITLE 'ANSTEC OPERATIONAL PLAN'.
  - THIS DRAWING SHOULD BE KEPT UNDER CLOSE SUPERVISORY CONTROL TO THE DESIGN TEAM.
  - OPERATIONAL PROCEDURES SHOULD BE FOLLOWED TO THE EXTENT POSSIBLE.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.
  - THIS DRAWING HAS BEEN CHECKED AND FOUND TO BE CORRECT AS SHOWN TO THE EXTENT POSSIBLE.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.
  - FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.

13. PROVIDE FLOW RESTRICTION PER NOTE 13 OF DRAWING E-302-673. FLOW RESTRICTION LEGEND NO CREDIT IS TAKEN FOR THIS FLOW RESTRICTION AS A SAFETY CLASS CHANGE.

AMENDMENT 95-02  
APRIL, 1995

FOR FLOW RESTRICTIONS SEE NOTE 13 OF DRAWING E-302-673.

SOUTH CAROLINA ELECTRIC & GAS CO. VIRGIL C. SUMMER NUCLEAR STATION	
CHEMICAL AND VOLUME CONTROL E-302-673 REV. 11	
Figure 9.3-16 SHT. 1C	

9506160376-12

2. Two laboratory hood exhaust fans and a chemical storage area exhaust fan.
3. Twelve electric unit heaters in the chemical storage and general floor areas.
4. Ductwork connecting the air handling unit with the sample room and the water treating laboratory and for supply and exhaust of the laboratory hoods.
5. Instrumentation and control devices to perform the following functions:
  - a. Automatically operate the condensing unit and the air handling unit heating coil in response to a room thermostat.
  - b. Automatically place the outside, return and relief dampers under control of the outside and return mixture temperature controller or at a fixed minimum position in accordance with outside temperature.
  - c. Automatically prevent or permit the condensing unit to operate in accordance with outside temperature.
  - d. Control electric unit heaters with integral thermostats.
  - e. Automatically close hood inlet dampers when the entering air is below a set temperature.

The air handling unit operates continuously. The laboratory hood and chemical storage area exhaust fans are operated as required from local control stations. System components are supplied from non-Class 1E power sources.

#### 9.4.7.2.10 CRDM Cooling Water System

The main components of this system include:

1. One CRDM cooler rack assembly which is an air to water heat exchanger.
2. One CRDM cooling water industrial cooler, including two electric heaters, eight forced convection fans, and four circulation pumps.
3. One expansion tank to control thermally induced water volume changes.
4. Two 100% circulating water pumps, including a bypass line with a chemical feed tank.
5. Four motor operated containment isolation valves, including two check valves on bypass lines on the Reactor Building Side.

The system is designed to remove heat from the containment air used to cool the Control Rod Drive Mechanism (CRDM) and dissipate this heat to the atmosphere via the Industrial Cooler.

The system can operate continuously while the plant is in operation. System components are powered from non-Class 1E power sources, except for the motor operators on the containment isolation valves, which are supplied from the Class 1E power sources.

#### 9.4.7.2.11 Turbine Building Switchgear Rooms Chilled Water System

The main components of this system include:

1. One air-cooled, electric motor drive, reciprocating water chiller.
2. One primary water pump.
3. Two 100% capacity secondary water pumps.
4. Chilled water piping system including a compression tank, an air separator, a chemical feed tank, and valves.
5. Chilled Water Coils - one coil in each of two redundant turbine building switchgear rooms air handling units. Each coil has two connections.
6. Instrumentation and control devices to perform the following functions:
  - a. Control the chiller. Included in a factory-furnished, factory-wired controls are a positive-acting timer to prevent short cycling of the compressors and to delay restart after shutdown, high and low pressure refrigerant safety pressurestats to stop the compressors, a multiple-step water temperature controller, a chilled water safety thermostat, circuit breakers, motor contactors, control relays, a control circuit ON-OFF switch, and a chilled water flow switch. The chiller is energized automatically when primary flow is established.
  - b. Control the primary pump. The pump is started by a remote manual switch. The pump will shutdown on a chiller malfunction.
  - c. Control the secondary pumps. These pumps are redundant and each is wired to run only with its respective air handling unit. The active pump is controlled by one of three parallel-wired room thermostats.
  - d. Indicate locally the level of water in the compressor tank and alarm of low level in the control.
  - e. Alarm in the control room of low water flow.
  - f. Indicate locally the temperature of water entering and leaving the chiller and provide a computer high temperature alarm and CRT display in the control room of water leaving the chiller.
  - g. Indicate locally the pressure of water entering and leaving each pump.

Under normal conditions, the primary pump continuously circulates water in the primary pipe loop. This water is maintained at 45°F by the chiller which loads/unloads and cycles automatically under its self contained controls. The secondary pump circulates water between the primary loop and the chilled water coils identified in Section 9.4.4.2.1, subitem 4. It cycles upon demand of room thermostats.

Additionally, this system can provide chilled water to the CRDM Switchgear Room cooling coils via a booster pump in the event that chilled water is unavailable to these coils. This system can be provided chilled water from the non-nuclear safety related chilled water system. The system is non-nuclear safety class.

#### 9.4.7.2.12 Non-nuclear Safety Related Chilled Water System

The main components of this system include:

1. One air-cooled, electric motor driven reciprocating water chiller.
2. Two 100% capacity chilled water circulating pumps.
3. One chilled water booster pump.
4. Chilled water piping system including an atmospheric expansion tank, provisions for chemical sample and feed, and provisions for balancing the system.
5. Chilled water cooling coils for the following areas:
  - a. CRDM Switchgear Room.
  - b. Controlled Access Area.
  - c. SAS/Computer Room.
  - d. Computer Room.
  - e. BOP Charger Area.
6. Instrumentation and control devices to perform the following functions:
  - a. Cause an alarm at a local panel and a common trouble alarm in the control room upon detection of either low chilled water flow, high chilled water temperature, or low expansion tank level.
  - b. Provide local indication of system flow.
  - c. Provide interlocks which shut the chiller down on low system flow.
  - d. Indicate water temperature locally at the pipe supply and return headers and at the inlet and outlet of each cooling coil.



- e. Provide thermowells for local testing in the supply and return headers at the chiller.
- f. Indicate water pressure locally at the suction and discharge of each pump.
- g. Provide the means for determining pressure drop across each system cooling coil.
- h. Provide local indication of expansion tank level.
- i. Provide a remote means for filling the system.
- j. Provide a local panel at the fill station to indicate "Normal," "Low," and "Fill Complete" expansion tank level with status lights.

Under normal conditions, the system provides chilled water via redundant circulating pumps to the cooling coils listed in Section 9.4.1.2.3, 9.4.1.2.4, 9.4.1.2.6, 9.4.6.2.1, and 9.4.6.2.3. The chiller loads/unloads and cycles automatically to maintain chilled water temperature at 45°F. This system can be aligned to provide a backup source of chilled water to the Turbine Building Switchgear Rooms cooling coils. In the event that chilled water is unavailable to the CRDM Switchgear Room cooling coils, the booster pump can be aligned to the Turbine Building Switchgear Rooms Chilled Water System to provide a backup source of cooling to the CRDM Switchgear Room.

#### 9.4.7.3 Safety Evaluation

The service building ventilation system, industrial system, industrial cooling water system, substation relay house cooling system, penetration access areas ventilation system, miscellaneous pump room systems and lube oil room systems, water treating area laboratory heating and cooling system, and turbine building switchgear rooms chilled water system perform no safety function. The CRDM Cooling Water System performs no safety function except for the containment isolation valves where motor operators are supplied by Class 1E power supplies. They do provide acceptable temperature levels in the various buildings.

Additionally, the substation battery room exhaust fan in the substation relay house cooling system prevents the occurrence of any appreciable hydrogen concentration in the battery room.

The diesel generator building ventilation system, service water pumphouse ventilation system, and chilled water system do perform safety functions since total loss of the heat removal capability of any one of these systems could produce conditions affecting the safety of the plant. These systems are designed with redundant equipment and piping systems and are so arranged, serviced, and maintained such that complete loss of system function or system cooling is highly unlikely. Each of the safety class systems is located in equipment rooms accessible for maintenance but not subject to floods, weather, external missiles, main steam line break effects, jet impingement,

TABLE 9.4-5 (Continued)

DESIGN BASES FOR MISCELLANEOUS BUILDING VENTILATION  
AND COOLING SYSTEMS

<u>System</u>	<u>System Function</u>	<u>Conditions Maintained</u>	<u>Safety Class</u>	<u>Seismic Category</u>
Chilled Water System	Provides continuous supply of chilled water to cooling coils for systems located in the control, auxiliary, intermediate, and turbine buildings.	Chilled water supplied at 45°F	2b	I
Industrial Cooling Water System	Operates continuously when normal power is available to provide means for rejecting reactor building and boron thermal regeneration system heat loads.	85°F maximum discharge water temperature	NNS	None
Substation Relay House Cooling System	Operates continuously to maintain relay room temperature and provide continuous exhaust of the substation battery room.	75°F	NNS	None
Non-nuclear Safety Related Chilled Water System	Operates continuously when normal power is available to supply chilled water to cooling coils for systems located in the control and intermediate buildings.	Chilled water supplied at 45°F	NNS	None

TABLE 9.4-6

REACTOR BUILDING COOLING AND FILTERING SYSTEMS  
FUNCTIONS, SAFETY CLASS AND SEISMIC CATEGORY


<u>System</u>	<u>Function</u>	<u>Safety Class</u>	<u>Seismic Category</u>
Reactor Building Cooling System	Normally: remove all reactor building heat, circulate cooled air to dome and into lower elevations. Post accident: depressurize and circulate.	2b	I'
Reactor Building Purge Supply and Exhaust System	Supply tempered air to the reactor building and exhaust reactor building atmosphere through high efficiency filters to the purge exhaust vent.	NSS (2a for purge isolation valves only)	I (plenums and purge isolation valves only)
Alternate Reactor Building Purge System	Supply filtered air to the reactor building and exhaust reactor building atmosphere through high efficiency filters to the purge exhaust vent.	NSS (2a for purge isolation valves only)	I (purge isolation valves only)
Reactor Building Charcoal Cleanup System	Filter reactor building atmosphere for pre-access cleanup.	NNS	I (fans and plenums only)
Reactor Building Reactor Compartment Cooling System	Supply cooled air to the reactor compartment with resultant air flow around the vessel, nozzles, neutron detectors, and supports.	NNS	I (fans only)
Reactor Building Secondary Compartment Cooling System	Supply cooled air to the steam generators compartments.	NNS	None
Reactor Building Refueling Water Surface System	Maintain air flow across the refueling canal surface during refueling operations.	NNS	None
Reactor Building CRDM Shroud Cooling System	Draw cooled air through the shroud for heat removal.	NNS	I
Reactor Building Elevator Machine Room System	Draw air through the machine room for heat removal.	NNS	None

SYS. OPER. DATA	
1	1700
2	1700
3	1700
4	1700
5	1700
6	1700

SAFETY CLASS VERIFICATION  
 ORIGINATED BY: [Signature]  
 REVIEWED BY: [Signature]

REV	DATE	BY	CHKD
P			


SYS. DESIGN DATA



COMPUTER ROOMS & SAS ROOM COOLING UNIT

# ANSTEC APERTURE CARD

Also Available on Aperture Card



ALL SYSTEM COMPONENTS ARE NON-NUCLEAR SAFETY, EXCEPT AS NOTED

AMENDMENT 94-10  
DECEMBER, 1994

- NOTE:
1. HEATING COIL INCLUDES OVERTEMP & LOW FLOW PROTECTIVE DEVICES.
  2. (F) INDICATES INSTR. IS FURNISHED WITH EQUIPMENT.
  3. FOR SAFETY CLASSIFICATION OF INSTR. SEE THE INSTR. LIST.
  4. EXCEPT WHERE OTHERWISE NOTED, ALL ALARMS & INDICATING LIGHTS ARE LOCATED AT THE HVAC CONTROL BOARD (CCP-6210-AH) IN THE MAIN CONTROL ROOM.
  5. COIL FACE DAMPERS FAIL OPEN AND COIL BYPASS DAMPERS FAIL CLOSED.
  6. ALL EQUIPMENT IDENTIFIED AS OR TO BE PER TRP-31.

THIS IS A NUCLEAR SAFETY RELATED DOCUMENT. REVISIONS SHALL BE NOTIFIED BY REVISIONS FROM SOUTH CAROLINA ELECTRIC & GAS COMPANY AND WRITTEN APPROVAL.

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

Building Service System Flow Diagram  
Computer Rooms and SAS Room Cooling Unit  
(Dwg. No. D-912-154 REV. 14)

Figure 9.4-5

ANSI Z39.18-1983 (Permanently Recorded) Rev. Mar 28 14 30 13 EST 1995

9506160376-13



SYSTEM OPERATING DATA		
NO.	HEATING TEMP.	CFM
1	8500	50-75
2	8500	50-75
3	14500	50-75
4	14500	50-75
5	21500	50-75
6	26000	50-75

A

B

C

D

E

F



G

H

J

K


3	8500	50-75		
2	14500	50-75		
1	48000	50-75		
4	21500	50-75		
5	26000	50-75		
NORMAL				
SYSTEM DESIGN DATA				



WATER TREATING AND HEATING & COOLING


4 ELECTRIC UNIT HEATERS  
CHEMICAL STORAGE AREA

- XHC-0050-AH 7 1/2 KW SM-28
- XHC-0041-AH 7 1/2 KW SM-28
- XHC-0045-AH 7 1/2 KW SM-28
- XHC-0044-AH 7 1/2 KW SM-28
- XHC-0046-AH 7 1/2 KW SM-28



# ANSTEC APERTURE CARD

Also Available on Aperture Card



- NOTES:-
- 1 (F) INDICATES INSTRUMENT IS FURNISHED WITH THE EQUIPMENT
  - 2 SELECTOR SWITCHES FOR LAB HOOD EXHAUST FANS ARE LOCATED ON THE RESPECTIVE HOODS.
  - 3 COMBINATION HEATING, COOLING AND THERMOSTAT LOCATED IN LAB
  - 4 FOR SAFETY CLASSIFICATION OF INSTRUMENTATION, SEE THE INSTRUMENT LIST.

ALL SYSTEM COMPONENTS ARE NON-NUCLEAR SAFETY CLASS

EA LABORATORY HEATING SYSTEM

ELECTRIC UNIT HEATERS WATER TREATING BUILDING GENERAL FLOOR AREA

XHC-0053-AH	30 KW	SM-27
XHC-0054-AH	30 KW	SM-27
XHC-0055-AH	30 KW	SM-27
XHC-0056-AH	30 KW	SM-27
XHC-0057-AH	30 KW	SM-27
XHC-0058-AH	30 KW	SM-27
XHC-0059-AH	30 KW	SM-27

DRAWING LEGIBILITY CLASS 1  
SCGEC CAD ENHANCED

AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

WATER TREATING AREA LABORATORY HEATING AND COOLING SYSTEM  
DWG. NO. D-912-153 REV. 6  
Figure 9.4-26c







9506160376-14

**SYS. OPER. DATA**

NO.	ROOM	AREA	NO. OF
1	DATA DISPLAY ROOM	1078	1
2	SHIFT SUPERVISORS OFFICE	1350	1
3	SCE&G TECHNICAL AREA	1486	1
4	NRC OFFICE	138	1
5	OPERATIONS CONF. ROOM	480	1
6	NRC CONF. ROOM	75	1
7	CORRIDOR	75	1

**SAFETY CLASS VERIFICATION**

ORIGINATED BY	J. F. [Signature]
REVIEWED BY	[Signature]




**TECHNICAL SUPPORT CENTER VENTILATION SYSTEM**



A  
B  
C  
D  
E  
F  
G  
H  
J  
K



SYSTEM DATA				
NO.	QTY	SIZE	BY	REMARKS
1	1500	15.0	4000	




**SAFETY CLASS VERIFICATION**  
 ORIGINATED BY: [Signature]  
 REVIEWED BY: [Signature]




**NOTE:**

1. LINE SPEC SHALL BE 1/2" ABOVE GROUND EXCEPT AS NOTED & SP-124-04461-001 FOR UNDERGROUND PIP.
2. PIPING TO SI NONNUCLEAR SAFETY CLASS EXCEPT AS NOTED.
3. MANUAL ACTUATION SWITCHES FOR CHARCOAL FILTER PLENUMS, DELUGE VALVES ARE LOCATED ON THE HVAC CONTROL DOWNS IN THE MAIN CONTROL PAV.
4. SIGNALS FROM ALARM VALVES (ZS) FIRE ALARM AND THROUBLE (TL) ALARM ARE ALARMED AT LOCAL PANELS AND ARE TRANSMITTED TO THE INTEGRATED FIRE & SECURITY SYSTEM (IFSS).
5. DELUGE CONTROL PANEL IS FURNISHED WITH & MOUNTED ON CHARCOAL FILTER PLENUM.



NO.	QTY	SIZE	BY	REMARKS
1	150	15.0	4000	
2	150	15.0	4000	
3	150	15.0	4000	
4	150	15.0	4000	
5	150	15.0	4000	
6	150	15.0	4000	
7	150	15.0	4000	
8	150	15.0	4000	
9	150	15.0	4000	
10	150	15.0	4000	

DESIGN DATA



DESIGN DATA






SYSTEM DATA					
NO	FORM	PHNO	BY	REMARKS	
1	ESD	SS	TC	HW	DESIGN
2	6	5	TC	SEC	
3	5	0	TC	HW	ST. CHECK

**SAFETY CLASS VERIFICATION**  
 ORIGINATED BY: J. J. C. 4/71  
 REVIEWED BY: J. A. B. 4/71

NEXT USED (H)



- NOTES:
1. LINE SPEC TO BE 152N UNLESS NOTED OTHERWISE
  2. INDIVIDUAL COMPONENTS MAY BE SHOP HYDROTESTED TO THE PRESSURE INDICATED.
  3. FIELD PRESS. TESTING OF THE COMPLETED SYS. OR PORTIONS THEREOF, SHALL BE BY PNEUMATIC TESTING AT THE PRESSURE INDICATED.
  4. ITEMS DESIGNATED WITH (F) ARE FURNISHED BY EQUIPMENT SUPPLIER.


5. ALL PIPING TO BE SAFETY CLASS 2B UNLESS OTHERWISE NOTED.

NO	REV	DATE	BY	CHK	DESCRIPTION
1	1	4/71	J. J. C.	J. A. B.	DESIGN
2	2	5/71	J. J. C.	J. A. B.	REVISED
3	3	6/71	J. J. C.	J. A. B.	REVISED
4	4	7/71	J. J. C.	J. A. B.	REVISED
5	5	8/71	J. J. C.	J. A. B.	REVISED
6	6	9/71	J. J. C.	J. A. B.	REVISED
7	7	10/71	J. J. C.	J. A. B.	REVISED
8	8	11/71	J. J. C.	J. A. B.	REVISED
9	9	12/71	J. J. C.	J. A. B.	REVISED
10	10	1/72	J. J. C.	J. A. B.	REVISED

DESIGN DATA

# ANSTEC APERTURE CARD

Also Available on Aperture Card



AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION  
PIPING SYSTEM FLOW DIAGRAM  
DIESEL GENERATOR-FUEL OIL  
(D-302-351 REV. 8)  
Figure 9.5-2

9506160376-17

(Rev. 11/84) (Rev. 1/85) (Rev. 1/86) (Rev. 1/87) (Rev. 1/88) (Rev. 1/89) (Rev. 1/90) (Rev. 1/91) (Rev. 1/92) (Rev. 1/93) (Rev. 1/94) (Rev. 1/95) (Rev. 1/96) (Rev. 1/97) (Rev. 1/98) (Rev. 1/99) (Rev. 1/00)


**SYSTEM DATA**

DESIGNED BY	DATE	BY	IN CHARGE
1. BOELEN D	10	EJA	1. PATRICIUS
2. P. A. J. A.	10	EJA	
3. BOELEN D	10	EJA	
4. 315	22	KSE	

**SAFETY CLASS VERIFICATION**

ORIGINATED BY: [Signature]

REVIEWED BY: [Signature]




**DESIGN DATA**

16	40	75	100	200	125	R/S	
17	5	1850	5	850		R/S	NOTE 6
18	0	70	0	100		R/S	NOTE 6
19	0	40	0	175		ROBKAUS	LUBE OIL
20	0	175	10	100		ROBKAUS	WATER
21	0	175	100	100		R/S	NOTE 6
22	0	175	100	100		R/S	NOTE 6
23	0	175	100	100		R/S	NOTE 6
24	0	175	100	100		R/S	NOTE 6
25	0	175	100	100		R/S	NOTE 6
26	0	175	100	100		R/S	NOTE 6
27	0	175	100	100		R/S	NOTE 6
28	0	175	100	100		R/S	NOTE 6
29	0	175	100	100		R/S	NOTE 6
30	0	175	100	100		R/S	NOTE 6
31	0	175	100	100		R/S	NOTE 6
32	0	175	100	100		R/S	NOTE 6
33	0	175	100	100		R/S	NOTE 6
34	0	175	100	100		R/S	NOTE 6
35	0	175	100	100		R/S	NOTE 6
36	0	175	100	100		R/S	NOTE 6
37	0	175	100	100		R/S	NOTE 6
38	0	175	100	100		R/S	NOTE 6
39	0	175	100	100		R/S	NOTE 6
40	0	175	100	100		R/S	NOTE 6
41	0	175	100	100		R/S	NOTE 6
42	0	175	100	100		R/S	NOTE 6
43	0	175	100	100		R/S	NOTE 6
44	0	175	100	100		R/S	NOTE 6
45	0	175	100	100		R/S	NOTE 6
46	0	175	100	100		R/S	NOTE 6
47	0	175	100	100		R/S	NOTE 6
48	0	175	100	100		R/S	NOTE 6
49	0	175	100	100		R/S	NOTE 6
50	0	175	100	100		R/S	NOTE 6
51	0	175	100	100		R/S	NOTE 6
52	0	175	100	100		R/S	NOTE 6
53	0	175	100	100		R/S	NOTE 6
54	0	175	100	100		R/S	NOTE 6
55	0	175	100	100		R/S	NOTE 6
56	0	175	100	100		R/S	NOTE 6
57	0	175	100	100		R/S	NOTE 6
58	0	175	100	100		R/S	NOTE 6
59	0	175	100	100		R/S	NOTE 6
60	0	175	100	100		R/S	NOTE 6
61	0	175	100	100		R/S	NOTE 6
62	0	175	100	100		R/S	NOTE 6
63	0	175	100	100		R/S	NOTE 6
64	0	175	100	100		R/S	NOTE 6
65	0	175	100	100		R/S	NOTE 6
66	0	175	100	100		R/S	NOTE 6
67	0	175	100	100		R/S	NOTE 6
68	0	175	100	100		R/S	NOTE 6
69	0	175	100	100		R/S	NOTE 6
70	0	175	100	100		R/S	NOTE 6
71	0	175	100	100		R/S	NOTE 6
72	0	175	100	100		R/S	NOTE 6
73	0	175	100	100		R/S	NOTE 6
74	0	175	100	100		R/S	NOTE 6
75	0	175	100	100		R/S	NOTE 6
76	0	175	100	100		R/S	NOTE 6
77	0	175	100	100		R/S	NOTE 6
78	0	175	100	100		R/S	NOTE 6
79	0	175	100	100		R/S	NOTE 6
80	0	175	100	100		R/S	NOTE 6
81	0	175	100	100		R/S	NOTE 6
82	0	175	100	100		R/S	NOTE 6
83	0	175	100	100		R/S	NOTE 6
84	0	175	100	100		R/S	NOTE 6
85	0	175	100	100		R/S	NOTE 6
86	0	175	100	100		R/S	NOTE 6
87	0	175	100	100		R/S	NOTE 6
88	0	175	100	100		R/S	NOTE 6
89	0	175	100	100		R/S	NOTE 6
90	0	175	100	100		R/S	NOTE 6
91	0	175	100	100		R/S	NOTE 6
92	0	175	100	100		R/S	NOTE 6
93	0	175	100	100		R/S	NOTE 6
94	0	175	100	100		R/S	NOTE 6
95	0	175	100	100		R/S	NOTE 6
96	0	175	100	100		R/S	NOTE 6
97	0	175	100	100		R/S	NOTE 6
98	0	175	100	100		R/S	NOTE 6
99	0	175	100	100		R/S	NOTE 6
100	0	175	100	100		R/S	NOTE 6



# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

DIESEL GENERATOR  
MISCELLANEOUS SERVICES  
D-302-353 REV. 9

Figure 9.5-11

9506160376-18



LIST OF FIGURES (Continued)

<u>Figure</u>	<u>Title</u>
10.4-7	Circulating Water Cooling
10.4-7a	Condensate Polishing
10.4-8	Condensate
10.4-8a	Condensate Polishers Kidney Loop Operation
10.4-9	Condensate - Auxiliary Condensers and Blowdown Heat Exchangers
10.4-10	Feedwater (Non-Nuclear)
10.4-11	Feedwater (Non-Nuclear)
10.4-12	Feedwater (Nuclear)
10.4-13	Steam Generator Blowdown
10.4-14	Nuclear Blowdown Processing System Holdup Tank and Demineralizers
10.4-15	Nuclear Blowdown Processing System Spent Resin Storage Tank
10.4-16	Emergency Feedwater (Nuclear)
10.4-17	Liquid Effluents from Nuclear Plant to Fairfield Penstocks

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 10 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-10 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.


<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 10-i	0	Aug. 1984	Page 10.3-12	0	Aug. 1984
10-ii	7	Aug. 1991	10.3-13	94-02	Feb. 1994
10-iii	94-02	Feb. 1994	10.3-14	6	Aug. 1990
10-iv	94-02	Feb. 1994	10.3-15	6	Aug. 1990
10-v	3	Aug. 1987	Fig. 10.3-1	94-01	Jan. 1994
10-vi	95-02	Apr. 1995	10.3-2	93-01	Jan. 1993
10-vii	95-02	Apr. 1995	10.3-3	0	Aug. 1984
10.1-1	0	Aug. 1984	10.3-4	94-02	Feb. 1994
10.1-2	0	Aug. 1984	Page 10.4-1	0	Aug. 1984
10.1-3	0	Aug. 1984	10.4-2	3	Aug. 1987
10.1-4	0	Aug. 1984	10.4-3	0	Aug. 1984
Fig. 10.1-1(1 of 2)	0	Aug. 1984	10.4-4	94-02	Feb. 1994
10.1-1(2 of 2)	0	Aug. 1984	10.4-5	0	Aug. 1984
10.1-2	0	Aug. 1984	10.4-6	0	Aug. 1984
10.1-3	0	Aug. 1984	10.4-7	0	Aug. 1984
Page 10.2-1	0	Aug. 1984	10.4-8	94-02	Feb. 1994
10.2-2	0	Aug. 1984	10.4-9	0	Aug. 1984
10.2-3	0	Aug. 1984	10.4-10	0	Aug. 1984
10.2-4	0	Aug. 1984	10.4-11	0	Aug. 1984
10.2-5	0	Aug. 1984	10.4-12	0	Aug. 1984
10.2-6	94-02	Feb. 1994	10.4-13	3	Aug. 1987
10.2-7	0	Aug. 1984	10.4-14	3	Aug. 1987
10.2-8	94-02	Feb. 1994	10.4-15	0	Aug. 1984
10.2-9	1	Aug. 1985	10.4-16	0	Aug. 1984
10.2-10	0	Aug. 1984	10.4-17	3	Aug. 1987
10.2-11	0	Aug. 1984	10.4-18	3	Aug. 1987
Fig. 10.2-1	0	Aug. 1984	10.4-18a	3	Aug. 1987
10.2-2	0	Aug. 1984	10.4-19	0	Aug. 1984
10.2-3	0	Aug. 1984	10.4-20	0	Aug. 1984
10.2-4	0	Aug. 1984	10.4-21	0	Aug. 1984
10.2-5	94-07	Aug. 1994	10.4-22	7	Aug. 1991
Page 10.3-1	0	Aug. 1984	10.4-23	2	Aug. 1986
10.3-2	0	Aug. 1984	10.4-24	1	Aug. 1985
10.3-3	0	Aug. 1984	10.4-25	0	Aug. 1985
10.3-4	6	Aug. 1990	10.4-26	94-08	Oct. 1994
10.3-5	6	Aug. 1990	10.4-26a	5	Aug. 1989
10.3-6	94-09	Nov. 1994	10.4-27	5	Aug. 1989
10.3-7	94-09	Nov. 1994	10.4-28	94-09	Nov. 1994
10.3-8	6	Aug. 1990	10.4-29	94-09	Nov. 1994
10.3-9	0	Aug. 1984	10.4-29a	5	Aug. 1989
10.3-10	0	Aug. 1984	10.4-30	91-1	Sep. 1991
10.3-11	0	Aug. 1984	10.4-30a	91-1	Sep. 1991

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 10.4-31	0	Aug. 1984	Fig. 10.4-9	93-11	Dec. 1993
10.4-31a	5	Aug. 1989	10.4-10	7	Aug. 1991
10.4-32	0	Aug. 1984	10.4-11	7	Aug. 1991
10.4-33	0	Aug. 1984	10.4-12	93-10	Dec. 1993
10.4-34	4	Aug. 1988	10.4-13	94-10	Dec. 1994
10.4-34a	4	Aug. 1988	10.4-14	95-02	Apr. 1995
10.4-35	4	Aug. 1988	10.4-15	0	Aug. 1984
10.4-36	5	Aug. 1989	10.4-16	95-02	Apr. 1995
10.4-37	5	Aug. 1989	10.4-17	93-01	Jan. 1993
10.4-38	4	Aug. 1988			
10.4-39	4	Aug. 1988			
10.4-40	0	Aug. 1984			
10.4-41	0	Aug. 1984			
10.4-42	0	Aug. 1984			
10.4-43	0	Aug. 1984			
10.4-44	0	Aug. 1984			
10.4-45	94-02	Feb. 1994			
10.4-46	94-02	Feb. 1994			
10.4-47	94-02	Feb. 1994			
10.4-48	0	Aug. 1984			
10.4-49	0	Aug. 1984			
10.4-50	0	Aug. 1984			
10.4-51	3	Aug. 1987			
10.4-52	0	Aug. 1984			
10.4-52a	3	Aug. 1987			
10.4-53	0	Aug. 1984			
10.4-54	0	Aug. 1984			
10.4-55	0	Aug. 1984			
10.4-56	0	Aug. 1984			
10.4-57	0	Aug. 1984			
10.4-58	94-09	Nov. 1994			
10.4-59	0	Aug. 1984			
10.4-60	0	Aug. 1984			
10.4-61	0	Aug. 1984			
Fig. 10.4-1	94-02	Feb. 1994			
10.4-3	94-02	Feb. 1994			
10.4-4(1 of 3)	94-02	Feb. 1994			
10.4-4(2 of 3)	94-02	Feb. 1994			
10.4-4(3 of 3)	94-02	Feb. 1994			
10.4-4a	94-02	Feb. 1994			
10.4-4b	0	Aug. 1984			
10.4-5	93-03	Mar. 1993			
10.4-6	93-01	Jan. 1993			
10.4-7	0	Aug. 1984			
10.4-7a	7	Aug. 1991			
10.4-8	94-09	Nov. 1994			
10.4-8a	6	Aug. 1990			

SYSTEM DATA			
NO.	SPN	PSID	REMARKS
1	150	150	
2	150	150	
3	250	150	
4	250	150	
5	300	150	
6	35	150	
7	40	35	

Ⓜ NEXT LETTER



NOTE: MIN HYDRO TEST TEMP 60°F

NO.	SPN	PSID	REMARKS
1	150	150	
2	150	150	
3	250	150	
4	250	150	
5	300	150	
6	35	150	
7	40	35	

DESIGN DATA





**SYSTEM DATA**

NO.	OPN	PSIG	REF	REMARKS	NOTE
1	550	18	40	SAFE SHUTDOWN WITH	2
2	550	1230	40	TRIP PUMP, HEAD STEAM	1
3	50	1230	40	TRIP TURBINE AT 1000 RPM	1
4	550	18	40	SAFE SHUTDOWN WITH	2
5	550	150	40	TRIP PUMP, HEAD STEAM	1
6	50	150	40	TURBINE AT 1000 RPM	1
7	510	18	40	SAFE SHUTDOWN WITH	2
8	510	1315	40	TRIP PUMP, HEAD STEAM	1
9	50	1315	40	TURBINE AT 1000 RPM	1
10	530	26	40	NORMAL STARTUP/SHUT-	3
11	530	230	40	DOWN WITH 2 HEAD PUMPS	1
12	530	230	40	HEAD STEAM PUMPS PRO-	1
13	575	230	40	FLOW TO 3/3 BOP	1
14	5	1428	40	SAMPLE	1
15	205	1130	40	NORMAL STARTUP/SHUT-	4

- SYSTEM DATA NOTES:**
1. CONTINUOUS MINIMUM FLOW RECIRCULATION.
  2. SUCTION PRESSURE BASED ON LEVEL IN CONDENSATE STORAGE TANK AT EF SUCTION NOZZLE.
  3. SUCTION PRESSURE BASED ON FULL CONDENSATE STORAGE TANK.
  4. REFER TO C-5.5.6 FOR PUMP DATA.
  5. DATA BASED ON TRIP PUMP AND HD EF PUMP NOT OPERATING SIMULTANEOUSLY.
  6. CONDENSATE STORAGE IS PREFERRED SOURCE OF SUCTION FOR EF PUMPS SW LOOPS PROVIDE BACKUP.
  7. ALL PIPING TO BE SAFETY CLASS 2B EXCEPT AS NOTED.

**SAFETY CLASS VERIFICATION**  
 ORIGINATED BY: J.L. Brown, spm  
 REVIEWED BY: J.L. Brown, spm

- NOTE:**
- A. TEMPORARY STRAINER FOR SYSTEM CLEAN UP TO BE REMOVED AFTER FINAL FLUSH.
  - B. SEE DNG-D-302-R1 FOR TURBINE CONTROLS.

**MOTOR DRIVEN E.F. PUMP FLOW CONTROL VALVES**

VALVE OPEN SIGNALS:  
 1. 20 AMP TO 50 LEVEL  
 2. 50VDC SIGNAL (5 PLCs)

**TURBINE DRIVEN E.F. PUMP FLOW CONTROL VALVES**



VALVE OPEN SIGNALS:  
 1. 20 AMP TO 50 LEVEL  
 2. UNDERVOLTAGE ON DIESEL ENGINE (5 PLCs)

- NOTES: DESIGN DATA**
1. ALL UPSET CONDITIONS HAVE DURATIONS OF LESS THAN 1% OF THE DESIGN LIFE OF THE SYSTEM.
  2. HYDRO TEST PRESS FOR SD IS SET BY HYDRO TEST PRESS FOR STM GEN SECONDARY SIDE BY (C).
  3. HYDRO NOT REQUIRED AS PER CODE CASE N-248

HYDROSTATIC TEST TEMP. 60 F

NO.	OPN	PSIG	REF	CL. V.	NOTE	STATUS
1	550	18	40	CL. V.	NOTE 1(1)	NORMAL
2	550	1230	40	CL. V.	NOTE 1(2)	NORMAL
3	50	1230	40	CL. V.	NOTE 1(3)	NORMAL
4	550	18	40	CL. V.	NOTE 1(4)	NORMAL
5	550	150	40	CL. V.	NOTE 1(5)	NORMAL
6	50	150	40	CL. V.	NOTE 1(6)	NORMAL
7	510	18	40	CL. V.	NOTE 1(7)	NORMAL
8	510	1315	40	CL. V.	NOTE 1(8)	NORMAL
9	50	1315	40	CL. V.	NOTE 1(9)	NORMAL
10	530	26	40	CL. V.	NOTE 1(10)	NORMAL
11	530	230	40	CL. V.	NOTE 1(11)	NORMAL
12	530	230	40	CL. V.	NOTE 1(12)	NORMAL
13	575	230	40	CL. V.	NOTE 1(13)	NORMAL
14	5	1428	40	CL. V.	NOTE 1(14)	NORMAL
15	205	1130	40	CL. V.	NOTE 1(15)	NORMAL


DESIGN DATA



1. 2/3 LD  
 2. 3/5 SD  
 3. ALL M  
 4. MDEFP  
 5. DWG

# ANSTEC APERTURE CARD

Also Available on Aperture Card



AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

PIPING SYSTEM FLOW DIAGRAM  
EMERGENCY FEEDWATER (NUCLEAR)  
(D-302-085 REV. 32)

Figure 10.4-16

9506160376-20

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 11 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-10 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 11-i	7	Aug. 1991	Page 11.2-12	3	Aug. 1987
11-ii	6	Aug. 1990	11.2-13	0	Aug. 1984
11-iii	6	Aug. 1990	11.2-14	3	Aug. 1987
11-iv	0	Aug. 1984	11.2-15	0	Aug. 1984
11-v	0	Aug. 1984	11.2-16	3	Aug. 1987
11-vi	0	Aug. 1984	11.2-17	3	Aug. 1987
11-vii	0	Aug. 1984	11.2-18	0	Aug. 1984
11-viii	0	Aug. 1984	11.2-19	3	Aug. 1987
11-ix	95-02	Apr. 1995	11.2-20	3	Aug. 1987
11-x	95-02	Apr. 1995	11.2-21	2	Aug. 1986
11-xi	95-02	Apr. 1995	11.2-22	0	Aug. 1984
11.1-1	0	Aug. 1984	11.2-23	0	Aug. 1984
11.1-2	0	Aug. 1984	11.2-24	0	Aug. 1984
11.1-3	0	Aug. 1984	11.2-25	0	Aug. 1984
11.1-4	0	Aug. 1984	11.2-26	0	Aug. 1984
11.1-5	2	Aug. 1986	11.2-27	0	Aug. 1984
11.1-6	0	Aug. 1984	11.2-28	0	Aug. 1984
11.1-7	0	Aug. 1984	11.2-29	0	Aug. 1984
11.1-8	0	Aug. 1984	11.2-30	0	Aug. 1984
11.1-9	0	Aug. 1984	11.2-31	0	Aug. 1984
11.1-10	0	Aug. 1984	11.2-32	0	Aug. 1984
11.1-11	6	Aug. 1990	11.2-33	0	Aug. 1984
11.1-12 (Deleted)	6	Aug. 1990	11.2-34	0	Aug. 1984
11.1-13	0	Aug. 1984	11.2-35	0	Aug. 1984
11.1-14	0	Aug. 1984	11.2-36	0	Aug. 1984
11.1-15	0	Aug. 1984	11.2-37	0	Aug. 1984
11.1-16	0	Aug. 1984	11.2-38	7	Aug. 1991
11.1-17	0	Aug. 1984	11.2-39	7	Aug. 1991
11.1-18	0	Aug. 1984	11.2-40	0	Aug. 1984
11.1-19	0	Aug. 1984	11.2-41	0	Aug. 1984
11.2-1	0	Aug. 1984	11.2-42	0	Aug. 1984
11.2-2	0	Aug. 1984	11.2-43	0	Aug. 1984
11.2-3	3	Aug. 1987	11.2-44	0	Aug. 1984
11.2-4	3	Aug. 1987	11.2-45	0	Aug. 1984
11.2-5	2	Aug. 1986	11.2-46	3	Aug. 1987
11.2-6	0	Aug. 1984	11.2-47	3	Aug. 1987
11.2-7	3	Aug. 1987	11.2-48	3	Aug. 1987
11.2-8	0	Aug. 1984	11.2-49	3	Aug. 1987
11.2-9	92-08	Aug. 1992	11.2-50	3	Aug. 1987
11.2-9a	5	Aug. 1989	11.2-51	3	Aug. 1987
11.2-10	5	Aug. 1989	11.2-52	3	Aug. 1987
11.2-11	0	Aug. 1984			

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 11.2-53	0	Aug. 1984	Page 11.3-26	0	Aug. 1984
11.2-54	0	Aug. 1984	11.3-27	0	Aug. 1984
11.2-55	0	Aug. 1984	11.3-28	0	Aug. 1984
11.2-56	0	Aug. 1984	11.3-29	0	Aug. 1984
11.2-57	0	Aug. 1984	11.3-30	0	Aug. 1984
11.2-58	0	Aug. 1984	11.3-31	0	Aug. 1984
11.2-59	0	Aug. 1984	11.3-32	0	Aug. 1984
11.2-60	0	Aug. 1984	11.3-33	0	Aug. 1984
11.2-61	3	Aug. 1987	11.3-34	0	Aug. 1984
11.2-62	0	Aug. 1984	11.3-35	0	Aug. 1984
11.2-63	0	Aug. 1984	11.3-36	0	Aug. 1984
11.2-64	0	Aug. 1984	11.3-37	0	Aug. 1984
11.2-65	0	Aug. 1984	Fig. 11.3-1	0	Aug. 1984
11.2-66	0	Aug. 1984	11.3-2	0	Aug. 1984
11.2-67	0	Aug. 1984	11.3-3	0	Aug. 1984
11.2-68	0	Aug. 1984	11.3-4(1 of 3)	94-02	Feb. 1994
Fig. 11.2-1	0	Aug. 1984	11.3-4(2 of 3)	7	Aug. 1991
11.2-2(1 of 5)	94-08	Oct. 1994	11.3-4(3 of 3)	93-04	Apr. 1993
11.2-2(2 of 5)	95-02	Apr. 1995	11.3-5	0	Aug. 1984
11.2-2(3 of 5)	95-02	Apr. 1995	11.3-6	0	Aug. 1984
11.2-2(4 of 5)	91-1	Sep. 1991	11.3-7	0	Aug. 1984
11.2-2(5 of 5)	91-1	Sep. 1991	11.3-8	0	Aug. 1984
11.2-3	0	Aug. 1984	Page 11.4-1	0	Aug. 1984
11.2-4	0	Aug. 1984	11.4-2	0	Aug. 1984
Page 11.3-1	0	Aug. 1984	11.4-3	0	Aug. 1984
11.3-2	2	Aug. 1986	11.4-4	0	Aug. 1984
11.3-3	0	Aug. 1984	11.4-5	0	Aug. 1984
11.3-4	0	Aug. 1984	11.4-6	0	Aug. 1984
11.3-5	0	Aug. 1984	11.4-7	0	Aug. 1984
11.3-6	0	Aug. 1984	11.4-8	0	Aug. 1984
11.3-7	2	Aug. 1986	11.4-9	0	Aug. 1984
11.3-8	2	Aug. 1986	11.4-10	0	Aug. 1984
11.3-9	0	Aug. 1984	11.4-11	0	Aug. 1984
11.3-10	0	Aug. 1984	11.4-12	0	Aug. 1984
11.3-11	0	Aug. 1984	11.4-13	0	Aug. 1984
11.3-12	93-10	Dec. 1993	11.4-14	0	Aug. 1984
11.3-13	0	Aug. 1984	11.4-15	0	Aug. 1984
11.3-14	0	Aug. 1984	11.4-16	0	Aug. 1984
11.3-15	0	Aug. 1984	11.4-17	0	Aug. 1984
11.3-16	0	Aug. 1984	11.4-18	0	Aug. 1984
11.3-17	0	Aug. 1984	Fig. 11.4-1	0	Aug. 1984
11.3-18	0	Aug. 1984	11.4-2	0	Aug. 1984
11.3-19	0	Aug. 1984	Page 11.5-1	6	Aug. 1990
11.3-20	2	Aug. 1986	11.5-2	6	Aug. 1990
11.3-21	0	Aug. 1984	11.5-3	6	Aug. 1990
11.3-22	0	Aug. 1984	11.5-4	6	Aug. 1990
11.3-23	0	Aug. 1984	11.5-5	6	Aug. 1990
11.3-24	0	Aug. 1984	11.5-6	6	Aug. 1990
11.3-25	0	Aug. 1984			

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 11.5-7	6	Aug. 1990			
11.5-8	6	Aug. 1990			
11.5-9	6	Aug. 1990			
11.5-10	6	Aug. 1990			
11.5-11	94-10	Dec. 1994			
11.5-12	6 (Corr)	Aug. 1990			
11.5-13	6	Aug. 1990			
11.5-14	6	Aug. 1990			
11.5-15	94-09	Nov. 1994			
11.5-16	0	Aug. 1984			
11.5-17	0	Aug. 1984			
11.5-18	0	Aug. 1984			
11.5-19	0	Aug. 1984			
11.5-20	0	Aug. 1984			
11.5-21	0	Aug. 1984			
11.5-22	0	Aug. 1984			
11.5-23	0	Aug. 1984			
11.5-24	0	Aug. 1984			
Fig. 11.5-1	0	Aug. 1984			
Page 11.6-1	0	Aug. 1984			
11.7-1	93-10	Dec. 1993			



### 11.5.6 STORAGE

Compactable waste, filled containers of compacted waste, and spent filter cartridges are stored in the shielded areas of the radwaste area or in a location determined by the Manager of Health Physics and Radwaste Services. Contaminated hardware and tools may also be stored in these rooms. Solidified waste, after solidification is complete, and dewatered resins, once dewatering is complete, may be shipped off-site for immediate burial at a licensed facility. Primary spent resins will normally have at least a one month decay period while being held in the spent resin storage tank. Evaporator bottoms and secondary blowdown resins do not normally require a decay period.

If solidified waste and/or dewatered resins require storage for any reason, they will be stored in the radiation control area outside the truck access on the storage pad (see Figure 1.2-25) or in a location determined by the Manager of Health Physics and Radwaste Services. The storage pad is approximately 40 feet wide by 120 feet long and is sloped toward a hold-up trench. Waste stored in the storage area will be shielded as required by portable shields and/or casks used for shipment.

Storage areas for solidified waste, dewatered resins, and compacted waste are sufficient, based on the estimates presented in Section 11.5.4, to accommodate greater than 30 days waste generation.

### 11.5.7 SHIPMENT

Shipment, in accordance with applicable regulations, is made as necessary--dependent upon operational considerations and storage area availability.

The primary activity determination method will be to sample the waste stream (resins and liquid waste) during transfer to a process container and analyze the sample using the appropriate counting instrumentation. An isotopic determination is made of the radionuclides present and the activity of each. Summation of the individual activities is used to calculate the Curie content of the processed container.

For cases where the primary method cannot be used, an alternate technique will be implemented. The alternate method entails using the dose rate of the packaged waste in order to calculate the Curie content. The calculation considers the waste characteristics, geometry of the waste package, characteristics of the container and solidification media (if applicable), and the average gamma energy. For spent cartridge filters, this alternate method will be used to determine the Curie content. The appropriate counting instrumentation is used to analyze samples taken from the process stream to identify radionuclides present and the average gamma energy.

## 11.5.8 POTENTIAL FOR RELEASES

### 11.5.8.1 Potential for Release during Container Filling

The filling operation may be terminated via visual inspection using a remote monitor/television camera. Termination is accomplished by closing valves MOV-2 and MOV-5.

There is no airborne release to the atmosphere in the fill areas. Air in the container and gas, if any, from the waste entering the container are vented to the building exhaust, through a local filter, or through a portable ventilation unit. Only one line feeds waste to the container. This is flushed with water as the final phase of the fill cycle.

If leaks of any kind or spills are observed, the operation in progress can be immediately terminated. Any spill which may occur will be contained by permanent curbing in the solidification area.

Except for the curb in the solidification area, there are no physical barriers in the immediate fill areas to contain spills. Spills from the shipping container would need to be drained to a specific location or container as determined by the type of material spilled.

The floor surfaces have a special nonporous finish to permit decontamination of the surface, if required.

### 11.5.8.2 Potential for Release from Storage Tanks

#### 11.5.8.2.1 Waste Evaporator Concentrates Tank


Essentially all radioactive gases are stripped from the concentrates in the waste evaporator. A normally closed vent is ducted to the auxiliary building exhaust system. A water seal, set for 2 feet of water, vents to the waste evaporator concentrates tank cubicle which is serviced by the auxiliary building exhaust system.

Overflow is not anticipated since waste evaporator concentrates tank capacity is sufficient for storage of the expected volume of concentrates generated by one year of normal operation. However, an overflow is directed to the waste holdup tank. Level indicators actuate alarms at the solid waste system control panel prior to tank overflow.

Floor drains in the cubicles for this tank and for the waste evaporator concentrates tank transfer pump drain to the floor drain tank. By appropriate valving, the concentrates can be pumped from the floor drain tank to either the waste holdup tank, waste evaporator, waste evaporator concentrates tank, or directly to the drumming station area for solidification.

#### 11.5.8.2.2 Chemical Drain Tank

This tank is vented to the building exhaust system. A high level alarm is provided on the solid waste system control panel. Overflow, or leakage, if it occurs, is directed to the auxiliary building sump by a floor drain. The




8 STANDP/WATER HYDRANT W/ WASTE HOLD UP TA CALLED TO HIGH LEVEL POINT

6	5	100	140	175	210	245
8	110	150	190	230	270	310
10	120	160	200	240	280	320
12	130	170	210	250	290	330
14	140	180	220	260	300	340
16	150	190	230	270	310	350
18	160	200	240	280	320	360
20	170	210	250	290	330	370
22	180	220	260	300	340	380
24	190	230	270	310	350	390
26	200	240	280	320	360	400
28	210	250	290	330	370	410
30	220	260	300	340	380	420
32	230	270	310	350	390	430
34	240	280	320	360	400	440
36	250	290	330	370	410	450
38	260	300	340	380	420	460
40	270	310	350	390	430	470
42	280	320	360	400	440	480
44	290	330	370	410	450	490
46	300	340	380	420	460	500
48	310	350	390	430	470	510
50	320	360	400	440	480	520
52	330	370	410	450	490	530
54	340	380	420	460	500	540
56	350	390	430	470	510	550
58	360	400	440	480	520	560
60	370	410	450	490	530	570
62	380	420	460	500	540	580
64	390	430	470	510	550	590
66	400	440	480	520	560	600
68	410	450	490	530	570	610
70	420	460	500	540	580	620
72	430	470	510	550	590	630
74	440	480	520	560	600	640
76	450	490	530	570	610	650
78	460	500	540	580	620	660
80	470	510	550	590	630	670
82	480	520	560	600	640	680
84	490	530	570	610	650	690
86	500	540	580	620	660	700
88	510	550	590	630	670	710
90	520	560	600	640	680	720
92	530	570	610	650	690	730
94	540	580	620	660	700	740
96	550	590	630	670	710	750
98	560	600	640	680	720	760
100	570	610	650	690	730	770
102	580	620	660	700	740	780
104	590	630	670	710	750	790
106	600	640	680	720	760	800
108	610	650	690	730	770	810
110	620	660	700	740	780	820
112	630	670	710	750	790	830
114	640	680	720	760	800	840
116	650	690	730	770	810	850
118	660	700	740	780	820	860
120	670	710	750	790	830	870
122	680	720	760	800	840	880
124	690	730	770	810	850	890
126	700	740	780	820	860	900
128	710	750	790	830	870	910
130	720	760	800	840	880	920
132	730	770	810	850	890	930
134	740	780	820	860	900	940
136	750	790	830	870	910	950
138	760	800	840	880	920	960
140	770	810	850	890	930	970
142	780	820	860	900	940	980
144	790	830	870	910	950	990
146	800	840	880	920	960	1000
148	810	850	890	930	970	
150	820	860	900	940	980	
152	830	870	910	950	990	
154	840	880	920	960	1000	
156	850	890	930	970		
158	860	900	940	980		
160	870	910	950	990		
162	880	920	960	1000		
164	890	930	970			
166	900	940	980			
168	910	950	990			
170	920	960	1000			
172	930	970				
174	940	980				
176	950	990				
178	960	1000				
180	970					
182	980					
184	990					
186	1000					
188						
190						
192						
194						
196						
198						
200						

DESIGN DATA

# ANSTEC APERTURE CARD

Also Available on Aperture Card



- NOTE:-
1. THIS DRAWING IS BASED UPON THE 1440077, SHEET 2 OF 6, REVISION 14 ("ALL WORK") OF THE WASTE EVAPORATOR CONDENSATE TANK SYSTEM. THE USER IS SOLELY RESPONSIBLE FOR THE ACCURACY AND RELIABILITY OF THE DESIGN INFORMATION PROVIDED BY THIS DRAWING.
  2. FOR ALTERNATE MATERIALS, SEE THE 1-30-80, PLAN NUMBER SYSTEM.
  3. REFER TO THE 1-30-80, PLAN NUMBER SYSTEM.
  4. FOR CONSTRUCTION PIPE SPECIFICATIONS, SEE THE PREPARATION OF 1-30-80-01, PLAN NO. 1-30-80-01, WHICH IS THE BASIS FOR THE DESIGN OF THIS SYSTEM.
  5. SYSTEM AND COMPONENT NAMES AS SHOWN ON THIS DRAWING HAVE BEEN ENCLASSED TO THE QUALITY RELATED AS COVERED BY QAP-1.
  6. LOOP SIZE TO EXCEED 12" BORE AND 4000 PSI.
  7. LOOP SIZE TO EXCEED 12" BORE OVERHEAD CONNECTION ON OTHER LOOP TO EXCEED 4" BORE DIAPHRAGM FLANGE OR TO TOP OF TANK FOR SAME TYPICAL DIAPHRAGM.
  8. FOR METALS REGARDING LINE SIZE AND NUMBER OF CONNECTIONS, REFER TO REQUIREMENTS ON THE DRAWING.
  9. VERIFY THESE VALUES AS CHECKED BY THE USER.
  10. CONNECTION LOCATED NEAR TANK BOTTOM TO PREVENT SLUR INTRUSION OR ENTRAPMENT.
  11. LOOP SIZE TO EXCEED 12" BORE TO ALLOW FOR QUALITY RELATED WASTE EVAPORATOR.
  12. WASTE SAMPLE LINE TO BE PLACED LINE FOR REPRESENTATIVE SAMPLE.
  13. SYSTEM SHOULD BE DESIGNED TO BE SAFE.
  14. WASTE GAS LINES HAVING THE POTENTIAL OF CAPSIVE CONSTRUCTION GAS INTRUSION SHALL BE MECHANICALLY SUPPORTED.

AMENDMENT 95-02  
APRIL, 1995

THIS IS A  
NUCLEAR SAFETY RELATED  
DRAWING. NO CHANGES SHALL BE  
MADE WITHOUT THE WRITTEN APPROVAL  
OF THE DESIGNER.


SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

---

WASTE PROCESSING  
E-302-736 REV. 11  
Figure 11.2-2 SHT. 2 OF 5

9506160376-21

1440077-1 (REV. 11) (SHEET 2 OF 6) (REV. 14) (ALL WORK)




NO.	1712	1713
TYPE	MP	MP
SYMBOL	MP	MP
DESCRIPTION	MP	MP

VALVE NUMBERING

NO.	137	140	142	144	146	148	150
SIZE	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"	1/2"
TYPE	MP	MP	MP	MP	MP	MP	MP
DESCRIPTION	MP	MP	MP	MP	MP	MP	MP


DESIGN DATA





# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



- NOTES
- THIS DRAWING IS BASED UPON DWG. 114E077, SHEET 3 OF 6, REVISION 14 FROM DRAWING OF WESTINGHOUSE ELECTRIC CORPORATION NUCLEAR ENERGY SYSTEMS DIVISION. THE USER IS SOLELY RESPONSIBLE FOR THE ACCURACY OF THE RELIABILITY OF THE DESIGN INFORMATION SET FORTH IN THIS DRAWING.
  - FOR ALPHA REFERENCES SEE ENCL. E-302-737-P.1 DIAGRAM LEGEND.
  - POSITION VALVE TO LEFT PUMP HEAD.
  - FOR CONVENTIONAL PIPING SPECIFICATIONS, SEE SAJ SPECIFICATION SP-071-444-NE PAGE 27. WESTINGHOUSE PIPE CLASSIFICATION TO ENGINEER'S PIPE LINE SPECIFICATION.
  - INSTRUMENTS SPARED IN PLACE BY 48-0771.
  - SYSTEMS AND COMPONENTS MARKED AS "P" HAVE BEEN DECLASSIFIED TO QUALITY RELATED AS COVERED BY 09P-1.
  - LOOP SEAL TO EXTEND 12" BELOW AND ABOVE PIPE.
  - BERNARDY ON SPENT RESIN STORAGE TANK CIRCUIT.
  - TANK FURNISHED WITH 50" Ø" ON COUPLING SPANNER CONNECTING TO BE PIPED IN FIELD.
  - LEAK-OFF LOOP TO EXTEND 50" BELOW OVERFLOW CONNECTOR AND UPPER LOOP TO TOP OF TANK.
  - USE 50 PPM BOND IN LINE FROM SPENT RESIN STORAGE TANK TO DRUMMING ROOM, CONTINUOUSLY SLOPE LINE.
  - CHIPPED TEE IS TO PROVIDE A STRAIGHT PATH FOR ROSSING IF THE PIPE SHOULD IT BECOME CLOGGED WITH RESIN.
  - LOCATE THIS VALVE CLOSE TO THE H<sub>2</sub> SUPPLY.
  - SPONGE-BREATH LOCK-TEE TOP OF TANK LOOP.
  - DRUMMING ROOM HEADERS AT HIGHEST ELEVATION WITH RESPECT TO RESIN LINE. RESIN LINE MUST NOT CONTAIN LUMP BALLS.
  - LOCATE SAMPLE LINE CLOSE TO PROCESS LINE FOR REPRESENTATIVE SAMPLE.

AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION

WASTE PROCESSING  
E-302-737 REV. 10  
Figure 11.2-2 SHT. 3 OF 5

9506160376-22

LIST OF EFFECTIVE PAGES (LEP)

The following list delineates pages to Chapter 12 of the Virgil C. Summer Nuclear Station Final Safety Analysis Report which are currently in effect. The latest changes to pages and figures are indicated below by Amendment 94-10 in the Amendment column along with the amendment number and date for each page and figure included in the Final Safety Analysis Report.

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 12-i	0	Aug. 1984	Page 12.1-32	0	Aug. 1984
12-ii	0	Aug. 1984	12.1-33	0	Aug. 1984
12-iii	0	Aug. 1984	12.1-34	0	Aug. 1984
12-iv	3	Aug. 1987	12.1-35	0	Aug. 1984
12-v	0	Aug. 1984	12.1-36	0	Aug. 1984
12-vi	0	Aug. 1984	12.1-37	0	Aug. 1984
12-vii	93-01	Jan. 1993	12.1-38	0	Aug. 1984
12-viii	0	Aug. 1984	12.1-39	0	Aug. 1984
12-ix	94-01	Jan. 1994	12.1-40	0	Aug. 1984
12-x	95-02	Apr. 1995	12.1-41	0	Aug. 1984
12-xi	95-02	Apr. 1995	12.1-42	0	Aug. 1984
Page 12.1-1	0	Aug. 1984	12.1-43	0	Aug. 1984
12.1-2	94-01	Jan. 1994	12.1-44	0	Aug. 1984
12.1-3	0	Aug. 1984	12.1-45	0	Aug. 1984
12.1-4	0	Aug. 1984	12.1-46	0	Aug. 1984
12.1-5	0	Aug. 1984	12.1-47	0	Aug. 1984
12.1-6	0	Aug. 1984	12.1-48	0	Aug. 1984
12.1-7	0	Aug. 1984	12.1-49	0	Aug. 1984
12.1-8	0	Aug. 1984	12.1-50	0	Aug. 1984
12.1-9	0	Aug. 1984	12.1-51	0	Aug. 1984
12.1-10	0	Aug. 1984	12.1-52	0	Aug. 1984
12.1-11	0	Aug. 1984	12.1-53	0	Aug. 1984
12.1-12	0	Aug. 1984	12.1-54	0	Aug. 1984
12.1-13	0	Aug. 1984	12.1-55	0	Aug. 1984
12.1-14	0	Aug. 1984	12.1-56	0	Aug. 1984
12.1-15	0	Aug. 1984	12.1-57	0	Aug. 1984
12.1-16	0	Aug. 1984	12.1-58	0	Aug. 1984
12.1-17	2	Aug. 1986	12.1-59	0	Aug. 1984
12.1-18	2	Aug. 1986	12.1-60	0	Aug. 1984
12.1-19	0	Aug. 1984	12.1-61	0	Aug. 1984
12.1-20	0	Aug. 1984	12.1-62	0	Aug. 1984
12.1-21	0	Aug. 1984	12.1-63	0	Aug. 1984
12.1-22	0	Aug. 1984	12.1-64	0	Aug. 1984
12.1-23	93-01	Jan. 1993	12.1-65	0	Aug. 1984
12.1-24	93-01	Jan. 1993	12.1-66	0	Aug. 1984
12.1-25	94-01	Jan. 1994	12.1-67	0	Aug. 1984
12.1-26	0	Aug. 1984	12.1-68	0	Aug. 1984
12.1-27	0	Aug. 1984	12.1-69	0	Aug. 1984
12.1-28	0	Aug. 1984	12.1-70	3	Aug. 1987
12.1-29	3	Aug. 1987	12.1-71	0	Aug. 1984
12.1-30	0	Aug. 1984	12.1-72	0	Aug. 1984
12.1-31	0	Aug. 1984	Fig. 12.1-1	2	Aug. 1986

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>	<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Fig. 12.1-2	2	Aug. 1986	Fig. 12.2-2	0	Aug. 1984
12.1-2a	2	Aug. 1986	12.2-3	0	Aug. 1984
12.1-3	2	Aug. 1986	12.2-4	0	Aug. 1984
12.1-4	2	Aug. 1986	Page 12.3-1	94-01	Jan. 1994
12.1-5(1 of 2)	93-10	Dec. 1993	12.3-2	94-01	Jan. 1994
12.1-5(2 of 2)	3	Aug. 1987	12.3-3	94-01	Jan. 1994
12.1-6	93-10	Dec. 1993	12.3-4	94-01	Jan. 1994
12.1-7	5	Aug. 1989	12.3-5	94-01	Jan. 1994
12.1-8	2	Aug. 1986	12.3-6	94-01	Jan. 1994
12.1-9	5	Aug. 1989	12.3-7	94-01	Jan. 1994
12.1-10	2	Aug. 1986	12.3-8	94-01	Jan. 1994
12.1-11	2	Aug. 1986	12.3-9	94-01	Jan. 1994
12.1-11a	2	Aug. 1986	12.3-10	94-01	Jan. 1994
12.1-12	2	Aug. 1986	12.3-11	94-01	Jan. 1994
12.1-13	2	Aug. 1986	12.3-12	94-01	Jan. 1994
12.1-14	93-10	Dec. 1993	12.3-13	94-01	Jan. 1994
12.1-15	93-10	Dec. 1993	12.3-14	94-01	Jan. 1994
12.1-16	5	Aug. 1989	12.3-14a	94-01	Jan. 1994
12.1-17	2	Aug. 1986	12.3-15	94-01	Jan. 1994
12.1-18	5	Aug. 1989	12.3-16	94-01	Jan. 1994
12.1-19	95-02	Apr. 1995	12.3-17	94-01	Jan. 1994
12.1-19a	5	Aug. 1989	12.3-18	94-01	Jan. 1994
12.1-20	0	Aug. 1984	12.3-19	2	Aug. 1986
12.1-21	0	Aug. 1984	12.3-20	0	Aug. 1984
12.1-22	0	Aug. 1984	Fig. 12.3-1	94-01	Jan. 1994
Page 12.2-1	0	Aug. 1984	Page 12A-1	0	Aug. 1984
12.2-2	0	Aug. 1984	12A-2	0	Aug. 1984
12.2-3	0	Aug. 1984	12A-3	0	Aug. 1984
12.2-4	0	Aug. 1984	12A-4	0	Aug. 1984
12.2-5	95-02	Apr. 1995	12A-5	0	Aug. 1984
12.2-6	0	Aug. 1984	12A-6	0	Aug. 1984
12.2-7	0	Aug. 1984	12A-7	0	Aug. 1984
12.2-8	0	Aug. 1984	12A-8	0	Aug. 1984
12.2-9	0	Aug. 1984	12A-9	0	Aug. 1984
12.2-10	0	Aug. 1984	12A-10	0	Aug. 1984
12.2-11	0	Aug. 1984	12A-11	0	Aug. 1984
12.2-12	0	Aug. 1984	12A-12	0	Aug. 1984
12.2-13	0	Aug. 1984	12A-13	0	Aug. 1984
12.2-14	0	Aug. 1984	12A-14	0	Aug. 1984
12.2-15	0	Aug. 1984	12A-15	0	Aug. 1984
12.2-16	0	Aug. 1984	12A-16	0	Aug. 1984
12.2-17	0	Aug. 1984	12A-17	0	Aug. 1984
12.2-18	0	Aug. 1984	12A-18	0	Aug. 1984
12.2-19	0	Aug. 1984	12A-19	0	Aug. 1984
12.2-20	0	Aug. 1984	12A-20	0	Aug. 1984
12.2-21	0	Aug. 1984	12A-21	0	Aug. 1984
12.2-22	0	Aug. 1984	12A-22	0	Aug. 1984
12.2-23	0	Aug. 1984	12A-23	0	Aug. 1984
12.2-24	0	Aug. 1984	12A-24	0	Aug. 1984
Fig. 12.2-1	0	Aug. 1984	12A-25	0	Aug. 1984
			12A-26	0	Aug. 1984

LIST OF EFFECTIVE PAGES (Cont'd)

<u>Page/Fig. No.</u>	<u>Amend. No.</u>	<u>Date</u>
Page 12A-27	0	Aug. 1984
12A-28	2	Aug. 1986
12A-29	0	Aug. 1984
12A-30	0	Aug. 1984
12A-31	0	Aug. 1984
12A-32	6	Aug. 1990
Fig. 12A.4-1	2	Aug. 1985
12A.4-2	2	Aug. 1986
12A.4-3	2	Aug. 1986
12A.4-4	3	Aug. 1987
12A.4-5	93-10	Dec. 1993
12A.4-6	5	Aug. 1989
12A.4-7	95-02	Apr. 1995
12A.4-8	2	Aug. 1986

In the control complex, the sampling room could be considered as a source of airborne activity. This air is monitored for airborne activity as discussed in Section 12.2.4.2.7.

Periodic surveillance of accessible areas, in accordance with Sections 12.1.5 and 12.3.2, will be performed.

Reliable power for the fixed instrumentation is obtained from the diesel backed, 120 volt instrument buses. Associated sample pumps obtain power from the 480 volt diesel backed buses. This assures continuity of operation in the event of a loss of offsite power. Measured activity levels are indicated and recorded on the radiation monitoring system control panel located in the control room. Local indication is provided for each channel. A differential pressure switch is provided on the particulate and iodine collection filter holders to cause an alarm on filter blockage.

Another differential pressure switch is provided across the two filter holders (except on RMA-4) to cause an alarm on loss of flow. The loss of flow alarm for RMA-4 originates from the flow indication device (photohelic). The movable monitors have local indication, recording and alarms. Detectors have remotely actuated check sources to provide functional verification. In addition, each channel is calibrated routinely by exposure to a calibrated source traceable either directly or indirectly to NBS for verification against its initial calibration. Calibration of the monitors is performed following any required maintenance of the detectors. Measurements have an accuracy of  $\pm 25$  percent of the true value. Precision is  $\pm 15$  percent at all levels. Each ratemeter is equipped with two adjustable alarm levels (alert and high) and a channel failure/or loss of power alarm. These alarms, associated with the fixed monitors, are annunciated on the radiation monitoring system control panel in the control room. Channels which have interlock functions with other systems (see Figure 11.4-1) are provided with a bypass switch for use during maintenance or testing. Use of this switch is annunciated.

#### 12.2.4.2.1 Control Room Supply Air, Channel RM-A1

This channel monitors the particulate, iodine and gaseous activity of air supplied to the control room. A sample of air is taken from the air supply duct through an isokinetic sampler nozzle and is drawn successively through a particulate sampler, an iodine sampler, and a gas sampler. The particulate sampler is equipped with a fixed filter which is continuously monitored by a lead shielded scintillator detector. The iodine sampler is similar to the particulate sampler except that an activated charcoal cartridge is used instead of a fixed filter. The fixed filter and the charcoal filter are designed to be removable for laboratory analysis. The sensitive volume of the gas sampler is shielded with lead and monitored by a scintillation detector. The approximate sensitivity and range of this channel are as follows:

1. Particulate,  $10^{-11}$  to  $10^{-7}$   $\mu\text{Ci/cc}$  based upon Cs-137.
2. Gas,  $2 \times 10^{-6}$  to  $2 \times 10^{-2}$   $\mu\text{Ci/cc}$  based upon Kr-85.
3. Iodine,  $3 \times 10^{-11}$  to  $10^{-7}$   $\mu\text{Ci/cc}$  based upon I-131.



A high activity alarm from the gas channel automatically places the control room, computer room, relay room and instrument repair room ventilation systems in the recirculation mode, starts the control room emergency ventilation system and closes the outside air dampers. The iodine and particulate channels provide high activity alarms to alert operating personnel. The high alarm setpoints are established on the basis of the requirements of 10 CFR 20 and the sensitivity of the detection channels.

#### 12.2.4.2.2 Reactor Building Air Sample Line, Channel RM-A2

This channel monitors the particulate, iodine and gaseous activity level of the air inside the reactor building and is located inside the auxiliary building. Reactor building air drawn from and returned through reactor building penetrations is monitored by RM-A2. The readout of the monitor is used to detect leaks in systems containing primary coolant. Channel ranges are similar to those of Channel RM-A1. The sensitivity of this monitor provides the capability to detect 10-MPC-hours of particulate and iodine radioactivity.

The monitor air sample and return lines are isolated (closed) upon occurrence of a containment isolation signal (Phase A). Post accident, this monitor can be used as a reactor building air sampling station, provided that reactor building pressure and temperature have been reduced sufficiently to allow opening of the sample line isolation valves. This monitor is also designed to withstand seismic conditions as recommended by Regulatory Guide 1.45.

The monitor design is similar to that of RM-A1, except that a moving particulate filter is used. An additional sample pump is also provided to allow operation when one pump is undergoing maintenance.

A high activity alarm from the gas channel initiates closure of the reactor building purge valves (see Figure 11.4-1).

High alarm setpoints are based upon plant operating requirements, sensitivity and measured normal background. The particulate alarm setpoints may be readjusted as a function of primary coolant activity, leakages or plant conditions.


A fixed alarm setpoint is not applicable to particulate radiation monitoring for reactor coolant leak detection. The activity of the reactor coolant and background radiation must be taken into consideration.

The particulate channel of radiation monitor RM-A2 will be operated with an initial setpoint of not less than twice background and may subsequently be readjusted based upon the results of periodic analysis of reactor coolant activity.


This setpoint is expressed as follows:

$$* [(B_1) + (C_1 R_1 K_1)] \geq \text{Setpoint} \geq 2B_1^* \quad \text{Eq. 12.2-1}$$

\*This setpoint may be adjusted greater than this expression to compensate for high containment equilibrium activity but no more than twice the operational equilibrium (same for in gas channel).



H.V.C. Control Room  
Floor EL 465 C



- TECHNICAL SUPPORT CENTER COMMUNICATION SYSTEMS**
- ① INDICATED LINE WITH SPEAKER
  - ② PLANT PHONE
  - ③ PLANT PHONE WITH PRGM. TWO WAY RADIO
  - ④ ALL DEDICATED LINES WITH SPEAKER
  - ⑤ PRIVATE BELL LINES
  - ⑥ INTER.COM - CONTROL ROOM TO TECH SUPPORT CENTER
  - ⑦ INTER.COM - OPERATIONAL SUPPORT CENTER TO TECH SUPPORT CENTER
  - ⑧ INTER.COM - CONTROL ROOM TO OPERATIONAL SUPPORT CENTER
  - ⑨ PRIVATE BELL LINES WITH SPEAKER
  - ⑩ ALL DEDICATED LINES

**CONTROL ROOM EQUIPMENT LIST**

NO.	GROUP NO.	SPRY	DESCRIPTION
1	SCP 1058	ANS	COMPUTER OPERATOR CONSOLE
2	SCP 1060	ANS	INSTRUMENT SYS. CONTROL CONSOLE
3	SCP 1060	RE	MAIN CONTROL BOARD
4	SCP 1060	ANS	PLANT SERVICE PANEL
5	SCP 1071	RE	NUCLEAR INSTRUMENT SYS. CONTROL CONSOLE 1
6	SCP 1071	RE	NUCLEAR INSTRUMENT SYS. CONTROL CONSOLE 2
7	SCP 1071	RE	NUCLEAR INSTRUMENT SYS. CONTROL CONSOLE 3
8	SCP 1074	RE	NUCLEAR INSTRUMENT SYS. CONTROL CONSOLE 4
9	SCP 1074	ANS	RADIATION MONITORING SYSTEM PANEL
10	SCP 1074	RE	H.V.C. CONTROL BOARD
11	SCP 1070	ANS	TEMP. SCANNING SYS. CONTROL PANEL
12	SCP 1070	ANS	TEMP. SCANNING SYS. CONTROL PANEL


**CONTROL ROOM EQUIPMENT LIST**

NO.	GROUP NO.	SPRY	DESCRIPTION
13	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
14	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
15	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
16	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
17	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
18	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
19	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT
20	SCP 1065	ANS	PLANT SAFETY STATUS DISPLAY CRT

CONTROL ROOM  
Floor EL 465 C

# ANSTEC APERTURE CARD

Also Available on Aperture Card




TECHNICAL SUPPORT CENTER INSTRUMENT, COMPUTER & RELAY RM EQUIPMENT LIST


ITEM NO.	EQUIP. NO.	DESCRIPTION
1	SPN7001	PROCESS I.E.C. BACK PROT. SUPPLY
2	SPN7002	PROCESS I.E.C. BACK PROT. SUPPLY
3	SPN7003	PROCESS I.E.C. BACK PROT. SUPPLY
4	SPN7004	PROCESS I.E.C. BACK PROT. SUPPLY
5	SPN7005	PROCESS I.E.C. BACK PROT. SUPPLY
6	SPN7006	PROCESS I.E.C. BACK PROT. SUPPLY
7	SPN7007	PROCESS I.E.C. BACK PROT. SUPPLY
8	SPN7008	PROCESS I.E.C. BACK PROT. SUPPLY
9	SPN7009	PROCESS I.E.C. BACK PROT. SUPPLY
10	SPN7010	PROCESS I.E.C. BACK PROT. SUPPLY
11	SPN7011	PROCESS I.E.C. BACK PROT. SUPPLY
12	SPN7012	PROCESS I.E.C. BACK PROT. SUPPLY
13	SPN7013	PROCESS I.E.C. BACK PROT. SUPPLY
14	SPN7014	PROCESS I.E.C. BACK PROT. SUPPLY
15	SPN7015	PROCESS I.E.C. BACK PROT. SUPPLY
16	SPN7016	PROCESS I.E.C. BACK PROT. SUPPLY
17	SPN7017	PROCESS I.E.C. BACK PROT. SUPPLY
18	SPN7018	PROCESS I.E.C. BACK PROT. SUPPLY
19	SPN7019	PROCESS I.E.C. BACK PROT. SUPPLY
20	SPN7020	PROCESS I.E.C. BACK PROT. SUPPLY
21	SPN7021	PROCESS I.E.C. BACK PROT. SUPPLY
22	SPN7022	PROCESS I.E.C. BACK PROT. SUPPLY
23	SPN7023	PROCESS I.E.C. BACK PROT. SUPPLY
24	SPN7024	PROCESS I.E.C. BACK PROT. SUPPLY
25	SPN7025	PROCESS I.E.C. BACK PROT. SUPPLY
26	SPN7026	PROCESS I.E.C. BACK PROT. SUPPLY
27	SPN7027	PROCESS I.E.C. BACK PROT. SUPPLY
28	SPN7028	PROCESS I.E.C. BACK PROT. SUPPLY
29	SPN7029	PROCESS I.E.C. BACK PROT. SUPPLY
30	SPN7030	PROCESS I.E.C. BACK PROT. SUPPLY
31	SPN7031	PROCESS I.E.C. BACK PROT. SUPPLY
32	SPN7032	PROCESS I.E.C. BACK PROT. SUPPLY
33	SPN7033	PROCESS I.E.C. BACK PROT. SUPPLY
34	SPN7034	PROCESS I.E.C. BACK PROT. SUPPLY
35	SPN7035	PROCESS I.E.C. BACK PROT. SUPPLY
36	SPN7036	PROCESS I.E.C. BACK PROT. SUPPLY
37	SPN7037	PROCESS I.E.C. BACK PROT. SUPPLY
38	SPN7038	PROCESS I.E.C. BACK PROT. SUPPLY
39	SPN7039	PROCESS I.E.C. BACK PROT. SUPPLY
40	SPN7040	PROCESS I.E.C. BACK PROT. SUPPLY
41	SPN7041	PROCESS I.E.C. BACK PROT. SUPPLY
42	SPN7042	PROCESS I.E.C. BACK PROT. SUPPLY
43	SPN7043	PROCESS I.E.C. BACK PROT. SUPPLY
44	SPN7044	PROCESS I.E.C. BACK PROT. SUPPLY
45	SPN7045	PROCESS I.E.C. BACK PROT. SUPPLY
46	SPN7046	PROCESS I.E.C. BACK PROT. SUPPLY
47	SPN7047	PROCESS I.E.C. BACK PROT. SUPPLY
48	SPN7048	PROCESS I.E.C. BACK PROT. SUPPLY
49	SPN7049	PROCESS I.E.C. BACK PROT. SUPPLY
50	SPN7050	PROCESS I.E.C. BACK PROT. SUPPLY
51	SPN7051	PROCESS I.E.C. BACK PROT. SUPPLY
52	SPN7052	PROCESS I.E.C. BACK PROT. SUPPLY
53	SPN7053	PROCESS I.E.C. BACK PROT. SUPPLY
54	SPN7054	PROCESS I.E.C. BACK PROT. SUPPLY
55	SPN7055	PROCESS I.E.C. BACK PROT. SUPPLY
56	SPN7056	PROCESS I.E.C. BACK PROT. SUPPLY
57	SPN7057	PROCESS I.E.C. BACK PROT. SUPPLY
58	SPN7058	PROCESS I.E.C. BACK PROT. SUPPLY
59	SPN7059	PROCESS I.E.C. BACK PROT. SUPPLY
60	SPN7060	PROCESS I.E.C. BACK PROT. SUPPLY
61	SPN7061	PROCESS I.E.C. BACK PROT. SUPPLY
62	SPN7062	PROCESS I.E.C. BACK PROT. SUPPLY
63	SPN7063	PROCESS I.E.C. BACK PROT. SUPPLY
64	SPN7064	PROCESS I.E.C. BACK PROT. SUPPLY
65	SPN7065	PROCESS I.E.C. BACK PROT. SUPPLY
66	SPN7066	PROCESS I.E.C. BACK PROT. SUPPLY
67	SPN7067	PROCESS I.E.C. BACK PROT. SUPPLY
68	SPN7068	PROCESS I.E.C. BACK PROT. SUPPLY
69	SPN7069	PROCESS I.E.C. BACK PROT. SUPPLY
70	SPN7070	PROCESS I.E.C. BACK PROT. SUPPLY
71	SPN7071	PROCESS I.E.C. BACK PROT. SUPPLY
72	SPN7072	PROCESS I.E.C. BACK PROT. SUPPLY
73	SPN7073	PROCESS I.E.C. BACK PROT. SUPPLY
74	SPN7074	PROCESS I.E.C. BACK PROT. SUPPLY
75	SPN7075	PROCESS I.E.C. BACK PROT. SUPPLY
76	SPN7076	PROCESS I.E.C. BACK PROT. SUPPLY
77	SPN7077	PROCESS I.E.C. BACK PROT. SUPPLY
78	SPN7078	PROCESS I.E.C. BACK PROT. SUPPLY
79	SPN7079	PROCESS I.E.C. BACK PROT. SUPPLY
80	SPN7080	PROCESS I.E.C. BACK PROT. SUPPLY
81	SPN7081	PROCESS I.E.C. BACK PROT. SUPPLY
82	SPN7082	PROCESS I.E.C. BACK PROT. SUPPLY
83	SPN7083	PROCESS I.E.C. BACK PROT. SUPPLY
84	SPN7084	PROCESS I.E.C. BACK PROT. SUPPLY
85	SPN7085	PROCESS I.E.C. BACK PROT. SUPPLY
86	SPN7086	PROCESS I.E.C. BACK PROT. SUPPLY
87	SPN7087	PROCESS I.E.C. BACK PROT. SUPPLY
88	SPN7088	PROCESS I.E.C. BACK PROT. SUPPLY
89	SPN7089	PROCESS I.E.C. BACK PROT. SUPPLY
90	SPN7090	PROCESS I.E.C. BACK PROT. SUPPLY
91	SPN7091	PROCESS I.E.C. BACK PROT. SUPPLY
92	SPN7092	PROCESS I.E.C. BACK PROT. SUPPLY
93	SPN7093	PROCESS I.E.C. BACK PROT. SUPPLY
94	SPN7094	PROCESS I.E.C. BACK PROT. SUPPLY
95	SPN7095	PROCESS I.E.C. BACK PROT. SUPPLY
96	SPN7096	PROCESS I.E.C. BACK PROT. SUPPLY
97	SPN7097	PROCESS I.E.C. BACK PROT. SUPPLY
98	SPN7098	PROCESS I.E.C. BACK PROT. SUPPLY
99	SPN7099	PROCESS I.E.C. BACK PROT. SUPPLY
100	SPN7100	PROCESS I.E.C. BACK PROT. SUPPLY

SOUTH CAROLINA ELECTRIC & GAS CO.  
 VIRGE C. SUMNER NUCLEAR STATION  
 PLANT LAYOUT CONTROL COMPLEX  
 PLAN AT EL. 412'-0", 436'-0",  
 463'-0", AND 482'-0"  
 E-005-001 REV. 38  
 Figure 12.1-19

0506160376-23



HVAC Equipment Floor EL 463.0



- TECHNICAL SUPPORT CENTER COMMUNICATION SYSTEMS**
- ① PHONE/DEDICATED LINE WITH SPEAKER
  - ② PLANT PHONE
  - ③ TWO WAY RADIO
  - ④ ALL DEDICATED LINES WITH SPEC. GR.
  - ⑤ PRIVATE BELL LINES
  - ⑥ INTERCOM - CONTROL ROOM TO TECH SUPPORT CENTER
  - ⑦ INTERCOM - OPERATIONAL SUPPORT CENTER TO TECH SUPPORT CENTER
  - ⑧ INTERCOM - CONTROL ROOM TO OPERATIONAL SUPPORT CENTER
  - ⑨ PRIVATE BELL LINES WITH SPEAKER
  - ⑩ ALL DEDICATED LINES

**CONTROL ROOM EQUIPMENT LIST**

UNIT	COUP NO.	DATE	DESCRIPTION
1	SEP 1028	18	COMPUTER OPERATOR CONSOLE
2	SEP 1030	18	INTEGRATED INSTRUMENTATION & LOGGING SYS
3	SEP 1030	18	INSTRUMENT CONTROL BOARD
4	SEP 1030	18	PLANT SERVICE PANEL
5	SEP 1031	18	NUCLEAR INSTRUMENTATION SYS CONSOLE CHAN I
6	SEP 1032	18	NUCLEAR INSTRUMENTATION SYS CONSOLE CHAN II
7	SEP 1034	18	NUCLEAR INSTRUMENTATION SYS CONSOLE CHAN III
8	SEP 1035	18	REACTOR MONITORING SYSTEM PANEL
9	SEP 1036	18	INSTRUMENTATION SYS CONSOLE CHAN IV
10	SEP 1037	18	INSTRUMENTATION SYS CONSOLE CHAN V
11	SEP 1038	18	INSTRUMENTATION SYS CONSOLE CHAN VI
12	SEP 1039	18	INSTRUMENTATION SYS CONSOLE CHAN VII
13	SEP 1040	18	INSTRUMENTATION SYS CONSOLE CHAN VIII
14	SEP 1041	18	INSTRUMENTATION SYS CONSOLE CHAN IX
15	SEP 1042	18	INSTRUMENTATION SYS CONSOLE CHAN X
16	SEP 1043	18	INSTRUMENTATION SYS CONSOLE CHAN XI
17	SEP 1044	18	INSTRUMENTATION SYS CONSOLE CHAN XII
18	SEP 1045	18	INSTRUMENTATION SYS CONSOLE CHAN XIII
19	SEP 1046	18	INSTRUMENTATION SYS CONSOLE CHAN XIV
20	SEP 1047	18	INSTRUMENTATION SYS CONSOLE CHAN XV
21	SEP 1048	18	INSTRUMENTATION SYS CONSOLE CHAN XVI
22	SEP 1049	18	INSTRUMENTATION SYS CONSOLE CHAN XVII
23	SEP 1050	18	INSTRUMENTATION SYS CONSOLE CHAN XVIII
24	SEP 1051	18	INSTRUMENTATION SYS CONSOLE CHAN XIX
25	SEP 1052	18	INSTRUMENTATION SYS CONSOLE CHAN XX


**CONTROL ROOM EQUIPMENT LIST**

UNIT	COUP NO.	DATE	DESCRIPTION
1	SEP 1053	18	INSTRUMENTATION SYS CONSOLE CHAN XXI
2	SEP 1054	18	INSTRUMENTATION SYS CONSOLE CHAN XXII
3	SEP 1055	18	INSTRUMENTATION SYS CONSOLE CHAN XXIII
4	SEP 1056	18	INSTRUMENTATION SYS CONSOLE CHAN XXIV
5	SEP 1057	18	INSTRUMENTATION SYS CONSOLE CHAN XXV
6	SEP 1058	18	INSTRUMENTATION SYS CONSOLE CHAN XXVI
7	SEP 1059	18	INSTRUMENTATION SYS CONSOLE CHAN XXVII
8	SEP 1060	18	INSTRUMENTATION SYS CONSOLE CHAN XXVIII
9	SEP 1061	18	INSTRUMENTATION SYS CONSOLE CHAN XXIX
10	SEP 1062	18	INSTRUMENTATION SYS CONSOLE CHAN XXX
11	SEP 1063	18	INSTRUMENTATION SYS CONSOLE CHAN XXXI
12	SEP 1064	18	INSTRUMENTATION SYS CONSOLE CHAN XXXII
13	SEP 1065	18	INSTRUMENTATION SYS CONSOLE CHAN XXXIII
14	SEP 1066	18	INSTRUMENTATION SYS CONSOLE CHAN XXXIV
15	SEP 1067	18	INSTRUMENTATION SYS CONSOLE CHAN XXXV
16	SEP 1068	18	INSTRUMENTATION SYS CONSOLE CHAN XXXVI
17	SEP 1069	18	INSTRUMENTATION SYS CONSOLE CHAN XXXVII
18	SEP 1070	18	INSTRUMENTATION SYS CONSOLE CHAN XXXVIII
19	SEP 1071	18	INSTRUMENTATION SYS CONSOLE CHAN XXXIX
20	SEP 1072	18	INSTRUMENTATION SYS CONSOLE CHAN XL
21	SEP 1073	18	INSTRUMENTATION SYS CONSOLE CHAN XLI
22	SEP 1074	18	INSTRUMENTATION SYS CONSOLE CHAN XLII
23	SEP 1075	18	INSTRUMENTATION SYS CONSOLE CHAN XLIII
24	SEP 1076	18	INSTRUMENTATION SYS CONSOLE CHAN XLIV
25	SEP 1077	18	INSTRUMENTATION SYS CONSOLE CHAN XLV
26	SEP 1078	18	INSTRUMENTATION SYS CONSOLE CHAN XLVI
27	SEP 1079	18	INSTRUMENTATION SYS CONSOLE CHAN XLVII
28	SEP 1080	18	INSTRUMENTATION SYS CONSOLE CHAN XLVIII
29	SEP 1081	18	INSTRUMENTATION SYS CONSOLE CHAN XLIX
30	SEP 1082	18	INSTRUMENTATION SYS CONSOLE CHAN L



# ANSTEC APERTURE CARD

Also Available on  
Aperture Card



### TECHNICAL SUPPORT CENTER INSTRUMENT, COMPUTER & RELAY RM EQUIPMENT LIST

ITEM NO.	EQUIP. NO.	QTY.	DESCRIPTION
1	SPN7003	10	PROCESS IEC BACK PROF. SET 3
2	SPN7004	10	PROCESS IEC BACK PROF. SET 2
3	SPN7001	10	PROCESS IEC BACK PROF. SET 1
4	SPN7005	10	PROCESS IEC BACK PROF. SET 4
5	SPN7006	10	PROCESS IEC BACK CONT. GWP 1
6	SPN7007	10	PROCESS IEC BACK CONT. GWP 2
7	SPN7008	10	PROCESS IEC BACK CONT. GWP 3
8	SPN7009	10	PROCESS IEC BACK CONT. GWP 4
9	SPN7010	10	PROCESS IEC BACK CONT. GWP 5
10	SPN7011	10	PROCESS IEC BACK CONT. GWP 6
11	SPN7012	10	PROCESS IEC BACK CONT. GWP 7
12	SPN7013	10	PROCESS IEC BACK CONT. GWP 8
13	SPN7014	10	PROCESS IEC BACK CONT. GWP 9
14	SPN7015	10	PROCESS IEC BACK CONT. GWP 10
15	SPN7016	10	PROCESS IEC BACK CONT. GWP 11
16	SPN7017	10	PROCESS IEC BACK CONT. GWP 12
17	SPN7018	10	PROCESS IEC BACK CONT. GWP 13
18	SPN7019	10	PROCESS IEC BACK CONT. GWP 14
19	SPN7020	10	PROCESS IEC BACK CONT. GWP 15
20	SPN7021	10	PROCESS IEC BACK CONT. GWP 16
21	SPN7022	10	PROCESS IEC BACK CONT. GWP 17
22	SPN7023	10	PROCESS IEC BACK CONT. GWP 18
23	SPN7024	10	PROCESS IEC BACK CONT. GWP 19
24	SPN7025	10	PROCESS IEC BACK CONT. GWP 20
25	SPN7026	10	PROCESS IEC BACK CONT. GWP 21
26	SPN7027	10	PROCESS IEC BACK CONT. GWP 22
27	SPN7028	10	PROCESS IEC BACK CONT. GWP 23
28	SPN7029	10	PROCESS IEC BACK CONT. GWP 24
29	SPN7030	10	PROCESS IEC BACK CONT. GWP 25
30	SPN7031	10	PROCESS IEC BACK CONT. GWP 26
31	SPN7032	10	PROCESS IEC BACK CONT. GWP 27
32	SPN7033	10	PROCESS IEC BACK CONT. GWP 28
33	SPN7034	10	PROCESS IEC BACK CONT. GWP 29
34	SPN7035	10	PROCESS IEC BACK CONT. GWP 30
35	SPN7036	10	PROCESS IEC BACK CONT. GWP 31
36	SPN7037	10	PROCESS IEC BACK CONT. GWP 32
37	SPN7038	10	PROCESS IEC BACK CONT. GWP 33
38	SPN7039	10	PROCESS IEC BACK CONT. GWP 34
39	SPN7040	10	PROCESS IEC BACK CONT. GWP 35
40	SPN7041	10	PROCESS IEC BACK CONT. GWP 36
41	SPN7042	10	PROCESS IEC BACK CONT. GWP 37
42	SPN7043	10	PROCESS IEC BACK CONT. GWP 38
43	SPN7044	10	PROCESS IEC BACK CONT. GWP 39
44	SPN7045	10	PROCESS IEC BACK CONT. GWP 40
45	SPN7046	10	PROCESS IEC BACK CONT. GWP 41
46	SPN7047	10	PROCESS IEC BACK CONT. GWP 42
47	SPN7048	10	PROCESS IEC BACK CONT. GWP 43
48	SPN7049	10	PROCESS IEC BACK CONT. GWP 44
49	SPN7050	10	PROCESS IEC BACK CONT. GWP 45
50	SPN7051	10	PROCESS IEC BACK CONT. GWP 46
51	SPN7052	10	PROCESS IEC BACK CONT. GWP 47
52	SPN7053	10	PROCESS IEC BACK CONT. GWP 48
53	SPN7054	10	PROCESS IEC BACK CONT. GWP 49
54	SPN7055	10	PROCESS IEC BACK CONT. GWP 50
55	SPN7056	10	PROCESS IEC BACK CONT. GWP 51
56	SPN7057	10	PROCESS IEC BACK CONT. GWP 52
57	SPN7058	10	PROCESS IEC BACK CONT. GWP 53
58	SPN7059	10	PROCESS IEC BACK CONT. GWP 54
59	SPN7060	10	PROCESS IEC BACK CONT. GWP 55
60	SPN7061	10	PROCESS IEC BACK CONT. GWP 56
61	SPN7062	10	PROCESS IEC BACK CONT. GWP 57
62	SPN7063	10	PROCESS IEC BACK CONT. GWP 58
63	SPN7064	10	PROCESS IEC BACK CONT. GWP 59
64	SPN7065	10	PROCESS IEC BACK CONT. GWP 60
65	SPN7066	10	PROCESS IEC BACK CONT. GWP 61
66	SPN7067	10	PROCESS IEC BACK CONT. GWP 62
67	SPN7068	10	PROCESS IEC BACK CONT. GWP 63
68	SPN7069	10	PROCESS IEC BACK CONT. GWP 64
69	SPN7070	10	PROCESS IEC BACK CONT. GWP 65
70	SPN7071	10	PROCESS IEC BACK CONT. GWP 66
71	SPN7072	10	PROCESS IEC BACK CONT. GWP 67
72	SPN7073	10	PROCESS IEC BACK CONT. GWP 68
73	SPN7074	10	PROCESS IEC BACK CONT. GWP 69
74	SPN7075	10	PROCESS IEC BACK CONT. GWP 70
75	SPN7076	10	PROCESS IEC BACK CONT. GWP 71
76	SPN7077	10	PROCESS IEC BACK CONT. GWP 72
77	SPN7078	10	PROCESS IEC BACK CONT. GWP 73
78	SPN7079	10	PROCESS IEC BACK CONT. GWP 74
79	SPN7080	10	PROCESS IEC BACK CONT. GWP 75
80	SPN7081	10	PROCESS IEC BACK CONT. GWP 76
81	SPN7082	10	PROCESS IEC BACK CONT. GWP 77
82	SPN7083	10	PROCESS IEC BACK CONT. GWP 78
83	SPN7084	10	PROCESS IEC BACK CONT. GWP 79
84	SPN7085	10	PROCESS IEC BACK CONT. GWP 80
85	SPN7086	10	PROCESS IEC BACK CONT. GWP 81
86	SPN7087	10	PROCESS IEC BACK CONT. GWP 82
87	SPN7088	10	PROCESS IEC BACK CONT. GWP 83
88	SPN7089	10	PROCESS IEC BACK CONT. GWP 84
89	SPN7090	10	PROCESS IEC BACK CONT. GWP 85
90	SPN7091	10	PROCESS IEC BACK CONT. GWP 86
91	SPN7092	10	PROCESS IEC BACK CONT. GWP 87
92	SPN7093	10	PROCESS IEC BACK CONT. GWP 88
93	SPN7094	10	PROCESS IEC BACK CONT. GWP 89
94	SPN7095	10	PROCESS IEC BACK CONT. GWP 90
95	SPN7096	10	PROCESS IEC BACK CONT. GWP 91
96	SPN7097	10	PROCESS IEC BACK CONT. GWP 92
97	SPN7098	10	PROCESS IEC BACK CONT. GWP 93
98	SPN7099	10	PROCESS IEC BACK CONT. GWP 94
99	SPN7100	10	PROCESS IEC BACK CONT. GWP 95
100	SPN7101	10	PROCESS IEC BACK CONT. GWP 96
101	SPN7102	10	PROCESS IEC BACK CONT. GWP 97
102	SPN7103	10	PROCESS IEC BACK CONT. GWP 98
103	SPN7104	10	PROCESS IEC BACK CONT. GWP 99
104	SPN7105	10	PROCESS IEC BACK CONT. GWP 100

AMENDMENT 95-02  
APRIL, 1995

SOUTH CAROLINA ELECTRIC & GAS CO.  
VIRGIL C. SUMMER NUCLEAR STATION  
PLANT LAYOUT CONTROL COMPLEX  
PLAN AT ELEVATIONS 412'-0", 436'-0",  
463'-0" & 482'-0"  
E-005-001 REV. 38  
Figure 12A.4-7

(Copyright) by ANSTEC (Anstec) Inc. 11/83 of EOT 1995

940610376-24