



**ENTERGY**

Entergy Operations, Inc.  
P.O. Box 3  
Kilgus LA 70066  
Tel: 504 739-6774

R. F. Burski  
11/11/91  
11/11/91  
11/11/91

W3F191-0676  
A1.05  
QA

December 11, 1991

U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Subject: Waterford 3 SES  
Docket No. 50-382  
License No. NPF-38  
Comments on Preliminary "Accident Sequence Precursor  
Program Cold Shutdown Analysis" for Waterford 3

Gentlemen:

In response to the November 29, 1991 letter from David L. Wigginton to  
Ross P. Barkhurst, the Attachment provides our comments on the subject  
preliminary report, which addresses the July 14, 1986 loss of shutdown cooling event  
that occurred at Waterford 3.

We wish to express our appreciation for the opportunity given to provide our  
comments on this preliminary report. Should you have any questions on our  
comments or need additional information, please contact Roy Prados at  
(504) 739-6632.

Very truly yours,

RFB/RWP/ssf

Attachment

cc: R.D. Martin, NRC Region IV  
D.L. Wigginton, NRC-NRR  
N.S. Reynolds  
R.B. McGehee  
NRC Resident Inspectors Office

9112190257 911211  
PDR ADOCK 050C0382  
PDR

11/11/91

Comments On Preliminary "Accident Sequence Precursor Program Cold Shutdown  
Event Analysis" For Waterford 3

1. Page A-232, Event Description, Par. 1 - The elevation of the centerline of the hot legs is 13' 4 1/2", not 107'.
2. Page A-232, Event Description, Par. 1 and elsewhere as applicable - Refueling water storage tank (RWST) should be refueling water storage pool (RWSP).
3. Page A-235, Par. 3 - The charging pumps are characterized as providing unborated water injection. Although the charging pumps can inject unborated water, they are normally aligned to take suction from a borated source of water.
4. Page A-235, Item b - The assumption was made that only one LPSI pump was available since the other LPSI pump cavitated while taking suction from the R/S hot leg. However, it is highly likely that this LPSI pump could also have been recovered by switching suction to the RWSP. In addition, the charging pumps could inject borated water which would as a minimum delay the time for core uncover (if not prevent core uncover).
5. Page A-235, Analysis Approach - The analysis does not credit continued makeup for core cooling success because the RCS was closed. However, with no decay heat removal, RCS pressure would increase due to boiling in the core until the low temperature overpressure protection (LTOP) relief valves would open at approximately 430 psia. Operators would respond to this loss of inventory according to their procedures by injecting with the HPSI pump. Thus, a once through cooling path would be established with feed by HPSI injection and bleed by the LTOP relief valves. The LTOP relief valves discharge to the containment sump which would allow recirculation using the HPSI pump if the refueling water storage pool empties. Although flow might be intermittent as cool water injected to the core would stop the boiling and would reduce RCS pressure causing the relief valve to reseal, adequate core cooling would be provided. Thus, an additional system failure would be necessary, given failure of RHR recovery and steam generator heat removal, to reach core damage. This could reduce the conditional core damage probability by at least an order of magnitude or two.
6. Page A-236, Item c - The failure probability given to RHR recovery does not seem to reflect the considerable amount of time available to recover RHR before core damage would occur. Filling the RCS to a higher level than mid-loop using the HPSI or LPSI pumps would considerably delay core uncover by increasing liquid heat capacity and aid recovery efforts by compressing the vapor bubble in the LPSI pump suction line. These potential actions do not appear to have been considered.

7. Page A-236, Item d - In addition to the Emergency Feedwater pumps, Waterford 3 has a motor driven Auxiliary Feedwater pump that is also capable of providing water to the steam generators for makeup. It is not clear if this alternate and diverse makeup path is considered in the failure probability for steam generator cooling.
8. Page A-238 - The centerline elevation of the loop seal in the shutdown cooling suction piping is 23', not 22'. The bottom of the RWSP is at elevation -4'.
9. Page A-236, Analysis Results - The first sentence should read "The estimated conditional core damage probability associated with the loss of RCS level and RHR cooling for the July 14, 1986, Waterford 3 event is (new number as a result of comments)."