

2.0 OPERATING LIMITS

The cycle-specific parameter limits for the specifications listed in Section 1.0 are presented in the subsections which follow. These limits have been developed using the NRC-approved methodologies specified in Technical Specification 6.9.1.9.

2.1 Moderator Temperature Coefficient  
(Specification 3.1.1.3)

- 2.1.1 The Moderator Temperature Coefficient shall be less positive than the limits shown in Figure 1. These limits shall be referred to as the Beginning of Cycle Life (BOL) Limit.

The Moderator Temperature Coefficient shall be less negative than ~~-21~~ pcm/°F. This limit shall be referred to as the End of Cycle Life (EOL) Limit.  
-49.3

- 2.1.2 The MTC 300 ppm surveillance limit is ~~21~~ pcm/°F (all rods withdrawn, Rated Thermal Power condition).  
-41.8