

S-4

Approval <i>W. Brumby</i>	Vogtle Electric Generating Plant NUCLEAR OPERATIONS	Procedure No. 11882-1
Date 12-1-89	Unit <u>1</u> '95 JUL 27 P.C. 58 Georgia Power	Revision No. 15
		Page No. of 29 1 of 29

OFFICE OF SECRETARY
DOCKETING & SERVICE
BRANCH

OUTSIDE AREAS ROUNDS SHEETS

1.0 PURPOSE

To provide checklists for performing shift rounds of plant-Outside Areas:

2.0 INSTRUCTION

2.1 Complete checklists similar to Figure 1.

2.2 Contact the USS and OSOS each shift prior to starting rounds for any items to be checked. The USS/OSOS should list items below.

	D	N
<i>N-SCW PVMP 1ST. Today</i>		
<i>1 A DG air receiver checks every 2 hrs.</i>		

WORKING COPY
APR 30 1990

NUCLEAR REGULATORY COMMISSION
Docket No. 50-424/425-OLA-3 EXHIBIT NO. *Staff 4*
In the matter of Georgia Power Co. et al., Vogtle Units 1 & 2
 Staff Applicant Intervenor Other
 Identified Received Rejected
Date *7/20/95* Witness *Mosbaugh* Reporter *KHW*

9508100352 950720
PDR ADDCK 05000424
G PDR

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 1 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.	
					DAY	NIGHT		
NORTH MS AND FW VALVE ROOM	TIME	XXX	XXX	XXX	0829	2003		
	GENERAL INSPECTION	XXX	XXX	XXX	NTW	RW		
MDAFW PUMP A	OIL LEVELS	PUMP	BOTTLES	XXX	XXX	NTW	RW	
		MOTOR	SIGHT GLASS	XXX	XXX	NTW	RW	
	VERIFY SUCTION AND DISCHARGE PIPING NOT HOT TO TOUCH		XXX	XXX	XXX	NTW	RW	
	GENERAL INSPECTION		XXX	XXX	XXX	NTW	RW	
	MDAFW PUMP B	OIL LEVELS	PUMP	BOTTLES	XXX	XXX	NTW	RW
MOTOR			SIGHT GLASS	XXX	XXX	NTW	RW	
VERIFY SUCTION AND DISCHARGE PIPING NOT HOT TO TOUCH		XXX	XXX	XXX	NTW	RW		
GENERAL INSPECTION		XXX	XXX	XXX	NTW	RW		
CST's		NO. 2 LEVEL (%)	1-LI-511*	100	69	97	95%	
	NO. 1 LEVEL (%)	1-LI-5100	100	69	96	96%		
	CST DEGASIFIER CONTROL PANEL	XXX	XXX	XXX	XXX	(RW)	IN	
	MOAT WATER LEVEL NOT INCREASING	XXX	BELOW GRILL	XXX	XXX	RW		
	SUMP PUMP WATER LEVEL NORMAL AND NO TRASH IN PUMP ROOM	XXX	XXX	XXX	XXX	NTW	RW	
			XXX	XXX	XXX	NTW	RW	
			XXX	XXX	XXX	NTW	RW	

COMMENTS: ^{IN} Degasifier pressure alarm is in, Also one pump (MO1) oil level is low, other two pumps - MO2 & MO3 - oil level is below bottom of sight glass & MO1 & MO3 are running.

Figure 1

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.	
					DAY	NIGHT		
IDAFW	LAMP TEST (1) PANEL 1-1302 P5-AFT (TERRY TURBINE PANEL)	PANEL	XXX	XXX	WTW	RW		
	T&T VALVE OPEN (LIGHT ON)	PANEL	XXX	XXX	ON	RW		
	T&T VALVE OPERATOR OPEN - (LIGHT ON)	PANEL	XXX	XXX	ON	RW		
	RESET LINKAGE (LIGHT OFF)	PANEL	XXX	XXX	OFF	RW		
	AUX FEEDWATER TURBINE DRIVEN PANEL (SHUTDOWN PANEL C) GENERAL INSPECTION	PANEL	XXX	XXX	WTW	RW		
	OIL LEVELS	TURBINE	SIGHT GLASS	XXX	XXX	< 1/2	RW	
		PUMP	BOTTLES	XXX	XXX	WTW	RW	
	VERIFY SUCTION AND DISCHARGE PIPING NOT HOT TO TOUCH	XXX	XXX	XXX	WTW	RW		
	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW		
	DC FUEL OIL STORAGE AREA	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	1
FUEL OIL TANK LEVEL TRAIN A (%)		1-LIS-9022	100	80	93%	93%		
FUEL OIL TANK LEVEL TRAIN B (%)		1-LIS-9023	100	80	97%	96%		

(1) NOTIFY CONTROL ROOM BEFORE TESTING ALARMS.

COMMENTS: ① B train side has water in pipe pit, and in Rm., o.c sock
cloth being used to absorb water needs changing.
A-TRAIN Drum full of water, needs to be removed.

VOGTLE ELECTRIC GENERATING PLANT ✓

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
DIESEL GENERATOR A	TIME	XXX	XXX	XXX	0720	1934	
	REMOVE ACCUMULATED DUST FROM CONTROL PANELS (SUNDAY ONLY)	XXX	XXX	XXX	N/A	N/A	
	FUEL OIL DAY TANK GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	LUBE OIL KEEP WARM STRAINER DP (PSID)	1-PDI-9090	20	0	<3	0	
	LUBE OIL KEEP WARM FILTER DP (PSID)	1-PDI-9094	20(4)	0	3	3	
	DIESEL GEN A LUBE OIL KEEP WARM PMP PRESS (PSIG)	1-PI-19145	50	25	28.5	30	
	DIESEL GEN A JACKET WATER KEEP WARM PMP PRESS (PSIG)	1-PI-19124	25	15	18.8	19	
	DIESEL GEN A JACKET WATER LEVEL (%)	1-LI-5741	98	90	98%	98%	
	D/G LUBE OIL SUMP LEVEL	DIP STICK	HIGH	LOW	-1 MAX STATIC	RW	
	GOVERNOR OIL LEVEL	SIGHT GLASS	FULL	HALF FULL	Full	RW	
	480V AC MCC LNBI GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	480V AC MCC LNBC GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	AIR COMPRESSOR NO. 2 POWER ON	XXX	XXX	XXX	(RW)	RW	1
	AIR COMPRESSOR NO. 1 POWER ON	XXX	XXX	XXX	RW	RW	
	STARTING AIR COMPRESSORS GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	AIR RECEIVERS AND AIR DRYERS BLOWDOWN, UNTIL MOISTURE FREE	XXX	XXX	XXX	XXX	RW	

4) INITIATE AN WRT IF FILTER DP IS GREATER THAN 15 PSID; IF GREATER THAN 20 PSID, CONTACT PLANT ENGINEER TO DETERMINE IF D/G SHOULD BE DECLARED INOPERABLE.

COMMENTS: (1) off due to clearance 1-9000531

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
DG A (CONT'D)	480V AC MCC LABY GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
ENGINE CONTROL PANEL PDC2	STARTING AIR BANK PRESSURE (PSIG)	RIGHT LEFT	1-PI-9052 1-PI-9056	250 250	225 225	236 238	238 1
	CONTROL AIR PRESSURE (PSIG)		1-PI-19174	62	58	61 61	
	UNIT AVAILABLE - BLUE LIGHT ON	PANEL	XXX	XXX	NO	RW=Yes	1
	THERMOCOUPLE SELECTOR, SELECT AND RECORD THE FOLLOWING:	PANEL	XXX	XXX	XXX	XXX	
	LUBRICATING OIL IN - POS. 19 (°F)	PANEL		170	142	164	159
	LUBRICATING OIL OUT - POS. 20 (°F)	PANEL		170	142	164	155
	JACKET WATER IN - POS. 21 (°F)	PANEL		170	142	169	172
	JACKET WATER OUT - POS. 22 (°F)	PANEL		170	142	166	168
	DAY TANK LEVEL	1-LI-19192	FULL	5/8 FULL	XXX	Full	
	NO ALARMS	PANEL	XXX	XXX	RW	RW	2, 4 ^B
	ALARM TEST	PANEL	XXX	XXX	XXX	RW	
GENERATOR CONTROL PANEL PDC1	LOCAL/REMOTE SWITCH, REMOTE POSITION	1-HS-4516	XXX	XXX	Remote	Remote	
	LOCKOUT RELAYS RESET POSITION	186A 186B 186C	PANEL PANEL PANEL	XXX XXX XXX	XXX XXX XXX	RW RW RW	
	VOLTAGE REGULATOR IN AUTO	PANEL	XXX	XXX	RW	RW	
	DIESEL GENERATOR GENERA. INSPECTION	XXX	XXX	XXX	RW	RW	3

COMMENTS: ① Due to compressor being tagged out.
 ② Disple how press starting air, switch not in auto, (Due to clearance on compressor)
 Low High Day tank level, ③ moisture in gauges. 19180, 19170, 19120
 19478 Figure 1 (Cont'd) DATE APR 30 1990
 4^B - Low or High level Day Tank Alarm is in

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 5 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
DIESEL GENERATOR B	TIME	XXX	XXX	XXX	0738	1942	
	REMOVE ACCUMULATED DUST FROM CONTROL PANELS (SUNDAY ONLY)	XXX	XXX	XXX	N/A	N/A	
	FUEL OIL DAY TANK GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	LUBE OIL KEEP WARM STRAINER DP (PSID)	1-PDI-9091	20	0	23	0	
	LUBE OIL KEEP WARM FILTER DP (PSID)	1-PDI-9095	20(4)	0	3	3	
	DIESEL GEN B LUBE OIL KEEP WARM PMP PRESS (PSIG)	1-PI-19152	50	23	27	27	
	DIESEL GEN B JACKET WATER KEEP WARM PMP PRESS (PSIG)	1-PI-19134	25	15	19.8	20	
	DIESEL GEN B JACKET WATER LEVEL (%)	1-LI-5742	98	90	94%	94%	
	D/G LUBE OIL SUMP LEVEL	DIP STICK	HIGH	LOW	-1" max static	RW	
	GOVERNOR OIL LEVEL	SIGHT GLASS	FULL	HALF FULL	Full	RW	
	480V AC MCC LNBO GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	480V AC MCC LNBO GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	AIR COMPRESSOR NO. 2 POWER ON	XXX	XXX	XXX	RW	RW	
	AIR COMPRESSOR NO. 1 POWER ON	XXX	XXX	XXX	RW	RW	
	STARTING AIR COMPRESSORS GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	

(4) INITIATE AN WRI IF FILTER DP IS GREATER THAN 15 PSID; IF GREATER THAN 20 PSID, CONTACT PLANT ENGINEER TO DETERMINE IF D/G SHOULD BE DECLARED INOPERABLE.

COMMENTS: _____

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 6 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.	
					DAY	NIGHT		
DG B (CONT'D)	AIR RECEIVERS AND AIR DRYERS BLOWDOWN UNTIL MOISTURE FREE	XXX	XXX	XXX	XXX	RW		
	80V AC MCC LBBF GENERAL INSPECTION	XXX	XXX	XXX	RWN	RW		
----- ENGIN. CONTROL PANEL FDG4	STARTING							
	AIR BANK							
	PRESSURE PSIG	RIGHT	1-PI-9053	250	225	234	225	
		LEFT	1-PI-9057	250	225	238	230	
	CONTROL AIR PRESSURE (PSIG)		1-PI-19175	62	58	6.1	6.1	
	UNIT AVAILABLE - BLUE LIGHT ON		PANEL	XXX	XXX	RWN	RW	
	THERMOCOUPLE SELECTOR, SELECT AND RECORD THE FOLLOWING:		PANEL	XXX	XXX	XXX	XXX	
	LUBRICATING OIL IN - POS. 19 (*F)		PANEL	170	142	150	150	
	LUBRICATING OIL OUT - POS. 20 (*F)		PANEL	170	142	147	148	
	JACKET WATER IN - POS. 21 (*F)		PANEL	170	142	169	170	
	JACKET WATER OUT-POS. 22 (*F)		PANEL	170	142	165	168	
	DAY TANK LEVEL		1-LI-19193	FULL	5/8 FULL	XXX	7/8	
	NO ALARMS		PANEL	XXX	XXX	(RWN)	(RW)	1
	ALARM TEST		PANEL	XXX	XXX	XXX	RW	

COMMENTS: ① H: Level main tank

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 7 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
GENERATOR CONTROL PANEL PDC3	LOCAL/REMOTE SWITCH, REMOTE POSITION	1-HS-4517	XXX	XXX	Remote	Remote	
	LOCKOUT RELAYS	186A	PANEL	XXX	XXX	WTW	RW
	RESET POSITION	186B	PANEL	XXX	XXX	WTW	RW
		186C	PANEL	XXX	XXX	WTW	RW
	VOLTAGE REGULATOR IN AUTO		PANEL	XXX	XXX	Auto	RW
	DIESEL GENERATOR GENERAL INSPECTION		XXX	XXX	XXX	WTW	RW

COMMENTS: _____

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS
UNIT 2

SHEET 5 OF 20

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SOUTH MS AND FW VLV ROOM	TIME	XXX	XXX	XXX	1006	1951	
	GENERAL INSPECTION	XXX	XXX	XXX	<i>WTW</i>	<i>RW</i>	

LEVEL A
AUXILIARY BUILDING

ROOM A08	GENERAL INSPECTION	XXX	XXX	XXX	XXX	<i>RW</i>	
CTB NORMAL PURGE FILTER AND SUPPLY UNIT	GENERAL INSPECTION	XXX	XXX	XXX	XXX	<i>RW</i>	
ROOM 125	GENERAL INSPECTION(3)	XXX	XXX	XXX	<i>WTW</i>	<i>RW</i>	

(3) If ROOM TEMPERATURE IS ABNORMALLY HIGH, IMMEDIATELY CONTACT THE USS AND PLANT ENGINEER.

COMMENTS: _____

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 9 OF 29

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
NSCW TOWER A	TIME	XXX	XXX	XXX	1005	2022	
	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
NSCW PUMP 1	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
NSCW PUMP 5	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
NSCW TRANSFER PUMP 7	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
NSCW PUMP 3	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
OPERATING NSCW PUMP(S) ONLY	VERIFY OIL COOLER OUTLET FLOW	XXX	XXX	XXX	WTV	RW	
<u>NSCW A TRAIN</u>							
<u>INSTRUMENT ROOM</u>							
NSCW TRANSFER PUMP #7	DISCH PRESS	1-PI-2154	XXX	50	OFF	46 OFF	
NSCW PUMP #3	DISCH PRESS	1-PI-2152	XXX	100	112	112	
NSCW PUMP #3	DISCH FLOW	1-FI-11762	XXX	XXX	4 th 30 ^{min} 112 9500	9500	
NSCW PUMP #5	DISCH FLOW	1-FI-11761	XXX	XXX	OFF	OFF	
NSCW PUMP #5	DISCH PRESS	1-PI-2150	XXX	100	OFF	OFF	
NSCW PUMP #1	DISCH PRESS	1-PI-2148	XXX	100	114	114	
NSCW TRANSFER PUMP #7	DISCH FLOW	1-FI-2156	XXX	XXX	OFF	650	
NSCW PUMP #1	DISCH FLOW	1-FI-11760	XXX	XXX	9400	9100	

RWST	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
RWST DEGASIFIER CONTROL PANEL	GENERAL INSPECTION	XXX	XXX	XXX	WTV	(RW)	2 nd
RWST (6)	GENERAL INSPECTION	XXX	XXX	XXX	(WTV)	RW	1

(6) ENSURE CHEMISTRY SAMPLES WATER PRIOR TO DRAINING FROM RWST HOIST BEFORE OPENING
1-1215-U4-280 or 1-1215-U4-281.

COMMENTS: 2 of 3 Lights out. 2nd Degasser Pressure alarm is in

VOOTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 2

SHEET 10 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
NSCW TOWER B	TIME	XXX	XXX	XXX	1020	2127	
	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	
NSCW PUMP 2	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	
NSCW PUMP 6	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	
NSCW TRANSFER PUMP 8	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	
NSCW PUMP 4	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	
OPERATING NSCW PUMP(S) ONLY	VERIFY OIL COOLER OUTLET FLOW	XXX	XXX	XXX	WTW	RW	
<u>NSCW B TRAIN</u>							
<u>INSTRUMENT ROOM</u>							
NSCW TRANSFER PUMP #8	DISCH PRESS	1-PI-2155	XXX	50	OFF	OFF	
NSCW PUMP #4	DISCH PRESS	1-PI-2153	XXX	100	114	114	
NSCW PUMP #4	DISCH FLOW	1-FI-11765	XXX	XXX	9700	9700	
NSCW PUMP #6	DISCH FLOW	1-FI-11764	XXX	XXX	4780 ³⁵⁰⁰	9500	
NSCW PUMP #6	DISCH PRESS	1-PI-2151	XXX	100	112 ⁴⁻³⁰⁻⁹⁰	112	
NSCW PUMP #2	DISCH PRESS	1-PI-2149	XXX	100	OFF	OFF	
NSCW TRANSFER PUMP #8	DISCH FLOW	1-FI-2157	XXX	XXX	OFF	↓	
NSCW PUMP #2	DISCH FLOW	1-FI-11763	XXX	XXX	OFF	↓	

COMMENTS:

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 11 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
NSCW CHLORINE STORAGE	GENERAL INSPECTION	XXX	XXX	XXX	(NTR)	RW	1
480V AC MCC CNBG	GENERAL INSPECTION	XXX	XXX	XXX	NTR	RW	
CHLORINE HEAT TRACE PANEL	NO ALARMS	XXX	XXX	XXX	NTR	RW	
SOUTH FIREWATER STOR TANK	LEVEL (FEET)	C-LI-18343	29	28	28.4'	28'4"	
ELECT FIRE PUMP HOUSE #1							
JOCKEY PUMP	ON/OFF	XXX	XXX	XXX	ON	ON	
ELECTRIC FIRE PUMP #1 PANEL	HANDSWITCH IN AUTO	C-HS-7904B	XXX	XXX	Auto NTR	RW	
480V AC MCC ANBJ	GENERAL INSPECTION	XXX	XXX	XXX	NTR	RW	
ELECTRIC FIRE PUMP #1	GENERAL INSPECTION	XXX	XXX	XXX	NTR	RW	
DEMIN STORAGE TANK	LEVEL (FEET)	A-LI-17648	25	15	22.6'	22'0"	
WELL WATER STOR TANK	LEVEL (FEET)	C-LISHL- 7420	XXX	8	23.5'	27'0"	

COMMENTS:

① Needs Light Bulbs Replaced

Figure 1 (Cont'd)

DATE

APR 30 1990

VOOTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 12 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
MAKE-UP WATER TREATMENT BLDG	TIME	XXX	XXX	XXX	1042	2137	
	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
AUX DEMIN CONTRL PANEL	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
3KVA EMERGENCY BATTERY STATION A-1801-P5-FZC	BATTERY VOLTAGE	PANEL	55	45	52	52	
	CHARGE CURRENT	PANEL	HI	TRICKLE	Trickle	TRICKLE	
	EMERGENCY POWER LIGHT - OFF	PANEL	XXX	XXX	OFF	OFF	
	UTILITY AC POWER LIGHT - ON	PANEL	XXX	XXX	ON	ON	
	HI CHARGE LIGHT - OFF	PANEL	XXX	XXX	OFF	OFF	
	OUTPUT VOLTS (VAC)	PANEL	120	0	0	0	
	BATTERY GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
	UTILITY WTR PUMPS	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW
DEMIN WTR TRANSFER PUMPS	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
DEMIN BOOSTER PUMPS	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
480V AC MCC ANBB	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
480V AC MCC ANBE	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
NSCT PUMPS	GENERAL INSPECTION	XXX	XXX	XXX	RW	RW	
INSTRUMENT AIR COMPRESSOR	BLOWDOWN MOISTURE THROUGH TANK DRAIN	XXX	XXX	XXX	XXX	RW	
	COMPRESSOR AIR RCVR PRESS (PSIG)	1-PI-19284	110	90	XXX	100	
	DRYER IN SERVICE	XXX	XXX	XXX	XXX	Let	

COMMENTS:

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 13 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SERVICE BLDG ELECT EQUIPMENT ROOM	TIME	XXX	XXX	XXX	1135	XXX	
	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
4160V AC SWGR ANA02	GENERAL II SECTION	XXX	XXX	XXX	WTW	XXX	
4160V AC SWGR ANA03	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
480V SWGR ANB02	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
480V AC SWGR ANB03	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
MCC S1	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
MCC S2	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
480V AC SWGR ANB04	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
480V AC SWGR ANB08	GENERAL INSPECTION	XXX	XXX	XXX	WTW	XXX	
BATTERY CHARGER A	DC VOLTS	PANEL	140	130	135	XXX	
	DC AMPS	PANEL	20	0	1	XXX	
	AC POWER ON	XXX	XXX	XXX	ON	XXX	
	CHG MODE FLOAT/EQUAL	XXX	XXX	XXX	NORM	XXX	
BATTERY CHARGER B	DC VOLTS	PANEL	140	130	135	XXX	
	DC AMPS	PANEL	20	0	7	XXX	
	AC POWER ON	XXX	XXX	XXX	DN	XXX	
	CHG MODE FLOAT/EQUAL	XXX	XXX	XXX	NORM	XXX	
BATTERY	ELECTROLYTE LEVEL	XXX	HI	LO	WTW/NVA	RW	
	GENERAL INSPECTION	XXX	XXX	XXX	WTW	RW	

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

PROCEDURE NO.

VEGP

11882-1

REVISION

15

PAGE NO.

15 of 29

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 14 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
AUX BOILER ROOM	TIME	XXX	XXX	XXX	1522	2144	
	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
480V AC MCC ANBC	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	
	GENERAL INSPECTION	XXX	XXX	XXX	WTV	RW	

CHEMICAL STOR
TANK AREA

HYDRAZINE STOR TANK	LEVEL (%)	A-LI-9653	XXX	XXX	39%	XXX	
AMMONIA STOR TANK	LEVEL (%)	A-LI-9621	XXX	XXX	39%	XXX	
CARDOX	LIQUID LVL	A-LI-16815	FULL	0.6	Full	XXX	
	PRESSURE	A-PI-16802	320	290	310	XXX	

L.O. AND F.O.
STOR AREA

AUX BLR F.O. STOR TANK	LEVEL (FEET)	A-LI-5822	20	16	16.5'	XXX	
CLEAN L.O. STOR TANK	LEVEL (FEET)	A-LI-5602	23	11.5	(4.2)	XXX	
DIRTY L.O. STOR TANK	LEVEL (FEET)	A-LI-5603	11.5	XXX	10.6'	XXX	

COMMENTS: Below spec's

Figure 1 (Cont'd)

DATE APR 30 1990

**VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS**

UNIT 1

SHEET 15 OF 24

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
LOW VOLTAGE SWITCHYARD	TIME	XXX	XXX	XXX	1200	2146	
UNIT AUX XFMR LNLAB	NITROGEN BOTTLE PRESSURE	XXX	XXX	200	1400	1375	
	NITROGEN COVER PRESSURE	XXX	6.5	0.5	6.0	6.0	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	AUTO	RW	
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	55°C	55°	
	LIQUID TEMP > 60°C VERIFY 3 FANS RUNNING > 65°C VERIFY 12 FANS RUNNING	XXX	12	0	0	0	
	WINDING TEMPERATURES (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HANDS	LEFT	100	XXX	55°C	55	
		MID	100	XXX	55°C	55	
		RIGHT	100	XXX	55°C	55	
	HOT SPOT TEMP > 80°C VERIFY 3 FANS RUNNING > 85°C VERIFY 12 FANS RUNNING	XXX	12	0	0	0	
	MAIN TANK OIL LEVEL	XXX	H	L	H	RW	
	OIL PUMP (ON/OFF)	XXX	XXX	XXX	OFF	OFF	
UNIT AUX XFMR LNAAA	NITROGEN BOTTLE PRESSURE	XXX	XXX	200	2550	2500	
	NITROGEN COVER PRESSURE	XXX	6.5	0.5	5.0	5.5	

COMMENTS: _____

Figure 1 (Cont'd)

DATE APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 16 OF 29

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.	
					DAY	NIGHT		
UNIT AUX XPMR 1MXAA (CONT'D)	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	55°C	57°		
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW		
	LIQUID TEMP > 60°C VERIFY 3 FANS RUNNING > 65°C VERIFY 12 FANS RUNNING	XXX	12	0	60 ³ C	3		
	WINDING TEMPERATURES (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HANDS	LEFT		100	XXX	60°C	60	
		MID		100	XXX	55°C	60	
		RIGHT		100	XXX	55°C	60	
	HOT SPOT TEMP > 80°C VERIFY 3 FANS RUNNING > 85°C VERIFY 12 FANS RUNNING	XXX	XXX	XXX	3	3		
	MAIN TANK OIL LEVEL	XXX	H	L	H	RW		
	OIL PUMP (ON/OFF)	XXX	XXX	XXX	OFF	OFF		
	ALARM PANEL 1MXPAUX	VERIFY NO ALARMS AND PERFORM PANEL TEST(1)	XXX	XXX	XXX	XXX	RW	

(1) NOTIFY CONTROL ROOM BEFORE TESTING ALARM.

COMMENTS: _____

Figure 1 (Cont'd)

DATE

APR 30 1990

VOOTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 17 OF 25

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.	
					DAY	NIGHT		
RESERVE AUX KPMR LNKRA (5)	NITROGEN BOTTLE PRESSURE	XXX	XXX	200	500	500		
	NITROGEN COVER PRESSURE	XXX	6.5	0.5	4.25	5.0		
	VERIFY COOLING FANS SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW		
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	45°C	45		
	LIQUID TEMP > 60°C VERIFY 17 FANS RUNNING > 65°C VERIFY 33 FANS RUNNING	XXX	33	0	0	0		
	WINDING TEMPERATURES (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HANDS	LEFT	100	XXX	45°C	50		
		RIGHT	100	XXX	42.5°C	50		
	HOT SPOT TEMP > 70°C VERIFY 17 FANS RUNNING > 75°C VERIFY 33 FANS RUNNING	XXX	33	0	0	0		
	MAIN TANK OIL LEVEL VERIFY ALL THREE @ BUSHING OIL LEVELS	XXX	H	L	H	RW		
			H	L	H	RW		
	SWITCHER 11M1A	SWITCHER GAS PRESSURE (SILVER/RED INDICATORS) 3 TOTAL	XXX	XXX	XXX	3 silver	3 SILVER	
	ALARM PANEL LNKPMPT	VERIFY NO ALARMS AND PERFORM PANEL TEST(1)	XXX	XXX	XXX	XXX	RW	

(1) NOTIFY CONTROL ROOM BEFORE TESTING ALARM.

(5) IF THE SPARE OR MAIN KPMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 19 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SPARE STEP UP KPMR(5)	BUSHING OIL LEVEL	XXX	H	L	#	RW	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	OOS	OOS	
	WINDING TEMPERATURE (HOT SPOT) (°C), ON NIGHT SHIFT RECORD						
	DRAG HAND TEMP AND RESET DRAG HAND	XXX	100	XXX			
	HOT SPOT TEMP > 75°C VERIFY 12 FANS RUNNING	XXX	12	6			
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD						
	DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX			
	LIQUID TEMP > 60°C VERIFY 12 FANS RUNNING	XXX	12	6			
	COMBUSTIBLE GAS MONITOR (cc)	XXX	100	0		XXX	
	TANK PRESSURE	XXX	6	1	+1	RW	
	OIL PUMP (ON/OFF)	XXX	4	2	OOS	OFF	
	MAIN TANK OIL LEVEL	XXX	H	L	#	RW	

(5) IF THE SPARE OR MAIN KPMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 19 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SPARE STEP UP INXMLC(5)	BUSHING OIL LEVEL	XXX	H	L	H	RW	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW	
	WINDING TEMPERATURE (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	100	XXX	55°C	60	
	HOT SPOT TEMP > 75°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	60°C	60	
	LIQUID TEMP > 60°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	COMBUSTIBLE GAS MONITOR (cc)	XXX	100	0	0	XXX	
	TANK PRESSURE	XXX	6	1	1	1	
	OIL PUMP (ON/OFF)	XXX	4	2	4 on	4 on	
	MAIN TANK OIL LEVEL	XXX	H	L	H	RW	

(5) IF THE SPARE OR MAIN XFMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTELE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 20 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
STEP UP XFMR LNK(5)	BUSHING OIL LEVEL	XXX	H	L	H	RW	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW	
	WINDING TEMPERATURE (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	100	XXX	67.5°C	70	
	HOT SPOT TEMP > 75°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	57.5°C	60	
	LIQUID TEMP > 60°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	COMBUSTIBLE GAS MONITOR (cc)	XXX	100	0	0	XXX	
	TANK PRESSURE	XXX	6	1	1	1	
	OIL PUMP (ON/OFF)	XXX	4	2	4 ON	4 on	
	MAIN TANK OIL LEVEL	XXX	H	L	Ⓛ	RW	1

(5) IF THE SPARE OR MAIN XFMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS: Ⓛ Below 25°C Reading

Figure 1 (Cont'd)

DATE APR 30 1990

PROCEDURE NO.

VECP

11882-1

REVISION

15

PAGE NO.

22 of 29

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 21 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
STEP UP XFMR 1N3D1A(5)	BUSHING OIL LEVEL	XXX	H	L	#	RW	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW	
	WINDING TEMPERATURE (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	100	XXX	65°C	65	
	HOT SPOT TEMP > 75°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	60°C	60	
	LIQUID TEMP > 60°C VERIFY 12 FANS RUNNING	XXX	12	6	12	12	
	COMBUSTIBLE GAS MONITOR (cc)	XXX	100	0	#	XXX	
	TANK PRESSURE	XXX	6	1	1	1	
	OIL PUMP (ON/OFF)	XXX	4	2	4 ON	4 on	
	MAIN TANK OIL LEVEL	XXX	H	L	#	RW	

(5) IF THE SPARE OR MAIN XFMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 22 OF 25

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
RESERVE AUX KFRM LINEB(5)	NITROGEN BOTTLE PRESSURE	XXX	XXX	200	1325	1300	
	NITROGEN COVER PRESSURE	XXX	6.5	0.5	4.75	5.0	
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX	Auto	RW	
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX	425°C	45	
	LIQUID TEMP > 60°C VERIFY 17 FANS RUNNING > 65°C VERIFY 33 FANS RUNNING	XXX	33	0	0	0	
	WINDING TEMPERATURES (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HANDS	LEFT	100	XXX	40°C	45	
		RIGHT	100	XXX	40°C	45	
	HOT SPOT TEMP > 80°C VERIFY 17 FANS RUNNING > 85°C VERIFY 33 FANS RUNNING	XXX	33	0	0	0	
	MAIN TANK OIL LEVEL		H	L	H	RW	
	VERIFY ALL THREE Ø BUSHING OIL LEVELS		H	L	H	RW	
	SWITCHER GAS PRESSURE (SILVER/RED INDICATORS) 3 TOTAL	XXX	XXX	XXX	3 silver	3 silver	

(5) IF THE SPARE OR MAIN KFRM IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS: _____

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 23 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SPARE RESERVE AUX XFMR LINES(5)	NITROGEN BOTTLE PRESSURE	XXX	XXX	200	OOS OFF	OOS	
	NITROGEN COVER PRESSURE	XXX	6.5	0.5			
	VERIFY COOLING FAN SWITCHES IN AUTO	XXX	XXX	XXX			
	LIQUID TEMPERATURE (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	XXX	90	XXX			
	LIQUID TEMP > 60°C VERIFY ONE GROUP OF FANS RUNNING, > 65°C VERIFY BOTH GROUPS RUNNING	XXX	XXX	XXX			
	WINDING TEMPERATURES (HOT SPOT) (°C), ON NIGHT SHIFT RECORD DRAG HAND TEMP AND RESET DRAG HAND	LEFT	100	XXX			
		RIGHT	100	XXX			
	HOT SPOT TEMP > 70°C VERIFY ONE GROUP OF FANS RUNNING > 75°C VERIFY BOTH GROUPS RUNNING	XXX	XXX	XXX	↓	↓	
	MAIN TANK OIL LEVEL	XXX	H	L	(L)	RW	1
	BUSHING OIL LEVEL	XXX	H	L	(NTW)	RW	2
LOW VOLTAGE SWITCHYARD	TIME	XXX	XXX	XXX	1237	2201	
	GENERAL INSPECTION	XXX	XXX	XXX	NTW	RW	

(5) IF THE SPARE OR MAIN XFMR IS NOT IN SERVICE, ONLY OIL LEVELS NEED TO BE CHECKED.

COMMENTS: ① main tank oil level below 25°C MARK.
② 1 Bushing level low.

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 24 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
LOW VOLTAGE SWITCHYARD	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
FIRE PROTECTION VALVE HOUSE	AIR COMPRESSOR DRYER GRANULES(2)	CLEAR CANISTER	XXX	XXX	XXX	RW	
WWRB NO. 2	LEVEL BELOW SURGE WALL	XXX	XXX	XXX	XXX	RW	
	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
WWRB NO. 1	LEVEL BELOW SURGE WALL	XXX	XXX	XXX	XXX	RW	
	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
UNIT 1 OILY WASTE SEPARATOR	OIL COMPARTMENT < 1/2 FULL	XXX	XXX	XXX	XXX	RW	
UNIT 2 OILY WASTE SEPARATOR	OIL COMPARTMENT < 1/2 FULL	XXX	XXX	XXX	XXX	RW	
POTABLE WATER CHLORINE FACILITY	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
POTABLE WATER STORAGE TANK	LEVEL (%)	C-LI-17422	94	31	54%	50%	

(2) Replace dryer when indicating granules become pink or white.

COMMENTS: _____

Figure 1 (Cont'd)

DATE

APR 30 1990

PROCEDURE NO.

VEGP

11882-1

REVISION

15

PAGE NO.

26 of 29

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 25 OF 29

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
FIREWATER PUMP HOUSE #2							
DIESEL F. O. TANK - WEST	LEVEL (%)	C-LG-9075	100	80	XXX	RW 48"/80%	1 ^N
480V AC MCC ANBK	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
JOCKEY PUMP	ON/OFF	XXX	XXX	XXX	XXX	ON	
DIESEL DRIVEN FIRE PUMP #2	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #2 PANEL	IN AUTO	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #2 BATTERY	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #2	DISCH PRESS	C-PI-18074	XXX	125	XXX	152	
DIESEL DRIVEN FIRE PUMP #1	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #1 PANEL	IN AUTO	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #1 BATTERY	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
DIESEL FIRE PUMP #1	DISCH PRESS	C-PI-7991	XXX	125	XXX	152	
DIESEL F.O TANK - EAST	LEVEL (%)	C-LG-7993	100	80	XXX	48"/80%	1 ^N

COMMENTS:

1^N Gauge reads in inches not in percent

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTLE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
NORTH FIREWATER STOR TANK	LEVEL (FT)	C-LI-18342	29	20	XXX	29	
NORTH FIREWATER PUMP HOUSE OILY WASTE SEPARATOR	OIL TRAY LEVEL < 1/2 FULL	XXX	XXX	XXX	NOTN		
BULK GAS STORAGE AREA						XXX	
LIQUID H ₂	LEVEL (INCHES)	A-LI-19671	150	24.4	XXX	005	
	VAPOR PRESS	A-PI-9702	130	100	XXX	005	
	HEADER PRESSURE	A-PI-19686	130	100	XXX	100	
	HELIUM BOTTLE PRESSURE (FIRE PROTECTION)	ATTACHED REGULATOR	XXX	500	XXX	1500	
	GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
LIQUID NITROGEN	LEVEL (INCHES)	A-LI-19619	150	56	(45)	(45)	1
	VAPOR PRESSURE	A-PI-19621	160	130	140	140	
	LOW PRESSURE TEMP CONTROL MANIFOLD PRESSURE	A-PI-9717	150	90	90	100	
	BANK PRESS	A-PI-29630	2100	1200	1680	1620	
	HEADER PRESS	A-PI-9721	680	650	(200)	(175)	2
	GENERAL INSPECTION	XXX	XXX	XXX	NOTN	RW	
OXYGEN	RESERVE BANK PRESS	A-PI-19652	2400	800	1200	1150	
	ACTIVE BANK PRESS	A-PI-19654	2400	800	1275	1250	
	HEADER PRESSURE PSIG	A-PI-19656	65	55	55	55	
	GENERAL INSPECTION	XXX	XXX	XXX	NOTN	RW	

COMMENTS: (1) Low Level
(2) Isolated

VOGTLE ELECTRIC GENERATING PLANT

OUTSIDE AREA OPERATOR ROUNDS

UNIT 1

SHEET 27 OF 28

EQUIPMENT/ COMPONENT	PARAMETER	INST	MAX	MIN	SHIFT		COMMENT NO.
					DAY	NIGHT	
SECURITY DIESEL GENERATOR	BATTERY GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	DIESEL OIL LEVEL	DIP STICK	H	L	XXX	RW	
	DIESEL GOVERNOR OIL LEVEL	DIP STICK	H	L	XXX	RW	
	BATTERY CHARGER POWER ON	PANEL	XXX	XXX	XXX	RW	
	CONTROL PANEL NO ALARMS	PANEL	XXX	XXX	XXX	RW	
	VERIFY DIESEL KEEP WARM SYSTEM OPERATING, DIESEL ENGINE IS WARM TO TOUCH	XXX	XXX	XXX	XXX	RW	
	DAY TANK LEVEL (%)	XXX	100	75	XXX	100%	
	SECURITY SWGR ROOM	480V AC MCC ANEL GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW
	480V AC SWGR ANB11 GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	BATTERY CHARGER ANDPCA GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	BATTERY CHARGER ANDPCB GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	480V AC INVERTER ANDP10 GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
	BATTERY GENERAL INSPECTION	XXX	XXX	XXX	XXX	RW	
SECURITY DIESEL GENERATOR FUEL OIL TANK	FUEL OIL LEVEL (INCHES)	LEVEL GAUGE	XXX	60	XXX	84"	

COMMENTS:

Figure 1 (Cont'd)

DATE

APR 30 1990

VOGTE ELECTRIC GENERATING PLANT
OUTSIDE AREA OPERATOR ROUNDS
 UNIT 1

SHEET 29 OF 28

ADDITIONAL COMMENTS:

DAY SHIFT

<i>William J. Wald</i>	14-30-90
OUTSIDE AREA OPERATOR	DATE
<i>R</i>	14-30-90
BALANCE OF PLANT OPERATOR	DATE
<i>W. J. Littleman</i>	14-30-90
SHIFT SUPERVISOR	DATE

ADDITIONAL COMMENTS:

NIGHT SHIFT

<i>Ray Wood</i>	14-30-90
OUTSIDE AREA OPERATOR	DATE
<i>BB Matheson</i>	14-30-90
BALANCE OF PLANT OPERATOR	DATE
<i>W. J. Littleman</i>	15-1-90
SHIFT SUPERVISOR	DATE

Figure 1 (Cont'd)

APR 30 1990